

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Maplewood Elementary School

Client Sample ID	Sample Location	Collection Date & Time	Analysis Date	Sample ID	Analyte	Results	EPA Action Level	Units
061-01A	Sink Faucet Boiler Room	6/23/16 14:35	7/15/2016	1606C88-01A	Copper	0.3	1.3	ppm
061-01A	Sink Faucet Boiler Room	6/23/16 14:35	7/15/2016	1606C88-01A	Lead	11	15	ppb
061-02A	Room 106 Sink Faucet	6/23/16 14:38	7/15/2016	1606C88-02A	Copper	ND	1.3	ppm
061-02A	Room 106 Sink Faucet	6/23/16 14:38	7/15/2016	1606C88-02A	Lead	5	15	ppb
061-03A	Room 106 Drinking Fountain	6/23/16 14:41	7/15/2016	1606C88-03A	Copper	ND	1.3	ppm
061-03A	Room 106 Drinking Fountain	6/23/16 14:41	7/15/2016	1606C88-03A	Lead	4	15	ppb
061-04A	Room 107 Sink Faucet	6/23/16 14:44	7/15/2016	1606C88-04A	Copper	0.2	1.3	ppm
061-04A	Room 107 Sink Faucet	6/23/16 14:44	7/15/2016	1606C88-04A	Lead	14	15	ppb
061-05A	Room 107 Drinking Fountain	6/23/16 14:47	7/15/2016	1606C88-05A	Copper	ND	1.3	ppm
061-05A	Room 107 Drinking Fountain	6/23/16 14:47	7/15/2016	1606C88-05A	Lead	4	15	ppb
061-06A	Room 108 Sink Faucet	6/23/16 14:50	7/15/2016	1606C88-06A	Copper	0.1	1.3	ppm
061-06A	Room 108 Sink Faucet	6/23/16 14:50	7/15/2016	1606C88-06A	Lead	5	15	ppb
061-07A	Room 108 Drinking Fountain	6/23/16 14:53	7/15/2016	1606C88-07A	Copper	ND	1.3	ppm
061-07A	Room 108 Drinking Fountain	6/23/16 14:53	7/15/2016	1606C88-07A	Lead	3	15	ppb
061-08A	Room 109 Sink Faucet	6/23/16 14:56	7/15/2016	1606C88-08A	Copper	ND	1.3	ppm
061-08A	Room 109 Sink Faucet	6/23/16 14:56	7/15/2016	1606C88-08A	Lead	2	15	ppb
061-09A	Room 109 Drinking Fountain	6/23/16 14:59	7/15/2016	1606C88-09A	Copper	ND	1.3	ppm
061-09A	Room 109 Drinking Fountain	6/23/16 14:59	7/15/2016	1606C88-09A	Lead	1	15	ppb
061-10A	Room 110 Sink Faucet	6/23/16 15:02	7/15/2016	1606C88-10A	Copper	0.2	1.3	ppm
061-10A	Room 110 Sink Faucet	6/23/16 15:02	7/15/2016	1606C88-10A	Lead	36	15	ppb
061-11A	Room 110 Drinking Fountain	6/23/16 15:05	7/15/2016	1606C88-11A	Copper	ND	1.3	ppm
061-11A	Room 110 Drinking Fountain	6/23/16 15:05	7/15/2016	1606C88-11A	Lead	2	15	ppb
061-12A	Room 111 Sink Faucet	6/23/16 15:08	7/15/2016	1606C88-12A	Copper	ND	1.3	ppm
061-12A	Room 111 Sink Faucet	6/23/16 15:08	7/15/2016	1606C88-12A	Lead	4	15	ppb
061-13A	Room 111 Drinking Fountain	6/23/16 15:11	7/15/2016	1606C88-13A	Copper	ND	1.3	ppm
061-13A	Room 111 Drinking Fountain	6/23/16 15:11	7/15/2016	1606C88-13A	Lead	2	15	ppb
061-14A	Room 113 Sink Faucet	6/23/16 15:13	7/15/2016	1606C88-14A	Copper	0.1	1.3	ppm
061-14A	Room 113 Sink Faucet	6/23/16 15:13	7/15/2016	1606C88-14A	Lead	9	15	ppb
061-15A	Room 113 Drinking Fountain	6/23/16 15:16	7/15/2016	1606C88-15A	Copper	ND	1.3	ppm
061-15A	Room 113 Drinking Fountain	6/23/16 15:16	7/15/2016	1606C88-15A	Lead	4	15	ppb
061-16A	Room 112 Sink Faucet	6/23/16 15:18	7/15/2016	1606C88-16A	Copper	0.2	1.3	ppm
061-16A	Room 112 Sink Faucet	6/23/16 15:18	7/15/2016	1606C88-16A	Lead	3	15	ppb
061-17A	Room 112 Drinking Fountain	6/23/16 15:21	7/15/2016	1606C88-17A	Copper	ND	1.3	ppm
061-17A	Room 112 Drinking Fountain	6/23/16 15:21	7/15/2016	1606C88-17A	Lead	ND	15	ppb
061-18A	Room 105 Sink Faucet	6/23/16 15:24	7/15/2016	1606C88-18A	Copper	ND	1.3	ppm
061-18A	Room 105 Sink Faucet	6/23/16 15:24	7/15/2016	1606C88-18A	Lead	5	15	ppb
061-19A	Drinking Fountain Hallway 1	6/23/16 15:26	7/15/2016	1606C88-19A	Copper	0.2	1.3	ppm
061-19A	Drinking Fountain Hallway 1	6/23/16 15:26	7/15/2016	1606C88-19A	Lead	10	15	ppb
061-20A	Drinking Fountain Hallway 2	6/23/16 15:28	7/15/2016	1606C88-20A	Copper	ND	1.3	ppm
061-20A	Drinking Fountain Hallway 2	6/23/16 15:28	7/15/2016	1606C88-20A	Lead	6	15	ppb
061-21A	Girls Bathroom Sink Faucet	6/23/16 15:30	7/15/2016	1606C88-21A	Copper	ND	1.3	ppm
061-21A	Girls Bathroom Sink Faucet	6/23/16 15:30	7/15/2016	1606C88-21A	Lead	9	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Maplewood Elementary School

Client Sample ID	Sample Location	Collection Date & Time	Analysis Date	Sample ID	Analyte	Results	EPA Action Level	Units
061-22A	Staff Bathroom Sink Faucet	6/23/16 15:32	7/15/2016	1606C88-22A	Copper	0.5	1.3	ppm
061-22A	Staff Bathroom Sink Faucet	6/23/16 15:32	7/15/2016	1606C88-22A	Lead	4	15	ppb
061-23A	Boys Bathroom Sink Faucet	6/23/16 15:34	7/15/2016	1606C88-23A	Copper	1.2	1.3	ppm
061-23A	Boys Bathroom Sink Faucet	6/23/16 15:34	7/15/2016	1606C88-23A	Lead	30	15	ppb
061-24A	Room 103A Sink Faucet	6/23/16 15:36	7/15/2016	1606C88-24A	Copper	1.1	1.3	ppm
061-24A	Room 103A Sink Faucet	6/23/16 15:36	7/15/2016	1606C88-24A	Lead	10	15	ppb
061-25A	Room 102 Sink Faucet	6/23/16 15:38	7/15/2016	1606C88-25A	Copper	ND	1.3	ppm
061-25A	Room 102 Sink Faucet	6/23/16 15:38	7/15/2016	1606C88-25A	Lead	57	15	ppb
061-26A	Room 102 Drinking Fountain	6/23/16 15:40	7/15/2016	1606C88-26A	Copper	ND	1.3	ppm
061-26A	Room 102 Drinking Fountain	6/23/16 15:40	7/15/2016	1606C88-26A	Lead	2	15	ppb
061-27A	Room 101 Sink Faucet	6/23/16 15:42	7/15/2016	1606C88-27A	Copper	0.2	1.3	ppm
061-27A	Room 101 Sink Faucet	6/23/16 15:42	7/15/2016	1606C88-27A	Lead	20	15	ppb
061-28A	Room 101 Drinking Fountain	6/23/16 15:44	7/15/2016	1606C88-28A	Copper	ND	1.3	ppm
061-28A	Room 101 Drinking Fountain	6/23/16 15:44	7/15/2016	1606C88-28A	Lead	11	15	ppb
061-29A	Main Office Sink Faucet	6/23/16 15:46	7/15/2016	1606C88-29A	Copper	0.2	1.3	ppm
061-29A	Main Office Sink Faucet	6/23/16 15:46	7/15/2016	1606C88-29A	Lead	4	15	ppb
061-30A	Teachers Lounge Sink Faucet	6/23/16 15:49	7/15/2016	1606C88-30A	Copper	0.2	1.3	ppm
061-30A	Teachers Lounge Sink Faucet	6/23/16 15:49	7/15/2016	1606C88-30A	Lead	3	15	ppb
061-31A	Dishwashing Sink Faucet	6/23/16 15:52	7/15/2016	1606C88-31A	Copper	0.1	1.3	ppm
061-31A	Dishwashing Sink Faucet	6/23/16 15:52	7/15/2016	1606C88-31A	Lead	7	15	ppb
061-32A	Kitchen Hand Sink	6/23/16 15:54	7/15/2016	1606C88-32A	Copper	0.6	1.3	ppm
061-32A	Kitchen Hand Sink	6/23/16 15:54	7/15/2016	1606C88-32A	Lead	17	15	ppb
061-33A	Food Preparation Sink Faucet	6/23/16 15:56	7/15/2016	1606C88-33A	Copper	0.5	1.3	ppm
061-33A	Food Preparation Sink Faucet	6/23/16 15:56	7/15/2016	1606C88-33A	Lead	23	15	ppb
061-34A	Girls Bathroom Sink Faucet	6/23/16 15:59	7/15/2016	1606C88-34A	Copper	0.3	1.3	ppm
061-34A	Girls Bathroom Sink Faucet	6/23/16 15:59	7/15/2016	1606C88-34A	Lead	4	15	ppb
061-35A	Boys Bathroom Sink Faucet	6/23/16 16:01	7/15/2016	1606C88-35A	Copper	0.2	1.3	ppm
061-35A	Boys Bathroom Sink Faucet	6/23/16 16:01	7/15/2016	1606C88-35A	Lead	10	15	ppb
061-36A	Cafeteria Drinking Fountain 1	6/23/16 16:03	7/15/2016	1606C88-36A	Copper	0.6	1.3	ppm
061-36A	Cafeteria Drinking Fountain 1	6/23/16 16:03	7/15/2016	1606C88-36A	Lead	ND	15	ppb
061-37A	Cafeteria Drinking Fountain 2	6/23/16 16:05	7/15/2016	1606C88-37A	Copper	0.7	1.3	ppm
061-37A	Cafeteria Drinking Fountain 2	6/23/16 16:05	7/15/2016	1606C88-37A	Lead	ND	15	ppb
061-38A	Room G10 Sink Faucet	6/23/16 16:07	7/15/2016	1606C88-38A	Copper	0.6	1.3	ppm
061-38A	Room G10 Sink Faucet	6/23/16 16:07	7/15/2016	1606C88-38A	Lead	18	15	ppb
061-39A	Room G8 Sink Faucet	6/23/16 16:09	7/15/2016	1606C88-39A	Copper	0.3	1.3	ppm
061-39A	Room G8 Sink Faucet	6/23/16 16:09	7/15/2016	1606C88-39A	Lead	48	15	ppb
061-40A	Hallway Drinking Fountain by stairwell	6/23/16 16:12	7/15/2016	1606C88-40A	Copper	ND	1.3	ppm
061-40A	Hallway Drinking Fountain by stairwell	6/23/16 16:12	7/15/2016	1606C88-40A	Lead	2	15	ppb
061-41A	Hallway Drinking Fountain by stairwell	6/23/16 16:14	7/15/2016	1606C88-41A	Copper	ND	1.3	ppm
061-41A	Hallway Drinking Fountain by stairwell	6/23/16 16:14	7/15/2016	1606C88-41A	Lead	7	15	ppb
061-42A	Community School Sink Faucet	6/23/16 16:17	7/15/2016	1606C88-42A	Copper	ND	1.3	ppm
061-42A	Community School Sink Faucet	6/23/16 16:17	7/15/2016	1606C88-42A	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Maplewood Elementary School

Client Sample ID	Sample Location	Collection Date & Time	Analysis Date	Sample ID	Analyte	Results	EPA Action Level	Units
061-43A	Exterior Water Spigot 1	6/23/16 16:22	7/15/2016	1606C88-43A	Copper	ND	1.3	ppm
061-43A	Exterior Water Spigot 1	6/23/16 16:22	7/15/2016	1606C88-43A	Lead	50	15	ppb
061-44A	Exterior Water Spigot 2	6/23/16 16:25	7/15/2016	1606C88-44A	Copper	23.0	1.3	ppm
061-44A	Exterior Water Spigot 2	6/23/16 16:25	7/15/2016	1606C88-44A	Lead	730	15	ppb
061-45A	Exterior Water Spigot 3	6/23/16 16:31	7/15/2016	1606C88-45A	Copper	ND	1.3	ppm
061-45A	Exterior Water Spigot 3	6/23/16 16:31	7/15/2016	1606C88-45A	Lead	20	15	ppb
061-47A	Exterior Water Spigot 4	6/23/16 16:41	7/15/2016	1606C88-46A	Copper	0.1	1.3	ppm
061-47A	Exterior Water Spigot 4	6/23/16 16:41	7/15/2016	1606C88-46A	Lead	18	15	ppb
061-48A	Portable A Sink Faucet	6/23/16 16:57	7/15/2016	1606C88-47A	Copper	0.1	1.3	ppm
061-48A	Portable A Sink Faucet	6/23/16 16:57	7/15/2016	1606C88-47A	Lead	27	15	ppb
061-49A	Portable A Boys Bathroom Sink Faucet	6/23/16 17:03	7/15/2016	1606C88-48A	Copper	0.2	1.3	ppm
061-49A	Portable A Boys Bathroom Sink Faucet	6/23/16 17:03	7/15/2016	1606C88-48A	Lead	17	15	ppb
061-50A	Portable A1 Sink Faucet	6/23/16 17:06	7/15/2016	1606C88-49A	Copper	0.3	1.3	ppm
061-50A	Portable A1 Sink Faucet	6/23/16 17:06	7/15/2016	1606C88-49A	Lead	19	15	ppb
061-51A	Portable A1 Drinking Fountain	6/23/16 17:09	7/15/2016	1606C88-50A	Copper	ND	1.3	ppm
061-51A	Portable A1 Drinking Fountain	6/23/16 17:09	7/15/2016	1606C88-50A	Lead	ND	15	ppb
061-52A	Sink Faucet Portable A2	6/23/16 17:13	7/15/2016	1606C88-51A	Copper	0.2	1.3	ppm
061-52A	Portable A2 Sink Faucet	6/23/16 17:13	7/15/2016	1606C88-51A	Lead	12	15	ppb
061-53A	Portable A2 Drinking Fountain	6/23/16 17:16	7/15/2016	1606C88-52A	Copper	0.1	1.3	ppm
061-53A	Portable A2 Drinking Fountain	6/23/16 17:16	7/15/2016	1606C88-52A	Lead	9	15	ppb
061-54A	Exterior Water Spigot 5	6/23/16 17:24	7/15/2016	1606C88-53A	Copper	0.2	1.3	ppm
061-54A	Exterior Water Spigot 5	6/23/16 17:24	7/15/2016	1606C88-53A	Lead	60	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.