

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Markham Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
062-01A Boiler Room Sink Faucet (187)	6/19/16 19:30	6/29/16 17:13	606212301	Copper	0.1	1.3	ppm
062-01A Boiler Room Sink Faucet (187)	6/19/16 19:30	6/29/16 17:13	606212301	Lead	11	15	ppb
062-02A Room 187A Custodian Bathroom Sink Faucet	6/19/16 19:33	6/29/16 17:14	606212302	Copper	0.1	1.3	ppm
062-02A Room 187A Custodian Bathroom Sink Faucet	6/19/16 19:33	6/29/16 17:14	606212302	Lead	6	15	ppb
062-04A 183 Attic Access Rm Sink Faucet	6/19/16 19:35	6/29/16 17:14	606212303	Copper	0.0	1.3	ppm
062-04A 183 Attic Access Rm Sink Faucet	6/19/16 19:35	6/29/16 17:14	606212303	Lead	1.5	15	ppb
062-05A 181 Kitchen Dishwash Sink Faucet	6/19/16 19:37	6/29/16 17:14	606212304	Copper	0.0	1.3	ppm
062-05A 181 Kitchen Dishwash Sink Faucet	6/19/16 19:37	6/29/16 17:14	606212304	Lead	5.5	15	ppb
062-06A 181 Kitchen Food Prep Sink Faucet	6/19/16 19:39	6/29/16 17:14	606212305	Copper	0.3	1.3	ppm
062-06A 181 Kitchen Food Prep Sink Faucet	6/19/16 19:39	6/29/16 17:14	606212305	Lead	5.2	15	ppb
062-07A 181 Kitchen White Handwash Sink Faucet	6/19/16 19:41	6/29/16 17:14	606212306	Copper	0.2	1.3	ppm
062-07A 181 Kitchen White Handwash Sink Faucet	6/19/16 19:41	6/29/16 17:14	606212306	Lead	17.5	15	ppb
062-08A 186 Bathroom Sink Faucet	6/19/16 19:43	6/29/16 17:14	606212307	Copper	0.1	1.3	ppm
062-08A 186 Bathroom Sink Faucet	6/19/16 19:43	6/29/16 17:14	606212307	Lead	8.7	15	ppb
062-09A Room 184 Sink Faucet	6/19/16 19:45	6/29/16 17:14	606212308	Copper	0.1	1.3	ppm
062-09A Room 184 Sink Faucet	6/19/16 19:45	6/29/16 17:14	606212308	Lead	13.8	15	ppb
062-100A Classroom 100 Drinking Fountain	6/19/16 21:38	7/1/16 8:47	606212399	Copper	0.0	1.3	ppm
062-100A Classroom 100 Drinking Fountain	6/19/16 21:38	7/1/16 8:47	606212399	Lead	1.4	15	ppb
062-101A Classroom 99 Sink Faucet	6/19/16 21:39	7/1/16 8:47	6062123100	Copper	0.4	1.3	ppm
062-101A Classroom 99 Sink Faucet	6/19/16 21:39	7/1/16 8:47	6062123100	Lead	4.4	15	ppb
062-102A Classroom 99 Drinking Fountain	6/19/16 21:42	7/1/16 8:47	6062123101	Copper	0.0	1.3	ppm
062-102A Classroom 99 Drinking Fountain	6/19/16 21:42	7/1/16 8:47	6062123101	Lead	1.4	15	ppb
062-103A Classroom 161 Drinking Fountain	6/19/16 20:12	7/1/16 8:47	6062123102	Copper	0.0	1.3	ppm
062-103A Classroom 161 Drinking Fountain	6/19/16 20:12	7/1/16 8:47	6062123102	Lead	16.6	15	ppb
062-104A Outdoor Spigot Outside UU Door	6/19/16 21:50	7/1/16 8:47	6062123103	Copper	0.1	1.3	ppm
062-104A Outdoor Spigot Outside UU Door	6/19/16 21:50	7/1/16 8:47	6062123103	Lead	60.8	15	ppb
062-105A Outdoor Spigot Outside Gym (NE)	6/19/16 21:54	7/1/16 8:47	6062123104	Copper	0.2	1.3	ppm
062-105A Outdoor Spigot Outside Gym (NE)	6/19/16 21:54	7/1/16 8:47	6062123104	Lead	53.0	15	ppb
062-106A Outdoor Spigot Outside Gym in Center School (SW)	6/19/16 21:58	7/1/16 8:47	6062123105	Copper	0.2	1.3	ppm
062-106A Outdoor Spigot Outside Gym in Center School (SW)	6/19/16 21:58	7/1/16 8:47	6062123105	Lead	33.8	15	ppb
062-107A Outdoor Spigot Outside Rm 131	6/19/16 22:02	7/1/16 8:48	6062123106	Copper	0.0	1.3	ppm
062-107A Outdoor Spigot Outside Rm 131	6/19/16 22:02	7/1/16 8:48	6062123106	Lead	7.0	15	ppb
062-108A Outdoor Spigot Outside Rm 99	6/19/16 22:06	7/1/16 8:48	6062123107	Copper	0.0	1.3	ppm
062-108A Outdoor Spigot Outside Rm 99	6/19/16 22:06	7/1/16 8:48	6062123107	Lead	1.6	15	ppb
062-109A Outdoor Spigot Outside Rm 100	6/19/16 22:10	7/1/16 8:48	6062123108	Copper	0.0	1.3	ppm
062-109A Outdoor Spigot Outside Rm 100	6/19/16 22:10	7/1/16 8:48	6062123108	Lead	1.9	15	ppb
062-10A Cafeteria Drinking Fountain	6/19/16 19:40	6/29/16 17:14	606212309	Copper	0.0	1.3	ppm
062-10A Cafeteria Drinking Fountain	6/19/16 19:40	6/29/16 17:14	606212309	Lead	3.4	15	ppb
062-110A Outdoor Spigot Outside Rm 132/134	6/19/16 22:14	7/1/16 7:49	6062123109	Copper	0.6	1.3	ppm
062-110A Outdoor Spigot Outside Rm 132/134	6/19/16 22:14	7/1/16 8:48	6062123109	Lead	51.6	15	ppb
062-111A Outdoor Spigot Outside Media Center	6/19/16 22:17	7/1/16 8:48	6062123110	Copper	0.2	1.3	ppm
062-111A Outdoor Spigot Outside Media Center	6/19/16 22:17	7/1/16 8:48	6062123110	Lead	21.3	15	ppb
062-11A Classroom 171 Sink Faucet	6/19/16 19:50	6/29/16 17:14	606212310	Copper	0.0	1.3	ppm
062-11A Classroom 171 Sink Faucet	6/19/16 19:50	6/29/16 17:14	606212310	Lead	4.5	15	ppb
062-12A Classroom 171 Drinking Fountain	6/19/16 19:52	6/29/16 17:15	606212311	Copper	0.1	1.3	ppm
062-12A Classroom 171 Drinking Fountain	6/19/16 19:52	6/29/16 17:15	606212311	Lead	6.7	15	ppb
062-13A Classroom 170 Sink Faucet	6/19/16 19:52	6/29/16 17:15	606212312	Copper	0.1	1.3	ppm
062-13A Classroom 170 Sink Faucet	6/19/16 19:52	6/29/16 17:15	606212312	Lead	5.4	15	ppb
062-14A 166 Girls Bathroom Sink Faucet Left	6/19/16 19:56	6/29/16 17:15	606212313	Copper	0.1	1.3	ppm
062-14A 166 Girls Bathroom Sink Faucet Left	6/19/16 19:56	6/29/16 17:15	606212313	Lead	4.9	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Markham Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
062-15A 166 Girls Bathroom Sink Faucet Right	6/19/16 19:58	6/29/16 17:15	606212314	Copper	0.1	1.3	ppm
062-15A 166 Girls Bathroom Sink Faucet Right	6/19/16 19:58	6/29/16 17:15	606212314	Lead	15.8	15	ppb
062-16A Drinking Fountain Btw 168 & 166 (GBR)	6/19/16 20:02	6/29/16 17:15	606212315	Copper	0.1	1.3	ppm
062-16A Drinking Fountain Btw 168 & 166 (GBR)	6/19/16 20:02	6/29/16 17:15	606212315	Lead	3.3	15	ppb
062-17A 167 Boys Bathroom Sink Faucet Left	6/19/16 20:05	6/29/16 17:15	606212316	Copper	0.1	1.3	ppm
062-17A 167 Boys Bathroom Sink Faucet Left	6/19/16 20:05	6/29/16 17:15	606212316	Lead	9.8	15	ppb
062-18A 167 Boys Bathroom Sink Faucet Right	6/19/16 20:07	6/29/16 17:15	606212317	Copper	0.0	1.3	ppm
062-18A 167 Boys Bathroom Sink Faucet Right	6/19/16 20:07	6/29/16 17:15	606212317	Lead	9.9	15	ppb
062-19A 167 Boys Bathroom Custodial Sink Faucet	6/19/16 20:09	6/29/16 17:15	606212318	Copper	0.0	1.3	ppm
062-19A 167 Boys Bathroom Custodial Sink Faucet	6/19/16 20:09	6/29/16 17:15	606212318	Lead	10.6	15	ppb
062-20A Classroom 161 Sink Faucet	6/19/16 20:12	6/29/16 17:15	606212319	Copper	0.1	1.3	ppm
062-20A Classroom 161 Sink Faucet	6/19/16 20:12	6/29/16 17:15	606212319	Lead	5.2	15	ppb
062-21A Classroom 163 Sink Faucet	6/19/16 20:16	6/29/16 17:15	606212320	Copper	0.4	1.3	ppm
062-21A Classroom 163 Sink Faucet	6/19/16 20:16	6/29/16 17:15	606212320	Lead	2.5	15	ppb
062-22A Classroom 163 Drinking Fountain	6/19/16 20:16	6/29/16 17:15	606212321	Copper	0.4	1.3	ppm
062-22A Classroom 163 Drinking Fountain	6/19/16 20:16	6/29/16 17:15	606212321	Lead	2.2	15	ppb
062-23A Classroom 164 Sink Faucet	6/19/16 20:19	6/29/16 17:16	606212322	Copper	0.1	1.3	ppm
062-23A Classroom 164 Sink Faucet	6/19/16 20:19	6/29/16 17:16	606212322	Lead	5.1	15	ppb
062-24A Classroom 162 Sink Faucet Left	6/19/16 20:22	6/29/16 17:16	606212323	Copper	0.1	1.3	ppm
062-24A Classroom 162 Sink Faucet Left	6/19/16 20:22	6/29/16 17:16	606212323	Lead	17.3	15	ppb
062-25A Classroom 162 Sink Faucet Middle	6/19/16 20:23	6/29/16 17:16	606212324	Copper	0.0	1.3	ppm
062-25A Classroom 162 Sink Faucet Middle	6/19/16 20:23	6/29/16 17:16	606212324	Lead	6.6	15	ppb
062-26A Classroom 162 Sink Faucet Right	6/19/16 20:24	6/29/16 17:16	606212325	Copper	0.1	1.3	ppm
062-26A Classroom 162 Sink Faucet Right	6/19/16 20:24	6/29/16 17:16	606212325	Lead	27.3	15	ppb
062-27A Drinking Fountain between Rooms 194 & 192	6/19/16 20:28	6/29/16 17:16	606212326	Copper	0.0	1.3	ppm
062-27A Drinking Fountain between Rooms 194 & 192	6/19/16 20:28	6/29/16 17:16	606212326	Lead	8.6	15	ppb
062-28A Mens Staff Bathroom Sink Faucet Left 192	6/19/16 20:31	6/29/16 17:16	606212327	Copper	0.1	1.3	ppm
062-28A Mens Staff Bathroom Sink Faucet Left 192	6/19/16 20:31	6/29/16 17:16	606212327	Lead	11.5	15	ppb
062-29A Mens Staff Bathroom Sink Faucet Right 192	6/19/16 20:33	6/29/16 17:16	606212328	Copper	0.0	1.3	ppm
062-29A Mens Staff Bathroom Sink Faucet Right 192	6/19/16 20:33	6/29/16 17:16	606212328	Lead	12.6	15	ppb
062-30A Womens Staff Bathroom 193 Sink Faucet	6/19/16 20:34	6/29/16 17:16	606212329	Copper	0.1	1.3	ppm
062-30A Womens Staff Bathroom 193 Sink Faucet	6/19/16 20:34	6/29/16 17:16	606212329	Lead	0.9	15	ppb
062-31A 200A PE Office Bathroom Sink Faucet	6/19/16 20:37	6/29/16 17:16	606212330	Copper	0.1	1.3	ppm
062-31A 200A PE Office Bathroom Sink Faucet	6/19/16 20:37	6/29/16 17:16	606212330	Lead	35.4	15	ppb
062-32A 200A PE Office Bathroom Shower	6/19/16 20:37	6/29/16 17:16	606212331	Copper	0.0	1.3	ppm
062-32A 200A PE Office Bathroom Shower	6/19/16 20:37	6/29/16 17:16	606212331	Lead	7.8	15	ppb
062-33A 201A PE Attic Access Bathroom Sink Faucet	6/19/16 20:40	6/29/16 17:17	606212332	Copper	0.1	1.3	ppm
062-33A 201A PE Attic Access Bathroom Sink Faucet	6/19/16 20:40	6/29/16 17:17	606212332	Lead	26.5	15	ppb
062-34A 201A PE Attic Access Bathroom Shower	6/19/16 20:40	6/29/16 17:17	606212333	Copper	0.0	1.3	ppm
062-34A 201A PE Attic Access Bathroom Shower	6/19/16 20:40	6/29/16 17:17	606212333	Lead	13.0	15	ppb
062-35A Gymnasium Drinking Fountain	6/19/16 20:43	6/29/16 17:17	606212334	Copper	0.0	1.3	ppm
062-35A Gymnasium Drinking Fountain	6/19/16 20:43	6/29/16 17:17	606212334	Lead	9.3	15	ppb
062-36A Small Gymnasium Drinking Fountain	6/19/16 20:46	6/29/16 17:17	606212335	Copper	0.0	1.3	ppm
062-36A Small Gymnasium Drinking Fountain	6/19/16 20:46	6/29/16 17:17	606212335	Lead	0.7	15	ppb
062-37A Small Gymnasium 215 Custodian Sink Faucet	6/19/16 20:49	6/29/16 17:17	606212336	Copper	0.0	1.3	ppm
062-37A Small Gymnasium 215 Custodian Sink Faucet	6/19/16 20:49	6/29/16 17:17	606212336	Lead	2.5	15	ppb
062-38A AA Girls Bathroom Sink Faucet	6/19/16 20:54	6/29/16 17:17	606212337	Copper	0.1	1.3	ppm
062-38A AA Girls Bathroom Sink Faucet	6/19/16 20:54	6/29/16 17:17	606212337	Lead	10.1	15	ppb
062-39A BB Boys Bathroom Sink Faucet	6/19/16 20:54	6/29/16 17:17	606212338	Copper	0.1	1.3	ppm
062-39A BB Boys Bathroom Sink Faucet	6/19/16 20:54	6/29/16 17:17	606212338	Lead	14.8	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Markham Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
062-40A 220 Art Room Sink Faucet	6/19/16 20:53	6/29/16 17:17	606212339	Copper	0.1	1.3	ppm
062-40A 220 Art Room Sink Faucet	6/19/16 20:53	6/29/16 17:17	606212339	Lead	31.7	15	ppb
062-41A 219 Art Room Custodial Sink Faucet	6/19/16 20:55	6/29/16 17:17	606212340	Copper	0.0	1.3	ppm
062-41A 219 Art Room Custodial Sink Faucet	6/19/16 20:55	6/29/16 17:17	606212340	Lead	9.4	15	ppb
062-42A 220 Art Room Drinking Fountain	6/19/16 20:57	6/29/16 17:17	606212341	Copper	0.0	1.3	ppm
062-42A 220 Art Room Drinking Fountain	6/19/16 20:57	6/29/16 17:17	606212341	Lead	2.7	15	ppb
062-43A Classroom 223 Sink Faucet	6/19/16 21:00	7/1/16 8:41	606212342	Copper	0.1	1.3	ppm
062-43A Classroom 223 Sink Faucet	6/19/16 21:00	7/1/16 8:41	606212342	Lead	12.7	15	ppb
062-44A Classroom 226 Sink Faucet Left	6/19/16 21:03	7/1/16 8:41	606212343	Copper	0.1	1.3	ppm
062-44A Classroom 226 Sink Faucet Left	6/19/16 21:03	7/1/16 8:41	606212343	Lead	17.5	15	ppb
062-45A Classroom 226 Sink Faucet (2nd from Left)	6/19/16 21:05	7/1/16 8:42	606212344	Copper	0.1	1.3	ppm
062-45A Classroom 226 Sink Faucet (2nd from Left)	6/19/16 21:05	7/1/16 8:42	606212344	Lead	24.9	15	ppb
062-46A Classroom 226 Sink Faucet (Middle-Right)	6/19/16 21:07	7/1/16 8:42	606212345	Copper	0.1	1.3	ppm
062-46A Classroom 226 Sink Faucet (Middle-Right)	6/19/16 21:07	7/1/16 8:42	606212345	Lead	30.0	15	ppb
062-47A Classroom 226 Sink Faucet (Right)	6/19/16 21:09	7/1/16 8:42	606212346	Copper	0.1	1.3	ppm
062-47A Classroom 226 Sink Faucet (Right)	6/19/16 21:09	7/1/16 8:42	606212346	Lead	42.8	15	ppb
062-48A 127B Mens Auditorium Bathroom Sink Faucet	6/19/16 21:16	7/1/16 8:42	606212347	Copper	0.4	1.3	ppm
062-48A 127B Mens Auditorium Bathroom Sink Faucet	6/19/16 21:16	7/1/16 8:42	606212347	Lead	17.4	15	ppb
062-49A 127A Custodial Auditorium Sink Faucet	6/19/16 21:18	7/1/16 8:43	606212348	Copper	0.1	1.3	ppm
062-49A 127A Custodial Auditorium Sink Faucet	6/19/16 21:18	7/1/16 8:43	606212348	Lead	219.0	15	ppb
062-50A 128B Womens Auditorium Bathroom Sink Faucet	6/19/16 21:21	7/1/16 7:49	606212350	Copper	0.8	1.3	ppm
062-50A 128B Womens Auditorium Bathroom Sink Faucet	6/19/16 21:21	7/1/16 8:43	606212350	Lead	37.4	15	ppb
062-51A 126 Auditorium Stage Sink Faucet	6/19/16 21:24	7/1/16 8:43	606212351	Copper	0.1	1.3	ppm
062-51A 126 Auditorium Stage Sink Faucet	6/19/16 21:24	7/1/16 8:43	606212351	Lead	7.4	15	ppb
062-52A 120 Psychologist Office Sink Faucet	6/19/16 21:27	7/1/16 8:43	606212352	Copper	0.1	1.3	ppm
062-52A 120 Psychologist Office Sink Faucet	6/19/16 21:27	7/1/16 8:43	606212352	Lead	16.2	15	ppb
062-53A 121 Pathologist Office Sink Faucet	6/19/16 21:30	7/1/16 8:43	606212353	Copper	0.1	1.3	ppm
062-53A 121 Pathologist Office Sink Faucet	6/19/16 21:30	7/1/16 8:43	606212353	Lead	131.0	15	ppb
062-54A 116 Girls Bathroom Sink Faucet Left	6/19/16 21:37	7/1/16 8:43	606212354	Copper	0.0	1.3	ppm
062-54A 116 Girls Bathroom Sink Faucet Left	6/19/16 21:37	7/1/16 8:43	606212354	Lead	2.9	15	ppb
062-55A 117 Mens/Headstart Bathroom Sink Faucet (left)	6/19/16 21:40	7/1/16 8:43	606212355	Copper	0.0	1.3	ppm
062-55A 117 Mens/Headstart Bathroom Sink Faucet (left)	6/19/16 21:40	7/1/16 8:43	606212355	Lead	2.2	15	ppb
062-56A 117 Mens/Headstart Bathroom Sink Faucet (mid)	6/19/16 21:58	7/1/16 8:43	606212356	Copper	0.1	1.3	ppm
062-56A 117 Mens/Headstart Bathroom Sink Faucet (mid)	6/19/16 21:58	7/1/16 8:43	606212356	Lead	4.4	15	ppb
062-57A 117 Mens/Headstart Bathroom Sink Faucet (right)	6/19/16 21:55	7/1/16 8:43	606212357	Copper	0.1	1.3	ppm
062-57A 117 Mens/Headstart Bathroom Sink Faucet (right)	6/19/16 21:55	7/1/16 8:43	606212357	Lead	5.3	15	ppb
062-58A Classroom 159 Sink Faucet	6/19/16 21:58	7/1/16 8:43	606212358	Copper	0.1	1.3	ppm
062-58A Classroom 159 Sink Faucet	6/19/16 21:58	7/1/16 8:43	606212358	Lead	4.7	15	ppb
062-59A Classroom 159 Drinking Fountain	6/19/16 21:58	7/1/16 8:43	606212359	Copper	0.0	1.3	ppm
062-59A Classroom 159 Drinking Fountain	6/19/16 21:58	7/1/16 8:43	606212359	Lead	5.8	15	ppb
062-60A Classroom 157 Sink Faucet	6/19/16 21:58	7/1/16 8:43	606212360	Copper	0.1	1.3	ppm
062-60A Classroom 157 Sink Faucet	6/19/16 21:58	7/1/16 8:43	606212360	Lead	35.2	15	ppb
062-61A Classroom 157 Drinking Fountain	6/19/16 21:59	7/1/16 8:43	606212361	Copper	0.0	1.3	ppm
062-61A Classroom 157 Drinking Fountain	6/19/16 21:59	7/1/16 8:43	606212361	Lead	2.4	15	ppb
062-62A 135 Office Kitchen Sink Faucet	6/19/16 22:00	7/1/16 8:43	606212362	Copper	0.5	1.3	ppm
062-62A 135 Office Kitchen Sink Faucet	6/19/16 22:00	7/1/16 7:49	606212362	Copper	0.5	1.3	ppm
062-62A 135 Office Kitchen Sink Faucet	6/19/16 22:00	7/1/16 8:43	606212362	Lead	8.4	15	ppb
062-63A 145 Nurse Office Bathroom Sink Faucet	6/19/16 22:02	7/1/16 7:54	606212363	Copper	1.0	1.3	ppm
062-63A 145 Nurse Office Bathroom Sink Faucet	6/19/16 22:02	7/1/16 8:44	606212363	Lead	7.2	15	ppb
062-64A 150 Storage Closet Sink Fountain	6/19/16 21:58	7/1/16 7:49	606212364	Copper	0.6	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Markham Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
062-64A 150 Storage Closet Sink Fountain	6/19/16 21:58	7/1/16 8:44	606212364	Lead	31.2	15	ppb
062-65A 138 Teachers Room Sink Faucet	6/19/16 22:01	7/1/16 8:45	606212365	Copper	0.0	1.3	ppm
062-65A 138 Teachers Room Sink Faucet	6/19/16 22:01	7/1/16 8:45	606212365	Lead	6.8	15	ppb
062-66A 136 Bathroom Sink Faucet	6/19/16 22:04	7/1/16 8:45	606212366	Copper	0.4	1.3	ppm
062-66A 136 Bathroom Sink Faucet	6/19/16 22:04	7/1/16 8:45	606212366	Lead	23.1	15	ppb
062-67A Classroom 134 Sink Faucet	6/19/16 22:05	7/1/16 8:45	606212367	Copper	0.1	1.3	ppm
062-67A Classroom 134 Sink Faucet	6/19/16 22:05	7/1/16 8:45	606212367	Lead	30.0	15	ppb
062-68A Classroom 134 Bathroom Sink Faucet	6/19/16 22:08	7/1/16 8:45	606212368	Copper	0.4	1.3	ppm
062-68A Classroom 134 Bathroom Sink Faucet	6/19/16 22:08	7/1/16 8:45	606212368	Lead	7.0	15	ppb
062-69A Classroom 133 Sink Faucet	6/19/16 22:11	7/1/16 8:45	606212369	Copper	0.1	1.3	ppm
062-69A Classroom 133 Sink Faucet	6/19/16 22:11	7/1/16 8:45	606212369	Lead	8.4	15	ppb
062-70A Classroom 133 Drinking Fountain	6/19/16 22:11	7/1/16 8:45	606212370	Copper	0.1	1.3	ppm
062-70A Classroom 133 Drinking Fountain	6/19/16 22:11	7/1/16 8:45	606212370	Lead	7.7	15	ppb
062-71A Classroom 132 Sink Faucet	6/19/16 22:19	7/1/16 8:45	606212371	Copper	0.0	1.3	ppm
062-71A Classroom 132 Sink Faucet	6/19/16 22:19	7/1/16 8:45	606212371	Lead	4.7	15	ppb
062-72A Classroom 132 Drinking Fountain	6/19/16 22:21	7/1/16 8:45	606212372	Copper	0.0	1.3	ppm
062-72A Classroom 132 Drinking Fountain	6/19/16 22:21	7/1/16 8:45	606212372	Lead	20.7	15	ppb
062-73A Classroom 131 Sink Faucet	6/19/16 22:13	7/1/16 8:45	606212373	Copper	0.1	1.3	ppm
062-73A Classroom 131 Sink Faucet	6/19/16 22:13	7/1/16 8:45	606212373	Lead	3.9	15	ppb
062-74A Classroom 131 Drinking Fountain	6/19/16 22:15	7/1/16 8:45	606212374	Copper	0.0	1.3	ppm
062-74A Classroom 131 Drinking Fountain	6/19/16 22:15	7/1/16 8:45	606212374	Lead	1.7	15	ppb
062-75A Classroom 113 Sink Faucet	6/19/16 22:19	7/1/16 8:45	606212375	Copper	0.0	1.3	ppm
062-75A Classroom 113 Sink Faucet	6/19/16 22:19	7/1/16 8:45	606212375	Lead	3.5	15	ppb
062-76A Classroom 113 Drinking Fountain	6/19/16 22:21	7/1/16 8:45	606212376	Copper	0.0	1.3	ppm
062-76A Classroom 113 Drinking Fountain	6/19/16 22:21	7/1/16 8:45	606212376	Lead	13.8	15	ppb
062-77A 115 Music Class Sink Faucet	6/19/16 22:10	7/1/16 8:45	606212377	Copper	0.1	1.3	ppm
062-77A 115 Music Class Sink Faucet	6/19/16 22:10	7/1/16 8:45	606212377	Lead	12.6	15	ppb
062-78A 115 Music Class Drinking Fountain	6/19/16 21:26	7/1/16 8:45	606212378	Copper	0.0	1.3	ppm
062-78A 115 Music Class Drinking Fountain	6/19/16 21:26	7/1/16 8:45	606212378	Lead	2.2	15	ppb
062-79A 114 Computer Room Sink Faucet	6/19/16 21:28	7/1/16 8:45	606212379	Copper	0.1	1.3	ppm
062-79A 114 Computer Room Sink Faucet	6/19/16 21:28	7/1/16 8:45	606212379	Lead	28.3	15	ppb
062-80A 114 Computer Room Drinking Fountain	6/19/16 21:31	7/1/16 8:45	606212380	Copper	0.0	1.3	ppm
062-80A 114 Computer Room Drinking Fountain	6/19/16 21:31	7/1/16 8:45	606212380	Lead	6.0	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Markham Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
062-81A 108 Girls Bathroom Sink Faucet (left)	6/19/16 21:22	7/1/16 8:45	606212381	Copper	0.0	1.3	ppm
062-81A 108 Girls Bathroom Sink Faucet (left)	6/19/16 21:22	7/1/16 8:45	606212381	Lead	10.8	15	ppb
062-82A 108 Girls Bathroom Sink Faucet (right)	6/19/16 21:24	7/1/16 8:45	606212382	Copper	0.1	1.3	ppm
062-82A 108 Girls Bathroom Sink Faucet (right)	6/19/16 21:24	7/1/16 8:45	606212382	Lead	7.8	15	ppb
062-83A 107 Boys Bathroom Sink Faucet (left)	6/19/16 21:29	7/1/16 8:46	606212383	Copper	0.1	1.3	ppm
062-83A 107 Boys Bathroom Sink Faucet (left)	6/19/16 21:29	7/1/16 8:46	606212383	Lead	4.8	15	ppb
062-84A 107 Boys Bathroom Sink Faucet (right)	6/19/16 21:29	7/1/16 8:46	606212384	Copper	0.1	1.3	ppm
062-84A 107 Boys Bathroom Sink Faucet (right)	6/19/16 21:29	7/1/16 8:46	606212384	Lead	7.9	15	ppb
062-85A 107 Boys Bathroom Custodial Sink Faucet	6/19/16 21:32	7/1/16 8:46	606212385	Copper	0.0	1.3	ppm
062-85A 107 Boys Bathroom Custodial Sink Faucet	6/19/16 21:32	7/1/16 8:46	606212385	Lead	3.2	15	ppb
062-86A 107 Drinking Fountain next to 107 BBR	6/19/16 21:13	7/1/16 8:46	606212386	Copper	0.1	1.3	ppm
062-86A 107 Drinking Fountain next to 107 BBR	6/19/16 21:13	7/1/16 8:46	606212386	Lead	19.7	15	ppb
062-87A 106 Classroom Sink Faucet	6/19/16 21:13	7/1/16 8:46	606212387	Copper	0.0	1.3	ppm
062-87A Classroom 106 Sink Faucet	6/19/16 21:13	7/1/16 8:46	606212387	Lead	5.8	15	ppb
062-88A Classroom 106 Drinking Fountain	6/19/16 21:15	7/1/16 8:46	606212388	Copper	0.1	1.3	ppm
062-88A Classroom 106 Drinking Fountain	6/19/16 21:15	7/1/16 8:46	606212388	Lead	8.7	15	ppb
062-90A Classroom 105 Drinking Fountain	6/19/16 21:28	7/1/16 8:46	606212389	Copper	0.0	1.3	ppm
062-90A Classroom 105 Drinking Fountain	6/19/16 21:28	7/1/16 8:46	606212389	Lead	18.3	15	ppb
062-91A Classroom 104 Sink Faucet	6/19/16 21:33	7/1/16 8:46	606212390	Copper	0.1	1.3	ppm
062-91A Classroom 104 Sink Faucet	6/19/16 21:33	7/1/16 8:46	606212390	Lead	27.0	15	ppb
062-92A Classroom 104 Drinking Fountain	6/19/16 21:34	7/1/16 8:46	606212391	Copper	0.0	1.3	ppm
062-92A Classroom 104 Drinking Fountain	6/19/16 21:34	7/1/16 8:46	606212391	Lead	3.3	15	ppb
062-93A Classroom 103 Sink Faucet	6/19/16 21:33	7/1/16 8:46	606212392	Copper	0.1	1.3	ppm
062-93A Classroom 103 Sink Faucet	6/19/16 21:33	7/1/16 8:46	606212392	Lead	25.2	15	ppb
062-94A Classroom 103 Drinking Fountain	6/19/16 21:35	7/1/16 8:46	606212393	Copper	0.0	1.3	ppm
062-94A Classroom 103 Drinking Fountain	6/19/16 21:35	7/1/16 8:46	606212393	Lead	7.0	15	ppb
062-95A Classroom 102 Sink Faucet	6/19/16 21:35	7/1/16 8:46	606212394	Copper	0.1	1.3	ppm
062-95A Classroom 102 Sink Faucet	6/19/16 21:35	7/1/16 8:46	606212394	Lead	10.5	15	ppb
062-96A Classroom 102 Drinking Fountain	6/19/16 21:37	7/1/16 8:46	606212395	Copper	0.1	1.3	ppm
062-96A Classroom 102 Drinking Fountain	6/19/16 21:37	7/1/16 8:46	606212395	Lead	6.5	15	ppb
062-97A Classroom 101 Sink Faucet	6/19/16 21:32	7/1/16 8:47	606212396	Copper	0.1	1.3	ppm
062-97A Classroom 101 Sink Faucet	6/19/16 21:32	7/1/16 8:47	606212396	Lead	16.9	15	ppb
062-98A Classroom 101 Drinking Fountain	6/19/16 21:34	7/1/16 8:47	606212397	Copper	0.0	1.3	ppm
062-98A Classroom 101 Drinking Fountain	6/19/16 21:34	7/1/16 8:47	606212397	Lead	4.2	15	ppb
062-99A Classroom 100 Sink Faucet	6/19/16 21:36	7/1/16 8:47	606212398	Copper	0.1	1.3	ppm
062-99A Classroom 100 Sink Faucet	6/19/16 21:36	7/1/16 8:47	606212398	Lead	4.3	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.