

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marysville Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
063-01A	Room 151 Sink Faucet	6/24/2016 2:45:00 PM	7/1/2016	BB67051	Copper	0.1	1.3	ppm
063-01A	Room 151 Sink Faucet	6/24/2016 2:45:00 PM	7/1/2016	BB67051	Lead	1	15	ppb
063-02A	Room 107 Sink Faucet	6/24/2016 2:49:00 PM	7/1/2016	BB67052	Copper	0.3	1.3	ppm
063-02A	Room 107 Sink Faucet	6/24/2016 2:49:00 PM	7/1/2016	BB67052	Lead	5	15	ppb
063-03A	Boiler Room Sink Hose	6/24/2016 2:56:00 PM	7/1/2016	BB67053	Copper	0.0	1.3	ppm
063-03A	Boiler Room Sink Hose	6/24/2016 2:56:00 PM	7/1/2016	BB67053	Lead	8	15	ppb
063-04A	Boiler Room Sink Faucet	6/24/2016 2:57:00 PM	7/1/2016	BB67054	Copper	0.3	1.3	ppm
063-04A	Boiler Room Sink Faucet	6/24/2016 2:57:00 PM	7/1/2016	BB67054	Lead	28	15	ppb
063-05A	Room 100B Kitchen Sprayer 1	6/24/2016 3:00:00 PM	7/10/2016 4:09:00 PM	BB67055	Copper	0.8	1.3	ppm
063-05A	Room 100B Kitchen Sprayer 1	6/24/2016 3:00:00 PM	7/10/2016 4:09:00 PM	BB67055	Lead	33	15	ppb
063-06A	Room 100B Kitchen Sink Faucet 1	6/24/2016 3:02:00 PM	7/1/2016	BB67056	Copper	0.1	1.3	ppm
063-06A	Room 100B Kitchen Sink Faucet 1	6/24/2016 3:02:00 PM	7/1/2016	BB67056	Lead	11	15	ppb
063-07A	Room 100B Kitchen Sprayer 2	6/24/2016 3:03:00 PM	7/1/2016	BB67057	Copper	0.1	1.3	ppm
063-07A	Room 100B Kitchen Sprayer 2	6/24/2016 3:03:00 PM	7/1/2016	BB67057	Lead	2	15	ppb
063-08A	Room 100B Kitchen Sink Faucet 2	6/24/2016 3:04:00 PM	7/1/2016	BB67058	Copper	0.2	1.3	ppm
063-08A	Room 100B Kitchen Sink Faucet 2	6/24/2016 3:04:00 PM	7/1/2016	BB67058	Lead	14.7	15	ppb
063-09A	Room 100B Kitchen Slop Sink Faucet	6/24/2016 3:06:00 PM	7/1/2016	BB67059	Copper	0.1	1.3	ppm
063-09A	Room 100B Kitchen Slop Sink Faucet	6/24/2016 3:06:00 PM	7/1/2016	BB67059	Lead	24	15	ppb
063-10A	Room 100B3 Kitchen Bathroom Sink Faucet	6/24/2016 3:07:00 PM	7/10/2016 5:08:00 PM	BB67060	Copper	4.4	1.3	ppm
063-10A	Room 100B3 Kitchen Bathroom Sink Faucet	6/24/2016 3:07:00 PM	7/10/2016 4:13:00 PM	BB67060	Lead	53	15	ppb
063-11A	Room 159 Sink Faucet	6/24/2016 3:11:00 PM	7/1/2016	BB67061	Copper	0.1	1.3	ppm
063-11A	Room 159 Sink Faucet	6/24/2016 3:11:00 PM	7/1/2016	BB67061	Lead	2	15	ppb
063-12A	Room 159A Bathroom Sink Faucet	6/24/2016 3:12:00 PM	7/1/2016	BB67062	Copper	0.1	1.3	ppm
063-12A	Room 159A Bathroom Sink Faucet	6/24/2016 3:12:00 PM	7/1/2016	BB67062	Lead	1	15	ppb
063-13A	Room 155 Sink Faucet	6/24/2016 3:16:00 PM	7/1/2016	BB67063	Copper	0.2	1.3	ppm
063-13A	Room 155 Sink Faucet	6/24/2016 3:16:00 PM	7/1/2016	BB67063	Lead	2	15	ppb
063-14A	Room 155 Drinking Fountain	6/24/2016 3:16:00 PM	7/1/2016	BB67064	Copper	0.2	1.3	ppm
063-14A	Room 155 Drinking Fountain	6/24/2016 3:16:00 PM	7/1/2016	BB67064	Lead	1	15	ppb
063-15A	Room 148 Handwash Left	6/24/2016 3:23:00 PM	7/1/2016	BB67065	Copper	0.1	1.3	ppm
063-15A	Room 148 Handwash Left	6/24/2016 3:23:00 PM	7/1/2016	BB67065	Lead	0	15	ppb
063-16A	Room 148 Handwash Right	6/24/2016 3:24:00 PM	7/1/2016	BB67066	Copper	0.1	1.3	ppm
063-16A	Room 148 Handwash Right	6/24/2016 3:24:00 PM	7/1/2016	BB67066	Lead	2	15	ppb
063-17A	Room 153 Sink Faucet	6/24/2016 3:18:00 PM	7/1/2016	BB67067	Copper	0.2	1.3	ppm
063-17A	Room 153 Sink Faucet	6/24/2016 3:18:00 PM	7/1/2016	BB67067	Lead	2	15	ppb
063-18A	Room 153 Drinking Fountain	6/24/2016 3:18:00 PM	7/1/2016	BB67068	Copper	0.1	1.3	ppm
063-18A	Room 153 Drinking Fountain	6/24/2016 3:18:00 PM	7/1/2016	BB67068	Lead	1	15	ppb
063-19A	Room 151 Drinking Fountain	6/24/2016 2:46:00 PM	7/1/2016	BB67069	Copper	0.1	1.3	ppm
063-19A	Room 151 Drinking Fountain	6/24/2016 2:46:00 PM	7/1/2016	BB67069	Lead	1	15	ppb
063-20A	Hall Drinking Fountain Left	6/24/2016 3:27:00 PM	7/1/2016	BB67070	Copper	1.8	1.3	ppm
063-20A	Hall Drinking Fountain Left	6/24/2016 3:27:00 PM	7/1/2016	BB67070	Lead	0.0	15	ppb
063-21A	Hall Drinking Fountain Right	6/24/2016 3:28:00 PM	7/1/2016	BB67071	Copper	0.0	1.3	ppm
063-21A	Hall Drinking Fountain Right	6/24/2016 3:28:00 PM	7/1/2016	BB67071	Lead	0.0	15	ppb
063-22A	Room 149 Sink Faucet	6/24/2016 3:30:00 PM	7/1/2016	BB67072	Copper	0.3	1.3	ppm
063-22A	Room 149 Sink Faucet	6/24/2016 3:30:00 PM	7/1/2016	BB67072	Lead	2	15	ppb
063-23A	Room 149 Drinking Fountain	6/24/2016 3:30:00 PM	7/1/2016	BB67073	Copper	0.3	1.3	ppm
063-23A	Room 149 Drinking Fountain	6/24/2016 3:30:00 PM	7/1/2016	BB67073	Lead	1	15	ppb
063-24A	Room 147 Sink Faucet	6/24/2016 3:33:00 PM	7/1/2016	BB67074	Copper	0.2	1.3	ppm
063-24A	Room 147 Sink Faucet	6/24/2016 3:33:00 PM	7/1/2016	BB67074	Lead	2	15	ppb
063-25A	Room 147 Drinking Fountain	6/24/2016 3:33:00 PM	7/1/2016	BB67075	Copper	0.2	1.3	ppm
063-25A	Room 147 Drinking Fountain	6/24/2016 3:33:00 PM	7/1/2016	BB67075	Lead	0	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marysville Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
063-26A	Room 145 Sink Faucet	6/24/2016 3:36:00 PM	7/10/2016 4:16:00 PM	BB67076	Copper	0.8	1.3	ppm
063-26A	Room 145 Sink Faucet	6/24/2016 3:36:00 PM	7/10/2016 4:16:00 PM	BB67076	Lead	4	15	ppb
063-27A	Room 145 Drinking Fountain	6/24/2016 3:36:00 PM	7/1/2016	BB67077	Copper	0.4	1.3	ppm
063-27A	Room 145 Drinking Fountain	6/24/2016 3:36:00 PM	7/1/2016	BB67077	Lead	1	15	ppb
063-28A	Room 143 Sink Faucet	6/24/2016 3:38:00 PM	7/1/2016	BB67078	Copper	0.3	1.3	ppm
063-28A	Room 143 Sink Faucet	6/24/2016 3:38:00 PM	7/1/2016	BB67078	Lead	1	15	ppb
063-29A	Room 143 Drinking Fountain	6/24/2016 3:38:00 PM	7/1/2016	BB67079	Copper	0.2	1.3	ppm
063-29A	Room 143 Drinking Fountain	6/24/2016 3:38:00 PM	7/1/2016	BB67079	Lead	1	15	ppb
063-30A	Room 141 Sink Faucet	6/24/2016 3:41:00 PM	7/1/2016	BB67080	Copper	0.3	1.3	ppm
063-30A	Room 141 Sink Faucet	6/24/2016 3:41:00 PM	7/1/2016	BB67080	Lead	1	15	ppb
063-31A	Room 141 Drinking Fountain	6/24/2016 3:41:00 PM	7/1/2016	BB67081	Copper	0.3	1.3	ppm
063-31A	Room 141 Drinking Fountain	6/24/2016 3:41:00 PM	7/1/2016	BB67081	Lead	0	15	ppb
063-32A	Room 136 Handwash Left	6/24/2016 1:48:00 PM	7/1/2016	BB67082	Copper	0.1	1.3	ppm
063-32A	Room 136 Handwash Left	6/24/2016 1:48:00 PM	7/1/2016	BB67082	Lead	2	15	ppb
063-33A	Room 136 Handwash Right	6/24/2016 1:48:00 PM	7/1/2016	BB67083	Copper	0.1	1.3	ppm
063-33A	Room 136 Handwash Right	6/24/2016 1:48:00 PM	7/1/2016	BB67083	Lead	1	15	ppb
063-34A	Room 137 Sink Faucet	6/24/2016 3:45:00 PM	7/1/2016	BB67084	Copper	0.3	1.3	ppm
063-34A	Room 137 Sink Faucet	6/24/2016 3:45:00 PM	7/1/2016	BB67084	Lead	1	15	ppb
063-35A	Room 137 Drinking Fountain	6/24/2016 3:45:00 PM	7/1/2016	BB67085	Copper	0.3	1.3	ppm
063-35A	Room 137 Drinking Fountain	6/24/2016 3:45:00 PM	7/1/2016	BB67085	Lead	0	15	ppb
063-36A	Room 132 Sink Faucet	6/24/2016 3:51:00 PM	7/1/2016	BB67086	Copper	0.1	1.3	ppm
063-36A	Room 132 Sink Faucet	6/24/2016 3:51:00 PM	7/1/2016	BB67086	Lead	9	15	ppb
063-37A	Room 130 Sink Faucet	6/24/2016 3:53:00 PM	7/1/2016	BB67087	Copper	0.3	1.3	ppm
063-37A	Room 130 Sink Faucet	6/24/2016 3:53:00 PM	7/1/2016	BB67087	Lead	1	15	ppb
063-38A	Room 131 Sink Hose	6/24/2016 3:56:00 PM	7/1/2016	BB67088	Copper	0.2	1.3	ppm
063-38A	Room 131 Sink Hose	6/24/2016 3:56:00 PM	7/1/2016	BB67088	Lead	1	15	ppb
063-39A	Room 129 Slop Sink Faucet	6/24/2016 4:03:00 PM	7/10/2016 4:20:00 PM	BB67089	Copper	0.1	1.3	ppm
063-39A	Room 129 Slop Sink Faucet	6/24/2016 4:03:00 PM	7/10/2016 4:20:00 PM	BB67089	Lead	63	15	ppb
063-40A	Room 127 Sink Faucet 1	6/24/2016 4:04:00 PM	7/10/2016 10:39:00 PM	BB67090	Copper	2.0	1.3	ppm
063-40A	Room 127 Sink Faucet 1	6/24/2016 4:04:00 PM	7/10/2016 10:22:00 PM	BB67090	Lead	19	15	ppb
063-41A	Room 127 Sink Faucet 2	6/24/2016 4:04:00 PM	7/10/2016 5:39:00 PM	BB67091	Copper	1.8	1.3	ppm
063-41A	Room 127 Sink Faucet 2	6/24/2016 4:04:00 PM	7/10/2016 5:39:00 PM	BB67091	Lead	21	15	ppb
063-42A	Room 127 Sink Faucet 3	6/24/2016 4:04:00 PM	7/10/2016 5:46:00 PM	BB67092	Copper	1.6	1.3	ppm
063-42A	Room 127 Sink Faucet 3	6/24/2016 4:04:00 PM	7/10/2016 5:46:00 PM	BB67092	Lead	15.1	15	ppb
063-43A	Room 127 Sink Faucet 4	6/24/2016 4:04:00 PM	7/10/2016 5:50:00 PM	BB67093	Copper	1.7	1.3	ppm
063-43A	Room 127 Sink Faucet 4	6/24/2016 4:04:00 PM	7/10/2016 5:50:00 PM	BB67093	Lead	17	15	ppb
063-44A	Room 127 Sink Faucet 5	6/24/2016 4:04:00 PM	7/10/2016 5:53:00 PM	BB67094	Copper	1.25	1.3	ppm
063-44A	Room 127 Sink Faucet 5	6/24/2016 4:04:00 PM	7/10/2016 5:53:00 PM	BB67094	Lead	9	15	ppb
063-45A	Room 127 Eye Wash	6/24/2016 4:04:00 PM	7/10/2016 5:57:00 PM	BB67095	Copper	0.7	1.3	ppm
063-45A	Room 127 Eye Wash	6/24/2016 4:04:00 PM	7/10/2016 5:57:00 PM	BB67095	Lead	280	15	ppb
063-46A	Room 120A, Bathroom Sink Faucet	6/24/2016 4:10:00 PM	7/1/2016	BB67096	Copper	0.1	1.3	ppm
063-46A	Room 120A, Bathroom Sink Faucet	6/24/2016 4:10:00 PM	7/1/2016	BB67096	Lead	59	15	ppb
063-47A	Hall Drinking Fountain 2	6/24/2016 4:14:00 PM	7/10/2016 6:00:00 PM	BB67097	Copper	0.1	1.3	ppm
063-47A	Hall Drinking Fountain 2	6/24/2016 4:14:00 PM	7/10/2016 6:00:00 PM	BB67097	Lead	12	15	ppb
063-48A	Hall Drinking Fountain 3	6/24/2016 4:14:00 PM	7/1/2016	BB67098	Copper	0.1	1.3	ppm
063-48A	Hall Drinking Fountain 3	6/24/2016 4:14:00 PM	7/1/2016	BB67098	Lead	10	15	ppb
063-49A	Hall Drinking Fountain 4	6/24/2016 4:14:00 PM	7/1/2016	BB67099	Copper	0.1	1.3	ppm
063-49A	Hall Drinking Fountain 4	6/24/2016 4:14:00 PM	7/1/2016	BB67099	Lead	6	15	ppb
063-50A	Room 118 Sink Faucet 1	6/24/2016 4:17:00 PM	7/10/2016 6:04:00 PM	BB67100	Copper	0.2	1.3	ppm
063-50A	Room 118 Sink Faucet 1	6/24/2016 4:17:00 PM	7/10/2016 6:04:00 PM	BB67100	Lead	28	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Marysville Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
063-51A	Room 118 Sink Faucet 2	6/24/2016 4:17:00 PM	7/10/2016 6:07:00 PM	BB67101	Copper	0.2	1.3	ppm
063-51A	Room 118 Sink Faucet 2	6/24/2016 4:17:00 PM	7/10/2016 6:07:00 PM	BB67101	Lead	36	15	ppb
063-52A	Room 118 Water Spigot	6/24/2016 4:19:00 PM	7/10/2016 6:11:00 PM	BB67102	Copper	0.1	1.3	ppm
063-52A	Room 118 Water Spigot	6/24/2016 4:19:00 PM	7/10/2016 6:11:00 PM	BB67102	Lead	26	15	ppb
063-53A	Room 118 Sink Faucet 3	6/24/2016 4:21:00 PM	7/10/2016 6:42:00 PM	BB67103	Copper	0.1	1.3	ppm
063-53A	Room 118 Sink Faucet 3	6/24/2016 4:21:00 PM	7/10/2016 6:42:00 PM	BB67103	Lead	30	15	ppb
063-54A	Room 118 Sink Faucet 4	6/24/2016 4:21:00 PM	7/10/2016 6:46:00 PM	BB67104	Copper	0.1	1.3	ppm
063-54A	Room 118 Sink Faucet 4	6/24/2016 4:21:00 PM	7/10/2016 6:46:00 PM	BB67104	Lead	36	15	ppb
063-55A	Room 119 Sink Faucet	6/24/2016 4:22:00 PM	7/1/2016	BB67105	Copper	0.1	1.3	ppm
063-55A	Room 119 Sink Faucet	6/24/2016 4:22:00 PM	7/1/2016	BB67105	Lead	52	15	ppb
063-56A	Room 119 Drinking Fountain	6/24/2016 4:23:00 PM	7/1/2016	BB67106	Copper	0.0	1.3	ppm
063-56A	Room 119 Drinking Fountain	6/24/2016 4:23:00 PM	7/1/2016	BB67106	Lead	9	15	ppb
063-57A	Room 113 Sink Faucet	6/24/2016 4:28:00 PM	7/1/2016 1:20:00 PM	BB67107	Copper	0.0	1.3	ppm
063-57A	Room 113 Sink Faucet	6/24/2016 4:28:00 PM	7/1/2016 1:20:00 PM	BB67107	Lead	32	15	ppb
063-58A	Room 106 Bathroom Sink Left	6/24/2016 4:32:00 PM	7/1/2016 1:22:00 PM	BB67108	Copper	0.3	1.3	ppm
063-58A	Room 106 Bathroom Sink Left	6/24/2016 4:32:00 PM	7/1/2016 1:22:00 PM	BB67108	Lead	4	15	ppb
063-59A	Room 106 Bathroom Sink Middle	6/24/2016 4:32:00 PM	7/1/2016 1:25:00 PM	BB67109	Copper	0.1	1.3	ppm
063-59A	Room 106 Bathroom Sink Middle	6/24/2016 4:32:00 PM	7/1/2016 1:25:00 PM	BB67109	Lead	7	15	ppb
063-60A	Room 106 Bathroom Sink Right	6/24/2016 4:32:00 PM	7/1/2016 1:43:00 PM	BB67110	Copper	0.1	1.3	ppm
063-60A	Room 106 Bathroom Sink Right	6/24/2016 4:32:00 PM	7/1/2016 1:43:00 PM	BB67110	Lead	8	15	ppb
063-61A	Room 109 Drinking Fountain	6/24/2016 2:49:00 PM	7/1/2016 1:46:00 PM	BB67111	Copper	0.4	1.3	ppm
063-61A	Room 109 Drinking Fountain	6/24/2016 2:49:00 PM	7/1/2016 1:46:00 PM	BB67111	Lead	2	15	ppb
063-62A	Room 107 Sink Faucet	6/24/2016 4:36:00 PM	7/1/2016 1:48:00 PM	BB67112	Copper	0.5	1.3	ppm
063-62A	Room 107 Sink Faucet	6/24/2016 4:36:00 PM	7/1/2016 1:48:00 PM	BB67112	Lead	6	15	ppb
063-63A	Room 107 Drinking Fountain	6/24/2016 4:36:00 PM	7/1/2016 1:51:00 PM	BB67113	Copper	0.5	1.3	ppm
063-63A	Room 107 Drinking Fountain	6/24/2016 4:36:00 PM	7/1/2016 1:51:00 PM	BB67113	Lead	2	15	ppb
063-64A	Hall Drinking Fountain at Room 102/104	6/24/2016 4:38:00 PM	7/1/2016 1:53:00 PM	BB67114	Copper	0.0	1.3	ppm
063-64A	Hall Drinking Fountain at Room 102/104	6/24/2016 4:38:00 PM	7/1/2016 1:53:00 PM	BB67114	Lead	1	15	ppb
063-65A	Room 102 Mop Sink Faucet	6/24/2016 4:39:00 PM	7/1/2016 1:56:00 PM	BB67115	Copper	0.1	1.3	ppm
063-65A	Room 102 Mop Sink Faucet	6/24/2016 4:39:00 PM	7/1/2016 1:56:00 PM	BB67115	Lead	3	15	ppb
063-66A	Room 105 Sink Faucet	6/24/2016 4:41:00 PM	7/1/2016 2:02:00 PM	BB67116	Copper	0.5	1.3	ppm
063-66A	Room 105 Sink Faucet	6/24/2016 4:41:00 PM	7/1/2016 2:02:00 PM	BB67116	Lead	4	15	ppb
063-67A	Room 105 Handwash Sink Faucet	6/24/2016 4:43:00 PM	7/1/2016 2:05:00 PM	BB67117	Copper	0.0	1.3	ppm
063-67A	Room 105 Handwash Sink Faucet	6/24/2016 4:43:00 PM	7/1/2016 2:05:00 PM	BB67117	Lead	12	15	ppb
063-68A	Room 101D Bathroom Sink Faucet	6/24/2016 4:35:00 PM	7/1/2016 2:07:00 PM	BB67118	Copper	0.0	1.3	ppm
063-68A	Room 101D Bathroom Sink Faucet	6/24/2016 4:35:00 PM	7/1/2016 2:07:00 PM	BB67118	Lead	1	15	ppb
063-69A	Exterior West Side Water Spigot	6/24/2016 4:15:00 PM	7/5/2016 12:51:00 PM	BB67119	Copper	0.0	1.3	ppm
063-69A	Exterior West Side Water Spigot	6/24/2016 4:15:00 PM	7/5/2016 12:51:00 PM	BB67119	Lead	155	15	ppb
063-70A	Exterior Courtyard Water Hose	6/24/2016 6:20:00 PM	7/5/2016 12:58:00 PM	BB67120	Copper	0.7	1.3	ppm
063-70A	Exterior Courtyard Water Hose	6/24/2016 6:20:00 PM	7/5/2016 12:58:00 PM	BB67120	Lead	3	15	ppb
063-71A	Exterior Courtyard Water Spigot	6/24/2016 4:23:00 PM	7/5/2016 1:20:00 PM	BB67121	Copper	0.0	1.3	ppm
063-71A	Exterior Courtyard Water Spigot	6/24/2016 4:23:00 PM	7/5/2016 1:20:00 PM	BB67121	Lead	56	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.