

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Meek (Alliance) High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
005-AR-01A Faucet Sink in Autoroom	6/17/16 17:03	6/24/16 14:38	606210201	Copper	0.1	1.3	ppm
005-AR-01A Faucet Sink in Autoroom	6/17/16 17:03	6/24/16 14:38	606210201	Lead	2	15	ppb
005-101-02A In Classroom 101 Faucet Sink	6/17/16 17:10	6/24/16 14:38	606210202	Copper	0.2	1.3	ppm
005-101-02A In Classroom 101 Faucet Sink	42538.71528	42545.60972	606210202	Lead	94	15	ppb
005-102-03A Manufacturing Tech Lab Faucet	6/17/16 17:16	6/24/16 14:41	606210203	Copper	0.1	1.3	ppm
005-102-03A Manufacturing Tech Lab Faucet	6/17/16 17:16	6/24/16 14:41	606210203	Lead	13	15	ppb
005-102-04A Manufacturing Tech Eye Wash Station	6/17/16 17:17	6/24/16 14:42	606210204	Copper	0.0	1.3	ppm
005-102-04A Manufacturing Tech Eye Wash Station	6/17/16 17:17	6/24/16 14:42	606210204	Lead	1	15	ppb
005-100-05A Classroom 100 Sink Faucet	6/17/16 17:20	6/24/16 14:42	606210205	Copper	0.1	1.3	ppm
005-100-05A Classroom 100 Sink Faucet	42538.72222	42545.6125	606210205	Lead	35	15	ppb
005-GBF-06A Girls Bathroom Faucet	6/17/16 17:25	6/24/16 14:42	606210206	Copper	0.1	1.3	ppm
005-GBF-06A Girls Bathroom Faucet	6/17/16 17:25	6/24/16 14:42	606210206	Lead	8	15	ppb
005-GBF-07A Girls Bathroom Faucet	6/17/16 17:27	6/24/16 14:42	606210207	Copper	0.2	1.3	ppm
005-GBF-07A Girls Bathroom Faucet	42538.72708	42545.6125	606210207	Lead	18	15	ppb
005-BBF-08A Boys Bathroom Faucet	6/17/16 17:37	6/24/16 14:42	606210208	Copper	0.2	1.3	ppm
005-BBF-08A Boys Bathroom Faucet	6/17/16 17:37	6/24/16 14:42	606210208	Lead	2	15	ppb
005-BBF-09A Boys Bathroom Faucet	6/17/16 17:34	6/24/16 14:43	606210209	Copper	0.2	1.3	ppm
005-BBF-09A Boys Bathroom Faucet	6/17/16 17:34	6/24/16 14:43	606210209	Lead	3	15	ppb
005-BBF-10A Boys Bathroom Faucet	6/17/16 17:35	6/24/16 14:43	606210210	Copper	0.4	1.3	ppm
005-BBF-10A Boys Bathroom Faucet	6/17/16 17:35	6/24/16 14:43	606210210	Lead	5	15	ppb
005-102-11A Sink Faucet in Classroom 102	6/17/16 17:40	6/24/16 14:43	606210211	Copper	0.1	1.3	ppm
005-102-11A Sink Faucet in Classroom 102	42538.73611	42545.61319	606210211	Lead	52	15	ppb
005-103-12A Sink Faucet in Classroom 103	6/17/16 17:42	6/24/16 14:43	606210212	Copper	0.1	1.3	ppm
005-103-12A Sink Faucet in Classroom 103	42538.7375	42545.61319	606210212	Lead	65	15	ppb
005-104-13A Sink Faucet in Classroom 104	6/17/16 17:44	6/24/16 14:43	606210213	Copper	0.1	1.3	ppm
005-104-13A Sink Faucet in Classroom 104	42538.73889	42545.61319	606210213	Lead	98	15	ppb
005-105-14A Sink Faucet in Classroom 105	6/17/16 17:46	6/24/16 14:43	606210214	Copper	0.1	1.3	ppm
005-105-14A Sink Faucet in Classroom 105	42538.74028	42545.61319	606210214	Lead	41	15	ppb
005-BF-15A Bathroom Faucet in Women Bathroom	6/17/16 17:52	6/24/16 14:43	606210215	Copper	0.1	1.3	ppm
005-BF-15A Bathroom Faucet in Women Bathroom	6/17/16 17:52	6/24/16 14:43	606210215	Lead	4	15	ppb
005-WS-16A Women Bathroom Water Spigot	42538.74306	42551.79931	606210216	Copper	90	1.3	ppm
005-WS-16A Women Bathroom Water Spigot	42538.74306	42551.79931	606210216	Lead	7320	15	ppb
005-GBF-17A Girls Bathroom Water Spigot	42538.72917	42549.44653	606210217	Copper	1.92	1.3	ppm
005-GBF-17A Girls Bathroom Water Spigot	42538.72917	42549.44653	606210217	Lead	538	15	ppb
005-BBF-18A Boys Bathroom Water Spigot	42538.73125	42551.79931	606210218	Copper	3.89	1.3	ppm
005-BBF-18A Boys Bathroom Water Spigot	42538.73125	42549.44653	606210218	Lead	308	15	ppb
005-DF-19A Drinking Fountain on Corridor by 10b	6/17/16 17:54	6/24/16 14:43	606210219	Copper	0.6	1.3	ppm
005-DF-19A Drinking Fountain on Corridor by 10b	42538.74583	42545.61319	606210219	Lead	40	15	ppb
005-DF-20A Water Bottle Dispenser at Drinking Fountain	42538.74653	42548.81458	606210220	Copper	2.29	1.3	ppm
005-DF-20A Water Bottle Dispenser at Drinking Fountain	6/17/16 17:55	6/24/16 14:43	606210220	Lead	ND	15	ppb
005-DF-21A Drinking Fountain with Bottle Dispenser	42538.74792	42548.81458	606210221	Copper	1.45	1.3	ppm
005-DF-21A Drinking Fountain with Bottle Dispenser	6/17/16 17:57	6/24/16 14:43	606210221	Lead	ND	15	ppb
005-107-22A Faucet Sink in room 107	6/17/16 17:59	6/24/16 14:44	606210222	Copper	0.1	1.3	ppm
005-107-22A Faucet Sink in room 107	42538.74931	42545.61389	606210222	Lead	37	15	ppb
005-BR-23A Bathroom Faucet in Staff Bathroom	6/17/16 18:05	6/24/16 14:44	606210223	Copper	0.1	1.3	ppm
005-BR-23A Bathroom Faucet in Staff Bathroom	6/17/16 18:05	6/24/16 14:44	606210223	Lead	6	15	ppb
005-BR-24A Water Spigot in Staff Bathroom	42538.75208	42556.38611	606210224	Copper	14.5	1.3	ppm
005-BR-24A Water Spigot in Staff Bathroom	42538.75208	42556.38611	606210224	Lead	4490	15	ppb
005-SS-25A Custodian Slop Sink	6/17/16 18:08	6/24/16 14:44	606210225	Copper	0.0	1.3	ppm
005-SS-25A Custodian Slop Sink	6/17/16 18:08	6/24/16 14:44	606210225	Lead	3	15	ppb
005-108-26A Classroom 108 Faucet	6/17/16 18:11	6/24/16 14:44	606210226	Copper	0.1	1.3	ppm
005-108-26A Classroom 108 Faucet	42538.75764	42545.61389	606210226	Lead	20	15	ppb
005-108-27A Classroom 108 Eyewash Station	6/17/16 18:13	6/24/16 14:44	606210227	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Meek (Alliance) High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
005-108-27A Classroom 108 Eyewash Station	6/17/16 18:13	6/24/16 14:44	606210227	Lead	7	15	ppb
005-109-28A Classroom 109 Sink Faucet	6/17/16 18:15	6/24/16 14:44	606210228	Copper	0.2	1.3	ppm
005-109-28A Classroom 109 Sink Faucet	6/17/16 18:15	6/24/16 14:44	606210228	Lead	9	15	ppb
005-109-29A Classroom 109 Drinking Fountain	6/17/16 18:16	6/24/16 14:44	606210229	Copper	0.0	1.3	ppm
005-109-29A Classroom 109 Drinking Fountain	6/17/16 18:16	6/24/16 14:44	606210229	Lead	2	15	ppb
005-BF-30A Emergency Bathroom Faucet Sink 1	6/17/16 18:26	6/24/16 14:44	606210230	Copper	0.1	1.3	ppm
005-BF-30A Emergency Bathroom Faucet Sink 1	6/17/16 18:26	6/24/16 14:44	606210230	Lead	6	15	ppb
005-BF-31A Emergency Bathroom Faucet Sink 2	6/17/16 18:27	6/24/16 14:44	606210231	Copper	0.1	1.3	ppm
005-BF-31A Emergency Bathroom Faucet Sink 2	6/17/16 18:27	6/24/16 14:44	606210231	Lead	6	15	ppb
005-BF-32A Emergency Bathroom Faucet Sink 3	6/17/16 18:28	6/24/16 14:44	606210232	Copper	0.1	1.3	ppm
005-BF-32A Emergency Bathroom Faucet Sink 3	6/17/16 18:28	6/24/16 14:44	606210232	Lead	10	15	ppb
005-BF-33A Emergency Bathroom Faucet Sink 4	6/17/16 18:29	6/24/16 14:45	606210233	Copper	0.1	1.3	ppm
005-BF-33A Emergency Bathroom Faucet Sink 4	6/17/16 18:29	6/24/16 14:45	606210233	Lead	14.7	15	ppb
005-BF-34A Emergency Bathroom Spigot	6/17/16 18:31	6/28/16 10:44	606210234	Copper	0.7	1.3	ppm
005-BF-34A Emergency Bathroom Spigot	42538.77153	42549.44722	606210234	Lead	103	15	ppb
005-CO-35A Custodian Office Faucet Sink	6/17/16 18:39	6/24/16 14:45	606210235	Copper	0.1	1.3	ppm
005-CO-35A Custodian Office Faucet Sink	6/17/16 18:39	6/24/16 14:45	606210235	Lead	9	15	ppb
005-CO-36A Custodian Office Slob Sink	6/17/16 18:37	6/24/16 14:45	606210236	Copper	0.4	1.3	ppm
005-CO-36A Custodian Office Slob Sink	42538.77569	42545.61458	606210236	Lead	33	15	ppb
005-KS-37A Kitchen Sink Faucet	6/17/16 18:43	6/24/16 14:46	606210237	Copper	0.8	1.3	ppm
005-KS-37A Kitchen Sink Faucet	6/17/16 18:43	6/24/16 14:46	606210237	Lead	6	15	ppb
005-KS-38A Kitchen Sink Spray	6/17/16 18:43	6/24/16 14:46	606210238	Copper	0.2	1.3	ppm
005-KS-38A Kitchen Sink Spray	6/17/16 18:43	6/24/16 14:46	606210238	Lead	5	15	ppb
005-KS-39A Kitchen Handwash Sink	6/17/16 18:45	6/24/16 14:46	606210239	Copper	0.6	1.3	ppm
005-KS-39A Kitchen Handwash Sink	42538.78125	42545.61528	606210239	Lead	20	15	ppb
005-KS-40A Kitchen Sink (food prep)	6/17/16 18:49	6/24/16 14:46	606210240	Copper	0.4	1.3	ppm
005-KS-40A Kitchen Sink (food prep)	42538.78403	42545.61528	606210240	Lead	16	15	ppb
005-KS-41A Kitchen Coffee Maker	6/17/16 18:47	6/24/16 14:46	606210241	Copper	0.5	1.3	ppm
005-KS-41A Kitchen Coffee Maker	42538.78264	42545.61528	606210241	Lead	91	15	ppb
005-110B-42A Classroom 110B Sink Faucet	6/17/16 18:52	6/24/16 14:46	606210242	Copper	0.5	1.3	ppm
005-110B-42A Classroom 110B Sink Faucet	42538.78611	42545.61528	606210242	Lead	58	15	ppb
005-110B-43A Classroom 110B Drinking Fountain	6/17/16 18:53	6/24/16 14:46	606210243	Copper	0.0	1.3	ppm
005-110B-43A Classroom 110B Drinking Fountain	6/17/16 18:53	6/24/16 14:46	606210243	Lead	1	15	ppb
005-110B-44A Classroom 110B Sink Faucet	6/17/16 18:55	6/24/16 14:51	606210244	Copper	0.1	1.3	ppm
005-110B-44A Classroom 110B Sink Faucet	42538.78819	42545.61875	606210244	Lead	24	15	ppb
005-FBR-45A Faculty Restroom Sink	6/17/16 18:59	6/24/16 14:51	606210245	Copper	0.3	1.3	ppm
005-FBR-45A Faculty Restroom Sink	6/17/16 18:59	6/24/16 14:51	606210245	Lead	2	15	ppb
005-DF-46A Drinking Fountain on Corridor by Bathrooms	6/17/16 18:57	6/24/16 14:51	606210246	Copper	0.6	1.3	ppm
005-DF-46A Drinking Fountain on Corridor by Bathrooms	6/17/16 18:57	6/24/16 14:51	606210246	Lead	1	15	ppb
005-GBF2-47A Girls Bathroom #2 Fountain 1	6/17/16 18:59	6/24/16 14:51	606210247	Copper	0.3	1.3	ppm
005-GBF2-47A Girls Bathroom #2 Fountain 1	6/17/16 18:59	6/24/16 14:51	606210247	Lead	10	15	ppb
005-GBF2-48A Girls Bathroom #2 Fountain 2	6/17/16 19:01	6/24/16 14:51	606210248	Copper	0.6	1.3	ppm
005-GBF2-48A Girls Bathroom #2 Fountain 2	6/17/16 19:01	6/24/16 14:51	606210248	Lead	13	15	ppb
005-GBF2-49A Girls Bathroom #2 Spigot	42538.79236	42551.8	606210249	Copper	4.49	1.3	ppm
005-GBF2-49A Girls Bathroom #2 Spigot	42538.79236	42549.44722	606210249	Lead	122	15	ppb
005-BBF2-50A Boys Bathroom #2 Fountain 1	6/17/16 19:04	6/24/16 14:51	606210250	Copper	0.6	1.3	ppm
005-BBF2-50A Boys Bathroom #2 Fountain 1	6/17/16 19:04	6/24/16 14:51	606210250	Lead	10	15	ppb
005-BBF2-51A Boys Bathroom #2 Fountain 2	6/17/16 19:06	6/24/16 14:51	606210251	Copper	0.4	1.3	ppm
005-BBF2-51A Boys Bathroom #2 Fountain 2	42538.79583	42545.61875	606210251	Lead	25	15	ppb
005-BBF2-52A Boys Bathroom #2 Spigot	42538.79514	42551.8	606210252	Copper	6.69	1.3	ppm
005-BBF2-52A Boys Bathroom #2 Spigot	42538.79514	42549.44792	606210252	Lead	422	15	ppb
005-111-53A Room 111 Faucet Sink	6/17/16 19:08	6/24/16 14:51	606210253	Copper	0.7	1.3	ppm
005-111-53A Room 111 Faucet Sink	42538.79722	42545.61875	606210253	Lead	17	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Meek (Alliance) High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
005-111-54A Room 111 Drinking Fountain	6/17/16 19:09	6/24/16 14:51	606210254	Copper	0.9	1.3	ppm
005-111-54A Room 111 Drinking Fountain	6/17/16 19:09	6/24/16 14:51	606210254	Lead	7	15	ppb
005-112-55A Classroom 112 Faucet Sink	6/17/16 19:11	6/24/16 14:51	606210255	Copper	0.6	1.3	ppm
005-112-55A Classroom 112 Faucet Sink	6/17/16 19:11	6/24/16 14:51	606210255	Lead	4	15	ppb
005-113-56A Classroom 113 Faucet Sink	6/17/16 19:13	6/24/16 14:52	606210256	Copper	1.0	1.3	ppm
005-113-56A Classroom 113 Faucet Sink	42538.80069	42545.61944	606210256	Lead	49	15	ppb
005-113-57A Classroom 113 Drinking Fountain	6/17/16 19:14	6/24/16 14:52	606210257	Copper	0.8	1.3	ppm
005-113-57A Classroom 113 Drinking Fountain	6/17/16 19:14	6/24/16 14:52	606210257	Lead	9	15	ppb
005-110A-58A Classroom 110A Faucet Sink	6/17/16 19:21	6/24/16 14:52	606210258	Copper	0.4	1.3	ppm
005-110A-58A Classroom 110A Faucet Sink	6/17/16 19:21	6/24/16 14:52	606210258	Lead	4	15	ppb
005-110A-59A Classroom 110A Drinking Fountain	6/17/16 19:22	6/24/16 14:52	606210259	Copper	0.1	1.3	ppm
005-110A-59A Classroom 110A Drinking Fountain	6/17/16 19:22	6/24/16 14:52	606210259	Lead	1	15	ppb
005-Auto-60A Autoroom Eye Wash	6/17/16 17:07	6/30/16 13:20	606210260	Copper	0.4	1.3	ppm
005-Auto-60A Autoroom Eye Wash	6/17/16 17:07	6/30/16 13:20	606210260	Lead	8	15	ppb
005-WS1-61A Exterior Spigot by 103	6/17/16 19:48	6/30/16 13:20	606210261	Copper	0.0	1.3	ppm
005-WS1-61A Exterior Spigot by 103	42538.825	42551.55556	606210261	Lead	20	15	ppb
005-WS2-62A Exterior Spigot by Room 110A	6/17/16 20:24	6/30/16 13:20	606210262	Copper	0.1	1.3	ppm
005-WS2-62A Exterior Spigot by Room 110A	42538.85	42551.55556	606210262	Lead	70	15	ppb
005-WS3-63A Exterior Spigot by Room 110B	6/17/16 19:39	6/30/16 13:20	606210263	Copper	0.0	1.3	ppm
005-WS3-63A Exterior Spigot by Room 110B	6/17/16 19:39	6/30/16 13:20	606210263	Lead	12	15	ppb
005-WS4-64A Exterior Spigot by Room 109	6/17/16 19:36	6/24/16 14:52	606210264	Copper	0.9	1.3	ppm
005-WS4-64A Exterior Spigot by Room 109	42538.81667	42545.61944	606210264	Lead	39	15	ppb
005-WS5-65A Exterior Spigot by Room 108	6/17/16 19:33	6/24/16 14:52	606210265	Copper	0.1	1.3	ppm
005-WS5-65A Exterior Spigot by Room 108	6/17/16 19:33	6/24/16 14:52	606210265	Lead	9	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.