

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Metropolitan Learning Center

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
064-01A Ground Floor - Room 106 Sink	6/27/2016 00:22	7/6/2016 11:30	10353843001	Copper	0.5	1.3	ppm
064-01A Ground Floor - Room 106 Sink	6/27/2016 00:22	7/5/2016 12:35	10353843001	Lead	3	15	ppb
064-02A Ground Floor - Kitchen-Scull-Northeast	6/27/2016 01:30	7/6/2016 11:32	10353843003	Copper	0.5	1.3	ppm
064-02A Ground Floor - Kitchen-Scull-Northeast	6/27/2016 01:30	7/5/2016 12:40	10353843003	Lead	6	15	ppb
064-03A Ground Floor - Kitchen-Scull-Northwest (1)	6/27/2016 01:32	7/6/2016 11:39	10353843005	Copper	0.4	1.3	ppm
064-03A Ground Floor - Kitchen-Scull-Northwest (1)	6/27/2016 01:32	7/5/2016 12:42	10353843005	Lead	3	15	ppb
064-04A Ground Floor - Kitchen-Scull-Northwest (2)	6/27/2016 01:30	7/6/2016 11:41	10353843007	Copper	0.6	1.3	ppm
064-04A Ground Floor - Kitchen-Scull-Northwest (2)	6/27/2016 01:30	7/5/2016 12:43	10353843007	Lead	12	15	ppb
064-05A Ground Floor - Kitchen-Sink North	6/27/2016 01:28	7/6/2016 11:42	10353843009	Copper	0.5	1.3	ppm
064-05A Ground Floor - Kitchen-Sink North	6/27/2016 01:28	7/5/2016 12:44	10353843009	Lead	10	15	ppb
064-06A Ground Floor - Kitchen Restroom Sink	6/27/2016 01:27	7/6/2016 11:43	10353843011	Copper	0.4	1.3	ppm
064-06A Ground Floor - Kitchen Restroom Sink	6/27/2016 01:27	7/5/2016 12:48	10353843011	Lead	6	15	ppb
064-07A Ground Floor - Room 116 Custodial Sink	6/27/2016 01:34	7/6/2016 11:45	10353843013	Copper	0.6	1.3	ppm
064-07A Ground Floor - Room 116 Custodial Sink	6/27/2016 01:34	7/5/2016 12:50	10353843013	Lead	2	15	ppb
064-08A Ground Floor - Hallway Southeast Drinking Fountain West	6/27/2016 01:35	7/6/2016 11:46	10353843015	Copper	0.7	1.3	ppm
064-08A Ground Floor - Hallway Southeast Drinking Fountain West	6/27/2016 01:35	7/5/2016 12:51	10353843015	Lead	0	15	ppb
064-09A Ground Floor - Hallway Southeast Drinking Fountain East	6/27/2016 01:39	7/6/2016 11:47	10353843017	Copper	0.6	1.3	ppm
064-09A Ground Floor - Hallway Southeast Drinking Fountain East	6/27/2016 01:39	7/5/2016 12:53	10353843017	Lead	0	15	ppb
064-10A Ground Floor - Girls Restroom Sink (1)	6/27/2016 01:41	7/6/2016 11:49	10353843019	Copper	0.4	1.3	ppm
064-10A Ground Floor - Girls Restroom Sink (1)	6/27/2016 01:41	7/5/2016 12:55	10353843019	Lead	4	15	ppb
064-11A Ground Floor - Girls Restroom Sink (2)	6/27/2016 01:44	7/6/2016 07:58	10353843021	Copper	0.3	1.3	ppm
064-11A Ground Floor - Girls Restroom Sink (2)	6/27/2016 01:44	7/6/2016 07:58	10353843021	Lead	13	15	ppb
064-12A Ground Floor - Girls Restroom Sink (3)	6/27/2016 01:40	7/6/2016 08:04	10353843023	Copper	0.4	1.3	ppm
064-12A Ground Floor - Girls Restroom Sink (3)	6/27/2016 01:40	7/6/2016 08:04	10353843023	Lead	6	15	ppb
064-13A Ground Floor - Girls Restroom Spigot (Center)	6/27/2016 01:42	7/6/2016 08:05	10353843025	Copper	0.3	1.3	ppm
064-13A Ground Floor - Girls Restroom Spigot (Center)	6/27/2016 01:42	7/6/2016 08:05	10353843025	Lead	64	15	ppb
064-14A Ground Floor - Boys Restroom Sink (1)	6/27/2016 01:49	7/6/2016 10:30	10353843027	Copper	0.4	1.3	ppm
064-14A Ground Floor - Boys Restroom Sink (1)	6/27/2016 01:49	7/6/2016 10:30	10353843027	Lead	13	15	ppb
064-15A Ground Floor - Boys Restroom Sink (2)	6/27/2016 01:48	7/6/2016 10:32	10353843029	Copper	0.6	1.3	ppm
064-15A Ground Floor - Boys Restroom Sink (2)	6/27/2016 01:48	7/6/2016 10:32	10353843029	Lead	24	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Metropolitan Learning Center

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
064-16A Ground Floor - Boys Restroom Spigot	6/27/2016 01:51	7/6/2016 09:02	10353843031	Copper	0.9	1.3	ppm
064-16A Ground Floor - Boys Restroom Spigot	6/27/2016 01:51	7/6/2016 08:07	10353843031	Lead	102	15	ppb
064-17A Ground Floor - Mens Locker Room Sink (1)	6/27/2016 00:18	7/6/2016 09:03	10353843033	Copper	1.0	1.3	ppm
064-17A Ground Floor - Mens Locker Room Sink (1)	6/27/2016 00:18	7/6/2016 08:08	10353843033	Lead	3	15	ppb
064-18A Ground Floor - Mens Locker Room Sink (2)	6/27/2016 00:20	7/6/2016 09:07	10353843035	Copper	0.7	1.3	ppm
064-18A Ground Floor - Mens Locker Room Sink (2)	6/27/2016 00:20	7/6/2016 08:15	10353843035	Lead	9	15	ppb
064-19A Ground Floor - Mens Locker Room Spigot (1)	6/27/2016 00:24	7/6/2016 09:09	10353843037	Copper	0.6	1.3	ppm
064-19A Ground Floor - Mens Locker Room Spigot (1)	6/27/2016 00:24	7/6/2016 08:16	10353843037	Lead	17	15	ppb
064-20A Ground Floor - Mens Locker Room Shower (1)	6/27/2016 00:48	7/6/2016 10:33	10353843039	Copper	2.3	1.3	ppm
064-20A Ground Floor - Mens Locker Room Shower (1)	6/27/2016 00:48	7/6/2016 10:33	10353843039	Lead	318	15	ppb
064-21A Ground Floor - Mens Locker Room Shower (2)	6/27/2016 00:51	7/1/2016 12:21	10353843041	Copper	0.4	1.3	ppm
064-21A Ground Floor - Mens Locker Room Shower (2)	6/27/2016 00:51	7/1/2016 12:21	10353843041	Lead	38	15	ppb
064-22A Ground Floor - Mens Locker Room Spigot (2)	6/27/2016 00:54	7/7/2016 14:40	10353843154	Copper	6.9	1.3	ppm
064-22A Ground Floor - Mens Locker Room Spigot (2)	6/27/2016 00:54	7/7/2016 11:20	10353843154	Lead	346	15	ppb
064-23A Ground Floor - Mens Locker Room Shower (3)	6/27/2016 00:56	7/7/2016 11:56	10353843043	Copper	0.1	1.3	ppm
064-23A Ground Floor - Mens Locker Room Shower (3)	6/27/2016 00:56	7/7/2016 11:56	10353843043	Lead	6	15	ppb
064-24A Ground Floor - Mens Locker Room Shower (4)	6/27/2016 00:49	7/6/2016 10:52	10353843045	Copper	9.9	1.3	ppm
064-24A Ground Floor - Mens Locker Room Shower (4)	6/27/2016 00:49	7/6/2016 10:52	10353843045	Lead	820	15	ppb
064-25A Ground Floor - Mens Locker Room Shower (5)	6/27/2016 00:51	7/6/2016 10:53	10353843047	Copper	0.9	1.3	ppm
064-25A Ground Floor - Mens Locker Room Shower (5)	6/27/2016 00:51	7/5/2016 16:57	10353843047	Lead	101	15	ppb
064-26A Ground Floor - Mens Locker Room Shower (6)	6/27/2016 00:54	7/6/2016 10:55	10353843049	Copper	1.0	1.3	ppm
064-26A Ground Floor - Mens Locker Room Shower (6)	6/27/2016 00:54	7/5/2016 17:01	10353843049	Lead	114	15	ppb
064-27A Ground Floor - Pool Northeast Corner Spigot	6/27/2016 00:30	7/6/2016 10:56	10353843051	Copper	0.7	1.3	ppm
064-27A Ground Floor - Pool Northeast Corner Spigot	6/27/2016 00:30	7/5/2016 17:02	10353843051	Lead	92	15	ppb
064-28A Ground Floor - Pool Southwest Drinking Fountain	6/27/2016 00:44	7/6/2016 11:02	10353843053	Copper	3.5	1.3	ppm
064-28A Ground Floor - Pool Southwest Drinking Fountain	6/27/2016 00:44	7/5/2016 17:03	10353843053	Lead	33	15	ppb
064-29A Ground Floor - Pool Southwest Spigot (1)	6/27/2016 00:44	7/6/2016 11:03	10353843055	Copper	1.1	1.3	ppm
064-29A Ground Floor - Pool Southwest Spigot (1)	6/27/2016 00:44	7/5/2016 17:05	10353843055	Lead	103	15	ppb
064-30A Ground Floor - Pool Southwest Spigot (2)	6/27/2016 00:47	7/1/2016 12:22	10353843057	Copper	0.1	1.3	ppm
064-30A Ground Floor - Pool Southwest Spigot (2)	6/27/2016 00:47	7/1/2016 12:22	10353843057	Lead	23	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Metropolitan Learning Center

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
064-31A Ground Floor - Womens Locker Room Shower (1)	6/27/2016 01:10	7/6/2016 11:04	10353843059	Copper	2.4	1.3	ppm
064-31A Ground Floor - Womens Locker Room Shower (1)	6/27/2016 01:10	7/5/2016 17:06	10353843059	Lead	174	15	ppb
064-32A Ground Floor - Womens Locker Room Shower (2)	6/27/2016 01:12	7/6/2016 11:06	10353843061	Copper	1.2	1.3	ppm
064-32A Ground Floor - Womens Locker Room Shower (2)	6/27/2016 01:12	7/5/2016 17:07	10353843061	Lead	86	15	ppb
064-33A Ground Floor - Womens Locker Room Shower (3)	6/27/2016 01:14	7/6/2016 11:07	10353843063	Copper	17.9	1.3	ppm
064-33A Ground Floor - Womens Locker Room Shower (3)	6/27/2016 01:14	7/6/2016 11:07	10353843063	Lead	1680	15	ppb
064-34A Ground Floor - Womens Locker Room Shower (4)	6/27/2016 01:16	7/6/2016 11:08	10353843065	Copper	5.7	1.3	ppm
064-34A Ground Floor - Womens Locker Room Shower (4)	6/27/2016 01:16	7/5/2016 17:12	10353843065	Lead	448	15	ppb
064-35A Ground Floor - Womens Locker Room Shower (5)	6/27/2016 01:16	7/6/2016 11:10	10353843067	Copper	4.9	1.3	ppm
064-35A Ground Floor - Womens Locker Room Shower (5)	6/27/2016 01:16	7/6/2016 11:10	10353843067	Lead	565	15	ppb
064-36A Ground Floor - Womens Locker Room Shower (6)	6/27/2016 01:13	7/6/2016 10:34	10353843069	Copper	0.3	1.3	ppm
064-36A Ground Floor - Womens Locker Room Shower (6)	6/27/2016 01:13	7/6/2016 10:34	10353843069	Lead	152	15	ppb
064-37A Ground Floor - Womens Locker Room Sink (1)	6/27/2016 00:31	7/6/2016 11:11	10353843071	Copper	0.9	1.3	ppm
064-37A Ground Floor - Womens Locker Room Sink (1)	6/27/2016 00:31	7/6/2016 11:11	10353843071	Lead	14.8	15	ppb
064-38A Ground Floor - Womens Locker Room Sink (2)	6/27/2016 00:33	7/6/2016 11:12	10353843073	Copper	0.7	1.3	ppm
064-38A Ground Floor - Womens Locker Room Sink (2)	6/27/2016 00:33	7/6/2016 11:12	10353843073	Lead	16	15	ppb
064-39A Ground Floor - Womens Locker Room Spigot South	6/27/2016 00:33	7/6/2016 11:16	10353843075	Copper	0.7	1.3	ppm
064-39A Ground Floor - Womens Locker Room Spigot South	6/27/2016 00:33	7/6/2016 11:16	10353843075	Lead	69	15	ppb
064-40A Ground Floor - Womens Locker Room Spigot North	6/27/2016 01:08	7/6/2016 11:23	10353843077	Copper	1.1	1.3	ppm
064-40A Ground Floor - Womens Locker Room Spigot North	6/27/2016 01:08	7/6/2016 11:23	10353843077	Lead	19	15	ppb
064-41A 1st Floor - Principals Office 200 Restroom Sink	6/27/2016 03:57	7/1/2016 12:30	10353843079	Copper	1.0	1.3	ppm
064-41A 1st Floor - Principals Office 200 Restroom Sink	6/27/2016 03:57	7/1/2016 09:43	10353843079	Lead	2	15	ppb
064-42A 1st Floor - Office 202 Restroom Sink	6/27/2016 03:14	7/5/2016 14:59	10353843081	Copper	0.5	1.3	ppm
064-42A 1st Floor - Office 202 Restroom Sink	6/27/2016 03:14	7/5/2016 12:05	10353843081	Lead	11	15	ppb
064-43A 1st Floor - Hallway Southwest - Drinking Fountain	6/27/2016 02:32	7/5/2016 15:02	10353843083	Copper	1.1	1.3	ppm
064-43A 1st Floor - Hallway Southwest - Drinking Fountain	6/27/2016 02:32	7/5/2016 15:02	10353843083	Lead	1	15	ppb
064-44A 1st Floor - Classroom 204 Sink	6/27/2016 02:34	7/5/2016 15:03	10353843085	Copper	0.3	1.3	ppm
064-44A 1st Floor - Classroom 204 Sink	6/27/2016 02:34	7/5/2016 12:12	10353843085	Lead	4	15	ppb
064-45A 1st Floor - Classroom 207 Sink	6/27/2016 02:24	7/5/2016 15:04	10353843087	Copper	0.3	1.3	ppm
064-45A 1st Floor - Classroom 207 Sink	6/27/2016 02:24	7/5/2016 12:13	10353843087	Lead	7	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Metropolitan Learning Center

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
064-46A 1st Floor - Girls Restroom Sink (1)	6/27/2016 02:39	7/7/2016 16:06	10353843089	Copper	0.8	1.3	ppm
064-46A 1st Floor - Girls Restroom Sink (1)	6/27/2016 02:39	7/7/2016 16:02	10353843089	Lead	80	15	ppb
064-47A 1st Floor - Girls Restroom Sink (2)	6/27/2016 02:41	7/6/2016 10:36	10353843091	Copper	0.7	1.3	ppm
064-47A 1st Floor - Girls Restroom Sink (2)	6/27/2016 02:41	7/6/2016 10:36	10353843091	Lead	60	15	ppb
064-48A 1st Floor - Girls Restroom Sink (3)	6/27/2016 02:43	7/6/2016 10:38	10353843093	Copper	0.4	1.3	ppm
064-48A 1st Floor - Girls Restroom Sink (3)	6/27/2016 02:43	7/6/2016 10:38	10353843093	Lead	36	15	ppb
064-49A 1st Floor - Girls Restroom Sink (4)	6/27/2016 02:40	7/6/2016 10:40	10353843095	Copper	0.8	1.3	ppm
064-49A 1st Floor - Girls Restroom Sink (4)	6/27/2016 02:40	7/6/2016 10:40	10353843095	Lead	72	15	ppb
064-50A 1st Floor - Girls Restroom Sink (5)	6/27/2016 02:39	7/6/2016 10:44	10353843097	Copper	0.8	1.3	ppm
064-50A 1st Floor - Girls Restroom Sink (5)	6/27/2016 02:39	7/6/2016 10:44	10353843097	Lead	103	15	ppb
064-51A 1st Floor - Girls Restroom Spigot	6/27/2016 02:43	7/6/2016 10:45	10353843099	Copper	0.3	1.3	ppm
064-51A 1st Floor - Girls Restroom Spigot	6/27/2016 02:43	7/6/2016 10:45	10353843099	Lead	182	15	ppb
064-52A 1st Floor - Boys Restroom Sink (1)	6/27/2016 02:46	7/5/2016 15:06	10353843101	Copper	0.4	1.3	ppm
064-52A 1st Floor - Boys Restroom Sink (1)	6/27/2016 02:46	7/5/2016 12:14	10353843101	Lead	36	15	ppb
064-53A 1st Floor - Boys Restroom Sink (2)	6/27/2016 02:49	7/5/2016 15:07	10353843103	Copper	0.3	1.3	ppm
064-53A 1st Floor - Boys Restroom Sink (2)	6/27/2016 02:49	7/5/2016 12:18	10353843103	Lead	9	15	ppb
064-54A 1st Floor - Boys Restroom Sink (3)	6/27/2016 02:51	7/5/2016 15:08	10353843105	Copper	0.3	1.3	ppm
064-54A 1st Floor - Boys Restroom Sink (3)	6/27/2016 02:51	7/5/2016 12:19	10353843105	Lead	127	15	ppb
064-55A 1st Floor - Boys Restroom Sink (4)	6/27/2016 02:50	7/5/2016 15:10	10353843107	Copper	0.2	1.3	ppm
064-55A 1st Floor - Boys Restroom Sink (4)	6/27/2016 02:50	7/5/2016 12:21	10353843107	Lead	23	15	ppb
064-56A 1st Floor - Boys Restroom Sink (5)	6/27/2016 02:48	7/5/2016 15:12	10353843109	Copper	0.4	1.3	ppm
064-56A 1st Floor - Boys Restroom Sink (5)	6/27/2016 02:48	7/5/2016 12:22	10353843109	Lead	143	15	ppb
064-57A 1st Floor - Boys Restroom Spigot	6/27/2016 02:46	7/6/2016 10:47	10353843111	Copper	3.1	1.3	ppm
064-57A 1st Floor - Boys Restroom Spigot	6/27/2016 02:46	7/6/2016 10:47	10353843111	Lead	697	15	ppb
064-58A 1st Floor - Media Center Sink	6/27/2016 02:54	7/5/2016 15:16	10353843113	Copper	0.7	1.3	ppm
064-58A 1st Floor - Media Center Sink	6/27/2016 02:54	7/5/2016 12:23	10353843113	Lead	6	15	ppb
064-59A 1st Floor - Hallway Northeast Sink (1)	6/27/2016 02:57	7/5/2016 15:17	10353843115	Copper	0.3	1.3	ppm
064-59A 1st Floor - Hallway Northeast Sink (1)	6/27/2016 02:57	7/5/2016 12:25	10353843115	Lead	59	15	ppb
064-60A 1st Floor - Hallway Northeast Sink (2)	6/27/2016 02:57	7/5/2016 15:18	10353843117	Copper	0.3	1.3	ppm
064-60A 1st Floor - Hallway Northeast Sink (2)	6/27/2016 02:57	7/5/2016 12:27	10353843117	Lead	16	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Metropolitan Learning Center

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
064-61A 1st Floor - Room 217 Sink	6/27/2016 03:20	7/5/2016 15:20	10353843119	Copper	0.3	1.3	ppm
064-61A 1st Floor - Room 217 Sink	6/27/2016 03:20	7/5/2016 12:29	10353843119	Lead	7	15	ppb
064-62A 2nd Floor - Room 315 Sink	6/27/2016 03:47	7/5/2016 15:21	10353843121	Copper	0.6	1.3	ppm
064-62A 2nd Floor - Room 315 Sink	6/27/2016 03:47	7/5/2016 11:19	10353843121	Lead	3	15	ppb
064-63A 2nd Floor - Room 308 Sink	6/27/2016 03:31	7/5/2016 14:42	10353843123	Copper	0.4	1.3	ppm
064-63A 2nd Floor - Room 308 Sink	6/27/2016 03:31	7/5/2016 11:24	10353843123	Lead	11	15	ppb
064-64A 2nd Floor - Room 308A Sink	6/27/2016 03:31	7/5/2016 15:22	10353843125	Copper	0.5	1.3	ppm
064-64A 2nd Floor - Room 308A Sink	6/27/2016 03:31	7/5/2016 11:26	10353843125	Lead	213	15	ppb
064-65A 2nd Floor - Room 308A Eyewash	6/27/2016 03:33	7/5/2016 15:24	10353843127	Copper	0.5	1.3	ppm
064-65A 2nd Floor - Room 308A Eyewash	6/27/2016 03:33	7/5/2016 11:27	10353843127	Lead	43	15	ppb
064-66A 2nd Floor - Southwest Stairwell Lobby Drinking Fountain	6/27/2016 03:39	7/5/2016 14:46	10353843129	Copper	1.0	1.3	ppm
064-66A 2nd Floor - Southwest Stairwell Lobby Drinking Fountain	6/27/2016 03:39	7/5/2016 11:28	10353843129	Lead	1	15	ppb
064-67A 2nd Floor - Room 301 Sink	6/27/2016 03:39	7/5/2016 14:47	10353843131	Copper	0.7	1.3	ppm
064-67A 2nd Floor - Room 301 Sink	6/27/2016 03:39	7/5/2016 11:32	10353843131	Lead	1	15	ppb
064-68A 2nd Floor - Room 300 Sink	6/27/2016 03:42	7/5/2016 14:48	10353843133	Copper	0.5	1.3	ppm
064-68A 2nd Floor - Room 300 Sink	6/27/2016 03:42	7/5/2016 11:33	10353843133	Lead	3	15	ppb
064-69A 2nd Floor - Room 305 Custodial Sink	6/27/2016 03:25	7/5/2016 15:25	10353843135	Copper	0.6	1.3	ppm
064-69A 2nd Floor - Room 305 Custodial Sink	6/27/2016 03:25	7/5/2016 11:35	10353843135	Lead	4	15	ppb
064-70A 1st Floor - Room 210 Custodial Sink	6/27/2016 02:21	7/5/2016 14:54	10353843137	Copper	0.5	1.3	ppm
064-70A 1st Floor - Room 210 Custodial Sink	6/27/2016 02:21	7/5/2016 11:36	10353843137	Lead	6	15	ppb
064-71A 2nd Floor - Room 315 Sink	6/27/2016 03:48	7/5/2016 14:55	10353843139	Copper	0.8	1.3	ppm
064-71A 2nd Floor - Room 315 Sink	6/27/2016 03:48	7/5/2016 11:37	10353843139	Lead	2	15	ppb
064-72A Basement - Room 109 Sink	6/27/2016 01:55	7/7/2016 10:32	10353843141	Copper	0.9	1.3	ppm
064-72A Basement - Room 109 Sink	6/27/2016 01:55	7/6/2016 21:11	10353843141	Lead	7	15	ppb
064-73A Exterior Spigot Westside	6/27/2016 04:17	7/6/2016 21:17	10353843143	Copper	0.2	1.3	ppm
064-73A Exterior Spigot Westside	6/27/2016 04:17	7/6/2016 21:17	10353843143	Lead	14	15	ppb
064-74A Exterior Spigot Southwest	6/27/2016 04:21	7/6/2016 21:18	10353843145	Copper	0.4	1.3	ppm
064-74A Exterior Spigot Southwest	6/27/2016 04:21	7/6/2016 21:18	10353843145	Lead	59	15	ppb
064-75A Exterior Spigot Southeast	6/27/2016 04:23	7/6/2016 21:20	10353843147	Copper	0.1	1.3	ppm
064-75A Exterior Spigot Southeast	6/27/2016 04:23	7/6/2016 21:20	10353843147	Lead	22	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Metropolitan Learning Center

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
064-76A Exterior Spigot East	6/27/2016 04:27	7/6/2016 21:24	10353843149	Copper	0.1	1.3	ppm
064-76A Exterior Spigot East	6/27/2016 04:27	7/6/2016 21:24	10353843149	Lead	3	15	ppb
064-77A Basement - Boiler Room	6/27/2016 02:18	7/6/2016 21:25	10353843151	Copper	0.4	1.3	ppm
064-77A Basement - Boiler Room	6/27/2016 02:18	7/6/2016 21:25	10353843151	Lead	5	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.