

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Mt. Tabor Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
065-01A Boiler Room Hose at Exit	6/27/2016 02:10	7/10/2016 16:13	10354326001	Copper	0.3	1.3	ppm
065-01A Boiler Room Hose at Exit	6/27/2016 02:10	7/10/2016 16:13	10354326001	Lead	7	15	ppb
065-02A Boiler Room South Wall (1)	6/27/2016 02:12	7/10/2016 16:18	10354326003	Copper	0.0	1.3	ppm
065-02A Boiler Room South Wall (1)	6/27/2016 02:12	7/10/2016 16:18	10354326003	Lead	10	15	ppb
065-03A Boiler Room South Wall (2)	6/27/2016 02:14	7/8/2016 16:01	10354326005	Copper	0.0	1.3	ppm
065-03A Boiler Room South Wall (2)	6/27/2016 02:14	7/8/2016 16:01	10354326005	Lead	11	15	ppb
065-04A Room 200 Sink Faucet	6/27/2016 02:17	7/8/2016 20:55	10354326007	Copper	0.8	1.3	ppm
065-04A Room 200 Sink Faucet	6/27/2016 02:17	7/8/2016 16:06	10354326007	Lead	1	15	ppb
065-05A Room 201 Sink Faucet	6/27/2016 02:20	7/8/2016 20:56	10354326009	Copper	0.8	1.3	ppm
065-05A Room 201 Sink Faucet	6/27/2016 02:20	7/8/2016 16:07	10354326009	Lead	5	15	ppb
065-06A Room 202 Sink Faucet	6/27/2016 02:24	7/8/2016 21:00	10354326011	Copper	0.6	1.3	ppm
065-06A Room 202 Sink Faucet	6/27/2016 02:24	7/8/2016 16:11	10354326011	Lead	4	15	ppb
065-07A Room 202 Drinking Fountain	6/27/2016 02:26	7/8/2016 16:12	10354326013	Copper	0.4	1.3	ppm
065-07A Room 202 Drinking Fountain	6/27/2016 02:26	7/8/2016 16:12	10354326013	Lead	10	15	ppb
065-08A Room 203 Sink Faucet	6/27/2016 02:29	7/8/2016 16:13	10354326015	Copper	0.5	1.3	ppm
065-08A Room 203 Sink Faucet	6/27/2016 02:29	7/8/2016 16:13	10354326015	Lead	17	15	ppb
065-09A Room 203 Drinking Fountain	6/27/2016 02:31	7/8/2016 21:01	10354326017	Copper	0.5	1.3	ppm
065-09A Room 203 Drinking Fountain	6/27/2016 02:31	7/8/2016 16:14	10354326017	Lead	2	15	ppb
065-10A Room 204 Drinking Fountain	6/27/2016 02:32	7/8/2016 21:02	10354326019	Copper	0.5	1.3	ppm
065-10A Room 204 Drinking Fountain	6/27/2016 02:32	7/8/2016 16:16	10354326019	Lead	4	15	ppb
065-11A Room 205 Sink Faucet	6/27/2016 02:34	7/8/2016 21:03	10354326021	Copper	0.6	1.3	ppm
065-11A Room 205 Sink Faucet	6/27/2016 02:34	7/8/2016 16:17	10354326021	Lead	12	15	ppb
065-12A Room 205 Drinking Fountain	6/27/2016 02:34	7/8/2016 21:05	10354326023	Copper	0.9	1.3	ppm
065-12A Room 205 Drinking Fountain	6/27/2016 02:34	7/8/2016 16:18	10354326023	Lead	3	15	ppb
065-13A Room 206 Sink Faucet	6/27/2016 02:38	7/8/2016 21:06	10354326025	Copper	0.8	1.3	ppm
065-13A Room 206 Sink Faucet	6/27/2016 02:38	7/8/2016 16:19	10354326025	Lead	17	15	ppb
065-14A Room 206 Drinking Fountain	6/27/2016 02:40	7/10/2016 20:32	10354326027	Copper	1.4	1.3	ppm
065-14A Room 206 Drinking Fountain	6/27/2016 02:40	7/10/2016 16:19	10354326027	Lead	5	15	ppb
065-15A Room 207 Sink Faucet	6/27/2016 02:43	7/8/2016 16:21	10354326029	Copper	0.4	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Mt. Tabor Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
065-15A Room 207 Sink Faucet	6/27/2016 02:43	7/8/2016 16:21	10354326029	Lead	30	15	ppb
065-16A Room 208 Sink Faucet	6/27/2016 02:47	7/8/2016 21:07	10354326031	Copper	0.7	1.3	ppm
065-16A Room 208 Sink Faucet	6/27/2016 02:47	7/8/2016 16:25	10354326031	Lead	0	15	ppb
065-17A Room 209 Sink Faucet	6/27/2016 02:50	7/8/2016 21:08	10354326033	Copper	0.6	1.3	ppm
065-17A Room 209 Sink Faucet	6/27/2016 02:50	7/8/2016 16:26	10354326033	Lead	2	15	ppb
065-18A Room 209 Drinking Fountain by door	6/27/2016 02:52	7/8/2016 21:09	10354326035	Copper	0.9	1.3	ppm
065-18A Room 209 Drinking Fountain by door	6/27/2016 02:52	7/8/2016 16:27	10354326035	Lead	5	15	ppb
065-19A Room 208 Drinking Fountain by door	6/27/2016 02:47	7/8/2016 21:11	10354326037	Copper	0.9	1.3	ppm
065-19A Room 208 Drinking Fountain by door	6/27/2016 02:47	7/8/2016 16:28	10354326037	Lead	9	15	ppb
065-20A Room 207 Drinking Fountain by door	6/27/2016 02:43	7/8/2016 16:30	10354326039	Copper	0.0	1.3	ppm
065-20A Room 207 Drinking Fountain by door	6/27/2016 02:43	7/8/2016 16:30	10354326039	Lead	22	15	ppb
065-21A Room 200 Drinking Fountain by door	6/27/2016 02:47	7/8/2016 20:42	10354326041	Copper	1.2	1.3	ppm
065-21A Room 200 Drinking Fountain by door	6/27/2016 02:47	7/8/2016 15:17	10354326041	Lead	24	15	ppb
065-22A Room 201 Drinking Fountain by door	6/27/2016 02:59	7/8/2016 20:47	10354326043	Copper	1.1	1.3	ppm
065-22A Room 201 Drinking Fountain by door	6/27/2016 02:59	7/8/2016 15:21	10354326043	Lead	3	15	ppb
065-23A Room 210 Sink Faucet	6/27/2016 03:03	7/8/2016 20:48	10354326045	Copper	0.7	1.3	ppm
065-23A Room 210 Sink Faucet	6/27/2016 03:03	7/8/2016 15:23	10354326045	Lead	2	15	ppb
065-24A Room 210 Drinking Fountain	6/27/2016 03:05	7/8/2016 20:49	10354326047	Copper	1.0	1.3	ppm
065-24A Room 210 Drinking Fountain	6/27/2016 03:05	7/8/2016 15:24	10354326047	Lead	2	15	ppb
065-25A Room 212 Sink Faucet (1)	6/27/2016 03:08	7/8/2016 20:50	10354326049	Copper	0.5	1.3	ppm
065-25A Room 212 Sink Faucet (1)	6/27/2016 03:08	7/8/2016 15:25	10354326049	Lead	1	15	ppb
065-26A Room 212 Sink Faucet (2)	6/27/2016 03:10	7/10/2016 20:33	10354326051	Copper	1.0	1.3	ppm
065-26A Room 212 Sink Faucet (2)	6/27/2016 03:10	7/10/2016 16:20	10354326051	Lead	2	15	ppb
065-27A Room 212 Sink Faucet (3)	6/27/2016 03:10	7/8/2016 20:52	10354326053	Copper	0.6	1.3	ppm
065-27A Room 212 Sink Faucet (3)	6/27/2016 03:10	7/8/2016 15:30	10354326053	Lead	0	15	ppb
065-28A Room 213B Sink Faucet	6/27/2016 03:13	7/8/2016 15:31	10354326055	Copper	0.3	1.3	ppm
065-28A Room 213B Sink Faucet	6/27/2016 03:13	7/8/2016 15:31	10354326055	Lead	39	15	ppb
065-29A Room 213B Drinking Fountain	6/27/2016 03:13	7/8/2016 15:32	10354326057	Copper	0.4	1.3	ppm
065-29A Room 213B Drinking Fountain	6/27/2016 03:13	7/8/2016 15:32	10354326057	Lead	4	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Mt. Tabor Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
065-30A Room 213 Shop Sink Faucet (1)	6/27/2016 03:17	7/8/2016 15:33	10354326059	Copper	0.3	1.3	ppm
065-30A Room 213 Shop Sink Faucet (1)	6/27/2016 03:17	7/8/2016 15:33	10354326059	Lead	23	15	ppb
065-31A Room 213 Shop Sink Faucet (2)	6/27/2016 03:19	7/8/2016 15:34	10354326061	Copper	0.2	1.3	ppm
065-31A Room 213 Shop Sink Faucet (2)	6/27/2016 03:19	7/8/2016 15:34	10354326061	Lead	2	15	ppb
065-32A Room 213 Shop Eyewash	6/27/2016 03:20	7/8/2016 20:53	10354326063	Copper	0.7	1.3	ppm
065-32A Room 213 Shop Eyewash	6/27/2016 03:20	7/8/2016 15:35	10354326063	Lead	7	15	ppb
065-33A Room 213 Shop Sink Faucet (3)	6/27/2016 03:22	7/8/2016 15:38	10354326065	Copper	0.3	1.3	ppm
065-33A Room 213 Shop Sink Faucet (3)	6/27/2016 03:22	7/8/2016 15:38	10354326065	Lead	1	15	ppb
065-34A Room 214 Science Sink Faucet (1)	6/27/2016 02:45	7/8/2016 15:39	10354326067	Copper	0.1	1.3	ppm
065-34A Room 214 Science Sink Faucet (1)	6/27/2016 02:45	7/8/2016 15:39	10354326067	Lead	3	15	ppb
065-35A Room 214 Science Eyewash	6/27/2016 02:47	7/8/2016 20:54	10354326069	Copper	0.5	1.3	ppm
065-35A Room 214 Science Eyewash	6/27/2016 02:47	7/8/2016 15:41	10354326069	Lead	22	15	ppb
065-36A Room 214 Science Sink Faucet (2)	6/27/2016 02:49	7/10/2016 20:34	10354326071	Copper	0.8	1.3	ppm
065-36A Room 214 Science Sink Faucet (2)	6/27/2016 02:49	7/10/2016 16:22	10354326071	Lead	49	15	ppb
065-37A Room 214 Science Sink Faucet (3)	6/27/2016 02:51	7/10/2016 20:36	10354326073	Copper	0.9	1.3	ppm
065-37A Room 214 Science Sink Faucet (3)	6/27/2016 02:51	7/10/2016 16:25	10354326073	Lead	170	15	ppb
065-38A Room 214 Science Sink Faucet (4)	6/27/2016 02:53	7/8/2016 15:44	10354326075	Copper	0.3	1.3	ppm
065-38A Room 214 Science Sink Faucet (4)	6/27/2016 02:53	7/8/2016 15:44	10354326075	Lead	13	15	ppb
065-39A Room 214 Science Sink Faucet (5)	6/27/2016 02:55	7/8/2016 15:45	10354326077	Copper	0.3	1.3	ppm
065-39A Room 214 Science Sink Faucet (5)	6/27/2016 02:55	7/8/2016 15:45	10354326077	Lead	19	15	ppb
065-40A Room 214 Science Sink Faucet (6)	6/27/2016 02:57	7/10/2016 16:29	10354326079	Copper	0.4	1.3	ppm
065-40A Room 214 Science Sink Faucet (6)	6/27/2016 02:57	7/10/2016 16:29	10354326079	Lead	110	15	ppb
065-41A Room 214 Science Sink Faucet (7)	6/27/2016 02:54	7/8/2016 18:21	10354326081	Copper	0.0	1.3	ppm
065-41A Room 214 Science Sink Faucet (7)	6/27/2016 02:54	7/8/2016 18:21	10354326081	Lead	12	15	ppb
065-42A Room 214 Science Eyewash	6/27/2016 03:01	7/8/2016 18:26	10354326083	Copper	0.1	1.3	ppm
065-42A Room 214 Science Eyewash	6/27/2016 03:01	7/8/2016 18:26	10354326083	Lead	147	15	ppb
065-43A Room 215B Bathroom on Right Sink Faucet	6/27/2016 03:04	7/8/2016 18:29	10354326085	Copper	0.2	1.3	ppm
065-43A Room 215B Bathroom on Right Sink Faucet	6/27/2016 03:04	7/8/2016 18:29	10354326085	Lead	27	15	ppb
065-44A Room 215A Bathroom on Left Sink Faucet	6/27/2016 03:06	7/8/2016 18:30	10354326087	Copper	0.2	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Mt. Tabor Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
065-44A Room 215A Bathroom on Left Sink Faucet	6/27/2016 03:06	7/8/2016 18:30	10354326087	Lead	30	15	ppb
065-45A Room 130 Sink Faucet	6/27/2016 03:17	7/8/2016 21:41	10354326089	Copper	0.6	1.3	ppm
065-45A Room 130 Sink Faucet	6/27/2016 03:17	7/8/2016 18:32	10354326089	Lead	3	15	ppb
065-46A Room 130 Drinking Fountain	6/27/2016 03:18	7/8/2016 21:44	10354326091	Copper	0.7	1.3	ppm
065-46A Room 130 Drinking Fountain	6/27/2016 03:18	7/8/2016 18:33	10354326091	Lead	2	15	ppb
065-47A Room 136 Sink Faucet (1)	6/27/2016 03:20	7/8/2016 21:46	10354326093	Copper	0.6	1.3	ppm
065-47A Room 136 Sink Faucet (1)	6/27/2016 03:20	7/8/2016 18:34	10354326093	Lead	2	15	ppb
065-48A Room 136 Sink Faucet (2)	6/27/2016 03:21	7/8/2016 21:47	10354326095	Copper	0.6	1.3	ppm
065-48A Room 136 Sink Faucet (2)	6/27/2016 03:21	7/8/2016 18:35	10354326095	Lead	0	15	ppb
065-49A Room 136 Sink Faucet (3)	6/27/2016 03:18	7/8/2016 21:48	10354326097	Copper	0.7	1.3	ppm
065-49A Room 136 Sink Faucet (3)	6/27/2016 03:18	7/8/2016 18:36	10354326097	Lead	1	15	ppb
065-50A Room 136 Sink Faucet (4)	6/27/2016 03:19	7/8/2016 21:49	10354326099	Copper	0.6	1.3	ppm
065-50A Room 136 Sink Faucet (4)	6/27/2016 03:19	7/8/2016 18:37	10354326099	Lead	1	15	ppb
065-51A Room 138 Sink Faucet (5)	6/27/2016 03:13	7/8/2016 21:50	10354326101	Copper	0.7	1.3	ppm
065-51A Room 138 Sink Faucet (5)	6/27/2016 03:13	7/8/2016 18:39	10354326101	Lead	1	15	ppb
065-52A Room 138 Drinking Fountain	6/27/2016 03:14	7/8/2016 21:52	10354326103	Copper	0.9	1.3	ppm
065-52A Room 138 Drinking Fountain	6/27/2016 03:14	7/8/2016 18:42	10354326103	Lead	1	15	ppb
065-53A Room 137 Drinking Fountain	6/27/2016 03:26	7/8/2016 21:53	10354326105	Copper	1.1	1.3	ppm
065-53A Room 137 Drinking Fountain	6/27/2016 03:26	7/8/2016 18:43	10354326105	Lead	1	15	ppb
065-54A Room 135 Sink Faucet	6/27/2016 03:27	7/8/2016 21:54	10354326107	Copper	0.6	1.3	ppm
065-54A Room 135 Sink Faucet	6/27/2016 03:27	7/8/2016 18:46	10354326107	Lead	11	15	ppb
065-55A Room 135 Drinking Fountain	6/27/2016 03:28	7/8/2016 18:47	10354326109	Copper	0.2	1.3	ppm
065-55A Room 135 Drinking Fountain	6/27/2016 03:28	7/8/2016 18:47	10354326109	Lead	6	15	ppb
065-56A Room 133 Sink Faucet	6/27/2016 03:44	7/8/2016 18:48	10354326111	Copper	0.4	1.3	ppm
065-56A Room 133 Sink Faucet	6/27/2016 03:44	7/8/2016 18:48	10354326111	Lead	25	15	ppb
065-57A Room 131 Music Sink Faucet (1)	6/27/2016 03:38	7/8/2016 21:55	10354326113	Copper	0.6	1.3	ppm
065-57A Room 131 Music Sink Faucet (1)	6/27/2016 03:38	7/8/2016 18:49	10354326113	Lead	55	15	ppb
065-58A Room 131 Music Sink Faucet (2)	6/27/2016 03:37	7/8/2016 18:50	10354326115	Copper	0.2	1.3	ppm
065-58A Room 131 Music Sink Faucet (2)	6/27/2016 03:37	7/8/2016 18:50	10354326115	Lead	22	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Mt. Tabor Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
065-59A Room 131 Music Drinking Fountain	6/27/2016 03:45	7/8/2016 18:54	10354326117	Copper	0.1	1.3	ppm
065-59A Room 131 Music Drinking Fountain	6/27/2016 03:45	7/8/2016 18:54	10354326117	Lead	6	15	ppb
065-60A Room 137E Custodial Sink Faucet	6/27/2016 03:50	7/8/2016 21:59	10354326119	Copper	0.6	1.3	ppm
065-60A Room 137E Custodial Sink Faucet	6/27/2016 03:50	7/8/2016 18:55	10354326119	Lead	2	15	ppb
065-61A Room 139 Girls Drinking Fountain	6/27/2016 04:01	7/8/2016 21:31	10354326121	Copper	0.8	1.3	ppm
065-61A Room 139 Girls Drinking Fountain	6/27/2016 04:01	7/8/2016 17:52	10354326121	Lead	5	15	ppb
065-62A Room 139 Girls Restroom Sink Faucet (1)	6/27/2016 04:04	7/8/2016 18:00	10354326123	Copper	0.2	1.3	ppm
065-62A Room 139 Girls Restroom Sink Faucet (1)	6/27/2016 04:04	7/8/2016 18:00	10354326123	Lead	28	15	ppb
065-63A Room 139 Girls Restroom Sink Faucet (2)	6/27/2016 04:07	7/10/2016 16:30	10354326125	Copper	0.2	1.3	ppm
065-63A Room 139 Girls Restroom Sink Faucet (2)	6/27/2016 04:07	7/10/2016 16:30	10354326125	Lead	86	15	ppb
065-64A Room 139 Girls Restroom Spigot	6/27/2016 04:09	7/10/2016 20:37	10354326127	Copper	1.0	1.3	ppm
065-64A Room 139 Girls Restroom Spigot	6/27/2016 04:09	7/10/2016 16:31	10354326127	Lead	22	15	ppb
065-65A Room 139A Boys Restroom Sink Faucet (1)	6/27/2016 04:15	7/10/2016 20:38	10354326129	Copper	0.7	1.3	ppm
065-65A Room 139A Boys Restroom Sink Faucet (1)	6/27/2016 04:15	7/10/2016 16:33	10354326129	Lead	79	15	ppb
065-66A Room 139A Boys Restroom Sink Faucet (2)	6/27/2016 04:16	7/10/2016 16:34	10354326131	Copper	0.2	1.3	ppm
065-66A Room 139A Boys Restroom Sink Faucet (2)	6/27/2016 04:16	7/10/2016 16:34	10354326131	Lead	63	15	ppb
065-67A Room 139A Boys Restroom Spigot	6/27/2016 03:53	7/10/2016 16:36	10354326133	Copper	0.3	1.3	ppm
065-67A Room 139A Boys Restroom Spigot	6/27/2016 03:53	7/10/2016 16:36	10354326133	Lead	12	15	ppb
065-68A Gymnasium Drinking Fountain	6/27/2016 03:53	7/8/2016 21:34	10354326135	Copper	0.9	1.3	ppm
065-68A Gymnasium Drinking Fountain	6/27/2016 03:53	7/8/2016 18:01	10354326135	Lead	3	15	ppb
065-69A Room 124A Teacher Sink Faucet	6/27/2016 03:58	7/8/2016 18:03	10354326137	Copper	0.2	1.3	ppm
065-69A Room 124A Teacher Sink Faucet	6/27/2016 03:58	7/8/2016 18:03	10354326137	Lead	25	15	ppb
065-70A Room 118 Sink Faucet (1)	6/27/2016 04:00	7/10/2016 16:37	10354326139	Copper	0.2	1.3	ppm
065-70A Room 118 Sink Faucet (1)	6/27/2016 04:00	7/10/2016 16:37	10354326139	Lead	28	15	ppb
065-71A Room 118 Sink Faucet (2)	6/27/2016 04:02	7/8/2016 18:04	10354326141	Copper	0.0	1.3	ppm
065-71A Room 118 Sink Faucet (2)	6/27/2016 04:02	7/8/2016 18:04	10354326141	Lead	8	15	ppb
065-72A Room 118 Spigot	6/27/2016 04:04	7/8/2016 11:03	10354326143	Copper	1.2	1.3	ppm
065-72A Room 118 Spigot	6/27/2016 04:04	7/8/2016 10:10	10354326143	Lead	225	15	ppb
065-73A Custodial Closet Sink Faucet	6/27/2016 04:07	7/8/2016 18:05	10354326145	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Mt. Tabor Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
065-73A Custodial Closet Sink Faucet	6/27/2016 04:07	7/8/2016 18:05	10354326145	Lead	5	15	ppb
065-74A Room 115 Drinking Fountain	6/27/2016 04:07	7/8/2016 21:35	10354326147	Copper	1.0	1.3	ppm
065-74A Room 115 Drinking Fountain	6/27/2016 04:07	7/8/2016 18:06	10354326147	Lead	4	15	ppb
065-75A Room 113 Sink Faucet	6/27/2016 04:10	7/8/2016 21:36	10354326149	Copper	0.6	1.3	ppm
065-75A Room 113 Sink Faucet	6/27/2016 04:10	7/8/2016 18:07	10354326149	Lead	2	15	ppb
065-76A Room 113 Drinking Fountain	6/27/2016 04:12	7/8/2016 21:37	10354326151	Copper	1.0	1.3	ppm
065-76A Room 113 Drinking Fountain	6/27/2016 04:12	7/8/2016 18:08	10354326151	Lead	7	15	ppb
065-77A Room 111 Sink Faucet	6/27/2016 04:15	7/8/2016 21:38	10354326153	Copper	0.8	1.3	ppm
065-77A Room 111 Sink Faucet	6/27/2016 04:15	7/8/2016 18:10	10354326153	Lead	2	15	ppb
065-78A Room 111 Drinking Fountain	6/27/2016 04:22	7/12/2016 03:34	10354326155	Copper	1.7	1.3	ppm
065-78A Room 111 Drinking Fountain	6/27/2016 04:22	7/8/2016 18:11	10354326155	Lead	16	15	ppb
065-79A Room 109 Sink Faucet (1)	6/27/2016 04:24	7/8/2016 18:16	10354326157	Copper	0.3	1.3	ppm
065-79A Room 109 Sink Faucet (1)	6/27/2016 04:24	7/8/2016 18:16	10354326157	Lead	0	15	ppb
065-80A Room 109 Sink Faucet Eyewash	6/27/2016 04:26	7/12/2016 09:47	10354326159	Copper	1.0	1.3	ppm
065-80A Room 109 Sink Faucet Eyewash	6/27/2016 04:26	7/8/2016 18:17	10354326159	Lead	15.2	15	ppb
065-81A Room 109 Sink Faucet (2)	6/27/2016 04:28	7/8/2016 22:00	10354326161	Copper	0.5	1.3	ppm
065-81A Room 109 Sink Faucet (2)	6/27/2016 04:28	7/8/2016 19:01	10354326161	Lead	1	15	ppb
065-82A Room 109 Drinking Fountain	6/27/2016 04:30	7/8/2016 22:02	10354326163	Copper	0.8	1.3	ppm
065-82A Room 109 Drinking Fountain	6/27/2016 04:30	7/8/2016 19:06	10354326163	Lead	6	15	ppb
065-83A Room 107 Sink Faucet	6/27/2016 04:29	7/8/2016 22:04	10354326165	Copper	0.6	1.3	ppm
065-83A Room 107 Sink Faucet	6/27/2016 04:29	7/8/2016 19:07	10354326165	Lead	1	15	ppb
065-84A Room 107 Drinking Fountain	6/27/2016 04:29	7/8/2016 22:05	10354326167	Copper	2.2	1.3	ppm
065-84A Room 107 Drinking Fountain	6/27/2016 04:29	7/8/2016 19:09	10354326167	Lead	6	15	ppb
065-85A Room 105 Sink Faucet	6/27/2016 04:34	7/8/2016 22:06	10354326169	Copper	0.6	1.3	ppm
065-85A Room 105 Sink Faucet	6/27/2016 04:34	7/8/2016 19:10	10354326169	Lead	1	15	ppb
065-86A Room 105 Drinking Fountain	6/27/2016 04:34	7/8/2016 22:07	10354326171	Copper	0.9	1.3	ppm
065-86A Room 105 Drinking Fountain	6/27/2016 04:34	7/8/2016 19:13	10354326171	Lead	1	15	ppb
065-87A Room 103 Sink Faucet	6/27/2016 04:40	7/8/2016 22:08	10354326173	Copper	0.5	1.3	ppm
065-87A Room 103 Sink Faucet	6/27/2016 04:40	7/8/2016 19:15	10354326173	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Mt. Tabor Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
065-88A Room 103 Drinking Fountain	6/27/2016 04:40	7/8/2016 22:10	10354326175	Copper	0.9	1.3	ppm
065-88A Room 103 Drinking Fountain	6/27/2016 04:40	7/8/2016 19:16	10354326175	Lead	4	15	ppb
065-89A Room 101 Faucet	6/27/2016 04:44	7/8/2016 22:13	10354326177	Copper	0.5	1.3	ppm
065-89A Room 101 Faucet	6/27/2016 04:44	7/8/2016 19:17	10354326177	Lead	1	15	ppb
065-90A Room 101 Drinking Fountain	6/27/2016 04:44	7/8/2016 22:14	10354326179	Copper	1.0	1.3	ppm
065-90A Room 101 Drinking Fountain	6/27/2016 04:44	7/8/2016 19:18	10354326179	Lead	16	15	ppb
065-91A Faculty Bathroom by Room 121 Sink Faucet	6/27/2016 04:45	7/8/2016 19:19	10354326181	Copper	0.1	1.3	ppm
065-91A Faculty Bathroom by Room 121 Sink Faucet	6/27/2016 04:45	7/8/2016 19:19	10354326181	Lead	13	15	ppb
065-92A Stage Sink Faucet in Back	6/27/2016 04:51	7/8/2016 19:22	10354326183	Copper	0.0	1.3	ppm
065-92A Stage Sink Faucet in Back	6/27/2016 04:51	7/8/2016 19:22	10354326183	Lead	34	15	ppb
065-93A Cafeteria Drinking Fountain	6/27/2016 04:54	7/8/2016 22:16	10354326185	Copper	0.7	1.3	ppm
065-93A Cafeteria Drinking Fountain	6/27/2016 04:54	7/8/2016 19:23	10354326185	Lead	5	15	ppb
065-94A Kitchen Sink Faucet (1)	6/27/2016 04:56	7/10/2016 20:39	10354326187	Copper	0.6	1.3	ppm
065-94A Kitchen Sink Faucet (1)	6/27/2016 04:56	7/10/2016 16:38	10354326187	Lead	3	15	ppb
065-95A Kitchen Sprayer (1)	6/27/2016 04:58	7/8/2016 19:24	10354326189	Copper	0.4	1.3	ppm
065-95A Kitchen Sprayer (1)	6/27/2016 04:58	7/8/2016 19:24	10354326189	Lead	3	15	ppb
065-96A Kitchen Sink Faucet (2)	6/27/2016 05:00	7/10/2016 20:40	10354326191	Copper	0.9	1.3	ppm
065-96A Kitchen Sink Faucet (2)	6/27/2016 05:00	7/10/2016 16:42	10354326191	Lead	115	15	ppb
065-97A Kitchen Sprayer (2)	6/27/2016 05:02	7/8/2016 22:17	10354326193	Copper	1.4	1.3	ppm
065-97A Kitchen Sprayer (2)	6/27/2016 05:02	7/8/2016 19:28	10354326193	Lead	9	15	ppb
065-98A Kitchen Bathroom Sink Faucet	6/27/2016 05:07	7/10/2016 20:41	10354326195	Copper	0.9	1.3	ppm
065-98A Kitchen Bathroom Sink Faucet	6/27/2016 05:07	7/10/2016 16:43	10354326195	Lead	3	15	ppb
065-99A Kitchen Sink Faucet (3)	6/27/2016 05:09	7/8/2016 19:29	10354326197	Copper	0.2	1.3	ppm
065-99A Kitchen Sink Faucet (3)	6/27/2016 05:09	7/8/2016 19:29	10354326197	Lead	3	15	ppb
065-100A Room 127 Teachers Sink Faucet	6/27/2016 04:58	7/8/2016 19:31	10354326199	Copper	0.2	1.3	ppm
065-100A Room 127 Teachers Sink Faucet	6/27/2016 04:58	7/8/2016 19:31	10354326199	Lead	1	15	ppb
065-101A Room 129A Sink Faucet	6/27/2016 05:30	7/8/2016 19:35	10354326201	Copper	0.0	1.3	ppm
065-101A Room 129A Sink Faucet	6/27/2016 05:30	7/8/2016 19:35	10354326201	Lead	1	15	ppb
065-102A Room 129A Shower	6/27/2016 05:32	7/10/2016 20:45	10354326203	Copper	0.8	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Mt. Tabor Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
065-102A Room 129A Shower	6/27/2016 05:32	7/10/2016 16:45	10354326203	Lead	83	15	ppb
065-103A Room 215 Sink Faucet	6/27/2016 05:25	7/8/2016 22:18	10354326205	Copper	0.6	1.3	ppm
065-103A Room 215 Sink Faucet	6/27/2016 05:25	7/8/2016 19:39	10354326205	Lead	2	15	ppb
065-104A Room 215 Drinking Fountain	6/27/2016 05:27	7/8/2016 22:19	10354326207	Copper	0.9	1.3	ppm
065-104A Room 215 Drinking Fountain	6/27/2016 05:27	7/8/2016 19:43	10354326207	Lead	2	15	ppb
065-105A Room 216 Girls Restroom Sink Faucet (1)	6/27/2016 05:07	7/8/2016 19:44	10354326209	Copper	0.3	1.3	ppm
065-105A Room 216 Girls Restroom Sink Faucet (1)	6/27/2016 05:07	7/8/2016 19:44	10354326209	Lead	9	15	ppb
065-106A Room 216 Girls Restroom Sink Faucet (2)	6/27/2016 05:09	7/8/2016 19:45	10354326211	Copper	0.1	1.3	ppm
065-106A Room 216 Girls Restroom Sink Faucet (2)	6/27/2016 05:09	7/8/2016 19:45	10354326211	Lead	3	15	ppb
065-107A Room 216 Girls Restroom Sink Faucet (3)	6/27/2016 05:11	7/8/2016 19:46	10354326213	Copper	0.2	1.3	ppm
065-107A Room 216 Girls Restroom Sink Faucet (3)	6/27/2016 05:11	7/8/2016 19:46	10354326213	Lead	4	15	ppb
065-108A Room 216 Girls Restroom Spigot	6/27/2016 05:13	7/8/2016 19:48	10354326215	Copper	0.0	1.3	ppm
065-108A Room 216 Girls Restroom Spigot	6/27/2016 05:13	7/8/2016 19:48	10354326215	Lead	5	15	ppb
065-109A Room 128A Boys Restroom Sink Faucet (1)	6/27/2016 05:15	7/8/2016 19:49	10354326217	Copper	0.2	1.3	ppm
065-109A Room 128A Boys Restroom Sink Faucet (1)	6/27/2016 05:15	7/8/2016 19:49	10354326217	Lead	4	15	ppb
065-110A Room 128A Boys Restroom Sink Faucet (2)	6/27/2016 05:17	7/8/2016 19:50	10354326219	Copper	0.3	1.3	ppm
065-110A Room 128A Boys Restroom Sink Faucet (2)	6/27/2016 05:17	7/8/2016 19:50	10354326219	Lead	2	15	ppb
065-111A Room 128A Boys Restroom Sink Faucet (3)	6/27/2016 04:20	7/10/2016 16:46	10354326221	Copper	0.4	1.3	ppm
065-111A Room 128A Boys Restroom Sink Faucet (3)	6/27/2016 04:20	7/10/2016 16:46	10354326221	Lead	5	15	ppb
065-112A Room 128A Boys Restroom Spigot	6/27/2016 04:22	7/8/2016 22:20	10354326223	Copper	0.6	1.3	ppm
065-112A Room 128A Boys Restroom Spigot	6/27/2016 04:22	7/8/2016 19:51	10354326223	Lead	4	15	ppb
065-113A Room 124C Nurse Office	6/27/2016 04:24	7/11/2016 22:22	10354326225	Copper	0.2	1.3	ppm
065-113A Room 124C Nurse Office	6/27/2016 04:24	7/11/2016 22:22	10354326225	Lead	111	15	ppb
065-114A Room 127B Staff Bathroom Sink Faucet	6/27/2016 04:26	7/8/2016 19:52	10354326227	Copper	0.0	1.3	ppm
065-114A Room 127B Staff Bathroom Sink Faucet	6/27/2016 04:26	7/8/2016 19:52	10354326227	Lead	3	15	ppb
065-115A Room 124 Office Sink Faucet	6/27/2016 04:27	7/8/2016 19:57	10354326229	Copper	0.4	1.3	ppm
065-115A Room 124 Office Sink Faucet	6/27/2016 04:27	7/8/2016 19:57	10354326229	Lead	5	15	ppb
065-116A Room 127A Staff Bathroom Sink Faucet	6/27/2016 04:28	7/8/2016 19:58	10354326231	Copper	0.1	1.3	ppm
065-116A Room 127A Staff Bathroom Sink Faucet	6/27/2016 04:28	7/8/2016 19:58	10354326231	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Mt. Tabor Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
065-117A Hallway Drinking Fountain by Room 122	6/27/2016 04:31	7/8/2016 22:22	10354326233	Copper	0.7	1.3	ppm
065-117A Hallway Drinking Fountain by Room 122	6/27/2016 04:31	7/8/2016 19:59	10354326233	Lead	3	15	ppb
065-118A Room 120 Drinking Fountain	6/27/2016 04:34	7/10/2016 20:46	10354326235	Copper	2.1	1.3	ppm
065-118A Room 120 Drinking Fountain	6/27/2016 04:34	7/10/2016 16:47	10354326235	Lead	20	15	ppb
065-119A Room 102A Boys Restroom Sink Faucet (1)	6/27/2016 04:34	7/8/2016 20:01	10354326237	Copper	0.0	1.3	ppm
065-119A Room 102A Boys Restroom Sink Faucet (1)	6/27/2016 04:34	7/8/2016 20:01	10354326237	Lead	29	15	ppb
065-120A Room 102A Boys Restroom Sink Faucet (2)	6/27/2016 04:36	7/8/2016 20:02	10354326239	Copper	0.0	1.3	ppm
065-120A Room 102A Boys Restroom Sink Faucet (2)	6/27/2016 04:36	7/8/2016 20:02	10354326239	Lead	23	15	ppb
065-121A Room 102A Boys Restroom Sink Faucet (3)	6/27/2016 04:38	7/8/2016 16:25	10354326241	Copper	0.0	1.3	ppm
065-121A Room 102A Boys Restroom Sink Faucet (3)	6/27/2016 04:38	7/8/2016 16:25	10354326241	Lead	6	15	ppb
065-122A Room 102A Boys Restroom Spigot	6/27/2016 04:41	7/10/2016 16:48	10354326243	Copper	0.1	1.3	ppm
065-122A Room 102A Boys Restroom Spigot	6/27/2016 04:41	7/10/2016 16:48	10354326243	Lead	106	15	ppb
065-123A Room 102 Girls Restroom Sink Faucet (1)	6/27/2016 04:43	7/8/2016 16:34	10354326245	Copper	0.1	1.3	ppm
065-123A Room 102 Girls Restroom Sink Faucet (1)	6/27/2016 04:43	7/8/2016 16:34	10354326245	Lead	2	15	ppb
065-124A Room 102 Girls Restroom Sink Faucet (2)	6/27/2016 04:45	7/8/2016 10:28	10354326247	Copper	0.1	1.3	ppm
065-124A Room 102 Girls Restroom Sink Faucet (2)	6/27/2016 04:45	7/8/2016 10:28	10354326247	Lead	20	15	ppb
065-125A Room 102 Girls Restroom Sink Faucet (3)	6/27/2016 04:47	7/8/2016 16:35	10354326249	Copper	0.1	1.3	ppm
065-125A Room 102 Girls Restroom Sink Faucet (3)	6/27/2016 04:47	7/8/2016 16:35	10354326249	Lead	2	15	ppb
065-126A Room 102 Girls Restroom Spigot	6/27/2016 04:49	7/8/2016 10:29	10354326251	Copper	0.4	1.3	ppm
065-126A Room 102 Girls Restroom Spigot	6/27/2016 04:49	7/8/2016 11:04	10354326251	Lead	524	15	ppb
065-127A Room 104 Custodial Closet	6/27/2016 04:52	7/8/2016 10:31	10354326253	Copper	0.2	1.3	ppm
065-127A Room 104 Custodial Closet	6/27/2016 04:52	7/8/2016 10:31	10354326253	Lead	6	15	ppb
065-128A Room 108 Sink Faucet	6/27/2016 04:54	7/8/2016 16:37	10354326255	Copper	0.1	1.3	ppm
065-128A Room 108 Sink Faucet	6/27/2016 04:54	7/8/2016 16:37	10354326255	Lead	18	15	ppb
065-129A Room 112 Sink Faucet	6/27/2016 04:56	7/8/2016 16:38	10354326257	Copper	0.0	1.3	ppm
065-129A Room 112 Sink Faucet	6/27/2016 04:56	7/8/2016 16:38	10354326257	Lead	2	15	ppb
065-130A Room 112 Drinking Fountain	6/27/2016 04:58	7/8/2016 16:39	10354326259	Copper	0.0	1.3	ppm
065-130A Room 112 Drinking Fountain	6/27/2016 04:58	7/8/2016 16:39	10354326259	Lead	5	15	ppb
065-131A Room 112 Sprayer	6/27/2016 05:01	7/8/2016 16:41	10354326261	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Mt. Tabor Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
065-131A Room 112 Sprayer	6/27/2016 05:01	7/8/2016 16:41	10354326261	Lead	12	15	ppb
065-132A Courtyard Spigot North	6/27/2016 05:09	7/8/2016 16:42	10354326263	Copper	0.0	1.3	ppm
065-132A Courtyard Spigot North	6/27/2016 05:09	7/8/2016 16:42	10354326263	Lead	2	15	ppb
065-133A Courtyard Spigot South	6/27/2016 05:12	7/8/2016 18:34	10354326265	Copper	0.8	1.3	ppm
065-133A Courtyard Spigot South	6/27/2016 05:12	7/8/2016 16:44	10354326265	Lead	3	15	ppb
065-134A Exterior Spigot by Stage	6/27/2016 05:11	7/8/2016 16:48	10354326267	Copper	0.0	1.3	ppm
065-134A Exterior Spigot by Stage	6/27/2016 05:11	7/8/2016 16:48	10354326267	Lead	6	15	ppb
065-135A Exterior Spigot at Main Entrance	6/27/2016 05:13	7/8/2016 16:49	10354326269	Copper	0.1	1.3	ppm
065-135A Exterior Spigot at Main Entrance	6/27/2016 05:13	7/8/2016 16:49	10354326269	Lead	19	15	ppb
065-136A Exterior Spigot at Central North	6/27/2016 05:16	7/8/2016 10:32	10354326271	Copper	0.0	1.3	ppm
065-136A Exterior Spigot at Central North	6/27/2016 05:16	7/8/2016 10:32	10354326271	Lead	34	15	ppb
065-137A Exterior Spigot at Northeast Exit	6/27/2016 05:18	7/8/2016 10:34	10354326273	Copper	0.1	1.3	ppm
065-137A Exterior Spigot at Northeast Exit	6/27/2016 05:18	7/8/2016 10:34	10354326273	Lead	43	15	ppb
065-138A Exterior Spigot under Bell	6/27/2016 05:20	7/8/2016 18:36	10354326275	Copper	0.4	1.3	ppm
065-138A Exterior Spigot under Bell	6/27/2016 05:20	7/8/2016 16:52	10354326275	Lead	8	15	ppb
065-139A Exterior Spigot behind 209	6/27/2016 05:22	7/8/2016 16:53	10354326277	Copper	0.2	1.3	ppm
065-139A Exterior Spigot behind 209	6/27/2016 05:22	7/8/2016 16:53	10354326277	Lead	234	15	ppb
065-140A Exterior Spigot behind 206	6/27/2016 05:25	7/8/2016 11:06	10354326279	Copper	1.1	1.3	ppm
065-140A Exterior Spigot behind 206	6/27/2016 05:25	7/8/2016 10:35	10354326279	Lead	8	15	ppb
065-141A Exterior Spigot behind 204	6/27/2016 05:27	7/8/2016 22:23	10354326281	Copper	0.6	1.3	ppm
065-141A Exterior Spigot behind 204	6/27/2016 05:27	7/8/2016 16:21	10354326281	Lead	25	15	ppb
065-142A Exterior Spigot behind 201	6/27/2016 05:29	7/8/2016 11:07	10354326283	Copper	0.7	1.3	ppm
065-142A Exterior Spigot behind 201	6/27/2016 05:29	7/8/2016 10:40	10354326283	Lead	319	15	ppb
065-143A Media Counter Sink Faucet	6/27/2016 05:03	7/8/2016 16:23	10354326285	Copper	0.1	1.3	ppm
065-143A Media Counter Sink Faucet	6/27/2016 05:03	7/8/2016 16:23	10354326285	Lead	28	15	ppb
065-144A Room 115 Sink Faucet	6/27/2016 05:06	7/8/2016 16:24	10354326287	Copper	0.4	1.3	ppm
065-144A Room 115 Sink Faucet	6/27/2016 05:06	7/8/2016 16:24	10354326287	Lead	3	15	ppb
065-145A Room 212 Sink Faucet	6/27/2016 05:09	7/8/2016 18:37	10354326289	Copper	0.7	1.3	ppm
065-145A Room 212 Sink Faucet	6/27/2016 05:09	7/8/2016 16:55	10354326289	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Mt. Tabor Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
065-146A Room 204 Sink Faucet	6/27/2016 05:11	7/8/2016 11:09	10354326291	Copper	0.8	1.3	ppm
065-146A Room 204 Sink Faucet	6/27/2016 05:11	7/8/2016 10:42	10354326291	Lead	20	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.