

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Ockley Green Middle School

Sample Identification # and Location	Date & Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
						Action Limit	Units
066-01A Boiler Room Sink Faucet	6/22/16 17:21	7/6/2016	1606C78-01A	Copper	ND	1.3	ppm
066-01A Boiler Room Sink Faucet	6/22/16 17:21	7/6/2016	1606C78-01A	Lead	1	15	ppb
066-02A Boiler Room Drinking Fountain	6/22/16 17:21	7/6/2016	1606C78-02A	Copper	ND	1.3	ppm
066-02A Boiler Room Drinking Fountain	6/22/16 17:21	7/6/2016	1606C78-02A	Lead	19	15	ppb
066-03A Room 104 Home Economics Sink Faucet	6/22/16 17:29	7/6/2016	1606C78-03A	Copper	0.4	1.3	ppm
066-03A Room 104 Home Economics Sink Faucet	6/22/16 17:29	7/6/2016	1606C78-03A	Lead	2	15	ppb
066-04A Room 104 Drinking Fountain	6/22/16 17:29	7/6/2016	1606C78-04A	Copper	0.5	1.3	ppm
066-04A Room 104 Drinking Fountain	6/22/16 17:29	7/6/2016	1606C78-04A	Lead	7	15	ppb
066-05A Room 104 Sink Faucet	6/22/16 17:30	7/6/2016	1606C78-05A	Copper	0.3	1.3	ppm
066-05A Room 104 Sink Faucet	6/22/16 17:30	7/6/2016	1606C78-05A	Lead	12	15	ppb
066-06A Room 104 Drinking Fountain	6/22/16 17:30	7/6/2016	1606C78-06A	Copper	0.4	1.3	ppm
066-06A Room 104 Drinking Fountain	6/22/16 17:30	7/6/2016	1606C78-06A	Lead	10	15	ppb
066-07A Room 101 Sink Faucet 1	6/22/16 17:33	7/6/2016	1606C78-07A	Copper	0.4	1.3	ppm
066-07A Room 101 Sink Faucet 1	6/22/16 17:33	7/6/2016	1606C78-07A	Lead	8	15	ppb
066-08A Room 101 Sink Faucet 2	6/22/16 17:33	7/6/2016	1606C78-08A	Copper	0.4	1.3	ppm
066-08A Room 101 Sink Faucet 2	6/22/16 17:33	7/6/2016	1606C78-08A	Lead	29	15	ppb
066-09A Cafeteria Drinking Fountain 1	6/22/16 17:38	7/6/2016	1606C78-09A	Copper	ND	1.3	ppm
066-09A Cafeteria Drinking Fountain 1	6/22/16 17:38	7/6/2016	1606C78-09A	Lead	7	15	ppb
066-10A Cafeteria Drinking Fountain 2	6/22/16 17:38	7/6/2016	1606C78-10A	Copper	ND	1.3	ppm
066-10A Cafeteria Drinking Fountain 2	6/22/16 17:38	7/6/2016	1606C78-10A	Lead	7	15	ppb
066-11A Kitchen Dish Sink Faucet	6/22/16 17:39	7/6/2016	1606C78-11A	Copper	0.1	1.3	ppm
066-11A Kitchen Dish Sink Faucet	6/22/16 17:39	7/6/2016	1606C78-11A	Lead	13	15	ppb
066-12A Kitchen Janitoritor Closet Sink Faucet	6/22/16 17:40	7/6/2016	1606C78-12A	Copper	0.1	1.3	ppm
066-12A Kitchen Janitoritor Closet Sink Faucet	6/22/16 17:40	7/6/2016	1606C78-12A	Lead	42	15	ppb
066-13A Kitchen Prep Sink Faucet	6/22/16 17:40	7/6/2016	1606C78-13A	Copper	0.1	1.3	ppm
066-13A Kitchen Prep Sink Faucet	6/22/16 17:40	7/6/2016	1606C78-13A	Lead	6	15	ppb
066-14A Kitchen Prep Sprayer	6/22/16 17:40	7/6/2016	1606C78-14A	Copper	ND	1.3	ppm
066-14A Kitchen Prep Sprayer	6/22/16 17:40	7/6/2016	1606C78-14A	Lead	9	15	ppb
066-15A Kitchen Hand Sink Faucet	6/22/16 17:43	7/6/2016	1606C78-15A	Copper	0.5	1.3	ppm
066-15A Kitchen Hand Sink Faucet	6/22/16 17:43	7/6/2016	1606C78-15A	Lead	13	15	ppb
066-16A Kitchen Bath Sink Faucet	6/22/16 17:44	7/6/2016	1606C78-16A	Copper	0.2	1.3	ppm
066-16A Kitchen Bath Sink Faucet	6/22/16 17:44	7/6/2016	1606C78-16A	Lead	15.0	15	ppb
066-17A Boys Sink Faucet 1	6/22/16 17:48	7/6/2016	1606C78-17A	Copper	0.3	1.3	ppm
066-17A Boys Sink Faucet 1	6/22/16 17:48	7/6/2016	1606C78-17A	Lead	18	15	ppb
066-18A Boys Sink Faucet 2	6/22/16 17:48	7/6/2016	1606C78-18A	Copper	0.4	1.3	ppm
066-18A Boys Sink Faucet 2	6/22/16 17:48	7/6/2016	1606C78-18A	Lead	12	15	ppb
066-19A Boys Water Spigot	6/22/16 17:52	7/7/2016	1606C78-19A	Copper	1.1	1.3	ppm
066-19A Boys Water Spigot	6/22/16 17:52	7/7/2016	1606C78-19A	Lead	190	15	ppb
066-20A Janitor Closet 114 Sink Faucet	6/22/16 17:54	7/6/2016	1606C78-20A	Copper	0.3	1.3	ppm
066-20A Janitor Closet 114 Sink Faucet	6/22/16 17:54	7/6/2016	1606C78-20A	Lead	5	15	ppb
066-21A Girls Sink Faucet 116	6/22/16 17:54	7/6/2016	1606C78-21A	Copper	0.3	1.3	ppm
066-21A Girls Sink Faucet 116	6/22/16 17:54	7/6/2016	1606C78-21A	Lead	20	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Ockley Green Middle School

066-22A	Girls Sink Faucet	6/22/16 17:56	7/6/2016	1606C78-22A	Copper	0.2	1.3	ppm
066-22A	Girls Sink Faucet	6/22/16 17:56	7/6/2016	1606C78-22A	Lead	11	15	ppb
066-23A	Girls Water Spigot	6/22/16 17:57	7/6/2016	1606C78-23A	Copper	0.2	1.3	ppm
066-23A	Girls Water Spigot	6/22/16 17:57	7/6/2016	1606C78-23A	Lead	78	15	ppb
066-24A	Hall Drinking Fountain	6/22/16 17:57	7/6/2016	1606C78-24A	Copper	0.4	1.3	ppm
066-24A	Hall Drinking Fountain	6/22/16 17:57	7/6/2016	1606C78-24A	Lead	11	15	ppb
066-25A	Library Sink Faucet Copy Room	6/22/16 18:00	7/6/2016	1606C78-25A	Copper	0.2	1.3	ppm
066-25A	Library Sink Faucet Copy Room	6/22/16 18:00	7/6/2016	1606C78-25A	Lead	15.0	15	ppb
066-26A	Office Storage Sink Faucet	6/22/16 18:00	7/7/2016	1606C78-26A	Copper	0.2	1.3	ppm
066-26A	Office Storage Sink Faucet	6/22/16 18:00	7/7/2016	1606C78-26A	Lead	37	15	ppb
066-27A	Room 130 Sink Faucet	6/22/16 18:04	7/7/2016	1606C78-27A	Copper	0.2	1.3	ppm
066-27A	Room 130 Sink Faucet	6/22/16 18:04	7/7/2016	1606C78-27A	Lead	6	15	ppb
066-28A	Room 130 Drinking Fountain Cooler	6/22/16 18:04	7/7/2016	1606C78-28A	Copper	ND	1.3	ppm
066-28A	Room 130 Drinking Fountain Cooler	6/22/16 18:04	7/7/2016	1606C78-28A	Lead	ND	15	ppb
066-29A	Office Bath Sink Faucet	6/22/16 18:10	7/7/2016	1606C78-29A	Copper	0.2	1.3	ppm
066-29A	Office Bath Sink Faucet	6/22/16 18:10	7/7/2016	1606C78-29A	Lead	3	15	ppb
066-30A	Staff Bath Hall Sink Faucet	6/22/16 18:12	7/7/2016	1606C78-30A	Copper	0.6	1.3	ppm
066-30A	Staff Bath Hall Sink Faucet	6/22/16 18:12	7/7/2016	1606C78-30A	Lead	5	15	ppb
066-31A	Girls Sink Faucet 1 Room 136	6/22/16 18:13	7/7/2016	1606C78-31A	Copper	0.3	1.3	ppm
066-31A	Girls Sink Faucet 1 Room 136	6/22/16 18:13	7/7/2016	1606C78-31A	Lead	3	15	ppb
066-32A	Girls Sink Faucet 2 Room 136	6/22/16 18:13	7/7/2016	1606C78-32A	Copper	0.1	1.3	ppm
066-32A	Girls Sink Faucet 2 Room 136	6/22/16 18:13	7/7/2016	1606C78-32A	Lead	3	15	ppb
066-33A	Girls Water Spigot	6/22/16 18:14	7/7/2016	1606C78-33A	Copper	0.4	1.3	ppm
066-33A	Girls Water Spigot	6/22/16 18:14	7/7/2016	1606C78-33A	Lead	63	15	ppb
066-34A	Boys Room 138 Sink Faucet 1	6/22/16 18:17	7/7/2016	1606C78-34A	Copper	0.3	1.3	ppm
066-34A	Boys Room 138 Sink Faucet 1	6/22/16 18:17	7/7/2016	1606C78-34A	Lead	4	15	ppb
066-35A	Boys Room 138 Sink Faucet 2	6/22/16 18:17	7/7/2016	1606C78-35A	Copper	0.2	1.3	ppm
066-35A	Boys Room 138 Sink Faucet 2	6/22/16 18:17	7/7/2016	1606C78-35A	Lead	3	15	ppb
066-36A	Boys Room 138 Water Spigot	6/22/16 18:19	7/3/2016	1606C78-36A	Copper	0.5	1.3	ppm
066-36A	Boys Room 138 Water Spigot	6/22/16 18:19	7/3/2016	1606C78-36A	Lead	54	15	ppb
066-37A	Hall Drinking Fountain by 138	6/22/16 18:20	7/7/2016	1606C78-37A	Copper	0.3	1.3	ppm
066-37A	Hall Drinking Fountain by 138	6/22/16 18:20	7/7/2016	1606C78-37A	Lead	ND	15	ppb
066-38A	Room 140 Janitor Sink Faucet	6/22/16 18:22	7/7/2016	1606C78-38A	Copper	0.2	1.3	ppm
066-38A	Room 140 Janitor Sink Faucet	6/22/16 18:22	7/7/2016	1606C78-38A	Lead	6	15	ppb
066-39A	Bath 140B Sink Faucet	6/22/16 18:24	7/7/2016	1606C78-39A	Copper	ND	1.3	ppm
066-39A	Bath 140B Sink Faucet	6/22/16 18:24	7/7/2016	1606C78-39A	Lead	4	15	ppb
066-40A	Room 121 Sink Faucet 1	6/22/16 18:27	7/7/2016	1606C78-40A	Copper	0.3	1.3	ppm
066-40A	Room 121 Sink Faucet 1	6/22/16 18:27	7/7/2016	1606C78-40A	Lead	20	15	ppb
066-41A	Room 121 Sink Faucet 2	6/22/16 18:27	7/7/2016	1606C78-41A	Copper	0.5	1.3	ppm
066-41A	Room 121 Sink Faucet 2	6/22/16 18:27	7/7/2016	1606C78-41A	Lead	60	15	ppb
066-42A	Room 121 Sink Faucet 3	6/22/16 18:29	7/7/2016	1606C78-42A	Copper	0.6	1.3	ppm
066-42A	Room 121 Sink Faucet 3	6/22/16 18:29	7/7/2016	1606C78-42A	Lead	7	15	ppb
066-43A	Room 121 Sink Faucet 4	6/22/16 18:29	7/7/2016	1606C78-43A	Copper	0.8	1.3	ppm
066-43A	Room 121 Sink Faucet 4	6/22/16 18:29	7/7/2016	1606C78-43A	Lead	13	15	ppb
066-44A	Room 304 Industrial Arts Sink Faucet	6/22/16 18:32	7/7/2016	1606C78-44A	Copper	0.3	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Ockley Green Middle School

066-44A	Room 304 Industrial Arts Sink Faucet	6/22/16 18:32	7/7/2016	1606C78-44A	Lead	24	15	ppb
066-45A	Room 306 Janitor Sink Faucet	6/22/16 18:35	7/7/2016	1606C78-45A	Copper	0.1	1.3	ppm
066-45A	Room 306 Janitor Sink Faucet	6/22/16 18:35	7/7/2016	1606C78-45A	Lead	9	15	ppb
066-46A	Girls Locker Room Sink Faucet 1	6/22/16 18:36	7/7/2016	1606C78-46A	Copper	0.3	1.3	ppm
066-46A	Girls Locker Room Sink Faucet 1	6/22/16 18:36	7/7/2016	1606C78-46A	Lead	2	15	ppb
066-47A	Girls Locker Room Sink Faucet 2	6/22/16 18:36	7/7/2016	1606C78-47A	Copper	0.2	1.3	ppm
066-47A	Girls Locker Room Sink Faucet 2	6/22/16 18:36	7/7/2016	1606C78-47A	Lead	21	15	ppb
066-48A	Girls Locker Room Water Spigot	6/22/16 18:39	7/7/2016	1606C78-48A	Copper	0.1	1.3	ppm
066-48A	Girls Locker Room Water Spigot	6/22/16 18:39	7/7/2016	1606C78-48A	Lead	160	15	ppb
066-55A	Boys Locker Sink Faucet	6/22/16 18:46	7/7/2016	1606C78-49A	Copper	0.2	1.3	ppm
066-55A	Boys Locker Sink Faucet	6/22/16 18:46	7/7/2016	1606C78-49A	Lead	2	15	ppb
066-56A	Boys Locker Sink Faucet	6/22/16 18:46	7/7/2016	1606C78-50A	Copper	0.2	1.3	ppm
066-56A	Boys Locker Sink Faucet	6/22/16 18:46	7/7/2016	1606C78-50A	Lead	35	15	ppb
066-57A	Boys Locker Water Spigot	6/22/16 18:47	7/7/2016	1606C78-51A	Copper	0.2	1.3	ppm
066-57A	Boys Locker Water Spigot	6/22/16 18:47	7/7/2016	1606C78-51A	Lead	61	15	ppb
066-58A	Boys Showers S1 Left	6/22/16 18:53	7/7/2016	1606C78-52A	Copper	0.3	1.3	ppm
066-58A	Boys Showers S1 Left	6/22/16 18:53	7/7/2016	1606C78-52A	Lead	21	15	ppb
066-59A	Boys Showers S2 Left	6/22/16 18:53	7/7/2016	1606C78-53A	Copper	0.7	1.3	ppm
066-59A	Boys Showers S2 Left	6/22/16 18:53	7/7/2016	1606C78-53A	Lead	74	15	ppb
066-60A	Boys Showers S3 Left	6/22/16 18:55	7/7/2016	1606C78-54A	Copper	0.3	1.3	ppm
066-60A	Boys Showers S3 Left	6/22/16 18:55	7/7/2016	1606C78-54A	Lead	47	15	ppb
066-61A	Boys Showers S4 Right	6/22/16 18:55	7/7/2016	1606C78-55A	Copper	ND	1.3	ppm
066-61A	Boys Showers S4 Right	6/22/16 18:55	7/7/2016	1606C78-55A	Lead	410	15	ppb
066-63A	Hall by Room 222 Drinking Fountain	6/22/16 19:00	7/7/2016	1606C78-56A	Copper	0.3	1.3	ppm
066-63A	Hall by Room 222 Drinking Fountain	6/22/16 19:00	7/7/2016	1606C78-56A	Lead	3	15	ppb
066-64A	Room 222 Janitor Sink Faucet	6/22/16 19:01	7/7/2016	1606C78-57A	Copper	0.2	1.3	ppm
066-64A	Room 222 Janitor Sink Faucet	6/22/16 19:01	7/7/2016	1606C78-57A	Lead	3	15	ppb
066-65A	Room 224 Boys Sink Faucet 1	6/22/16 19:04	7/7/2016	1606C78-58A	Copper	0.2	1.3	ppm
066-65A	Room 224 Boys Sink Faucet 1	6/22/16 19:04	7/7/2016	1606C78-58A	Lead	8	15	ppb
066-66A	Room 224 Boys Sink Faucet 2	6/22/16 19:04	7/7/2016	1606C78-59A	Copper	0.2	1.3	ppm
066-66A	Room 224 Boys Sink Faucet 2	6/22/16 19:04	7/7/2016	1606C78-59A	Lead	6	15	ppb
066-67A	Room 224 Boys Water Spigot	6/22/16 19:05	7/8/2016	1606C78-60A	Copper	0.5	1.3	ppm
066-67A	Room 224 Boys Water Spigot	6/22/16 19:05	7/8/2016	1606C78-60A	Lead	110	15	ppb
066-68A	Room 226 Girls Sink Faucet 1	6/22/16 19:08	7/7/2016	1606C78-61A	Copper	0.4	1.3	ppm
066-68A	Room 226 Girls Sink Faucet 1	6/22/16 19:08	7/7/2016	1606C78-61A	Lead	11	15	ppb
066-69A	Room 226 Girls Sink Faucet 2	6/22/16 19:09	7/7/2016	1606C78-62A	Copper	0.3	1.3	ppm
066-69A	Room 226 Girls Sink Faucet 2	6/22/16 19:09	7/7/2016	1606C78-62A	Lead	10	15	ppb
066-70A	Room 226 Girls Water Spigot	6/22/16 19:09	7/7/2016	1606C78-63A	Copper	0.8	1.3	ppm
066-70A	Room 226 Girls Water Spigot	6/22/16 19:09	7/7/2016	1606C78-63A	Lead	170	15	ppb
066-71A	Room 225 Sink Faucet	6/22/16 19:13	7/7/2016	1606C78-64A	Copper	0.7	1.3	ppm
066-71A	Room 225 Sink Faucet	6/22/16 19:13	7/7/2016	1606C78-64A	Lead	44	15	ppb
066-72A	Room 220 Staff Bath Sink Faucet	6/22/16 19:14	7/7/2016	1606C78-65A	Copper	0.2	1.3	ppm
066-72A	Room 220 Staff Bath Sink Faucet	6/22/16 19:14	7/7/2016	1606C78-65A	Lead	12	15	ppb
066-73A	Room 218 Sink Faucet	6/22/16 19:16	7/7/2016	1606C78-66A	Copper	0.6	1.3	ppm
066-73A	Room 218 Sink Faucet	6/22/16 19:16	7/7/2016	1606C78-66A	Lead	51	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Ockley Green Middle School

066-74A Room 216 Sink Faucet 1	6/22/16 19:18	7/8/2016	1606C78-67A	Copper	0.5	1.3	ppm
066-74A Room 216 Sink Faucet 1	6/22/16 19:18	7/8/2016	1606C78-67A	Lead	18	15	ppb
066-75A Room 216 Sink Faucet 2	6/22/16 19:20	7/8/2016	1606C78-68A	Copper	0.4	1.3	ppm
066-75A Room 216 Sink Faucet 2	6/22/16 19:20	7/8/2016	1606C78-68A	Lead	17	15	ppb
066-76A Room 214 Sink Faucet 1	6/22/16 19:22	7/7/2016	1606C78-69A	Copper	0.7	1.3	ppm
066-76A Room 214 Sink Faucet 1	6/22/16 19:22	7/7/2016	1606C78-69A	Lead	22	15	ppb
066-77A Room 214 Sink Faucet 2	6/22/16 19:22	7/7/2016	1606C78-70A	Copper	0.4	1.3	ppm
066-77A Room 214 Sink Faucet 2	6/22/16 19:22	7/7/2016	1606C78-70A	Lead	33	15	ppb
066-78A Room 210 Work Room Sink Faucet	6/22/16 19:23	7/7/2016	1606C78-71A	Copper	0.2	1.3	ppm
066-78A Room 210 Work Room Sink Faucet	6/22/16 19:23	7/7/2016	1606C78-71A	Lead	7	15	ppb
066-79A Faculty Restroom Sink Faucet	6/22/16 19:24	7/7/2016	1606C78-72A	Copper	0.2	1.3	ppm
066-79A Faculty Restroom Sink Faucet	6/22/16 19:24	7/7/2016	1606C78-72A	Lead	26	15	ppb
066-80A Hall Drinking Fountain 1	6/22/16 19:26	7/7/2016	1606C78-73A	Copper	0.4	1.3	ppm
066-80A Hall Drinking Fountain 1	6/22/16 19:26	7/7/2016	1606C78-73A	Lead	ND	15	ppb
066-81A Hall Drinking Fountain 2	6/22/16 19:26	7/7/2016	1606C78-74A	Copper	0.2	1.3	ppm
066-81A Hall Drinking Fountain 2	6/22/16 19:26	7/7/2016	1606C78-74A	Lead	1	15	ppb
066-82A Room 208 Custodial Closet Sink Faucet	6/22/16 19:28	7/7/2016	1606C78-75A	Copper	0.2	1.3	ppm
066-82A Room 208 Custodial Closet Sink Faucet	6/22/16 19:28	7/7/2016	1606C78-75A	Lead	7	15	ppb
066-84A Girls 206 Sink Faucet 2	6/22/16 19:31	7/7/2016	1606C78-76A	Copper	0.1	1.3	ppm
066-84A Girls 206 Sink Faucet 2	6/22/16 19:31	7/7/2016	1606C78-76A	Lead	8	15	ppb
066-85A Girls 206 Water Spigot	6/22/16 19:31	7/8/2016	1606C78-77A	Copper	0.3	1.3	ppm
066-85A Girls 206 Water Spigot	6/22/16 19:31	7/8/2016	1606C78-77A	Lead	91	15	ppb
066-86A Boys 204 Sink Faucet 1	6/22/16 19:33	7/7/2016	1606C78-78A	Copper	0.4	1.3	ppm
066-86A Boys 204 Sink Faucet 1	6/22/16 19:33	7/7/2016	1606C78-78A	Lead	63	15	ppb
066-87A Boys 204 Sink Faucet 2	6/22/16 19:33	7/7/2016	1606C78-79A	Copper	0.6	1.3	ppm
066-87A Boys 204 Sink Faucet 2	6/22/16 19:33	7/7/2016	1606C78-79A	Lead	20	15	ppb
066-88A Boys 204 Water Spigot	6/22/16 19:34	7/7/2016	1606C78-80A	Copper	0.4	1.3	ppm
066-88A Boys 204 Water Spigot	6/22/16 19:34	7/7/2016	1606C78-80A	Lead	260	15	ppb
066-89A Basement Paint Room Sink Faucet	6/22/16 19:46	7/7/2016	1606C78-81A	Copper	ND	1.3	ppm
066-89A Basement Paint Room Sink Faucet	6/22/16 19:46	7/7/2016	1606C78-81A	Lead	51	15	ppb
066-90A Outside Water Spigot 1	6/22/16 19:51	7/7/2016	1606C78-82A	Copper	0.4	1.3	ppm
066-90A Outside Water Spigot 1	6/22/16 19:51	7/7/2016	1606C78-82A	Lead	9	15	ppb
066-91A Outside Water Spigot 2	6/22/16 19:54	7/7/2016	1606C78-83A	Copper	0.4	1.3	ppm
066-91A Outside Water Spigot 2	6/22/16 19:54	7/7/2016	1606C78-83A	Lead	17	15	ppb
066-92A Outside Water Spigot 3	6/22/16 19:57	7/7/2016	1606C78-84A	Copper	0.2	1.3	ppm
066-92A Outside Water Spigot 3	6/22/16 19:57	7/7/2016	1606C78-84A	Lead	67	15	ppb
066-93A Outside Water Spigot 4	6/22/16 20:03	7/7/2016	1606C78-85A	Copper	ND	1.3	ppm
066-93A Outside Water Spigot 4	6/22/16 20:03	7/7/2016	1606C78-85A	Lead	24	15	ppb

EPA Action Level for Lead of 15 ppb

ND = Non Detect

EPA Action Level for Copper of 1.3 ppm

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.