

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Pioneer at Youngson Elementary School

Sample Identification # and Location		Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
69-01A	Cafeteria Drinking Fountain	6/22/2016 11:30:00 PM	6/25/2016 3:55:00 PM	BB66418	Copper	0.1	1.3	ppm
69-01A	Cafeteria Drinking Fountain	6/22/2016 11:30:00 PM	6/25/2016 3:55:00 PM	BB66418	Lead	1	15	ppb
69-02A	Kitchen Dish Sink Faucet	6/22/2016 11:35:00 PM	6/25/2016 3:58:00 PM	BB66419	Copper	0.0	1.3	ppm
69-02A	Kitchen Dish Sink Faucet	6/22/2016 11:35:00 PM	6/25/2016 3:58:00 PM	BB66419	Lead	3	15	ppb
69-03A	Kitchen Hand Sink Faucet	6/22/2016 11:37:00 PM	6/25/2016 4:01:00 PM	BB66420	Copper	0.3	1.3	ppm
69-03A	Kitchen Hand Sink Faucet	6/22/2016 11:37:00 PM	6/25/2016 4:01:00 PM	BB66420	Lead	2	15	ppb
69-04A	Kitchen Bathroom Sink Faucet	6/22/2016 11:39:00 PM	6/25/2016 4:22:00 PM	BB66421	Copper	0.2	1.3	ppm
69-04A	Kitchen Bathroom Sink Faucet	6/22/2016 11:39:00 PM	6/25/2016 4:22:00 PM	BB66421	Lead	4	15	ppb
69-05A	Kitchen Prep Sink Faucet	6/22/2016 11:41:00 PM	6/25/2016 4:25:00 PM	BB66422	Copper	0.3	1.3	ppm
69-05A	Kitchen Prep Sink Faucet	6/22/2016 11:41:00 PM	6/25/2016 4:25:00 PM	BB66422	Lead	3	15	ppb
69-06A	Kitchen Janitors Closet Sink Faucet	6/22/2016 11:43:00 PM	6/25/2016 4:28:00 PM	BB66423	Copper	0.4	1.3	ppm
69-06A	Kitchen Janitors Closet Sink Faucet	6/22/2016 11:43:00 PM	6/25/2016 4:28:00 PM	BB66423	Lead	2	15	ppb
69-07A	Mens Restroom by Boiler Room Sink Faucet	6/22/2016 11:49:00 PM	7/5/2016 1:21:00 PM	BB66424	Copper	0.1	1.3	ppm
69-07A	Mens Restroom By Boiler Room Sink Faucet	6/22/2016 11:49:00 PM	7/5/2016 1:21:00 PM	BB66424	Lead	7	15	ppb
69-08A	Room 24 Custodian Sink Faucet	6/22/2016 11:52:00 PM	6/25/2016 4:31:00 PM	BB66425	Copper	0.2	1.3	ppm
69-08A	Room 24 Custodian Sink Faucet	6/22/2016 11:52:00 PM	6/25/2016 4:31:00 PM	BB66425	Lead	2	15	ppb
69-09A	Boys Restroom Sink Faucet (1)	6/22/2016 11:55:00 PM	6/25/2016 4:34:00 PM	BB66426	Copper	0.3	1.3	ppm
69-09A	Boys Restroom Sink Faucet (1)	6/22/2016 11:55:00 PM	6/25/2016 4:34:00 PM	BB66426	Lead	2	15	ppb
69-10A	Boys Restroom Sink Faucet (2)	6/22/2016 11:57:00 PM	6/25/2016 4:37:00 PM	BB66427	Copper	0.3	1.3	ppm
69-10A	Boys Restroom Sink Faucet (2)	6/22/2016 11:57:00 PM	6/25/2016 4:37:00 PM	BB66427	Lead	0	15	ppb
69-11A	Boys Restroom Sink Faucet (3)	6/23/2016 12:00:00 AM	6/25/2016 4:40:00 PM	BB66428	Copper	0.5	1.3	ppm
69-11A	Boys Restroom Sink Faucet (3)	6/23/2016 12:00:00 AM	6/25/2016 4:40:00 PM	BB66428	Lead	3	15	ppb
69-12A	Boys Restroom Spigot	6/23/2016 12:01:00 AM	6/25/2016 4:43:00 PM	BB66429	Copper	0.6	1.3	ppm
69-12A	Boys Restroom Spigot	6/23/2016 12:01:00 AM	6/25/2016 4:43:00 PM	BB66429	Lead	64	15	ppb
69-13A	Girls Restroom Sink Faucet (1)	6/23/2016 12:09:00 AM	6/25/2016 4:47:00 PM	BB66430	Copper	0.2	1.3	ppm
69-13A	Girls Restroom Sink Faucet (1)	6/23/2016 12:09:00 AM	6/25/2016 4:47:00 PM	BB66430	Lead	2	15	ppb
69-14A	Girls Restroom Sink Faucet (2)	6/23/2016 12:11:00 AM	7/5/2016 1:25:00 PM	BB66431	Copper	0.4	1.3	ppm
69-14A	Girls Restroom Sink Faucet (2)	6/23/2016 12:11:00 AM	7/5/2016 1:25:00 PM	BB66431	Lead	6	15	ppb
69-15A	Girls Restroom Sink Faucet (3)	6/23/2016 12:13:00 AM	6/25/2016 4:49:00 PM	BB66432	Copper	0.2	1.3	ppm
69-15A	Girls Restroom Sink Faucet (3)	6/23/2016 12:13:00 AM	6/25/2016 4:49:00 PM	BB66432	Lead	3	15	ppb
69-16A	Girls Restroom Spigot	6/23/2016 12:15:00 AM	6/25/2016 5:05:00 PM	BB66433	Copper	0.1	1.3	ppm
69-16A	Girls Restroom Spigot	6/23/2016 12:15:00 AM	6/25/2016 5:05:00 PM	BB66433	Lead	1	15	ppb
69-17A	Room 27 Staff Restroom Sink Faucet	6/23/2016 12:18:00 AM	6/25/2016 5:08:00 PM	BB66434	Copper	0.4	1.3	ppm
69-17A	Room 27 Staff Restroom Sink Faucet	6/23/2016 12:18:00 AM	6/25/2016 5:08:00 PM	BB66434	Lead	1	15	ppb
69-18A	Library Sink Faucet	6/23/2016 12:22:00 AM	6/25/2016 5:11:00 PM	BB66435	Copper	0.8	1.3	ppm
69-18A	Library Sink Faucet	6/23/2016 12:22:00 AM	6/25/2016 5:11:00 PM	BB66435	Lead	5	15	ppb
69-19A	Room 31 Sink Faucet	6/23/2016 12:25:00 AM	6/25/2016 5:14:00 PM	BB66436	Copper	0.4	1.3	ppm
69-19A	Room 31 Sink Faucet	6/23/2016 12:25:00 AM	6/25/2016 5:14:00 PM	BB66436	Lead	3	15	ppb
69-20A(1)	Room 21 Bathroom Sink Faucet	6/23/2016 12:27:00 AM	6/25/2016 5:17:00 PM	BB66437	Copper	0.4	1.3	ppm
69-20A(1)	Room 21 Bathroom Sink Faucet	6/23/2016 12:27:00 AM	6/25/2016 5:17:00 PM	BB66437	Lead	5	15	ppb
69-20A(2)	Room 21 Bathroom Sink Faucet	6/23/2016 12:27:00 AM	6/25/2016 8:13:00 PM	BB66475	Copper	0.3	1.3	ppm
69-20A(2)	Room 21 Bathroom Sink Faucet	6/23/2016 12:27:00 AM	6/25/2016 8:13:00 PM	BB66475	Lead	2	15	ppb
69-21A	Room 4 Sink Faucet	6/23/2016 12:30:00 AM	6/25/2016 5:20:00 PM	BB66438	Copper	0.7	1.3	ppm
69-21A	Room 4 Sink Faucet	6/23/2016 12:30:00 AM	6/25/2016 5:20:00 PM	BB66438	Lead	1	15	ppb
69-22A	Room 4 Drinking Fountain	6/23/2016 12:32:00 AM	6/25/2016 5:23:00 PM	BB66439	Copper	0.4	1.3	ppm
69-22A	Room 4 Drinking Fountain	6/23/2016 12:32:00 AM	6/25/2016 5:23:00 PM	BB66439	Lead	4	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Pioneer at Youngson Elementary School

Sample Identification # and Location		Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
69-23A	Room 3 Sink Faucet	6/23/2016 12:40:00 AM	6/25/2016 5:26:00 PM	BB66440	Copper	0.3	1.3	ppm
69-23A	Room 3 Sink Faucet	6/23/2016 12:40:00 AM	6/25/2016 5:26:00 PM	BB66440	Lead	61	15	ppb
69-24A	Room 3 Drinking Fountain	6/23/2016 12:43:00 AM	6/25/2016 5:29:00 PM	BB66441	Copper	0.3	1.3	ppm
69-24A	Room 3 Drinking Fountain	6/23/2016 12:43:00 AM	6/25/2016 5:29:00 PM	BB66441	Lead	12	15	ppb
69-25A	Room 32 Sink Faucet	6/23/2016 12:46:00 AM	6/25/2016 5:32:00 PM	BB66442	Copper	0.2	1.3	ppm
69-25A	Room 32 Sink Faucet	6/23/2016 12:46:00 AM	6/25/2016 5:32:00 PM	BB66442	Lead	3	15	ppb
69-26A	Room 1 Sink Faucet	6/23/2016 12:49:00 AM	6/25/2016 5:53:00 PM	BB66443	Copper	0.8	1.3	ppm
69-26A	Room 1 Sink Faucet	6/23/2016 12:49:00 AM	6/25/2016 5:53:00 PM	BB66443	Lead	1	15	ppb
69-27A	Room 2 Sink Faucet	6/23/2016 12:52:00 AM	6/25/2016 5:56:00 PM	BB66444	Copper	0.5	1.3	ppm
69-27A	Room 2 Sink Faucet	6/23/2016 12:52:00 AM	6/25/2016 5:56:00 PM	BB66444	Lead	3	15	ppb
69-28A	Room 7 Sink Faucet	6/23/2016 12:54:00 AM	6/25/2016 5:59:00 PM	BB66445	Copper	0.3	1.3	ppm
69-28A	Room 7 Sink Faucet	6/23/2016 12:54:00 AM	6/25/2016 5:59:00 PM	BB66445	Lead	4	15	ppb
69-29A	Room 7 Drinking Fountain	6/23/2016 12:56:00 AM	6/25/2016 6:02:00 PM	BB66446	Copper	0.4	1.3	ppm
69-29A	Room 7 Drinking Fountain	6/23/2016 12:56:00 AM	6/25/2016 6:02:00 PM	BB66446	Lead	5	15	ppb
69-30A	Room 8 Sink Faucet	6/23/2016 1:01:00 AM	6/25/2016 6:05:00 PM	BB66447	Copper	0.4	1.3	ppm
69-30A	Room 8 Sink Faucet	6/23/2016 1:01:00 AM	6/25/2016 6:05:00 PM	BB66447	Lead	2	15	ppb
69-31A	Room 8 Drinking Fountain	6/23/2016 1:03:00 AM	6/25/2016 6:08:00 PM	BB66448	Copper	0.2	1.3	ppm
69-31A	Room 8 Drinking Fountain	6/23/2016 1:03:00 AM	6/25/2016 6:08:00 PM	BB66448	Lead	1	15	ppb
69-32A	Room 9 Sink Faucet	6/23/2016 1:07:00 AM	6/25/2016 6:11:00 PM	BB66449	Copper	0.3	1.3	ppm
69-32A	Room 9 Sink Faucet	6/23/2016 1:07:00 AM	6/25/2016 6:11:00 PM	BB66449	Lead	1	15	ppb
69-33A	Room 9 Drinking Fountain	6/23/2016 1:09:00 AM	6/25/2016 6:14:00 PM	BB66450	Copper	0.2	1.3	ppm
69-33A	Room 9 Drinking Fountain	6/23/2016 1:09:00 AM	6/25/2016 6:14:00 PM	BB66450	Lead	2	15	ppb
69-34A	Room 17 Sink Faucet	6/23/2016 1:15:00 AM	6/25/2016 6:17:00 PM	BB66451	Copper	0.1	1.3	ppm
69-34A	Room 17 Sink Faucet	6/23/2016 1:15:00 AM	6/25/2016 6:17:00 PM	BB66451	Lead	0	15	ppb
69-35A	Room 17 Drinking Fountain	6/23/2016 1:17:00 AM	6/25/2016 6:20:00 PM	BB66452	Copper	0.3	1.3	ppm
69-35A	Room 17 Drinking Fountain	6/23/2016 1:17:00 AM	6/25/2016 6:20:00 PM	BB66452	Lead	3	15	ppb
69-36A	Room 10 Sink Faucet	6/23/2016 1:20:00 AM	6/25/2016 6:36:00 PM	BB66453	Copper	0.3	1.3	ppm
69-36A	Room 10 Sink Faucet	6/23/2016 1:20:00 AM	6/25/2016 6:36:00 PM	BB66453	Lead	7	15	ppb
69-37A	Room 10 Drinking Fountain	6/23/2016 1:22:00 AM	6/25/2016 6:39:00 PM	BB66454	Copper	0.3	1.3	ppm
69-37A	Room 10 Drinking Fountain	6/23/2016 1:22:00 AM	6/25/2016 6:39:00 PM	BB66454	Lead	5	15	ppb
69-38A	Girls Restroom Sink Faucet (1)	6/23/2016 1:25:00 AM	6/25/2016 6:42:00 PM	BB66455	Copper	0.3	1.3	ppm
69-38A	Girls Restroom Sink Faucet (1)	6/23/2016 1:25:00 AM	6/25/2016 6:42:00 PM	BB66455	Lead	1	15	ppb
69-39A	Girls Restroom Sink Faucet (2)	6/23/2016 1:27:00 AM	6/25/2016 6:45:00 PM	BB66456	Copper	0.4	1.3	ppm
69-39A	Girls Restroom Sink Faucet (2)	6/23/2016 1:27:00 AM	6/25/2016 6:45:00 PM	BB66456	Lead	10	15	ppb
69-40A	Girls Restroom Sink Faucet (3)	6/23/2016 1:29:00 AM	6/25/2016 6:48:00 PM	BB66457	Copper	0.5	1.3	ppm
69-40A	Girls Restroom Sink Faucet (3)	6/23/2016 1:29:00 AM	6/25/2016 6:48:00 PM	BB66457	Lead	1	15	ppb
69-41A	Girls Restroom Spigot	6/23/2016 1:31:00 AM	6/25/2016 6:51:00 PM	BB66458	Copper	0.6	1.3	ppm
69-41A	Girls Restroom Spigot	6/23/2016 1:31:00 AM	6/25/2016 6:51:00 PM	BB66458	Lead	4	15	ppb
69-42A	Room 11 Sink Faucet	6/23/2016 1:35:00 AM	6/25/2016 6:54:00 PM	BB66459	Copper	0.3	1.3	ppm
69-42A	Room 11 Sink Faucet	6/23/2016 1:35:00 AM	6/25/2016 6:54:00 PM	BB66459	Lead	2	15	ppb
69-43A	Room 11 Drinking Fountain	6/23/2016 1:39:00 AM	6/25/2016 6:57:00 PM	BB66460	Copper	0.3	1.3	ppm
69-43A	Room 11 Drinking Fountain	6/23/2016 1:39:00 AM	6/25/2016 6:57:00 PM	BB66460	Lead	1	15	ppb
69-44A	Room 12 Sink Faucet	6/23/2016 1:41:00 AM	6/25/2016 7:00:00 PM	BB66461	Copper	0.3	1.3	ppm
69-44A	Room 12 Sink Faucet	6/23/2016 1:41:00 AM	6/25/2016 7:00:00 PM	BB66461	Lead	2	15	ppb
69-45A	Room 12 Drinking Fountain	6/23/2016 1:43:00 AM	6/25/2016 7:03:00 PM	BB66462	Copper	0.2	1.3	ppm
69-45A	Room 12 Drinking Fountain	6/23/2016 1:43:00 AM	6/25/2016 7:03:00 PM	BB66462	Lead	1	15	ppb
69-46A	Boys Restroom Sink Faucet (1)	6/23/2016 1:48:00 AM	6/25/2016 7:24:00 PM	BB66463	Copper	0.1	1.3	ppm
69-46A	Boys Restroom Sink Faucet (1)	6/23/2016 1:48:00 AM	6/25/2016 7:24:00 PM	BB66463	Lead	3	15	ppb
69-47A	Boys Restroom Sink Faucet (2)	6/23/2016 1:50:00 AM	6/25/2016 7:27:00 PM	BB66464	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Pioneer at Youngson Elementary School

Sample Identification # and Location		Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
69-47A	Boys Restroom Sink Faucet (2)	6/23/2016 1:50:00 AM	6/25/2016 7:27:00 PM	BB66464	Lead	0	15	ppb
69-48A	Boys Restroom Sink Faucet (3)	6/23/2016 1:52:00 AM	6/25/2016 7:30:00 PM	BB66465	Copper	0.1	1.3	ppm
69-48A	Boys Restroom Sink Faucet (3)	6/23/2016 1:52:00 AM	6/25/2016 7:30:00 PM	BB66465	Lead	1	15	ppb
69-49A	Boys Restroom Spigot	6/23/2016 1:54:00 AM	6/25/2016 7:33:00 PM	BB66466	Copper	0.1	1.3	ppm
69-49A	Boys Restroom Spigot	6/23/2016 1:54:00 AM	6/25/2016 7:33:00 PM	BB66466	Lead	18	15	ppb
69-50A	Janitors Closet Sink Faucet	6/23/2016 1:56:00 AM	6/25/2016 7:36:00 PM	BB66467	Copper	0.1	1.3	ppm
69-50A	Janitors Closet Sink Faucet	6/23/2016 1:56:00 AM	6/25/2016 7:36:00 PM	BB66467	Lead	19	15	ppb
69-51A	Outside Water Spigot (1)	6/23/2016 2:00:00 AM	6/25/2016 7:39:00 PM	BB66468	Copper	0.1	1.3	ppm
69-51A	Outside Water Spigot (1)	6/23/2016 2:00:00 AM	6/25/2016 7:39:00 PM	BB66468	Lead	0	15	ppb
69-52A	Outside Water Spigot (2)	6/23/2016 2:03:00 AM	6/25/2016 7:42:00 PM	BB66469	Copper	0.1	1.3	ppm
69-52A	Outside Water Spigot (2)	6/23/2016 2:03:00 AM	6/25/2016 7:42:00 PM	BB66469	Lead	0	15	ppb
69-53A	Outside Water Spigot (3)	6/23/2016 2:07:00 AM	6/25/2016 7:45:00 PM	BB66470	Copper	0.1	1.3	ppm
69-53A	Outside Water Spigot (3)	6/23/2016 2:07:00 AM	6/25/2016 7:45:00 PM	BB66470	Lead	0	15	ppb
69-54A	Outside Water Spigot (4)	6/23/2016 2:09:00 AM	6/25/2016 7:48:00 PM	BB66471	Copper	0.1	1.3	ppm
69-54A	Outside Water Spigot (4)	6/23/2016 2:09:00 AM	6/25/2016 7:48:00 PM	BB66471	Lead	0	15	ppb
69-55A	Outside Water Spigot (5)	6/23/2016 2:12:00 AM	6/25/2016 7:51:00 PM	BB66472	Copper	0.1	1.3	ppm
69-55A	Outside Water Spigot (5)	6/23/2016 2:12:00 AM	6/25/2016 7:51:00 PM	BB66472	Lead	1	15	ppb
69-56A	Outside Water Spigot (6)	6/23/2016 2:15:00 AM	6/25/2016 8:07:00 PM	BB66473	Copper	0.1	1.3	ppm
69-56A	Outside Water Spigot (6)	6/23/2016 2:15:00 AM	6/25/2016 8:07:00 PM	BB66473	Lead	0	15	ppb
69-57A	Outside Water Spigot (7)	6/23/2016 2:18:00 AM	6/25/2016 8:10:00 PM	BB66474	Copper	0.1	1.3	ppm
69-57A	Outside Water Spigot (7)	6/23/2016 2:18:00 AM	6/25/2016 8:10:00 PM	BB66474	Lead	1	15	ppb

EPA Action Level for Lead of 15 ppb
EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.