

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Rice Elementary School

| Sample Identification # and Location                | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|-----------------------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 070-01A Room 5 Sink Faucet                          | 6/23/2016 5:38:00 PM  | 6/29/2016 2:05:00 PM | BB66611      | Copper  | 0.0     | 1.3              | ppm   |
| 070-01A Room 5 Sink Faucet                          | 6/23/2016 5:38:00 PM  | 6/29/2016 2:05:00 PM | BB66611      | Lead    | 10      | 15               | ppb   |
| 070-02A Boiler Room Mens Restroom Sink Faucet       | 6/23/2016 5:41:00 PM  | 6/29/2016 2:08:00 PM | BB66612      | Copper  | 0.0     | 1.3              | ppm   |
| 070-02A Boiler Room Mens Restroom Sink Faucet       | 6/23/2016 5:41:00 PM  | 6/29/2016 2:08:00 PM | BB66612      | Lead    | 14      | 15               | ppb   |
| 070-03A Room 9 Sink Faucet                          | 6/23/2016 5:44:00 PM  | 6/29/2016 2:11:00 PM | BB66613      | Copper  | 0.0     | 1.3              | ppm   |
| 070-03A Room 9 Sink Faucet                          | 6/23/2016 5:44:00 PM  | 6/29/2016 2:11:00 PM | BB66613      | Lead    | 8       | 15               | ppb   |
| 070-04A Room 9 Drinking Fountain                    | 6/23/2016 5:45:00 PM  | 6/29/2016 2:14:00 PM | BB66614      | Copper  | 0.0     | 1.3              | ppm   |
| 070-04A Room 9 Drinking Fountain                    | 6/23/2016 5:45:00 PM  | 6/29/2016 2:14:00 PM | BB66614      | Lead    | 2       | 15               | ppb   |
| 070-05A Room 8 Drinking Fountain                    | 6/23/2016 5:48:00 PM  | 6/29/2016 2:17:00 PM | BB66615      | Copper  | 0.0     | 1.3              | ppm   |
| 070-05A Room 8 Drinking Fountain                    | 6/23/2016 5:48:00 PM  | 6/29/2016 2:17:00 PM | BB66615      | Lead    | 4       | 15               | ppb   |
| 070-06A Drinking Fountain in Hall by Girls Restroom | 6/23/2016 5:51:00 PM  | 6/29/2016 2:20:00 PM | BB66616      | Copper  | 0.0     | 1.3              | ppm   |
| 070-06A Drinking Fountain in Hall by Girls Restroom | 6/23/2016 5:51:00 PM  | 6/29/2016 2:20:00 PM | BB66616      | Lead    | 4       | 15               | ppb   |
| 070-07A Boys Restroom Sink Faucet (1)               | 6/23/2016 5:54:00 PM  | 6/29/2016 2:23:00 PM | BB66617      | Copper  | 0.0     | 1.3              | ppm   |
| 070-07A Boys Restroom Sink Faucet (1)               | 6/23/2016 5:54:00 PM  | 6/29/2016 2:23:00 PM | BB66617      | Lead    | 3       | 15               | ppb   |
| 070-08A Boys Restroom Sink Faucet (2)               | 6/23/2016 5:55:00 PM  | 6/29/2016 3:19:00 PM | BB66618      | Copper  | 0.0     | 1.3              | ppm   |
| 070-08A Boys Restroom Sink Faucet (2)               | 6/23/2016 5:55:00 PM  | 6/29/2016 3:19:00 PM | BB66618      | Lead    | 5       | 15               | ppb   |
| 070-09A Boys Restroom Sink Faucet (3)               | 6/23/2016 5:56:00 PM  | 6/29/2016 3:23:00 PM | BB66619      | Copper  | 0.0     | 1.3              | ppm   |
| 070-09A Boys Restroom Sink Faucet (3)               | 6/23/2016 5:56:00 PM  | 6/29/2016 3:23:00 PM | BB66619      | Lead    | 6       | 15               | ppb   |
| 070-10A Boys Restroom Spigot                        | 6/23/2016 5:57:00 PM  | 7/5/2016 1:04:00 PM  | BB66620      | Copper  | 1.0     | 1.3              | ppm   |
| 070-10A Boys Restroom Spigot                        | 6/23/2016 5:57:00 PM  | 7/5/2016 1:04:00 PM  | BB66620      | Lead    | 133     | 15               | ppb   |
| 070-11A Girls Restroom Sink Faucet (1)              | 6/23/2016 6:02:00 PM  | 7/5/2016 1:28:00 PM  | BB66621      | Copper  | 0.0     | 1.3              | ppm   |
| 070-11A Girls Restroom Sink Faucet (1)              | 6/23/2016 6:02:00 PM  | 7/5/2016 1:28:00 PM  | BB66621      | Lead    | 67      | 15               | ppb   |
| 070-12A Girls Restroom Sink Faucet (2)              | 6/23/2016 6:03:00 PM  | 6/29/2016 3:26:00 PM | BB66622      | Copper  | 0.0     | 1.3              | ppm   |
| 070-12A Girls Restroom Sink Faucet (2)              | 6/23/2016 6:03:00 PM  | 6/29/2016 3:26:00 PM | BB66622      | Lead    | 13      | 15               | ppb   |
| 070-13A Girls Restroom Sink Faucet (3)              | 6/23/2016 6:04:00 PM  | 7/5/2016 1:32:00 PM  | BB66623      | Copper  | 0.0     | 1.3              | ppm   |
| 070-13A Girls Restroom Sink Faucet (3)              | 6/23/2016 6:04:00 PM  | 7/5/2016 1:32:00 PM  | BB66623      | Lead    | 58      | 15               | ppb   |
| 070-14A Girls Restroom Spigot                       | 6/23/2016 6:05:00 PM  | 7/5/2016 1:35:00 PM  | BB66624      | Copper  | 0.3     | 1.3              | ppm   |
| 070-14A Girls Restroom Spigot                       | 6/23/2016 6:05:00 PM  | 7/5/2016 1:35:00 PM  | BB66624      | Lead    | 34      | 15               | ppb   |
| 070-15A Custodial Storage 1 Sink Faucet             | 6/23/2016 6:07:00 PM  | 6/29/2016 3:29:00 PM | BB66625      | Copper  | 0.0     | 1.3              | ppm   |
| 070-15A Custodial Storage 1 Sink Faucet             | 6/23/2016 6:07:00 PM  | 6/29/2016 3:29:00 PM | BB66625      | Lead    | 5       | 15               | ppb   |
| 070-16A Room 1 Sink Faucet                          | 6/23/2016 6:11:00 PM  | 6/29/2016 3:32:00 PM | BB66626      | Copper  | 0.0     | 1.3              | ppm   |
| 070-16A Room 1 Sink Faucet                          | 6/23/2016 6:11:00 PM  | 6/29/2016 3:32:00 PM | BB66626      | Lead    | 12      | 15               | ppb   |
| 070-17A Room 1 Drinking Fountain                    | 6/23/2016 6:11:00 PM  | 6/29/2016 3:35:00 PM | BB66627      | Copper  | 0.0     | 1.3              | ppm   |
| 070-17A Room 1 Drinking Fountain                    | 6/23/2016 6:11:00 PM  | 6/29/2016 3:35:00 PM | BB66627      | Lead    | 21      | 15               | ppb   |
| 070-18A Storeroom 1 Sink Faucet                     | 6/23/2016 6:14:00 PM  | 6/29/2016 3:38:00 PM | BB66628      | Copper  | 0.0     | 1.3              | ppm   |
| 070-18A Storeroom 1 Sink Faucet                     | 6/23/2016 6:14:00 PM  | 6/29/2016 3:38:00 PM | BB66628      | Lead    | 175     | 15               | ppb   |
| 070-19A Storeroom 1 Drinking Fountain               | 6/23/2016 6:15:00 PM  | 7/5/2016 2:10:00 PM  | BB66629      | Copper  | 0.0     | 1.3              | ppm   |
| 070-19A Storeroom 1 Drinking Fountain               | 6/23/2016 6:15:00 PM  | 7/5/2016 2:10:00 PM  | BB66629      | Lead    | 132     | 15               | ppb   |
| 070-20A Girls Restroom Sink Faucet                  | 6/23/2016 6:17:00 PM  | 6/29/2016 3:41:00 PM | BB66630      | Copper  | 0.1     | 1.3              | ppm   |
| 070-20A Girls Restroom Sink Faucet                  | 6/23/2016 6:17:00 PM  | 6/29/2016 3:41:00 PM | BB66630      | Lead    | 12      | 15               | ppb   |
| 070-21A Girls Restroom Spigot                       | 6/23/2016 6:18:00 PM  | 7/5/2016 7:41:00 PM  | BB66631      | Copper  | 2.8     | 1.3              | ppm   |
| 070-21A Girls Restroom Spigot                       | 6/23/2016 6:18:00 PM  | 7/5/2016 2:14:00 PM  | BB66631      | Lead    | 385     | 15               | ppb   |
| 070-22A Faculty Room Faucet                         | 6/23/2016 6:21:00 PM  | 6/29/2016 3:44:00 PM | BB66632      | Copper  | 0.1     | 1.3              | ppm   |
| 070-22A Faculty Room Faucet                         | 6/23/2016 6:21:00 PM  | 6/29/2016 3:44:00 PM | BB66632      | Lead    | 13      | 15               | ppb   |
| 070-23A Room 2 Sink Faucet                          | 6/23/2016 6:25:00 PM  | 6/29/2016 3:47:00 PM | BB66633      | Copper  | 0.0     | 1.3              | ppm   |
| 070-23A Room 2 Sink Faucet                          | 6/23/2016 6:25:00 PM  | 6/29/2016 3:47:00 PM | BB66633      | Lead    | 5       | 15               | ppb   |
| 070-24A Room 2 Drinking Fountain                    | 6/23/2016 6:25:00 PM  | 6/29/2016 4:02:00 PM | BB66634      | Copper  | 0.0     | 1.3              | ppm   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Rice Elementary School

| Sample Identification # and Location  | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|---------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 070-24A Room 2 Drinking Fountain      | 6/23/2016 6:25:00 PM  | 6/29/2016 4:02:00 PM | BB66634      | Lead    | 11      | 15               | ppb   |
| 070-25A Room 7 Sink Faucet            | 6/23/2016 6:28:00 PM  | 6/29/2016 4:05:00 PM | BB66635      | Copper  | 0.1     | 1.3              | ppm   |
| 070-25A Room 7 Sink Faucet            | 6/23/2016 6:28:00 PM  | 6/29/2016 4:05:00 PM | BB66635      | Lead    | 10      | 15               | ppb   |
| 070-26A Room 7 Drinking Fountain      | 6/23/2016 6:28:00 PM  | 6/29/2016 4:08:00 PM | BB66636      | Copper  | 0.0     | 1.3              | ppm   |
| 070-26A Room 7 Drinking Fountain      | 6/23/2016 6:28:00 PM  | 6/29/2016 4:08:00 PM | BB66636      | Lead    | 5       | 15               | ppb   |
| 070-27A Room 3 Sink Faucet            | 6/23/2016 6:31:00 PM  | 6/29/2016 4:11:00 PM | BB66637      | Copper  | 0.0     | 1.3              | ppm   |
| 070-27A Room 3 Sink Faucet            | 6/23/2016 6:31:00 PM  | 6/29/2016 4:11:00 PM | BB66637      | Lead    | 11      | 15               | ppb   |
| 070-28A Room 3 Drinking Fountain      | 6/23/2016 6:31:00 PM  | 6/29/2016 4:14:00 PM | BB66638      | Copper  | 0.0     | 1.3              | ppm   |
| 070-28A Room 3 Drinking Fountain      | 6/23/2016 6:31:00 PM  | 6/29/2016 4:14:00 PM | BB66638      | Lead    | 8       | 15               | ppb   |
| 070-29A Room 6 Sink Faucet            | 6/23/2016 6:33:00 PM  | 6/29/2016 4:17:00 PM | BB66639      | Copper  | 0.0     | 1.3              | ppm   |
| 070-29A Room 6 Sink Faucet            | 6/23/2016 6:33:00 PM  | 6/29/2016 4:17:00 PM | BB66639      | Lead    | 9       | 15               | ppb   |
| 070-30A Room 6 Drinking Fountain      | 6/23/2016 6:34:00 PM  | 6/29/2016 4:20:00 PM | BB66640      | Copper  | 0.0     | 1.3              | ppm   |
| 070-30A Room 6 Drinking Fountain      | 6/23/2016 6:34:00 PM  | 6/29/2016 4:20:00 PM | BB66640      | Lead    | 13      | 15               | ppb   |
| 070-31A Room 4 Sink Faucet            | 6/23/2016 6:40:00 PM  | 6/29/2016 5:12:00 PM | BB66641      | Copper  | 0.0     | 1.3              | ppm   |
| 070-31A Room 4 Sink Faucet            | 6/23/2016 6:40:00 PM  | 6/29/2016 5:12:00 PM | BB66641      | Lead    | 5       | 15               | ppb   |
| 070-32A Room 4 Drinking Fountain      | 6/23/2016 6:40:00 PM  | 6/29/2016 4:26:00 PM | BB66642      | Copper  | 0.0     | 1.3              | ppm   |
| 070-32A Room 4 Drinking Fountain      | 6/23/2016 6:40:00 PM  | 6/29/2016 4:26:00 PM | BB66642      | Lead    | 5       | 15               | ppb   |
| 070-33A Room 5 Drinking Fountain      | 6/23/2016 6:43:00 PM  | 6/29/2016 4:29:00 PM | BB66643      | Copper  | 0.0     | 1.3              | ppm   |
| 070-33A Room 5 Drinking Fountain      | 6/23/2016 6:43:00 PM  | 6/29/2016 4:29:00 PM | BB66643      | Lead    | 13      | 15               | ppb   |
| 070-34A Outside Spigot by Boiler Room | 6/23/2016 6:47:00 PM  | 7/5/2016 2:17:00 PM  | BB66644      | Copper  | 0.5     | 1.3              | ppm   |
| 070-34A Outside Spigot by Boiler Room | 6/23/2016 6:47:00 PM  | 7/5/2016 2:17:00 PM  | BB66644      | Lead    | 64      | 15               | ppb   |
| 070-35A Outside Spigot by Room 9      | 6/23/2016 6:49:00 PM  | 7/5/2016 2:20:00 PM  | BB66645      | Copper  | 0.2     | 1.3              | ppm   |
| 070-35A Outside Spigot by Room 9      | 6/23/2016 6:49:00 PM  | 7/5/2016 2:20:00 PM  | BB66645      | Lead    | 55      | 15               | ppb   |
| 070-36A Outside Spigot by Park Room   | 6/23/2016 6:52:00 PM  | 6/29/2016 5:09:00 PM | BB66646      | Copper  | 0.0     | 1.3              | ppm   |
| 070-36A Outside Spigot by Park Room   | 6/23/2016 6:52:00 PM  | 6/29/2016 5:09:00 PM | BB66646      | Lead    | 44      | 15               | ppb   |

EPA Action Level for Lead of 15 ppb  
EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.