

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Richmond Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
071-01A Basement Can Wash Sink Faucet	6/23/2016 22:18	6/28/2016 11:10	10353467001	Copper	0.1	1.3	ppm
071-01A Basement Can Wash Sink Faucet	6/23/2016 22:18	6/28/2016 11:10	10353467001	Lead	3	15	ppb
071-02A Basement Hall by Library - Drinking Fountain (1)	6/23/2016 22:23	6/30/2016 14:58	10353467003	Copper	0.6	1.3	ppm
071-02A Basement Hall by Library - Drinking Fountain (1)	6/23/2016 22:23	6/30/2016 12:53	10353467003	Lead	2	15	ppb
071-03A Basement Hall by Library - Drinking Fountain (2)	6/23/2016 22:25	6/28/2016 12:14	10353467005	Copper	0.2	1.3	ppm
071-03A Basement Hall by Library - Drinking Fountain (2)	6/23/2016 22:25	6/28/2016 11:15	10353467005	Lead	1	15	ppb
071-04A Basement Hall - Water Spigot	6/23/2016 22:28	7/1/2016 08:53	10353467007	Copper	0.1	1.3	ppm
071-04A Basement Hall - Water Spigot	6/23/2016 22:28	6/30/2016 13:03	10353467007	Lead	181	15	ppb
071-05A Learning Center - Sink Faucet	6/23/2016 22:34	6/30/2016 13:05	10353467009	Copper	0.4	1.3	ppm
071-05A Learning Center - Sink Faucet	6/23/2016 22:34	6/30/2016 13:05	10353467009	Lead	5	15	ppb
071-06A Bathroom 37F - Sink Faucet	6/23/2016 22:36	6/28/2016 12:17	10353467011	Copper	0.5	1.3	ppm
071-06A Bathroom 37F - Sink Faucet	6/23/2016 22:36	6/28/2016 11:28	10353467011	Lead	4	15	ppb
071-07A Bathroom 37E - Sink Faucet	6/23/2016 22:39	6/28/2016 12:46	10353467013	Copper	0.4	1.3	ppm
071-07A Bathroom 37E - Sink Faucet	6/23/2016 22:39	6/28/2016 11:31	10353467013	Lead	4	15	ppb
071-08A Room 37D - Sink Faucet (1)	6/23/2016 22:41	6/30/2016 14:19	10353467015	Copper	0.3	1.3	ppm
071-08A Room 37D - Sink Faucet (1)	6/23/2016 22:41	6/30/2016 14:19	10353467015	Lead	14	15	ppb
071-09A Room 37D - Sprayer	6/23/2016 22:42	6/30/2016 13:07	10353467017	Copper	0.2	1.3	ppm
071-09A Room 37D - Sprayer	6/23/2016 22:42	6/30/2016 13:07	10353467017	Lead	3	15	ppb
071-10A Room 37D - Sink Faucet (2)	6/23/2016 22:44	6/28/2016 12:48	10353467019	Copper	0.3	1.3	ppm
071-10A Room 37D - Sink Faucet (2)	6/23/2016 22:44	6/28/2016 11:37	10353467019	Lead	2	15	ppb
071-11A Library - Drinking Fountain (1)	6/23/2016 22:46	6/28/2016 12:51	10353467021	Copper	0.8	1.3	ppm
071-11A Library - Drinking Fountain (1)	6/23/2016 22:46	6/28/2016 11:48	10353467021	Lead	1	15	ppb
071-12A Library - Drinking Fountain (2)	6/23/2016 22:48	6/28/2016 12:55	10353467023	Copper	0.6	1.3	ppm
071-12A Library - Drinking Fountain (2)	6/23/2016 22:48	6/28/2016 11:51	10353467023	Lead	0	15	ppb
071-13A Room 33 - Bathroom - Sink Faucet (1)	6/23/2016 22:50	6/30/2016 13:08	10353467025	Copper	0.4	1.3	ppm
071-13A Room 33 - Bathroom - Sink Faucet (1)	6/23/2016 22:50	6/30/2016 13:08	10353467025	Lead	7	15	ppb
071-14A Room 33 - Bathroom - Sink Faucet (2)	6/23/2016 22:51	6/30/2016 15:03	10353467027	Copper	0.4	1.3	ppm
071-14A Room 33 - Bathroom - Sink Faucet (2)	6/23/2016 22:51	6/30/2016 13:11	10353467027	Lead	6	15	ppb
071-15A Room 33 - Bathroom - Sink Faucet (3)	6/23/2016 22:53	6/30/2016 15:05	10353467029	Copper	0.5	1.3	ppm
071-15A Room 33 - Bathroom - Sink Faucet (3)	6/23/2016 22:53	6/30/2016 13:13	10353467029	Lead	2	15	ppb
071-16A Room 33 - Water Spigot	6/23/2016 22:54	6/30/2016 15:06	10353467031	Copper	0.7	1.3	ppm
071-16A Room 33 - Water Spigot	6/23/2016 22:54	6/30/2016 13:17	10353467031	Lead	57	15	ppb
071-17A Room 34 - Custodial - Sink Faucet	6/23/2016 22:57	6/30/2016 13:20	10353467033	Copper	0.3	1.3	ppm
071-17A Room 34 - Custodial - Sink Faucet	6/23/2016 22:57	6/30/2016 13:20	10353467033	Lead	4	15	ppb
071-18A Boiler Room - Sink Faucet (1)	6/23/2016 23:03	6/30/2016 13:21	10353467035	Copper	0.1	1.3	ppm
071-18A Boiler Room - Sink Faucet (1)	6/23/2016 23:03	6/30/2016 13:21	10353467035	Lead	2	15	ppb
071-19A Boiler Room - Sink Faucet (2)	6/23/2016 23:04	6/28/2016 12:09	10353467037	Copper	0.1	1.3	ppm
071-19A Boiler Room - Sink Faucet (2)	6/23/2016 23:04	6/28/2016 12:09	10353467037	Lead	2	15	ppb
071-20A Boiler Room - Sink Faucet (3)	6/23/2016 23:06	6/30/2016 15:08	10353467039	Copper	3.1	1.3	ppm
071-20A Boiler Room - Sink Faucet (3)	6/23/2016 23:06	6/30/2016 13:23	10353467039	Lead	228	15	ppb
071-21A Boiler Room - Sink Faucet (4)	6/23/2016 23:09	6/30/2016 15:09	10353467041	Copper	1.1	1.3	ppm
071-21A Boiler Room - Sink Faucet (4)	6/23/2016 23:09	6/30/2016 13:25	10353467041	Lead	64	15	ppb
071-22A Boiler Room - Sink Faucet (5)	6/23/2016 23:11	6/30/2016 15:11	10353467043	Copper	0.9	1.3	ppm
071-22A Boiler Room - Sink Faucet (5)	6/23/2016 23:11	6/30/2016 13:28	10353467043	Lead	51	15	ppb
071-23A Boiler Room - Sink Faucet (6)	6/23/2016 23:13	6/30/2016 13:31	10353467045	Copper	0.1	1.3	ppm
071-23A Boiler Room - Sink Faucet (6)	6/23/2016 23:13	6/30/2016 13:31	10353467045	Lead	13	15	ppb
071-24A Kindergarten - Boys Bathroom - Sink Faucet	6/23/2016 23:23	6/30/2016 14:57	10353467047	Copper	0.9	1.3	ppm
071-24A Kindergarten - Boys Bathroom - Sink Faucet	6/23/2016 23:23	6/30/2016 12:37	10353467047	Lead	13	15	ppb
071-25A Kindergarten - Girls Bathroom - Sink Faucet	6/23/2016 23:25	6/30/2016 12:38	10353467049	Copper	0.3	1.3	ppm
071-25A Kindergarten - Girls Bathroom - Sink Faucet	6/23/2016 23:25	6/30/2016 12:38	10353467049	Lead	5	15	ppb
071-26A Kindergarten - Sink Faucet	6/23/2016 23:27	6/30/2016 12:40	10353467051	Copper	0.4	1.3	ppm
071-26A Kindergarten - Sink Faucet	6/23/2016 23:27	6/30/2016 12:40	10353467051	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Richmond Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
071-27A Kindergarten - Drinking Fountain	6/23/2016 23:29	6/28/2016 12:30	10353467053	Copper	0.0	1.3	ppm
071-27A Kindergarten - Drinking Fountain	6/23/2016 23:29	6/28/2016 12:30	10353467053	Lead	1	15	ppb
071-28A By Gymnasium - Hall - Drinking Fountain (1)	6/23/2016 23:35	6/30/2016 12:50	10353467055	Copper	0.3	1.3	ppm
071-28A By Gymnasium - Hall - Drinking Fountain (1)	6/23/2016 23:35	6/30/2016 12:50	10353467055	Lead	2	15	ppb
071-29A By Gymnasium - Hall - Drinking Fountain (2)	6/23/2016 23:37	6/30/2016 12:52	10353467057	Copper	0.3	1.3	ppm
071-29A By Gymnasium - Hall - Drinking Fountain (2)	6/23/2016 23:37	6/30/2016 12:52	10353467057	Lead	2	15	ppb
071-30A By Gymnasium - Hall - Drinking Fountain (3)	6/23/2016 23:39	6/30/2016 13:01	10353467059	Copper	0.3	1.3	ppm
071-30A By Gymnasium - Hall - Drinking Fountain (3)	6/23/2016 23:39	6/30/2016 13:01	10353467059	Lead	1	15	ppb
071-31A By Gymnasium - Hall - Drinking Fountain (4)	6/23/2016 23:41	6/30/2016 14:15	10353467061	Copper	0.3	1.3	ppm
071-31A By Gymnasium - Hall - Drinking Fountain (4)	6/23/2016 23:41	6/30/2016 14:15	10353467061	Lead	1	15	ppb
071-32A Basement Room 20 - Sink Faucet	6/23/2016 23:44	6/30/2016 14:16	10353467063	Copper	0.3	1.3	ppm
071-32A Basement Room 20 - Sink Faucet	6/23/2016 23:44	6/30/2016 14:16	10353467063	Lead	3	15	ppb
071-33A Basement Room 20 - Drinking Fountain	6/23/2016 23:46	6/29/2016 15:14	10353467065	Copper	0.5	1.3	ppm
071-33A Basement Room 20 - Drinking Fountain	6/23/2016 23:46	6/28/2016 15:05	10353467065	Lead	2	15	ppb
071-34A Room 21 - Custodial Closet - Sink Faucet	6/23/2016 23:50	6/30/2016 15:38	10353467067	Copper	0.5	1.3	ppm
071-34A Room 21 - Custodial Closet - Sink Faucet	6/23/2016 23:50	6/30/2016 14:18	10353467067	Lead	49	15	ppb
071-35A Restroom - Sink Faucet	6/23/2016 23:53	6/28/2016 15:14	10353467069	Copper	0.4	1.3	ppm
071-35A Restroom - Sink Faucet	6/23/2016 23:53	6/28/2016 15:14	10353467069	Lead	1	15	ppb
071-36A Restroom - Water Spigot	6/23/2016 23:55	6/30/2016 15:39	10353467071	Copper	0.4	1.3	ppm
071-36A Restroom - Water Spigot	6/23/2016 23:55	6/30/2016 14:30	10353467071	Lead	1	15	ppb
071-37A Boys Bathroom 11 - Sink Faucet (1)	6/24/2016 00:02	6/30/2016 14:32	10353467073	Copper	0.3	1.3	ppm
071-37A Boys Bathroom 11 - Sink Faucet (1)	6/24/2016 00:02	6/30/2016 14:32	10353467073	Lead	2	15	ppb
071-38A Boys Bathroom 11 - Sink Faucet (2)	6/24/2016 00:04	6/28/2016 15:34	10353467075	Copper	0.2	1.3	ppm
071-38A Boys Bathroom 11 - Sink Faucet (2)	6/24/2016 00:04	6/28/2016 15:34	10353467075	Lead	3	15	ppb
071-39A Boys Bathroom 11 - Water Spigot	6/24/2016 00:06	6/30/2016 15:49	10353467077	Copper	4.7	1.3	ppm
071-39A Boys Bathroom 11 - Water Spigot	6/24/2016 00:06	6/30/2016 14:33	10353467077	Lead	358	15	ppb
071-40A Room 12 - Custodial - Sink Faucet	6/24/2016 00:08	6/30/2016 14:36	10353467079	Copper	0.3	1.3	ppm
071-40A Room 12 - Custodial - Sink Faucet	6/24/2016 00:08	6/30/2016 14:36	10353467079	Lead	1	15	ppb
071-41A Hall by Room 12 - Drinking Fountain	6/24/2016 00:10	6/28/2016 15:53	10353467081	Copper	0.0	1.3	ppm
071-41A Hall by Room 12 - Drinking Fountain	6/24/2016 00:10	6/28/2016 15:53	10353467081	Lead	0	15	ppb
071-42A Girls Bathroom 14 - Sink Faucet (1)	6/24/2016 00:12	6/28/2016 16:16	10353467083	Copper	0.3	1.3	ppm
071-42A Girls Bathroom 14 - Sink Faucet (1)	6/24/2016 00:12	6/28/2016 16:16	10353467083	Lead	2	15	ppb
071-43A Girls Bathroom 14 - Sink Faucet (2)	6/24/2016 00:14	6/28/2016 16:22	10353467085	Copper	0.3	1.3	ppm
071-43A Girls Bathroom 14 - Sink Faucet (2)	6/24/2016 00:14	6/28/2016 16:22	10353467085	Lead	3	15	ppb
071-44A Cafeteria - Drinking Fountain	6/24/2016 00:17	6/28/2016 16:29	10353467087	Copper	0.0	1.3	ppm
071-44A Cafeteria - Drinking Fountain	6/24/2016 00:17	6/28/2016 16:29	10353467087	Lead	2	15	ppb
071-45A Kitchen Food Preparation Sink - Sprayer	6/24/2016 00:18	6/28/2016 16:35	10353467089	Copper	0.2	1.3	ppm
071-45A Kitchen Food Preparation Sink - Sprayer	6/24/2016 00:18	6/28/2016 16:35	10353467089	Lead	2	15	ppb
071-46A Kitchen Bathroom - Sink Faucet	6/24/2016 00:20	6/28/2016 16:48	10353467091	Copper	0.2	1.3	ppm
071-46A Kitchen Bathroom - Sink Faucet	6/24/2016 00:20	6/28/2016 16:48	10353467091	Lead	3	15	ppb
071-47A Kitchen Custodial - Sink Faucet	6/24/2016 00:22	6/30/2016 14:37	10353467093	Copper	0.2	1.3	ppm
071-47A Kitchen Custodial - Sink Faucet	6/24/2016 00:22	6/30/2016 14:37	10353467093	Lead	28	15	ppb
071-48A Kitchen Hand - Sink Faucet	6/24/2016 00:24	6/30/2016 15:43	10353467095	Copper	0.5	1.3	ppm
071-48A Kitchen Hand - Sink Faucet	6/24/2016 00:24	6/30/2016 14:40	10353467095	Lead	4	15	ppb
071-49A Kitchen Dish - Sink Faucet	6/24/2016 00:26	6/28/2016 16:58	10353467097	Copper	0.2	1.3	ppm
071-49A Kitchen Dish - Sink Faucet	6/24/2016 00:26	6/28/2016 16:58	10353467097	Lead	0	15	ppb
071-50A Kitchen Dish - Sprayer	6/24/2016 00:28	6/28/2016 17:05	10353467099	Copper	0.3	1.3	ppm
071-50A Kitchen Dish - Sprayer	6/24/2016 00:28	6/28/2016 17:05	10353467099	Lead	0	15	ppb
071-51A Faculty Room - Sink Faucet	6/24/2016 00:31	6/28/2016 15:57	10353467101	Copper	0.3	1.3	ppm
071-51A Faculty Room - Sink Faucet	6/24/2016 00:31	6/28/2016 14:10	10353467101	Lead	1	15	ppb
071-52A Boys Bathroom Near 103 - Sink Faucet (1)	6/24/2016 00:42	6/28/2016 16:00	10353467103	Copper	0.4	1.3	ppm
071-52A Boys Bathroom Near 103 - Sink Faucet (1)	6/24/2016 00:42	6/28/2016 14:13	10353467103	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Richmond Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	Units
						Action Level	
071-53A Boys Bathroom Near 103 - Sink Faucet (2)	6/24/2016 00:44	6/28/2016 16:04	10353467105	Copper	0.4	1.3	ppm
071-53A Boys Bathroom Near 103 - Sink Faucet (2)	6/24/2016 00:44	6/28/2016 14:16	10353467105	Lead	4	15	ppb
071-54A Boys Bathroom Near 103 - Sink Faucet (3)	6/24/2016 00:47	6/28/2016 16:05	10353467107	Copper	0.4	1.3	ppm
071-54A Boys Bathroom Near 103 - Sink Faucet (3)	6/24/2016 00:47	6/28/2016 14:26	10353467107	Lead	3	15	ppb
071-55A Boys Bathroom Near 103 - Water Spigot	6/24/2016 00:49	6/28/2016 16:08	10353467109	Copper	0.9	1.3	ppm
071-55A Boys Bathroom Near 103 - Water Spigot	6/24/2016 00:49	6/28/2016 14:29	10353467109	Lead	32	15	ppb
071-56A Room 103 - Sink Faucet	6/24/2016 00:55	6/28/2016 16:11	10353467111	Copper	0.3	1.3	ppm
071-56A Room 103 - Sink Faucet	6/24/2016 00:55	6/28/2016 14:32	10353467111	Lead	3	15	ppb
071-57A Room 103 - Drinking Fountain	6/24/2016 00:57	6/28/2016 14:35	10353467113	Copper	0.1	1.3	ppm
071-57A Room 103 - Drinking Fountain	6/24/2016 00:57	6/28/2016 14:35	10353467113	Lead	3	15	ppb
071-58A Room 102 - Sink Faucet	6/24/2016 01:03	6/28/2016 16:18	10353467115	Copper	0.3	1.3	ppm
071-58A Room 102 - Sink Faucet	6/24/2016 01:03	6/28/2016 14:38	10353467115	Lead	2	15	ppb
071-59A Room 102 - Drinking Fountain	6/24/2016 01:05	6/28/2016 14:45	10353467117	Copper	0.1	1.3	ppm
071-59A Room 102 - Drinking Fountain	6/24/2016 01:05	6/28/2016 14:45	10353467117	Lead	3	15	ppb
071-60A Hall by 102 - Drinking Fountain	6/24/2016 01:10	6/30/2016 15:45	10353467119	Copper	0.7	1.3	ppm
071-60A Hall by 102 - Drinking Fountain	6/24/2016 01:10	6/30/2016 14:47	10353467119	Lead	2	15	ppb
071-61A Hall by 101 - Drinking Fountain (1)	6/24/2016 01:12	6/28/2016 13:13	10353467121	Copper	0.0	1.3	ppm
071-61A Hall by 101 - Drinking Fountain (1)	6/24/2016 01:12	6/28/2016 13:13	10353467121	Lead	5	15	ppb
071-62A Hall by 101 - Drinking Fountain (2)	6/24/2016 01:14	6/28/2016 13:16	10353467123	Copper	0.1	1.3	ppm
071-62A Hall by 101 - Drinking Fountain (2)	6/24/2016 01:14	6/28/2016 13:16	10353467123	Lead	3	15	ppb
071-63A Restroom by 101 - Sink Faucet (1)	6/24/2016 01:16	6/28/2016 13:56	10353467125	Copper	0.4	1.3	ppm
071-63A Restroom by 101 - Sink Faucet (1)	6/24/2016 01:16	6/28/2016 13:18	10353467125	Lead	3	15	ppb
071-64A Restroom by 101 - Sink Faucet (2)	6/24/2016 01:18	6/28/2016 13:59	10353467127	Copper	0.3	1.3	ppm
071-64A Restroom by 101 - Sink Faucet (2)	6/24/2016 01:18	6/28/2016 13:29	10353467127	Lead	1	15	ppb
071-65A Room 101 - Sink Faucet	6/24/2016 01:20	6/28/2016 14:00	10353467129	Copper	0.4	1.3	ppm
071-65A Room 101 - Sink Faucet	6/24/2016 01:20	6/28/2016 13:32	10353467129	Lead	6	15	ppb
071-66A Restroom by 104 - Sink Faucet	6/24/2016 01:22	6/28/2016 14:49	10353467131	Copper	0.3	1.3	ppm
071-66A Restroom by 104 - Sink Faucet	6/24/2016 01:22	6/28/2016 13:35	10353467131	Lead	2	15	ppb
071-67A Room 111 - Sink Faucet	6/24/2016 01:25	6/28/2016 14:53	10353467133	Copper	0.2	1.3	ppm
071-67A Room 111 - Sink Faucet	6/24/2016 01:25	6/28/2016 13:38	10353467133	Lead	0	15	ppb
071-68A Room 111 - Drinking Fountain (cooler)	6/24/2016 01:27	6/28/2016 13:48	10353467135	Copper	0.0	1.3	ppm
071-68A Room 111 - Drinking Fountain (cooler)	6/24/2016 01:27	6/28/2016 13:48	10353467135	Lead	0	15	ppb
071-69A Room 104 - Sink Faucet	6/24/2016 01:29	6/28/2016 14:56	10353467137	Copper	0.3	1.3	ppm
071-69A Room 104 - Sink Faucet	6/24/2016 01:29	6/28/2016 13:51	10353467137	Lead	9	15	ppb
071-70A Book Room - Sink Faucet	6/24/2016 01:31	6/28/2016 14:57	10353467139	Copper	0.4	1.3	ppm
071-70A Book Room - Sink Faucet	6/24/2016 01:31	6/28/2016 13:52	10353467139	Lead	3	15	ppb
071-71A Principals Office - Sink Faucet	6/24/2016 01:36	6/30/2016 22:35	10353467141	Copper	0.6	1.3	ppm
071-71A Principals Office - Sink Faucet	6/24/2016 01:36	6/30/2016 22:14	10353467141	Lead	3	15	ppb
071-72A Hall - Drinking Fountain	6/24/2016 01:38	6/30/2016 22:45	10353467143	Copper	0.4	1.3	ppm
071-72A Hall - Drinking Fountain	6/24/2016 01:38	6/30/2016 22:45	10353467143	Lead	1	15	ppb
071-73A Room 110 Sink Faucet	6/24/2016 01:40	6/30/2016 22:52	10353467145	Copper	0.4	1.3	ppm
071-73A Room 110 Sink Faucet	6/24/2016 01:40	6/30/2016 22:52	10353467145	Lead	17	15	ppb
071-74A Room 105 Sink Faucet	6/24/2016 01:42	6/30/2016 23:10	10353467147	Copper	0.6	1.3	ppm
071-74A Room 105 Sink Faucet	6/24/2016 01:42	6/30/2016 22:59	10353467147	Lead	5	15	ppb
071-75A Room 109 Sink Faucet	6/24/2016 01:44	6/30/2016 23:16	10353467149	Copper	0.4	1.3	ppm
071-75A Room 109 Sink Faucet	6/24/2016 01:44	6/30/2016 23:16	10353467149	Lead	5	15	ppb
071-76A Room 107 Sink Faucet	6/24/2016 01:46	6/30/2016 23:23	10353467151	Copper	0.4	1.3	ppm
071-76A Room 107 Sink Faucet	6/24/2016 01:46	6/30/2016 23:23	10353467151	Lead	37	15	ppb
071-77A Room 106 Sink Faucet	6/24/2016 01:48	6/30/2016 23:30	10353467153	Copper	0.3	1.3	ppm
071-77A Room 106 Sink Faucet	6/24/2016 01:48	6/30/2016 23:30	10353467153	Lead	2	15	ppb
071-78A Room 106 Drinking Fountain	6/24/2016 01:50	6/30/2016 23:34	10353467155	Copper	0.4	1.3	ppm
071-78A Room 106 Drinking Fountain	6/24/2016 01:50	6/30/2016 23:34	10353467155	Lead	2	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Richmond Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
071-79A Girls Bathroom by 106 - Sink Faucet (1)	6/24/2016 01:52	6/30/2016 14:54	10353467157	Copper	0.4	1.3	ppm
071-79A Girls Bathroom by 106 - Sink Faucet (1)	6/24/2016 01:52	6/30/2016 14:54	10353467157	Lead	6	15	ppb
071-80A Girls Bathroom by 106 - Sink Faucet (2)	6/24/2016 01:54	6/30/2016 23:51	10353467159	Copper	0.2	1.3	ppm
071-80A Girls Bathroom by 106 - Sink Faucet (2)	6/24/2016 01:54	6/30/2016 23:51	10353467159	Lead	2	15	ppb
071-81A Girls Bathroom by 106 - Sink Faucet (3)	6/24/2016 01:56	7/1/2016 00:08	10353467161	Copper	0.3	1.3	ppm
071-81A Girls Bathroom by 106 - Sink Faucet (3)	6/24/2016 01:56	7/1/2016 00:08	10353467161	Lead	1	15	ppb
071-82A Girls Bathroom by 106 - Water Spigot	6/24/2016 01:58	6/30/2016 15:15	10353467163	Copper	1.8	1.3	ppm
071-82A Girls Bathroom by 106 - Water Spigot	6/24/2016 01:58	6/30/2016 13:43	10353467163	Lead	123	15	ppb
071-83A Hall by Elevator - Drinking Fountain	6/24/2016 02:01	6/30/2016 13:39	10353467165	Copper	0.3	1.3	ppm
071-83A Hall by Elevator - Drinking Fountain	6/24/2016 02:01	6/30/2016 13:39	10353467165	Lead	3	15	ppb
071-84A Room 211 - Sink Faucet	6/24/2016 02:11	7/1/2016 00:15	10353467167	Copper	0.2	1.3	ppm
071-84A Room 211 - Sink Faucet	6/24/2016 02:11	7/1/2016 00:15	10353467167	Lead	15.0	15	ppb
071-85A Boys Bathroom by 211 - Sink Faucet (1)	6/24/2016 02:13	6/30/2016 15:14	10353467169	Copper	0.7	1.3	ppm
071-85A Boys Bathroom by 211 - Sink Faucet (1)	6/24/2016 02:13	6/30/2016 13:41	10353467169	Lead	9	15	ppb
071-86A Boys Bathroom by 211 - Sink Faucet (2)	6/24/2016 02:15	6/30/2016 15:20	10353467171	Copper	0.5	1.3	ppm
071-86A Boys Bathroom by 211 - Sink Faucet (2)	6/24/2016 02:15	6/30/2016 13:51	10353467171	Lead	4	15	ppb
071-87A Boys Bathroom by 211 - Sink Faucet (3)	6/24/2016 02:17	6/30/2016 15:22	10353467173	Copper	1.4	1.3	ppm
071-87A Boys Bathroom by 211 - Sink Faucet (3)	6/24/2016 02:17	6/30/2016 13:52	10353467173	Lead	72	15	ppb
071-88A Boys Bathroom by 211 - Water Spigot	6/24/2016 02:19	6/30/2016 15:23	10353467175	Copper	1.5	1.3	ppm
071-88A Boys Bathroom by 211 - Water Spigot	6/24/2016 02:19	6/30/2016 13:54	10353467175	Lead	119	15	ppb
071-89A Hall by Elevator - Drinking Fountain	6/24/2016 02:21	7/1/2016 00:39	10353467177	Copper	0.5	1.3	ppm
071-89A Hall by Elevator - Drinking Fountain	6/24/2016 02:21	7/1/2016 00:36	10353467177	Lead	2	15	ppb
071-90A Room 213 - Sink Faucet	6/24/2016 02:09	7/1/2016 00:49	10353467179	Copper	0.6	1.3	ppm
071-90A Room 213 - Sink Faucet	6/24/2016 02:09	7/1/2016 00:46	10353467179	Lead	7	15	ppb
071-91A Girls Bathroom by Room 203 - Sink Faucet (1)	6/24/2016 02:23	6/29/2016 15:24	10353467181	Copper	0.4	1.3	ppm
071-91A Girls Bathroom by Room 203 - Sink Faucet (1)	6/24/2016 02:23	6/29/2016 15:24	10353467181	Lead	3	15	ppb
071-92A Girls Bathroom by Room 203 - Sink Faucet (2)	6/24/2016 02:25	6/29/2016 15:44	10353467183	Copper	0.4	1.3	ppm
071-92A Girls Bathroom by Room 203 - Sink Faucet (2)	6/24/2016 02:25	6/29/2016 15:44	10353467183	Lead	6	15	ppb
071-93A Girls Bathroom by Room 203 - Sink Faucet (3)	6/24/2016 02:27	6/29/2016 15:57	10353467185	Copper	0.4	1.3	ppm
071-93A Girls Bathroom by Room 203 - Sink Faucet (3)	6/24/2016 02:27	6/29/2016 15:57	10353467185	Lead	5	15	ppb
071-94A Girls Bathroom by Room 203 - Water Spigot	6/24/2016 02:28	6/29/2016 16:03	10353467187	Copper	0.4	1.3	ppm
071-94A Girls Bathroom by Room 203 - Water Spigot	6/24/2016 02:28	6/29/2016 16:03	10353467187	Lead	21	15	ppb
071-95A Hall by 202 - Drinking Fountain (1)	6/24/2016 02:30	6/29/2016 16:10	10353467189	Copper	0.1	1.3	ppm
071-95A Hall by 202 - Drinking Fountain (1)	6/24/2016 02:30	6/29/2016 16:10	10353467189	Lead	7	15	ppb
071-96A Hall by 202 - Drinking Fountain (2)	6/24/2016 02:32	6/29/2016 16:16	10353467191	Copper	0.1	1.3	ppm
071-96A Hall by 202 - Drinking Fountain (2)	6/24/2016 02:32	6/29/2016 16:16	10353467191	Lead	10	15	ppb
071-97A Room 201 - Sink Faucet	6/24/2016 02:34	6/30/2016 13:56	10353467193	Copper	0.4	1.3	ppm
071-97A Room 201 - Sink Faucet	6/24/2016 02:34	6/30/2016 13:56	10353467193	Lead	3	15	ppb
071-98A Room 201 - Drinking Fountain	6/24/2016 02:36	6/29/2016 16:26	10353467195	Copper	0.3	1.3	ppm
071-98A Room 201 - Drinking Fountain	6/24/2016 02:36	6/29/2016 16:26	10353467195	Lead	3	15	ppb
071-99A Room 200 - Sink Faucet	6/24/2016 02:38	6/30/2016 15:26	10353467197	Copper	0.7	1.3	ppm
071-99A Room 200 - Sink Faucet	6/24/2016 02:38	6/30/2016 13:58	10353467197	Lead	3	15	ppb
071-100A Room 200 - Drinking Fountain	6/24/2016 02:41	6/30/2016 21:57	10353467199	Copper	0.0	1.3	ppm
071-100A Room 200 - Drinking Fountain	6/24/2016 02:41	6/30/2016 21:57	10353467199	Lead	6	15	ppb
071-101A Outside Water Spigot (1)	6/24/2016 03:27	6/30/2016 15:27	10353467201	Copper	0.5	1.3	ppm
071-101A Outside Water Spigot (1)	6/24/2016 03:27	6/30/2016 13:59	10353467201	Lead	7	15	ppb
071-102A Outside Water Spigot (2)	6/24/2016 03:24	6/30/2016 15:28	10353467203	Copper	0.5	1.3	ppm
071-102A Outside Water Spigot (2)	6/24/2016 03:24	6/30/2016 14:02	10353467203	Lead	8	15	ppb
071-103A Outside Water Spigot (3)	6/24/2016 03:17	6/30/2016 15:30	10353467205	Copper	0.8	1.3	ppm
071-103A Outside Water Spigot (3)	6/24/2016 03:17	6/30/2016 14:03	10353467205	Lead	3	15	ppb
071-104A Outside Water Spigot (4)	6/24/2016 03:15	7/1/2016 01:55	10353467207	Copper	0.4	1.3	ppm
071-104A Outside Water Spigot (4)	6/24/2016 03:15	7/1/2016 01:55	10353467207	Lead	5	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Richmond Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
071-105A Outside Water Spigot (5)	6/24/2016 03:12	6/30/2016 15:31	10353467209	Copper	0.8	1.3	ppm
071-105A Outside Water Spigot (5)	6/24/2016 03:12	6/30/2016 14:14	10353467209	Lead	11	15	ppb
071-106A Outside Water Spigot (6)	6/24/2016 03:09	7/1/2016 02:06	10353467211	Copper	0.3	1.3	ppm
071-106A Outside Water Spigot (6)	6/24/2016 03:09	7/1/2016 02:06	10353467211	Lead	3	15	ppb
071-107A Outside Water Spigot (7)	6/24/2016 03:30	7/1/2016 02:16	10353467213	Copper	0.6	1.3	ppm
071-107A Outside Water Spigot (7)	6/24/2016 03:30	7/1/2016 02:12	10353467213	Lead	5	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.