

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Rigler Elementary School

Sample Identification # Location		Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
073 - 01A	Custodial Sink Faucet	6/26/2016 12:05:00 AM	7/1/2016	BB66725	Copper	0.0	1.3	ppm
073 - 01A	Custodial Sink Faucet	6/26/2016 12:05:00 AM	7/1/2016	BB66725	Lead	13	15	ppb
073 - 02A	Girls Bathroom Sink Faucet	6/26/2016 12:12:00 AM	7/1/2016	BB66726	Copper	0.1	1.3	ppm
073 - 02A	Girls Bathroom Sink Faucet	6/26/2016 12:12:00 AM	7/1/2016	BB66726	Lead	9	15	ppb
073 - 03A	Room 19 Sink Faucet	6/26/2016 12:17:00 AM	7/1/2016	BB66727	Copper	0.1	1.3	ppm
073 - 03A	Room 19 Sink Faucet	6/26/2016 12:17:00 AM	7/1/2016	BB66727	Lead	33	15	ppb
073 - 04A	Room 18B Sink Faucet	6/26/2016 12:19:00 AM	7/1/2016	BB66728	Copper	0.1	1.3	ppm
073 - 04A	Room 18B Sink Faucet	6/26/2016 12:19:00 AM	7/1/2016	BB66728	Lead	7	15	ppb
073 - 05A	Room 18B Drinking Fountain	6/26/2016 12:21:00 AM	6/30/2016	BB66729	Copper	0.0	1.3	ppm
073 - 05A	Room 18B Drinking Fountain	6/26/2016 12:21:00 AM	6/30/2016	BB66729	Lead	3	15	ppb
073 - 06A	Drinking Fountain by Rooms 17 & 18 (1)	6/26/2016 12:10:00 AM	6/30/2016	BB66730	Copper	0.0	1.3	ppm
073 - 06A	Drinking Fountain by Rooms 17 & 18 (1)	6/26/2016 12:10:00 AM	6/30/2016	BB66730	Lead	1	15	ppb
073 - 07A	Drinking Fountain by Rooms 17 & 18 (2)	6/26/2016 12:12:00 AM	6/30/2016	BB66731	Copper	0.0	1.3	ppm
073 - 07A	Drinking Fountain by Rooms 17 & 18 (2)	6/26/2016 12:12:00 AM	6/30/2016	BB66731	Lead	0	15	ppb
073 - 08A	Room 10C Janitors Sink Faucet	6/26/2016 12:39:00 AM	6/30/2016	BB66732	Copper	0.1	1.3	ppm
073 - 08A	Room 10C Janitors Sink Faucet	6/26/2016 12:39:00 AM	6/30/2016	BB66732	Lead	9	15	ppb
073 - 09A	Custodian Sink Faucet	6/26/2016 12:27:00 AM	6/30/2016	BB66733	Copper	0.0	1.3	ppm
073 - 09A	Custodian Sink Faucet	6/26/2016 12:27:00 AM	6/30/2016	BB66733	Lead	1	15	ppb
073 - 10A	Hallway Drinking Fountain	6/26/2016 12:29:00 AM	6/30/2016	BB66734	Copper	0.0	1.3	ppm
073 - 10A	Hallway Drinking Fountain	6/26/2016 12:29:00 AM	6/30/2016	BB66734	Lead	4	15	ppb
073 - 11A	Womens Restroom 43D Sink Faucet	6/26/2016 12:27:00 AM	6/30/2016	BB66735	Copper	0.0	1.3	ppm
073 - 11A	Womens Restroom 43D Sink Faucet	6/26/2016 12:27:00 AM	6/30/2016	BB66735	Lead	5	15	ppb
073 - 12A	Kitchen Sink Faucet (1)	6/26/2016 12:27:00 AM	6/30/2016	BB66736	Copper	0.1	1.3	ppm
073 - 12A	Kitchen Sink Faucet (1)	6/26/2016 12:27:00 AM	6/30/2016	BB66736	Lead	9	15	ppb
073 - 13A	Kitchen Sink Faucet (2)	6/26/2016 12:37:00 AM	7/8/2016 9:52:00 AM	BB66737	Copper	0.1	1.3	ppm
073 - 13A	Kitchen Sink Faucet (2)	6/26/2016 12:37:00 AM	7/8/2016 9:52:00 AM	BB66737	Lead	8	15	ppb
073 - 14A	Kitchen Sink Faucet (3)	6/26/2016 12:39:00 AM	6/30/2016	BB66738	Copper	0.1	1.3	ppm
073 - 14A	Kitchen Sink Faucet (3)	6/26/2016 12:39:00 AM	6/30/2016	BB66738	Lead	5	15	ppb
073 - 15A	Kitchen Sink Faucet (4)	6/26/2016 12:41:00 AM	6/30/2016	BB66739	Copper	0.0	1.3	ppm
073 - 15A	Kitchen Sink Faucet (4)	6/26/2016 12:41:00 AM	6/30/2016	BB66739	Lead	3	15	ppb
073 - 16A	Kitchen Sink Faucet (5)	6/26/2016 12:43:00 AM	7/10/2016 4:37:00 PM	BB66740	Copper	0.3	1.3	ppm
073 - 16A	Kitchen Sink Faucet (5)	6/26/2016 12:43:00 AM	7/10/2016 4:37:00 PM	BB66740	Lead	14	15	ppb
073 - 17A	Kitchen Sink Faucet (6)	6/26/2016 12:45:00 AM	6/30/2016	BB66741	Copper	0.0	1.3	ppm
073 - 17A	Kitchen Sink Faucet (6)	6/26/2016 12:45:00 AM	6/30/2016	BB66741	Lead	4	15	ppb
073 - 18A	Custodian Sink Faucet	6/26/2016 12:47:00 AM	6/30/2016	BB66742	Copper	0.0	1.3	ppm
073 - 18A	Custodian Sink Faucet	6/26/2016 12:47:00 AM	6/30/2016	BB66742	Lead	4	15	ppb
073 - 19A	Boys Restroom Sink Faucet (1)	6/26/2016 12:50:00 AM	6/30/2016	BB66743	Copper	0.0	1.3	ppm
073 - 19A	Boys Restroom Sink Faucet (1)	6/26/2016 12:50:00 AM	6/30/2016	BB66743	Lead	5	15	ppb
073 - 20A	Boys Restroom Sink Faucet (2)	6/26/2016 12:52:00 AM	6/30/2016	BB66744	Copper	0.1	1.3	ppm
073 - 20A	Boys Restroom Sink Faucet (2)	6/26/2016 12:52:00 AM	6/30/2016	BB66744	Lead	4	15	ppb
073 - 21A	Boys Restroom Water Spigot	6/26/2016 12:54:00 AM	6/30/2016	BB66745	Copper	0.1	1.3	ppm
073 - 21A	Boys Restroom Water Spigot	6/26/2016 12:54:00 AM	6/30/2016	BB66745	Lead	7	15	ppb
073 - 22A	Girls Restroom Sink Faucet (1)	6/26/2016 12:54:00 AM	6/30/2016	BB66746	Copper	0.0	1.3	ppm
073 - 22A	Girls Restroom Sink Faucet (1)	6/26/2016 12:54:00 AM	6/30/2016	BB66746	Lead	3	15	ppb
073 - 23A	Girls Restroom Sink Faucet (2)	6/26/2016 12:56:00 AM	6/30/2016	BB66747	Copper	0.0	1.3	ppm
073 - 23A	Girls Restroom Sink Faucet (2)	6/26/2016 12:56:00 AM	6/30/2016	BB66747	Lead	4	15	ppb
073 - 24A	Girls Restroom Water Spigot	6/26/2016 12:58:00 AM	6/30/2016	BB66748	Copper	0.0	1.3	ppm
073 - 24A	Girls Restroom Water Spigot	6/26/2016 12:58:00 AM	6/30/2016	BB66748	Lead	7	15	ppb
073 - 25A	Room 16A Sink Faucet	6/26/2016 1:03:00 AM	6/30/2016	BB66749	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Rigler Elementary School

Sample Identification # Location		Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
073 - 25A	Room 16A Sink Faucet	6/26/2016 1:03:00 AM	6/30/2016	BB66749	Lead	4	15	ppb
073 - 26A	Room 16A Drinking Fountain	6/26/2016 1:05:00 AM	6/30/2016	BB66750	Copper	0.0	1.3	ppm
073 - 26A	Room 16A Drinking Fountain	6/26/2016 1:05:00 AM	6/30/2016	BB66750	Lead	0	15	ppb
073 - 27A	Room 15 Sink Faucet (1)	6/26/2016 1:06:00 AM	6/30/2016	BB66751	Copper	0.1	1.3	ppm
073 - 27A	Room 15 Sink Faucet (1)	6/26/2016 1:06:00 AM	6/30/2016	BB66751	Lead	6	15	ppb
073 - 28A	Room 15 Sink Faucet (2)	6/26/2016 1:08:00 AM	6/30/2016	BB66752	Copper	0.0	1.3	ppm
073 - 28A	Room 15 Sink Faucet (2)	6/26/2016 1:08:00 AM	6/30/2016	BB66752	Lead	5	15	ppb
073 - 29A	Room 13 Sink Faucet	6/26/2016 1:11:00 AM	6/30/2016	BB66753	Copper	0.0	1.3	ppm
073 - 29A	Room 13 Sink Faucet	6/26/2016 1:11:00 AM	6/30/2016	BB66753	Lead	4	15	ppb
073 - 30A	Room 14 Sink Faucet	6/26/2016 1:21:00 AM	6/30/2016	BB66754	Copper	0.1	1.3	ppm
073 - 30A	Room 14 Sink Faucet	6/26/2016 1:21:00 AM	6/30/2016	BB66754	Lead	9	15	ppb
073 - 31A	Room 14 Drinking Fountain	6/26/2016 1:23:00 AM	6/30/2016	BB66755	Copper	0.0	1.3	ppm
073 - 31A	Room 14 Drinking Fountain	6/26/2016 1:23:00 AM	6/30/2016	BB66755	Lead	3	15	ppb
073 - 32A	Hallway Drinking Fountain	6/26/2016 1:25:00 AM	6/30/2016	BB66756	Copper	0.0	1.3	ppm
073 - 32A	Hallway Drinking Fountain	6/26/2016 1:25:00 AM	6/30/2016	BB66756	Lead	4	15	ppb
073 - 34A	Room 12 Sink Faucet	6/26/2016 1:38:00 AM	6/30/2016	BB66757	Copper	0.0	1.3	ppm
073 - 34A	Room 12 Sink Faucet	6/26/2016 1:38:00 AM	6/30/2016	BB66757	Lead	7	15	ppb
073 - 35A	Room 12 Drinking Fountain	6/26/2016 1:40:00 AM	6/30/2016	BB66758	Copper	0.0	1.3	ppm
073 - 35A	Room 12 Drinking Fountain	6/26/2016 1:40:00 AM	6/30/2016	BB66758	Lead	4	15	ppb
073 - 36A	Room 11 Sink Faucet	6/26/2016 1:31:00 AM	6/30/2016	BB66759	Copper	0.1	1.3	ppm
073 - 36A	Room 11 Sink Faucet	6/26/2016 1:31:00 AM	6/30/2016	BB66759	Lead	11	15	ppb
073 - 37A	Hall Drinking Fountain by Kitchen	6/26/2016 1:49:00 AM	6/30/2016	BB66760	Copper	0.0	1.3	ppm
073 - 37A	Hall Drinking Fountain by Kitchen	6/26/2016 1:49:00 AM	6/30/2016	BB66760	Lead	5	15	ppb
073 - 38A	Hall Drinking Fountain by 21F (1)	6/26/2016 1:56:00 AM	6/30/2016	BB66761	Copper	0.0	1.3	ppm
073 - 38A	Hall Drinking Ountain by 21F (1)	6/26/2016 1:56:00 AM	6/30/2016	BB66761	Lead	18	15	ppb
073 - 39A	Hall Drinking Fountain by 21F (2)	6/26/2016 1:58:00 AM	6/30/2016	BB66762	Copper	0.0	1.3	ppm
073 - 39A	Hall Drinking Fountain by 21F (2)	6/26/2016 1:58:00 AM	6/30/2016	BB66762	Lead	10	15	ppb
073 - 40A	Library Sink Faucet (1)	6/26/2016 1:58:00 AM	6/30/2016	BB66763	Copper	0.0	1.3	ppm
073 - 40A	Library Sink Faucet (1)	6/26/2016 1:58:00 AM	6/30/2016	BB66763	Lead	18	15	ppb
073 - 41A	Library Sink Faucet (2)	6/26/2016 2:00:00 AM	6/30/2016	BB66764	Copper	0.0	1.3	ppm
073 - 41A	Library Sink Faucet (2)	6/26/2016 2:00:00 AM	6/30/2016	BB66764	Lead	6	15	ppb
073 - 42A	Room 21F Custodial Sink Faucet	6/26/2016 2:03:00 AM	6/30/2016	BB66765	Copper	0.0	1.3	ppm
073 - 42A	Room 21F Custodial Sink Faucet	6/26/2016 2:03:00 AM	6/30/2016	BB66765	Lead	11	15	ppb
073 - 43A	Bathroom Sink Faucet	6/26/2016 2:05:00 AM	6/30/2016	BB66766	Copper	0.1	1.3	ppm
073 - 43A	Bathroom Sink Faucet	6/26/2016 2:05:00 AM	6/30/2016	BB66766	Lead	6	15	ppb
073 - 44A	Girls Restroom Sink Faucet (1)	6/26/2016 2:08:00 AM	6/30/2016	BB66767	Copper	0.0	1.3	ppm
073 - 44A	Girls Restroom Sink Faucet (1)	6/26/2016 2:08:00 AM	6/30/2016	BB66767	Lead	2	15	ppb
073 - 45A	Girls Restroom Sink Faucet (2)	6/26/2016 2:10:00 AM	6/30/2016	BB66768	Copper	0.1	1.3	ppm
073 - 45A	Girls Restroom Sink Faucet (2)	6/26/2016 2:10:00 AM	6/30/2016	BB66768	Lead	5	15	ppb
073 - 46A	Girls Restroom Sink Faucet (3)	6/26/2016 2:12:00 AM	6/30/2016	BB66769	Copper	0.0	1.3	ppm
073 - 46A	Girls Restroom Sink Faucet (3)	6/26/2016 2:12:00 AM	6/30/2016	BB66769	Lead	3	15	ppb
073 - 47A	Girls Restroom Sink Faucet (4)	6/26/2016 2:14:00 AM	6/30/2016	BB66770	Copper	0.0	1.3	ppm
073 - 47A	Girls Restroom Sink Faucet (4)	6/26/2016 2:14:00 AM	6/30/2016	BB66770	Lead	5	15	ppb
073 - 48A	Girls Restroom Sink Faucet (5)	6/26/2016 2:16:00 AM	6/30/2016	BB66771	Copper	0.2	1.3	ppm
073 - 48A	Girls Restroom Sink Faucet (5)	6/26/2016 2:16:00 AM	6/30/2016	BB66771	Lead	11	15	ppb
073 - 49A	Office Sink Faucet	6/26/2016 2:19:00 AM	6/30/2016	BB66772	Copper	0.1	1.3	ppm
073 - 49A	Office Sink Faucet	6/26/2016 2:19:00 AM	6/30/2016	BB66772	Lead	47	15	ppb
073 - 50A	Office Bathroom Sink Faucet	6/26/2016 2:21:00 AM	6/30/2016	BB66773	Copper	0.1	1.3	ppm
073 - 50A	Office Bathroom Sink Faucet	6/26/2016 2:21:00 AM	6/30/2016	BB66773	Lead	20	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Rigler Elementary School

Sample Identification # Location		Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
073 - 51A	Principals Bathroom Sink Faucet	6/26/2016 2:23:00 AM	6/30/2016	BB66774	Copper	0.1	1.3	ppm
073 - 51A	Principals Bathroom Sink Faucet	6/26/2016 2:23:00 AM	6/30/2016	BB66774	Lead	7	15	ppb
073 - 52A	Hall Drinking Fountain by Office	6/26/2016 2:25:00 AM	6/30/2016	BB66775	Copper	0.0	1.3	ppm
073 - 52A	Hall Drinking Fountain by Office	6/26/2016 2:25:00 AM	6/30/2016	BB66775	Lead	1	15	ppb
073 - 53A	Room 24A Sink Faucet	6/26/2016 2:27:00 AM	6/30/2016	BB66776	Copper	0.2	1.3	ppm
073 - 53A	Room 24A Sink Faucet	6/26/2016 2:27:00 AM	6/30/2016	BB66776	Lead	27	15	ppb
073 - 54A	Room 24A Drinking Fountain	6/26/2016 2:29:00 AM	6/30/2016	BB66777	Copper	0.0	1.3	ppm
073 - 54A	Room 24A Drinking Fountain	6/26/2016 2:29:00 AM	6/30/2016	BB66777	Lead	5	15	ppb
073 - 55A	Boys Restroom Sink Faucet (1)	6/26/2016 2:31:00 AM	6/30/2016	BB66778	Copper	0.0	1.3	ppm
073 - 55A	Boys Restroom Sink Faucet (1)	6/26/2016 2:31:00 AM	6/30/2016	BB66778	Lead	5	15	ppb
073 - 56A	Boys Restroom Sink Faucet (2)	6/26/2016 2:33:00 AM	6/30/2016	BB66779	Copper	0.0	1.3	ppm
073 - 56A	Boys Restroom Sink Faucet (2)	6/26/2016 2:33:00 AM	6/30/2016	BB66779	Lead	1	15	ppb
073 - 57A	Boys Restroom Sink Faucet (3)	6/26/2016 2:36:00 AM	6/30/2016	BB66780	Copper	0.0	1.3	ppm
073 - 57A	Boys Restroom Sink Faucet (3)	6/26/2016 2:36:00 AM	6/30/2016	BB66780	Lead	5	15	ppb
073 - 58A	Boys Restroom Sink Faucet (4)	6/26/2016 2:38:00 AM	6/30/2016	BB66781	Copper	0.0	1.3	ppm
073 - 58A	Boys Restroom Sink Faucet (4)	6/26/2016 2:38:00 AM	6/30/2016	BB66781	Lead	3	15	ppb
073 - 59A	Boys Restroom Sink Faucet (5)	6/26/2016 2:40:00 AM	6/30/2016	BB66782	Copper	0.0	1.3	ppm
073 - 59A	Boys Restroom Sink Faucet (5)	6/26/2016 2:40:00 AM	6/30/2016	BB66782	Lead	13	15	ppb
073 - 60A	Boys Restroom Sink Faucet (6)	6/26/2016 2:43:00 AM	6/30/2016	BB66783	Copper	0.0	1.3	ppm
073 - 60A	Boys Restroom Sink Faucet (6)	6/26/2016 2:43:00 AM	6/30/2016	BB66783	Lead	4	15	ppb
073 - 61A	Hallway Drinking Fountain (1)	6/26/2016 2:47:00 AM	6/30/2016	BB66784	Copper	0.1	1.3	ppm
073 - 61A	Hallway Drinking Fountain (1)	6/26/2016 2:47:00 AM	6/30/2016	BB66784	Lead	2	15	ppb
073 - 62A	Hallway Drinking Fountain (2)	6/26/2016 2:49:00 AM	6/30/2016	BB66785	Copper	0.0	1.3	ppm
073 - 62A	Hallway Drinking Fountain (2)	6/26/2016 2:49:00 AM	6/30/2016	BB66785	Lead	1	15	ppb
073 - 63A	Room 27 Bathroom Sink Faucet	6/26/2016 2:41:00 AM	6/30/2016	BB66786	Copper	0.0	1.3	ppm
073 - 63A	Room 27 Bathroom Sink Faucet	6/26/2016 2:41:00 AM	6/30/2016	BB66786	Lead	13	15	ppb
073 - 64A	Room 27 Sink Faucet	6/26/2016 2:54:00 AM	6/30/2016	BB66787	Copper	0.0	1.3	ppm
073 - 64A	Room 27 Sink Faucet	6/26/2016 2:54:00 AM	6/30/2016	BB66787	Lead	3	15	ppb
073 - 65A	Room 27 Drinking Fountain	6/26/2016 2:56:00 AM	6/30/2016	BB66788	Copper	0.0	1.3	ppm
073 - 65A	Room 27 Drinking Fountain	6/26/2016 2:56:00 AM	6/30/2016	BB66788	Lead	22	15	ppb
073 - 66A	Room 27A Custodial Sink Faucet	6/26/2016 2:56:00 AM	6/30/2016	BB66789	Copper	0.0	1.3	ppm
073 - 66A	Room 27A Custodial Sink Faucet	6/26/2016 2:56:00 AM	6/30/2016	BB66789	Lead	6	15	ppb
073 - 67A	Room 25A Sink Faucet	6/26/2016 3:02:00 AM	6/30/2016	BB66790	Copper	0.1	1.3	ppm
073 - 67A	Room 25A Sink Faucet	6/26/2016 3:02:00 AM	6/30/2016	BB66790	Lead	2	15	ppb
073 - 68A	Room 23A Sink Faucet	6/26/2016 3:05:00 AM	6/30/2016	BB66791	Copper	0.0	1.3	ppm
073 - 68A	Room 23A Sink Faucet	6/26/2016 3:05:00 AM	6/30/2016	BB66791	Lead	40	15	ppb
073 - 69A	Room 31B Custodial Sink Faucet	6/26/2016 3:10:00 AM	6/30/2016	BB66792	Copper	0.0	1.3	ppm
073 - 69A	Room 31B Custodial Sink Faucet	6/26/2016 3:10:00 AM	6/30/2016	BB66792	Lead	3	15	ppb
073 - 70A	Hallway Sink Faucet	6/26/2016 3:12:00 AM	7/8/2016 9:59:00 AM	BB66793	Copper	0.3	1.3	ppm
073 - 70A	Hallway Sink Faucet	6/26/2016 3:12:00 AM	7/8/2016 9:59:00 AM	BB66793	Lead	82	15	ppb
073 - 71A	Hallway Drinking Fountain	6/26/2016 3:14:00 AM	7/8/2016 10:02:00 AM	BB66794	Copper	0.0	1.3	ppm
073 - 71A	Hallway Drinking Fountain	6/26/2016 3:14:00 AM	7/8/2016 10:02:00 AM	BB66794	Lead	6	15	ppb
073 - 72A	Room 31E Girls Bathroom Sink Faucet (1)	6/26/2016 3:17:00 AM	7/8/2016 9:45:00 AM	BB66795	Copper	0.1	1.3	ppm
073 - 72A	Room 31E Girls Bathroom Sink Faucet (1)	6/26/2016 3:17:00 AM	7/8/2016 9:45:00 AM	BB66795	Lead	29	15	ppb
073 - 73A	Room 31E Girls Bathroom Sink Faucet (2)	6/26/2016 3:19:00 AM	7/10/2016 4:58:00 PM	BB66796	Copper	5.0	1.3	ppm
073 - 73A	Room 31E Girls Bathroom Sink Faucet (2)	6/26/2016 3:19:00 AM	7/8/2016 10:05:00 AM	BB66796	Lead	324	15	ppb
073 - 74A	Room 31E Girls Bathroom Sink Faucet (3)	6/26/2016 3:21:00 AM	6/30/2016	BB66797	Copper	0.1	1.3	ppm
073 - 74A	Room 31E Girls Bathroom Sink Faucet (3)	6/26/2016 3:21:00 AM	6/30/2016	BB66797	Lead	2	15	ppb
073 - 75A	Room 31E Girls Bathroom Sink Faucet (4)	6/26/2016 3:23:00 AM	6/30/2016	BB66798	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Rigler Elementary School

Sample Identification # Location		Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
073 - 75A	Room 31E Girls Bathroom Sink Faucet (4)	6/26/2016 3:23:00 AM	6/30/2016	BB66798	Lead	8	15	ppb
073 - 76A	Room 34 Drinking Fountain	6/26/2016 3:26:00 AM	6/30/2016	BB66799	Copper	0.0	1.3	ppm
073 - 76A	Room 34 Drinking Fountain	6/26/2016 3:26:00 AM	6/30/2016	BB66799	Lead	5	15	ppb
073 - 77A	Room 34 Sink Faucet (1)	6/26/2016 3:28:00 AM	6/30/2016	BB66800	Copper	0.1	1.3	ppm
073 - 77A	Room 34 Sink Faucet (1)	6/26/2016 3:28:00 AM	6/30/2016	BB66800	Lead	11	15	ppb
073 - 78A	Room 34 Sink Faucet (2)	6/26/2016 3:30:00 AM	7/10/2016 5:01:00 PM	BB66801	Copper	5.8	1.3	ppm
073 - 78A	Room 34 Sink Faucet (2)	6/26/2016 3:30:00 AM	7/8/2016 10:09:00 AM	BB66801	Lead	538	15	ppb
073 - 79A	Room 32D Boys Bathroom Sink Faucet (1)	6/26/2016 3:33:00 AM	6/30/2016	BB66802	Copper	0.0	1.3	ppm
073 - 79A	Room 32D Boys Bathroom Sink Faucet (1)	6/26/2016 3:33:00 AM	6/30/2016	BB66802	Lead	7	15	ppb
073 - 80A	Room 32D Boys Bathroom Sink Faucet (2)	6/26/2016 3:36:00 AM	6/30/2016	BB66803	Copper	0.0	1.3	ppm
073 - 80A	Room 32D Boys Bathroom Sink Faucet (2)	6/26/2016 3:36:00 AM	6/30/2016	BB66803	Lead	7	15	ppb
073 - 81A	Room 32D Boys Bathroom Sink Faucet (3)	6/26/2016 3:38:00 AM	6/30/2016	BB66804	Copper	0.1	1.3	ppm
073 - 81A	Room 32D Boys Bathroom Sink Faucet (3)	6/26/2016 3:38:00 AM	6/30/2016	BB66804	Lead	38	15	ppb
073 - 82A	Room 32D Boys Bathroom Sink Faucet (4)	6/26/2016 3:40:00 AM	6/30/2016	BB66805	Copper	0.0	1.3	ppm
073 - 82A	Room 32D Boys Bathroom Sink Faucet (4)	6/26/2016 3:40:00 AM	6/30/2016	BB66805	Lead	4	15	ppb
073 - 83A	Room 32D Boys Bathroom Water Spigot	6/26/2016 3:43:00 AM	7/1/2016	BB66806	Copper	0.1	1.3	ppm
073 - 83A	Room 32D Boys Bathroom Water Spigot	6/26/2016 3:43:00 AM	7/1/2016	BB66806	Lead	17	15	ppb
073 - 84A	Hallway Sink Faucet	6/26/2016 3:36:00 AM	7/1/2016	BB66807	Copper	0.0	1.3	ppm
073 - 84A	Hallway Sink Faucet	6/26/2016 3:36:00 AM	7/1/2016	BB66807	Lead	3	15	ppb
073 - 85A	Hallway Drinking Fountain	6/26/2016 3:36:00 AM	7/1/2016	BB66808	Copper	0.0	1.3	ppm
073 - 85A	Hallway Drinking Fountain	6/26/2016 3:36:00 AM	7/1/2016	BB66808	Lead	3	15	ppb
073 - 86A	Room 41A Sink Faucet	6/26/2016 3:43:00 AM	7/1/2016	BB66809	Copper	0.0	1.3	ppm
073 - 86A	Room 41A Sink Faucet	6/26/2016 3:43:00 AM	7/1/2016	BB66809	Lead	7	15	ppb
073 - 87A	Room 31 Sink Faucet	6/26/2016 3:46:00 AM	7/1/2016	BB66810	Copper	0.1	1.3	ppm
073 - 87A	Room 31 Sink Faucet	6/26/2016 3:46:00 AM	7/1/2016	BB66810	Lead	26	15	ppb
073 - 88A	Portable 2 Bathroom Sink Faucet	6/26/2016 4:24:00 AM	7/1/2016	BB66811	Copper	0.0	1.3	ppm
073 - 88A	Portable 2 Bathroom Sink Faucet	6/26/2016 4:24:00 AM	7/1/2016	BB66811	Lead	51	15	ppb
073 - 89A	Portable 1 Sink Faucet	6/26/2016 4:09:00 AM	7/1/2016	BB66812	Copper	0.0	1.3	ppm
073 - 89A	Portable 1 Sink Faucet	6/26/2016 4:09:00 AM	7/1/2016	BB66812	Lead	3	15	ppb
073 - 90A	Portable 1 Drinking Fountain	6/26/2016 4:11:00 AM	7/10/2016 4:41:00 PM	BB66813	Copper	0.0	1.3	ppm
073 - 90A	Portable 1 Drinking Fountain	6/26/2016 4:11:00 AM	7/10/2016 4:41:00 PM	BB66813	Lead	84	15	ppb
073 - 91A	Portable 1 Bathroom Sink Faucet (1)	6/26/2016 4:13:00 AM	7/1/2016	BB66814	Copper	0.1	1.3	ppm
073 - 91A	Portable 1 Bathroom Sink Faucet (1)	6/26/2016 4:13:00 AM	7/1/2016	BB66814	Lead	56	15	ppb
073 - 92A	Portable 1 Bathroom Sink Faucet (2)	6/26/2016 4:15:00 AM	7/1/2016	BB66815	Copper	0.1	1.3	ppm
073 - 92A	Portable 1 Bathroom Sink Faucet (2)	6/26/2016 4:15:00 AM	7/1/2016	BB66815	Lead	73	15	ppb
073 - 93A	Porrrtable 2 Water Spigot	6/26/2016 4:17:00 AM	7/8/2016 10:16:00 AM	BB66816	Copper	0.1	1.3	ppm
073 - 93A	Portable 2 Water Spigot	6/26/2016 4:17:00 AM	7/8/2016 10:16:00 AM	BB66816	Lead	89	15	ppb
073 - 94A	Gymnasium Water Spigot	6/26/2016 4:29:00 AM	7/1/2016	BB66817	Copper	0.0	1.3	ppm
073 - 94A	Gymnasium Water Spigot	6/26/2016 4:29:00 AM	7/1/2016	BB66817	Lead	1	15	ppb
073 - 95A	Water Spigot by Basketball Court	6/26/2016 4:32:00 AM	7/8/2016 10:58:00 AM	BB66818	Copper	0.0	1.3	ppm
073 - 95A	Water Spigot by Basketball Court	6/26/2016 4:32:00 AM	7/8/2016 10:58:00 AM	BB66818	Lead	12	15	ppb
073 - 96A	Water Spigot on Side Street (1)	6/26/2016 4:35:00 AM	7/1/2016	BB66819	Copper	0.0	1.3	ppm
073 - 96A	Water Spigot on Side Street (1)	6/26/2016 4:35:00 AM	7/1/2016	BB66819	Lead	44	15	ppb
073 - 97A	Water Spigot on Side Street (2)	6/26/2016 4:38:00 AM	7/1/2016	BB66820	Copper	0.0	1.3	ppm
073 - 97A	Water Spigot on Side Street (2)	6/26/2016 4:38:00 AM	7/1/2016	BB66820	Lead	10	15	ppb
073 - 98A	Water Spigot near Library	6/26/2016 4:41:00 AM	7/1/2016	BB66821	Copper	0.1	1.3	ppm
073 - 98A	Water Spigot near Library	6/26/2016 4:41:00 AM	7/1/2016	BB66821	Lead	12	15	ppb
073 - 99A	Water Spigot to the Left of School Front	6/26/2016 4:44:00 AM	7/1/2016	BB66822	Copper	0.0	1.3	ppm
073 - 99A	Water Spigot to the Left of School Front	6/26/2016 4:44:00 AM	7/1/2016	BB66822	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Rigler Elementary School

Sample Identification # Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
073 - 100A Boiler Room Sink Faucet	6/26/2016 4:54:00 AM	7/1/2016	BB66823	Copper	0.0	1.3	ppm
073 - 100A Boiler Room Sink Faucet	6/26/2016 4:54:00 AM	7/1/2016	BB66823	Lead	2	15	ppb
073 - 28.1 A Room 13A Sink Faucet	6/26/2016 1:18:00 AM	7/1/2016	BB66824	Copper	0.0	1.3	ppm
073 - 28.1 A Room 13A Sink Faucet	6/26/2016 1:18:00 AM	7/1/2016	BB66824	Lead	10	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.