

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Roosevelt High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
075-01A 175F Custodian Sink	6/19/16 10:07	6/30/16 13:20	606221101	Copper	0.0	1.3	ppm
075-01A 175F Custodian Sink	6/19/16 10:07	6/30/16 13:20	606221101	Lead	2	15	ppb
075-02A 175E Bathroom Faucet	6/19/16 10:04	6/30/16 13:20	606221102	Copper	0.1	1.3	ppm
075-02A 175E Bathroom Faucet	6/19/16 10:04	6/30/16 13:20	606221102	Lead	2	15	ppb
075-03A 175F Kitchen H Sink Faucet	6/19/16 10:08	6/30/16 13:20	606221103	Copper	0.1	1.3	ppm
075-03A 175F Kitchen H Sink Faucet	6/19/16 10:08	6/30/16 13:20	606221103	Lead	17	15	ppb
075-04A 175 Kitchen Dish Sink Faucet 1	6/19/16 10:12	6/30/16 13:20	606221104	Copper	0.1	1.3	ppm
075-04A 175 Kitchen Dish Sink Faucet 1	6/19/16 10:12	6/30/16 13:20	606221104	Lead	2	15	ppb
075-05A 175 Kitchen Dish Sink Faucet 2	6/19/16 10:13	6/30/16 13:20	606221105	Copper	0.0	1.3	ppm
075-05A 175 Kitchen Dish Sink Faucet 2	6/19/16 10:13	6/30/16 13:20	606221105	Lead	7	15	ppb
075-06A 175 Kitchen Prep Sink 3	6/19/16 10:15	6/30/16 13:21	606221106	Copper	0.1	1.3	ppm
075-06A 175 Kitchen Prep Sink 3	6/19/16 10:15	6/30/16 13:21	606221106	Lead	15.4	15	ppb
075-08A 175 Kitchen Soup Sink	6/19/16 10:19	6/30/16 13:21	606221108	Copper	0.2	1.3	ppm
075-08A 175 Kitchen Soup Sink	6/19/16 10:19	6/30/16 13:21	606221108	Lead	144	15	ppb
075-09A 175 Kitchen Prep Table Sink Faucet	6/19/16 10:14	6/30/16 18:39	606221109	Copper	0.1	1.3	ppm
075-09A 175 Kitchen Prep Table Sink Faucet	6/19/16 10:14	6/30/16 18:39	606221109	Lead	672	15	ppb
075-10A Head Start Girls Bathroom Sink Faucet	6/19/16 10:19	6/30/16 13:24	606221110	Copper	0.2	1.3	ppm
075-10A Head Start Girls Bathroom Sink Faucet	6/19/16 10:19	6/30/16 13:24	606221110	Lead	8	15	ppb
075-11A Head Start Boys Bathroom Sink Faucet	6/19/16 10:19	7/6/16 10:02	606221111	Copper	16.8	1.3	ppm
075-11A Head Start Boys Bathroom Sink Faucet	6/19/16 10:19	6/30/16 18:39	606221111	Lead	1180	15	ppb
075-12A Head Start Play Rm Sink Faucet	6/19/16 10:22	6/30/16 13:24	606221112	Copper	0.4	1.3	ppm
075-12A Head Start Play Rm Sink Faucet	6/19/16 10:22	6/30/16 13:24	606221112	Lead	2	15	ppb
075-13A Head Start Play Rm Sink Faucet	6/19/16 10:22	6/30/16 13:24	606221113	Copper	0.3	1.3	ppm
075-13A Head Start Play Rm Sink Faucet	6/19/16 10:22	6/30/16 13:24	606221113	Lead	3	15	ppb
075-14A Head Start Kitchen Sink Faucet 1	6/19/16 10:24	6/30/16 13:24	606221114	Copper	0.2	1.3	ppm
075-14A Head Start Kitchen Sink Faucet 1	6/19/16 10:24	6/30/16 13:24	606221114	Lead	13	15	ppb
075-15A Head Start Kitchen Sink Faucet 2	6/19/16 10:26	6/30/16 13:24	606221115	Copper	0.4	1.3	ppm
075-15A Head Start Kitchen Sink Faucet 2	6/19/16 10:26	6/30/16 13:24	606221115	Lead	8	15	ppb
075-16A Head Start Sink Faucet 3	6/19/16 10:26	6/30/16 13:24	606221116	Copper	0.5	1.3	ppm
075-16A Head Start Sink Faucet 3	6/19/16 10:26	6/30/16 13:24	606221116	Lead	18	15	ppb
075-17A Head Start Toddler Rm Sink Faucet	6/19/16 10:25	6/30/16 13:24	606221117	Copper	0.2	1.3	ppm
075-17A Head Start Toddler Rm Sink Faucet	6/19/16 10:25	6/30/16 13:24	606221117	Lead	4	15	ppb
075-18A 171 Girls Bathroom Sink Faucet 1	6/19/16 10:29	6/30/16 13:24	606221118	Copper	0.1	1.3	ppm
075-18A 171 Girls Bathroom Sink Faucet 1	6/19/16 10:29	6/30/16 13:24	606221118	Lead	6	15	ppb
075-19A 171 Girls Bathroom Sink Faucet 2	6/19/16 10:32	6/30/16 13:24	606221119	Copper	0.1	1.3	ppm
075-19A 171 Girls Bathroom Sink Faucet 2	6/19/16 10:32	6/30/16 13:24	606221119	Lead	9	15	ppb
075-20A 171 Girls Bathroom Sink Faucet 3	6/19/16 10:34	6/30/16 13:24	606221120	Copper	0.2	1.3	ppm
075-20A 171 Girls Bathroom Sink Faucet 3	6/19/16 10:34	6/30/16 13:24	606221120	Lead	9	15	ppb
075-21A 171 Girls Bathroom Sink Faucet 4	6/19/16 10:36	6/30/16 13:25	606221121	Copper	0.1	1.3	ppm
075-21A 171 Girls Bathroom Sink Faucet 4	6/19/16 10:36	6/30/16 13:25	606221121	Lead	5	15	ppb
075-22A 172 Custodian Sink Faucet	6/19/16 10:45	6/30/16 13:25	606221122	Copper	0.1	1.3	ppm
075-22A 172 Custodian Sink Faucet	6/19/16 10:45	6/30/16 13:25	606221122	Lead	5	15	ppb
075-23A 172 Basement Sink Faucet 1	6/19/16 10:49	6/30/16 13:25	606221123	Copper	0.0	1.3	ppm
075-23A 172 Basement Sink Faucet 1	6/19/16 10:49	6/30/16 13:25	606221123	Copper	0.0	1.3	ppm
075-23A 172 Basement Sink Faucet 1	6/19/16 10:49	6/30/16 13:25	606221123	Lead	80	15	ppb
075-24A 172 Basement Sink Faucet 2	6/19/16 10:53	6/30/16 13:25	606221124	Copper	0.0	1.3	ppm
075-24A 172 Basement Sink Faucet 2	6/19/16 10:53	6/30/16 13:25	606221124	Lead	39	15	ppb
075-25A 172 Basement Sink Faucet 3	6/19/16 10:56	6/30/16 13:25	606221125	Copper	0.0	1.3	ppm
075-25A 172 Basement Sink Faucet 3	6/19/16 10:56	6/30/16 13:25	606221125	Lead	11	15	ppb
075-26A 172 Basement Sink Faucet 4	6/19/16 10:49	6/30/16 13:25	606221126	Copper	0.6	1.3	ppm
075-26A 172 Basement Sink Faucet 4	6/19/16 10:49	6/30/16 13:25	606221126	Lead	128	15	ppb
075-27A 173 Dish Room Sink Faucet 1	6/19/16 11:03	6/30/16 13:25	606221127	Copper	0.0	1.3	ppm
075-27A 173 Dish Room Sink Faucet 1	6/19/16 11:03	6/30/16 13:25	606221127	Lead	9	15	ppb
075-28A 173 Dish Sink Faucet 2	6/19/16 11:05	6/30/16 13:25	606221128	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Roosevelt High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
075-28A 173 Dish Sink Faucet 2	6/19/16 11:05	6/30/16 13:25	606221128	Lead	144	15	ppb
075-29A 173 Dish Sink Faucet 3	6/19/16 11:03	6/30/16 13:25	606221129	Copper	0.1	1.3	ppm
075-29A 173 Dish Sink Faucet 3	6/19/16 11:03	6/30/16 13:25	606221129	Lead	19	15	ppb
075-30A 173 Dish L Spigot	6/19/16 11:07	6/30/16 13:25	606221130	Copper	0.0	1.3	ppm
075-30A 173 Dish L Spigot	6/19/16 11:07	6/30/16 13:25	606221130	Lead	35	15	ppb
075-31A 170 Bathroom Sink Faucet 1	6/19/16 11:12	6/30/16 13:26	606221131	Copper	0.1	1.3	ppm
075-31A 170 Bathroom Sink Faucet 1	6/19/16 11:12	6/30/16 13:26	606221131	Lead	6	15	ppb
075-32A 170 Bathroom Sink Faucet 2	6/19/16 11:13	6/30/16 13:26	606221132	Copper	0.2	1.3	ppm
075-32A 170 Bathroom Sink Faucet 2	6/19/16 11:13	6/30/16 13:26	606221132	Lead	6	15	ppb
075-33A 170 Bathroom Sink Faucet 3	6/19/16 11:15	6/30/16 13:26	606221133	Copper	0.2	1.3	ppm
075-33A 170 Bathroom Sink Faucet 3	6/19/16 11:15	6/30/16 13:26	606221133	Lead	6	15	ppb
075-34A 170 Bathroom Sink Faucet 4	6/19/16 11:17	6/30/16 13:29	606221134	Copper	0.1	1.3	ppm
075-34A 170 Bathroom Sink Faucet 4	6/19/16 11:17	6/30/16 13:29	606221134	Lead	6	15	ppb
075-35A 111A Sink Faucet	6/19/16 11:19	6/30/16 13:29	606221135	Copper	0.0	1.3	ppm
075-35A 111A Sink Faucet	6/19/16 11:19	6/30/16 13:29	606221135	Lead	79	15	ppb
075-36A Hall Drinking Fountain by Nurses Office	6/19/16 11:21	6/30/16 13:29	606221136	Copper	0.0	1.3	ppm
075-36A Hall Drinking Fountain by Nurses Office	6/19/16 11:21	6/30/16 13:29	606221136	Lead	13	15	ppb
075-37A Nurses Office Sink Faucet	6/19/16 11:22	6/30/16 13:29	606221137	Copper	0.9	1.3	ppm
075-37A Nurses Office Sink Faucet	6/19/16 11:22	6/30/16 13:29	606221137	Lead	91	15	ppb
075-38A Janitor Closet Sink by Stairwell	6/19/16 11:24	6/30/16 13:29	606221138	Copper	0.3	1.3	ppm
075-38A Janitor Closet Sink by Stairwell	6/19/16 11:24	6/30/16 13:29	606221138	Lead	2	15	ppb
075-39A Staff Sink Faucet	6/19/16 11:25	6/30/16 13:29	606221139	Copper	0.3	1.3	ppm
075-39A Staff Sink Faucet	6/19/16 11:25	6/30/16 13:29	606221139	Lead	5	15	ppb
075-40A 121 Sink Faucet	6/19/16 11:26	6/30/16 13:29	606221140	Copper	0.2	1.3	ppm
075-40A 121 Sink Faucet	6/19/16 11:26	6/30/16 13:29	606221140	Lead	10	15	ppb
075-41A Hall Drinking Fountain	6/19/16 11:28	6/30/16 13:29	606221141	Copper	0.7	1.3	ppm
075-41A Hall Drinking Fountain	6/19/16 11:28	6/30/16 13:29	606221141	Lead	ND	15	ppb
075-43A Boys Bathroom Sink Faucet 2	6/19/16 11:29	6/30/16 13:29	606221142	Copper	0.2	1.3	ppm
075-43A Boys Bathroom Sink Faucet 2	6/19/16 11:29	6/30/16 13:29	606221142	Lead	7	15	ppb
075-44A Boys Bathroom Sink Faucet 3	6/19/16 11:29	6/30/16 18:39	606221143	Copper	1.3	1.3	ppm
075-44A Boys Bathroom Sink Faucet 3	6/19/16 11:29	6/30/16 18:39	606221143	Lead	101	15	ppb
075-46A Boys Bathroom Spigot	6/19/16 11:35	6/30/16 13:29	606221144	Copper	0.4	1.3	ppm
075-46A Boys Bathroom Spigot	6/19/16 11:35	6/30/16 13:29	606221144	Lead	212	15	ppb
075-47A 129 Sink Faucet 1	6/19/16 11:44	6/30/16 13:29	606221145	Copper	0.0	1.3	ppm
075-47A 129 Sink Faucet 1	6/19/16 11:44	6/30/16 13:29	606221145	Lead	49	15	ppb
075-48A 129 Sink Faucet 2	6/19/16 11:45	6/30/16 13:29	606221146	Copper	0.1	1.3	ppm
075-48A 129 Sink Faucet 2	6/19/16 11:45	6/30/16 13:29	606221146	Lead	68	15	ppb
075-49A 129 Sink Faucet 3	6/19/16 11:47	6/30/16 13:29	606221147	Copper	0.0	1.3	ppm
075-49A 129 Sink Faucet 3	6/19/16 11:47	6/30/16 13:29	606221147	Lead	41	15	ppb
075-50A 129 Sink Faucet 4	6/19/16 11:45	6/30/16 13:29	606221148	Copper	0.0	1.3	ppm
075-50A 129 Sink Faucet 4	6/19/16 11:45	6/30/16 13:29	606221148	Lead	45	15	ppb
075-51A 129 Sink Faucet 5	6/19/16 11:45	6/30/16 13:29	606221149	Copper	0.0	1.3	ppm
075-51A 129 Sink Faucet 5	6/19/16 11:45	6/30/16 13:29	606221149	Lead	21	15	ppb
075-52A 129 Drinking Fountain	6/19/16 11:46	6/30/16 13:29	606221150	Copper	0.0	1.3	ppm
075-52A 129 Drinking Fountain	6/19/16 11:46	6/30/16 13:29	606221150	Lead	12	15	ppb
075-53A 131 Sink Faucet	6/19/16 11:51	6/30/16 13:29	606221151	Copper	0.1	1.3	ppm
075-53A 131 Sink Faucet	6/19/16 11:51	6/30/16 13:29	606221151	Lead	18	15	ppb
075-54A 130 Bathroom Sink Faucet	6/19/16 11:57	6/30/16 13:30	606221152	Copper	0.2	1.3	ppm
075-54A 130 Bathroom Sink Faucet	6/19/16 11:57	6/30/16 13:30	606221152	Lead	23	15	ppb
075-55A 130 Sink Faucet	6/19/16 11:59	6/30/16 13:30	606221153	Copper	0.2	1.3	ppm
075-55A 130 Sink Faucet	6/19/16 11:59	6/30/16 13:30	606221153	Lead	15.1	15	ppb
075-56A 128 Sink Faucet 1	6/19/16 11:58	6/30/16 13:30	606221154	Copper	0.1	1.3	ppm
075-56A 128 Sink Faucet 1	6/19/16 11:58	6/30/16 13:30	606221154	Lead	7	15	ppb
075-57A 128 Sink Faucet 2	6/19/16 11:58	6/30/16 13:30	606221155	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Roosevelt High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
075-57A 128 Sink Faucet 2	6/19/16 11:58	6/30/16 13:30	606221155	Lead	8	15	ppb
075-58A 128 Sink Faucet 3	6/19/16 11:58	6/30/16 13:30	606221156	Copper	0.1	1.3	ppm
075-58A 128 Sink Faucet 3	6/19/16 11:58	6/30/16 13:30	606221156	Lead	6	15	ppb
075-59A 128 Sink Faucet 4	6/19/16 11:59	6/30/16 13:30	606221157	Copper	0.1	1.3	ppm
075-59A 128 Sink Faucet 4	6/19/16 11:59	6/30/16 13:30	606221157	Lead	12	15	ppb
075-60A 128 Drinking Fountain	6/19/16 12:01	6/30/16 13:30	606221158	Copper	0.2	1.3	ppm
075-60A 128 Drinking Fountain	6/19/16 12:01	6/30/16 13:30	606221158	Lead	40	15	ppb
075-61A Stairwell Girls Bathroom Sink Faucet	6/19/16 11:55	6/30/16 13:30	606221159	Copper	0.2	1.3	ppm
075-61A Stairwell Girls Bathroom Sink Faucet	6/19/16 11:55	6/30/16 13:30	606221159	Lead	42	15	ppb
075-62A Stairwell Boys Bathroom Sink Faucet	6/19/16 11:55	6/30/16 13:30	606221160	Copper	0.1	1.3	ppm
075-62A Stairwell Boys Bathroom Sink Faucet	6/19/16 11:55	6/30/16 13:30	606221160	Lead	12	15	ppb
075-63A Girls Bathroom by 111 Spigot	6/19/16 12:07	6/30/16 18:39	606221161	Copper	0.1	1.3	ppm
075-63A Girls Bathroom by 111 Spigot	6/19/16 12:07	6/30/16 18:39	606221161	Lead	253	15	ppb
075-64A Girls Bathroom Sink Faucet 1	6/19/16 12:07	6/30/16 13:30	606221162	Copper	0.2	1.3	ppm
075-64A Girls Bathroom Sink Faucet 1	6/19/16 12:07	6/30/16 13:30	606221162	Lead	6	15	ppb
075-65A Girls Bathroom Sink Faucet 2	6/19/16 12:08	6/30/16 13:32	606221163	Copper	0.1	1.3	ppm
075-65A Girls Bathroom Sink Faucet 2	6/19/16 12:08	6/30/16 13:32	606221163	Lead	18	15	ppb
075-66A Girls Bathroom Sink Faucet 3	6/19/16 12:08	6/30/16 13:32	606221164	Copper	0.2	1.3	ppm
075-66A Girls Bathroom Sink Faucet 3	6/19/16 12:08	6/30/16 13:32	606221164	Lead	9	15	ppb
075-67A Girls Bathroom Sink Faucet 4	6/19/16 12:11	6/30/16 13:32	606221165	Copper	0.2	1.3	ppm
075-67A Girls Bathroom Sink Faucet 4	6/19/16 12:11	6/30/16 13:32	606221165	Lead	6	15	ppb
075-68A Girls Bathroom Sink Faucet 5	6/19/16 12:12	7/1/16 16:07	606221166	Copper	1.9	1.3	ppm
075-68A Girls Bathroom Sink Faucet 5	6/19/16 12:12	6/30/16 13:33	606221166	Lead	56	15	ppb
075-69A Girls Bathroom Sink Faucet 6	6/19/16 12:10	6/30/16 13:33	606221167	Copper	0.2	1.3	ppm
075-69A Girls Bathroom Sink Faucet 6	6/19/16 12:10	6/30/16 13:33	606221167	Lead	9	15	ppb
075-70A Girls Bathroom Sink Faucet 7	6/19/16 12:10	6/30/16 13:33	606221168	Copper	0.2	1.3	ppm
075-70A Girls Bathroom Sink Faucet 7	6/19/16 12:10	6/30/16 13:33	606221168	Lead	9	15	ppb
075-71A Head Start Drinking Fountain	6/19/16 10:30	6/30/16 13:33	606221169	Copper	0.0	1.3	ppm
075-71A Head Start Drinking Fountain	6/19/16 10:30	6/30/16 13:33	606221169	Lead	6	15	ppb
075-72A Cafe Drinking Fountain 1	6/19/16 10:45	6/30/16 13:33	606221170	Copper	0.0	1.3	ppm
075-72A Cafe Drinking Fountain 1	6/19/16 10:45	6/30/16 13:33	606221170	Lead	12	15	ppb
075-73A Cafe Drinking Fountain 2	6/19/16 10:47	6/30/16 13:33	606221171	Copper	0.0	1.3	ppm
075-73A Cafe Drinking Fountain 2	6/19/16 10:47	6/30/16 13:33	606221171	Lead	14	15	ppb
075-74A 175 Kitchen Prep Sink 4	6/19/16 10:17	6/30/16 13:21	606221107	Copper	0.1	1.3	ppm
075-74A 175 Kitchen Prep Sink 4	6/19/16 10:17	6/30/16 13:21	606221107	Lead	23	15	ppb
075-74A Basement 2 Sink Faucet	6/19/16 12:19	6/30/16 13:34	606221172	Copper	0.0	1.3	ppm
075-74A Basement 2 Sink Faucet	6/19/16 12:19	6/30/16 13:34	606221172	Lead	5	15	ppb
075-75A Basement 2 Sink Faucet	6/19/16 12:19	6/30/16 13:54	6062211129	Copper	0.1	1.3	ppm
075-75A Basement 2 Sink Faucet	6/19/16 12:19	6/30/16 13:54	6062211129	Lead	62	15	ppb
075-76A Basement 2 Drinking Fountain	6/19/16 12:21	6/30/16 13:37	606221173	Copper	0.0	1.3	ppm
075-76A Basement 2 Drinking Fountain	6/19/16 12:21	6/30/16 13:37	606221173	Lead	3	15	ppb
075-77A Basement 3 Sink Faucet	6/19/16 12:25	6/30/16 13:37	606221174	Copper	0.1	1.3	ppm
075-77A Basement 3 Sink Faucet	6/19/16 12:25	6/30/16 13:37	606221174	Lead	8	15	ppb
075-78A Basement 3 Drinking Fountain	6/19/16 12:25	6/30/16 13:38	606221175	Copper	0.0	1.3	ppm
075-78A Basement 3 Drinking Fountain	6/19/16 12:25	6/30/16 13:38	606221175	Lead	3	15	ppb
075-79A Basement 4 Sink Faucet	6/19/16 12:28	6/30/16 13:38	606221176	Copper	0.1	1.3	ppm
075-79A Basement 4 Sink Faucet	6/19/16 12:28	6/30/16 13:38	606221176	Lead	21	15	ppb
075-80A Basement 6 Sink Faucet 1	6/19/16 12:24	6/30/16 13:38	606221177	Copper	0.1	1.3	ppm
075-80A Basement 6 Sink Faucet 1	6/19/16 12:24	6/30/16 13:38	606221177	Lead	74	15	ppb
075-81A Basement 6 Sink Faucet 2	6/19/16 12:26	6/30/16 13:38	606221178	Copper	0.1	1.3	ppm
075-81A Basement 6 Sink Faucet 2	6/19/16 12:26	6/30/16 13:38	606221178	Lead	19	15	ppb
075-82A Basement 6 Sink Faucet 3	6/19/16 12:27	7/6/16 10:02	606221179	Copper	14.3	1.3	ppm
075-82A Basement 6 Sink Faucet 3	6/19/16 12:27	6/30/16 18:40	606221179	Lead	176	15	ppb
075-83A 231 Sink Faucet	6/19/16 12:35	6/30/16 13:38	606221180	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Roosevelt High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
075-83A 231 Sink Faucet	6/19/16 12:35	6/30/16 13:38	606221180	Lead	4	15	ppb
075-84A 230 Sink Faucet	6/19/16 12:36	6/30/16 13:38	606221181	Copper	0.1	1.3	ppm
075-84A 230 Sink Faucet	6/19/16 12:36	6/30/16 13:38	606221181	Lead	14	15	ppb
075-85A 228 Sink Faucet	6/19/16 12:36	6/30/16 13:38	606221182	Copper	0.1	1.3	ppm
075-85A 228 Sink Faucet	6/19/16 12:36	6/30/16 13:38	606221182	Lead	8	15	ppb
075-87A Girls Bathroom Sink Faucet 1	6/19/16 12:41	6/30/16 13:38	606221183	Copper	0.1	1.3	ppm
075-87A Girls Bathroom Sink Faucet 1	6/19/16 12:41	6/30/16 13:38	606221183	Lead	6	15	ppb
075-88A Girls Bathroom Sink Faucet 2	6/19/16 12:41	7/1/16 16:07	606221184	Copper	0.5	1.3	ppm
075-88A Girls Bathroom Sink Faucet 2	6/19/16 12:41	6/30/16 13:40	606221184	Lead	49	15	ppb
075-89A Girls Bathroom Sink Faucet 3	6/19/16 12:42	6/30/16 13:40	606221185	Copper	0.2	1.3	ppm
075-89A Girls Bathroom Sink Faucet 3	6/19/16 12:42	6/30/16 13:40	606221185	Lead	5	15	ppb
075-90A Girls Bathroom Sink Faucet 4	6/19/16 12:42	6/30/16 13:40	606221186	Copper	0.1	1.3	ppm
075-90A Girls Bathroom Sink Faucet 4	6/19/16 12:42	6/30/16 13:40	606221186	Lead	4	15	ppb
075-91A Girls Bathroom Sink Faucet 5	6/19/16 12:44	6/30/16 13:41	606221187	Copper	0.2	1.3	ppm
075-91A Girls Bathroom Sink Faucet 5	6/19/16 12:44	6/30/16 13:41	606221187	Lead	7	15	ppb
075-92A Boys Bathroom Sink Faucet 1	6/19/16 12:47	6/30/16 13:41	606221188	Copper	0.1	1.3	ppm
075-92A Boys Bathroom Sink Faucet 1	6/19/16 12:47	6/30/16 13:41	606221188	Lead	7	15	ppb
075-93A Boys Bathroom Sink Faucet 2	6/19/16 12:47	6/30/16 13:41	606221189	Copper	0.1	1.3	ppm
075-93A Boys Bathroom Sink Faucet 2	6/19/16 12:47	6/30/16 13:41	606221189	Lead	5	15	ppb
075-94A Boys Bathroom Sink Faucet 3	6/19/16 12:49	6/30/16 13:41	606221190	Copper	0.2	1.3	ppm
075-94A Boys Bathroom Sink Faucet 3	6/19/16 12:49	6/30/16 13:41	606221190	Lead	5	15	ppb
075-95A Boys Bathroom Sink Faucet 4	6/19/16 12:51	6/30/16 13:41	606221191	Copper	0.1	1.3	ppm
075-95A Boys Bathroom Sink Faucet 4	6/19/16 12:51	6/30/16 13:41	606221191	Lead	3	15	ppb
075-96A Boys Bathroom Sink Faucet 5	6/19/16 12:47	6/30/16 13:42	606221192	Copper	0.2	1.3	ppm
075-96A Boys Bathroom Sink Faucet 5	6/19/16 12:47	6/30/16 13:42	606221192	Lead	27	15	ppb
075-97A Boys Bathroom Sink Faucet 6	6/19/16 12:51	6/30/16 13:42	606221193	Copper	0.1	1.3	ppm
075-97A Boys Bathroom Sink Faucet 6	6/19/16 12:51	6/30/16 13:42	606221193	Lead	21	15	ppb
075-98A Boys Bathroom Spigot	6/19/16 12:55	7/1/16 17:18	606221194	Copper	0.6	1.3	ppm
075-98A Boys Bathroom Spigot	6/19/16 12:55	6/30/16 13:44	606221194	Lead	58	15	ppb
075-99A 220 Sink Faucet	6/19/16 12:57	6/30/16 13:45	606221195	Copper	0.1	1.3	ppm
075-99A 220 Sink Faucet	6/19/16 12:57	6/30/16 13:45	606221195	Lead	9	15	ppb
075-106A 211 Sink Faucet 1	6/19/16 12:57	6/30/16 13:45	606221196	Copper	0.2	1.3	ppm
075-106A 211 Sink Faucet 1	6/19/16 12:57	6/30/16 13:45	606221196	Lead	14	15	ppb
075-107A 211 Sink Faucet 2	6/19/16 12:57	6/30/16 13:46	606221197	Copper	0.1	1.3	ppm
075-107A 211 Sink Faucet 2	6/19/16 12:57	6/30/16 13:46	606221197	Lead	29	15	ppb
075-108A 263 Cust Sink Faucet	6/19/16 12:51	6/30/16 13:46	606221198	Copper	0.1	1.3	ppm
075-108A 263 Cust Sink Faucet	6/19/16 12:51	6/30/16 13:46	606221198	Lead	21	15	ppb
075-109A L158 Restroom Sink Faucet	6/19/16 12:56	6/30/16 13:46	606221199	Copper	0.1	1.3	ppm
075-109A L158 Restroom Sink Faucet	6/19/16 12:56	6/30/16 13:46	606221199	Lead	3	15	ppb
075-110A L160 Sink Faucet	6/19/16 13:01	6/30/16 13:46	6062211100	Copper	0.1	1.3	ppm
075-110A L160 Sink Faucet	6/19/16 13:01	6/30/16 13:46	6062211100	Lead	18	15	ppb
075-111A L160 Sink Faucet	6/19/16 12:01	6/30/16 13:46	6062211101	Copper	0.1	1.3	ppm
075-111A L160 Sink Faucet	6/19/16 12:01	6/30/16 13:46	6062211101	Lead	20	15	ppb
075-112A L161 Sink Faucet	6/19/16 13:01	6/30/16 13:46	6062211102	Copper	0.2	1.3	ppm
075-112A L161 Sink Faucet	6/19/16 13:01	6/30/16 13:46	6062211102	Lead	18	15	ppb
075-113A L161A Sink Faucet	6/19/16 13:01	6/30/16 13:46	6062211103	Copper	0.0	1.3	ppm
075-113A L161A Sink Faucet	6/19/16 13:01	6/30/16 13:46	6062211103	Lead	33	15	ppb
075-114A Girls Bathroom Spigot	6/19/16 13:03	6/30/16 13:48	6062211104	Copper	0.1	1.3	ppm
075-114A Girls Bathroom Spigot	6/19/16 13:03	6/30/16 13:48	6062211104	Lead	22	15	ppb
075-115A Girls Bathroom Sink Faucet 1	6/19/16 13:03	6/30/16 13:48	6062211105	Copper	0.2	1.3	ppm
075-115A Girls Bathroom Sink Faucet 1	6/19/16 13:03	6/30/16 13:48	6062211105	Lead	8	15	ppb
075-116A Girls Bathroom Sink Faucet 2	6/19/16 13:03	6/30/16 13:48	6062211106	Copper	0.2	1.3	ppm
075-116A Girls Bathroom Sink Faucet 2	6/19/16 13:03	6/30/16 13:48	6062211106	Lead	7	15	ppb
075-117A Girls Bathroom Sink Faucet 3	6/19/16 13:03	6/30/16 13:48	6062211107	Copper	0.2	1.3	ppm
075-117A Girls Bathroom Sink Faucet 3	6/19/16 13:03	6/30/16 13:48	6062211107	Lead	15.4	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Roosevelt High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
075-118A L163 Janitor Closet Sink Faucet	6/19/16 13:00	6/30/16 13:48	6062211108	Copper	0.0	1.3	ppm
075-118A L163 Janitor Closet Sink Faucet	6/19/16 13:00	6/30/16 13:48	6062211108	Lead	7	15	ppb
075-119A Boys Bathroom Sink Faucet 1	6/19/16 13:02	6/30/16 13:48	6062211109	Copper	0.1	1.3	ppm
075-119A Boys Bathroom Sink Faucet 1	6/19/16 13:02	6/30/16 13:48	6062211109	Lead	7	15	ppb
075-120A Boys Bathroom Sink Faucet 2	6/19/16 13:02	6/30/16 13:49	6062211110	Copper	0.2	1.3	ppm
075-120A Boys Bathroom Sink Faucet 2	6/19/16 13:02	6/30/16 13:49	6062211110	Lead	7	15	ppb
075-121A Boys Bathroom Sink Faucet 3	6/19/16 13:02	6/30/16 13:54	6062211130	Copper	0.1	1.3	ppm
075-121A Boys Bathroom Sink Faucet 3	6/19/16 13:02	6/30/16 13:54	6062211130	Lead	7	15	ppb
075-122A Boys Bathroom Sink Faucet 4	6/19/16 13:03	6/30/16 13:49	6062211111	Copper	0.2	1.3	ppm
075-122A Boys Bathroom Sink Faucet 4	6/19/16 13:03	6/30/16 13:49	6062211111	Lead	17	15	ppb
075-123A Boys Bathroom Sink Faucet 5	6/19/16 13:03	6/30/16 13:49	6062211112	Copper	0.1	1.3	ppm
075-123A Boys Bathroom Sink Faucet 5	6/19/16 13:03	6/30/16 13:49	6062211112	Lead	5	15	ppb
075-125A Hall Drinking Fountain	6/19/16 13:06	6/30/16 13:49	6062211113	Copper	0.0	1.3	ppm
075-125A Hall Drinking Fountain	6/19/16 13:06	6/30/16 13:49	6062211113	Lead	10	15	ppb
075-126A L166 Sink Faucet	6/19/16 13:08	6/30/16 13:51	6062211114	Copper	0.1	1.3	ppm
075-126A L166 Sink Faucet	6/19/16 13:08	6/30/16 13:51	6062211114	Lead	12	15	ppb
075-127A Lib L167 Drinking Fountain	6/19/16 13:08	6/30/16 13:51	6062211115	Copper	0.0	1.3	ppm
075-127A Lib L167 Drinking Fountain	6/19/16 13:08	6/30/16 13:51	6062211115	Lead	6	15	ppb
075-128A L165 Sink Faucet	6/19/16 13:08	6/30/16 13:51	6062211116	Copper	0.0	1.3	ppm
075-128A L165 Sink Faucet	6/19/16 13:08	6/30/16 13:51	6062211116	Lead	5	15	ppb
075-129A L165A Sink Faucet	6/19/16 13:10	6/30/16 13:51	6062211117	Copper	0.1	1.3	ppm
075-129A L165A Sink Faucet	6/19/16 13:10	6/30/16 13:51	6062211117	Lead	13	15	ppb
075-130A L248 Janitor Closet Sink Faucet	6/19/16 13:12	6/30/16 13:51	6062211118	Copper	0.0	1.3	ppm
075-130A L248 Janitor Closet Sink Faucet	6/19/16 13:12	6/30/16 13:51	6062211118	Lead	78	15	ppb
075-131A Exterior Spigot by Audio Storage	6/19/16 13:29	6/30/16 13:51	6062211119	Copper	0.1	1.3	ppm
075-131A Exterior Spigot by Audio Storage	6/19/16 13:29	6/30/16 13:51	6062211119	Lead	27	15	ppb
075-132A Exterior Spigot Corner from Main Office	6/19/16 13:29	6/30/16 13:51	6062211120	Copper	0.0	1.3	ppm
075-132A Exterior Spigot Corner from Main Office	6/19/16 13:29	6/30/16 13:51	6062211120	Lead	12	15	ppb
075-133A Main Out 2	6/19/16 13:31	6/30/16 13:51	6062211121	Copper	0.1	1.3	ppm
075-133A Main Out 2	6/19/16 13:31	6/30/16 13:51	6062211121	Lead	9	15	ppb
075-134A Exterior Spigot by Main Entrance 3	6/19/16 13:33	6/30/16 13:51	6062211122	Copper	0.2	1.3	ppm
075-134A Exterior Spigot by Main Entrance 3	6/19/16 13:33	6/30/16 13:51	6062211122	Lead	29	15	ppb
075-135A Exterior Spigot 4	6/19/16 13:35	6/30/16 13:51	6062211123	Copper	0.1	1.3	ppm
075-135A Exterior Spigot 4	6/19/16 13:35	6/30/16 13:51	6062211123	Lead	229	15	ppb
075-136A Exterior Spigot 5	6/19/16 13:37	6/30/16 13:54	6062211124	Copper	0.0	1.3	ppm
075-136A Exterior Spigot 5	6/19/16 13:37	6/30/16 13:54	6062211124	Lead	5	15	ppb
075-137A Exterior Spigot 6	6/19/16 13:41	6/30/16 18:40	6062211125	Copper	1.2	1.3	ppm
075-137A Exterior Spigot 6	6/19/16 13:41	6/30/16 18:40	6062211125	Lead	3170	15	ppb
075-138A Exterior Spigot 7	6/19/16 13:42	6/30/16 13:54	6062211126	Copper	0.1	1.3	ppm
075-138A Exterior Spigot 7	6/19/16 13:42	6/30/16 13:54	6062211126	Lead	17	15	ppb
075-139A Exterior Spigot 8	6/19/16 13:45	6/30/16 13:54	6062211127	Copper	0.0	1.3	ppm
075-139A Exterior Spigot 8	6/19/16 13:45	6/30/16 13:54	6062211127	Lead	5	15	ppb
075-140A Exterior Spigot 9 Court Yard	6/19/16 13:47	6/30/16 13:54	6062211128	Copper	0.1	1.3	ppm
075-140A Exterior Spigot 9 Court Yard	6/19/16 13:47	6/30/16 13:54	6062211128	Lead	9	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.