

Portland Public Schools
Lead and Copper Water Sample Results
A (First Draw) Sample Data
Roseway Heights School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
077-01A Room 170 East Lab Sink	6/26/2016 18:06	7/7/2016 00:33	10353872001	Copper	0.2	1.3	ppm
077-01A Room 170 East Lab Sink	6/26/2016 18:06	7/7/2016 00:33	10353872001	Lead	0	15	ppb
077-02A Room 123 Sink	6/26/2016 18:11	7/7/2016 08:29	10353872003	Copper	0.3	1.3	ppm
077-02A Room 123 Sink	6/26/2016 18:11	7/7/2016 08:29	10353872003	Lead	2	15	ppb
077-03A Room 132 Boiler Room	6/26/2016 18:15	7/7/2016 08:33	10353872005	Copper	0.3	1.3	ppm
077-03A Room 132 Boiler Room	6/26/2016 18:15	7/7/2016 08:33	10353872005	Lead	1	15	ppb
077-04A Room 129 Drinking Fountain	6/26/2016 18:17	7/8/2016 10:13	10353872007	Copper	1.8	1.3	ppm
077-04A Room 129 Drinking Fountain	6/26/2016 18:17	7/8/2016 10:11	10353872007	Lead	13	15	ppb
077-05A Room 129 Sink (1)	6/26/2016 18:21	7/7/2016 08:34	10353872009	Copper	0.2	1.3	ppm
077-05A Room 129 Sink (1)	6/26/2016 18:21	7/7/2016 08:34	10353872009	Lead	2	15	ppb
077-06A Room 129 Sink (2)	6/26/2016 18:21	7/7/2016 08:36	10353872011	Copper	0.3	1.3	ppm
077-06A Room 129 Sink (2)	6/26/2016 18:21	7/7/2016 08:36	10353872011	Lead	2	15	ppb
077-07A Hallway by 129 Drinking Fountain	6/26/2016 18:26	7/8/2016 07:30	10353872013	Copper	1.1	1.3	ppm
077-07A Hallway by 129 Drinking Fountain	6/26/2016 18:26	7/7/2016 17:03	10353872013	Lead	4	15	ppb
077-08A Kitchen Room 124 Scullery	6/26/2016 18:29	7/7/2016 08:37	10353872015	Copper	0.1	1.3	ppm
077-08A Kitchen Room 124 Scullery	6/26/2016 18:29	7/7/2016 08:37	10353872015	Lead	2	15	ppb
077-09A Kitchen Food Preparation Sink	6/26/2016 18:29	7/7/2016 08:38	10353872017	Copper	0.4	1.3	ppm
077-09A Kitchen Food Preparation Sink	6/26/2016 18:29	7/7/2016 08:38	10353872017	Lead	3	15	ppb
077-10A Kitchen Room 125 Sink	6/26/2016 18:32	7/7/2016 11:16	10353872019	Copper	0.6	1.3	ppm
077-10A Kitchen Room 125 Sink	6/26/2016 18:32	7/7/2016 08:40	10353872019	Lead	11	15	ppb
077-11A Kitchen Room 124C Restroom Sink	6/26/2016 18:32	7/7/2016 08:41	10353872021	Copper	0.3	1.3	ppm
077-11A Kitchen Room 124C Restroom Sink	6/26/2016 18:32	7/7/2016 08:41	10353872021	Lead	4	15	ppb
077-12A Room 122 Sink	6/26/2016 18:41	7/7/2016 08:42	10353872023	Copper	0.4	1.3	ppm
077-12A Room 122 Sink	6/26/2016 18:41	7/7/2016 08:42	10353872023	Lead	9	15	ppb
077-13A Room 125 Sink	6/26/2016 18:46	7/7/2016 08:45	10353872025	Copper	0.4	1.3	ppm
077-13A Room 125 Sink	6/26/2016 18:46	7/7/2016 08:45	10353872025	Lead	4	15	ppb
077-14A Room 116 Custodian Sink	6/26/2016 18:38	7/7/2016 08:49	10353872027	Copper	0.4	1.3	ppm
077-14A Room 116 Custodian Sink	6/26/2016 18:38	7/7/2016 08:49	10353872027	Lead	18	15	ppb
077-15A Room 110 Sink North	6/26/2016 18:49	7/7/2016 11:17	10353872029	Copper	0.4	1.3	ppm

Portland Public Schools
Lead and Copper Water Sample Results
A (First Draw) Sample Data
Roseway Heights School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
077-15A Room 110 Sink North	6/26/2016 18:49	7/7/2016 08:51	10353872029	Lead	6	15	ppb
077-16A Room 110 Sink South	6/26/2016 18:52	7/7/2016 08:52	10353872031	Copper	0.3	1.3	ppm
077-16A Room 110 Sink South	6/26/2016 18:52	7/7/2016 08:52	10353872031	Lead	2	15	ppb
077-17A Faculty Restroom	6/26/2016 18:50	7/7/2016 08:53	10353872033	Copper	0.3	1.3	ppm
077-17A Faculty Restroom	6/26/2016 18:50	7/7/2016 08:53	10353872033	Lead	30	15	ppb
077-18A Boys Restroom 106 South Sink	6/26/2016 18:53	7/7/2016 08:55	10353872035	Copper	0.4	1.3	ppm
077-18A Boys Restroom 106 South Sink	6/26/2016 18:53	7/7/2016 08:55	10353872035	Lead	2	15	ppb
077-19A Boys Restroom 106 North Sink	6/26/2016 18:55	7/7/2016 17:05	10353872037	Copper	0.2	1.3	ppm
077-19A Boys Restroom 106 North Sink	6/26/2016 18:55	7/7/2016 17:05	10353872037	Lead	1	15	ppb
077-20A Room 103 Sink	6/26/2016 18:59	7/7/2016 11:19	10353872039	Copper	0.9	1.3	ppm
077-20A Room 103 Sink	6/26/2016 18:59	7/7/2016 08:56	10353872039	Lead	8	15	ppb
077-21A By Room 103 Drinking Fountain	6/26/2016 19:02	7/7/2016 01:13	10353872041	Copper	0.1	1.3	ppm
077-21A By Room 103 Drinking Fountain	6/26/2016 19:02	7/7/2016 01:13	10353872041	Lead	2	15	ppb
077-22A Room 104 Custodian Sink	6/26/2016 19:03	7/7/2016 01:19	10353872043	Copper	0.2	1.3	ppm
077-22A Room 104 Custodian Sink	6/26/2016 19:03	7/7/2016 01:19	10353872043	Lead	4	15	ppb
077-23A Nurse Room 102C Sink	6/26/2016 19:05	7/7/2016 01:20	10353872045	Copper	0.2	1.3	ppm
077-23A Nurse Room 102C Sink	6/26/2016 19:05	7/7/2016 01:20	10353872045	Lead	1	15	ppb
077-24A Hallway Drinking Fountain by Room 191	6/26/2016 19:10	7/7/2016 01:21	10353872047	Copper	0.2	1.3	ppm
077-24A Hallway Drinking Fountain by Room 191	6/26/2016 19:10	7/7/2016 01:21	10353872047	Lead	2	15	ppb
077-25A Custodial Sink Under West Stairs	6/26/2016 19:13	7/7/2016 11:07	10353872049	Copper	0.8	1.3	ppm
077-25A Custodial Sink Under West Stairs	6/26/2016 19:13	7/7/2016 01:23	10353872049	Lead	11	15	ppb
077-26A Room 109 Sink South	6/26/2016 19:09	7/7/2016 08:58	10353872051	Copper	0.3	1.3	ppm
077-26A Room 109 Sink South	6/26/2016 19:09	7/7/2016 08:58	10353872051	Lead	91	15	ppb
077-27A Room 109 Sink Northeast	6/26/2016 19:11	7/7/2016 17:06	10353872053	Copper	0.4	1.3	ppm
077-27A Room 109 Sink Northeast	6/26/2016 19:11	7/7/2016 17:06	10353872053	Lead	17	15	ppb
077-28A Boys Restroom West South	6/26/2016 19:22	7/7/2016 08:59	10353872055	Copper	0.2	1.3	ppm
077-28A Boys Restroom West South	6/26/2016 19:22	7/7/2016 08:59	10353872055	Lead	5	15	ppb
077-29A Boys Restroom West North	6/26/2016 19:24	7/7/2016 09:01	10353872057	Copper	0.4	1.3	ppm
077-29A Boys Restroom West North	6/26/2016 19:24	7/7/2016 09:01	10353872057	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sample Results
A (First Draw) Sample Data
Roseway Heights School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
077-30A Faculty Restroom West	6/26/2016 19:15	7/7/2016 09:02	10353872059	Copper	0.2	1.3	ppm
077-30A Faculty Restroom West	6/26/2016 19:15	7/7/2016 09:02	10353872059	Lead	6	15	ppb
077-31A Girls Restroom West (1)	6/26/2016 19:17	7/7/2016 09:07	10353872061	Copper	0.3	1.3	ppm
077-31A Girls Restroom West (1)	6/26/2016 19:17	7/7/2016 09:07	10353872061	Lead	3	15	ppb
077-32A Girls Restroom West (2)	6/26/2016 19:19	7/7/2016 09:09	10353872063	Copper	0.3	1.3	ppm
077-32A Girls Restroom West (2)	6/26/2016 19:19	7/7/2016 09:09	10353872063	Lead	5	15	ppb
077-33A Room 187 East	6/26/2016 19:18	7/7/2016 11:20	10353872065	Copper	0.6	1.3	ppm
077-33A Room 187 East	6/26/2016 19:18	7/7/2016 09:12	10353872065	Lead	15.0	15	ppb
077-34A Room 184 Sink North	6/26/2016 19:21	7/7/2016 09:14	10353872067	Copper	0.4	1.3	ppm
077-34A Room 184 Sink North	6/26/2016 19:21	7/7/2016 09:14	10353872067	Lead	9	15	ppb
077-35A Room 184 Drinking Fountain	6/26/2016 19:22	7/7/2016 09:15	10353872069	Copper	0.1	1.3	ppm
077-35A Room 184 Drinking Fountain	6/26/2016 19:22	7/7/2016 09:15	10353872069	Lead	7	15	ppb
077-36A Room 184B Restroom Sink	6/26/2016 19:27	7/7/2016 11:21	10353872071	Copper	1.9	1.3	ppm
077-36A Room 184B Restroom Sink	6/26/2016 19:27	7/7/2016 09:17	10353872071	Lead	23	15	ppb
077-37A Room 185 Sink Northwest (1)	6/26/2016 19:31	7/7/2016 11:23	10353872073	Copper	0.7	1.3	ppm
077-37A Room 185 Sink Northwest (1)	6/26/2016 19:31	7/7/2016 09:18	10353872073	Lead	6	15	ppb
077-38A Room 185 Sink Northwest (2)	6/26/2016 19:30	7/7/2016 11:27	10353872075	Copper	0.8	1.3	ppm
077-38A Room 185 Sink Northwest (2)	6/26/2016 19:30	7/7/2016 09:20	10353872075	Lead	5	15	ppb
077-39A Room 185 Sink Northwest (3)	6/26/2016 19:32	7/8/2016 07:34	10353872077	Copper	0.9	1.3	ppm
077-39A Room 185 Sink Northwest (3)	6/26/2016 19:32	7/7/2016 17:07	10353872077	Lead	12	15	ppb
077-40A Room 185 Sink Northwest (4)	6/26/2016 19:34	7/7/2016 11:28	10353872079	Copper	0.6	1.3	ppm
077-40A Room 185 Sink Northwest (4)	6/26/2016 19:34	7/7/2016 09:21	10353872079	Lead	9	15	ppb
077-41A Room 182 Sink Northwest (5)	6/26/2016 19:44	7/6/2016 23:58	10353872081	Copper	0.3	1.3	ppm
077-41A Room 182 Sink Northwest (5)	6/26/2016 19:44	7/6/2016 23:58	10353872081	Lead	48	15	ppb
077-42A Room 182 Sink Southwest (1)	6/26/2016 19:46	7/7/2016 00:06	10353872083	Copper	0.3	1.3	ppm
077-42A Room 182 Sink Southwest (1)	6/26/2016 19:46	7/7/2016 00:06	10353872083	Lead	44	15	ppb
077-43A Room 182 Sink Southwest (2)	6/26/2016 19:42	7/7/2016 10:55	10353872085	Copper	0.6	1.3	ppm
077-43A Room 182 Sink Southwest (2)	6/26/2016 19:42	7/7/2016 00:07	10353872085	Lead	5	15	ppb
077-44A Room 182 Sink South Center	6/26/2016 19:44	7/7/2016 10:57	10353872087	Copper	0.6	1.3	ppm

Portland Public Schools
Lead and Copper Water Sample Results
A (First Draw) Sample Data
Roseway Heights School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
077-44A Room 182 Sink South Center	6/26/2016 19:44	7/7/2016 00:09	10353872087	Lead	18	15	ppb
077-45A Room 182 Sink Southwest (3)	6/26/2016 19:46	7/8/2016 07:36	10353872089	Copper	0.6	1.3	ppm
077-45A Room 182 Sink Southwest (3)	6/26/2016 19:46	7/7/2016 17:09	10353872089	Lead	14	15	ppb
077-46A Room 168 Sink Northwest	6/26/2016 20:49	7/7/2016 10:58	10353872091	Copper	0.4	1.3	ppm
077-46A Room 168 Sink Northwest	6/26/2016 20:49	7/7/2016 10:58	10353872091	Lead	0	15	ppb
077-47A Room 168 Sink Northeast	6/26/2016 20:51	7/7/2016 17:10	10353872093	Copper	0.3	1.3	ppm
077-47A Room 168 Sink Northeast	6/26/2016 20:51	7/7/2016 17:10	10353872093	Lead	1	15	ppb
077-48A Room 168 Sink East	6/26/2016 20:53	7/7/2016 00:11	10353872095	Copper	0.2	1.3	ppm
077-48A Room 168 Sink East	6/26/2016 20:53	7/7/2016 00:11	10353872095	Lead	2	15	ppb
077-49A Room 168 Sink Southeast	6/26/2016 20:55	7/7/2016 17:12	10353872097	Copper	0.4	1.3	ppm
077-49A Room 168 Sink Southeast	6/26/2016 20:55	7/7/2016 17:12	10353872097	Lead	4	15	ppb
077-50A Room 168 Sink Southwest	6/26/2016 20:57	7/7/2016 17:13	10353872099	Copper	0.4	1.3	ppm
077-50A Room 168 Sink Southwest	6/26/2016 20:57	7/7/2016 17:13	10353872099	Lead	11	15	ppb
077-51A Room 168 Eyewash Station Southwest	6/26/2016 20:58	7/7/2016 00:13	10353872101	Copper	0.4	1.3	ppm
077-51A Room 168 Eyewash Station Southwest	6/26/2016 20:58	7/7/2016 00:13	10353872101	Lead	35	15	ppb
077-52A Room 170A True Room 168	6/26/2016 21:14	7/7/2016 11:00	10353872103	Copper	0.6	1.3	ppm
077-52A Room 170A True Room 168	6/26/2016 21:14	7/7/2016 00:14	10353872103	Lead	13	15	ppb
077-53A Room 173 Sink	6/26/2016 21:10	7/7/2016 00:16	10353872105	Copper	0.3	1.3	ppm
077-53A Room 173 Sink	6/26/2016 21:10	7/7/2016 00:16	10353872105	Lead	2	15	ppb
077-54A Room 179 Custodian Sink	6/26/2016 21:03	7/7/2016 00:17	10353872107	Copper	0.2	1.3	ppm
077-54A Room 179 Custodian Sink	6/26/2016 21:03	7/7/2016 00:17	10353872107	Lead	9	15	ppb
077-55A Hallway Northwest Drinking Fountain	6/26/2016 21:04	7/7/2016 00:18	10353872109	Copper	0.2	1.3	ppm
077-55A Hallway Northwest Drinking Fountain	6/26/2016 21:04	7/7/2016 00:18	10353872109	Lead	1	15	ppb
077-56A Room 170 Sink Southeast	6/26/2016 20:49	7/7/2016 11:01	10353872111	Copper	0.7	1.3	ppm
077-56A Room 170 Sink Southeast	6/26/2016 20:49	7/7/2016 00:24	10353872111	Lead	2	15	ppb
077-57A Room 170 Sink Southwest	6/26/2016 20:51	7/7/2016 00:25	10353872113	Copper	0.4	1.3	ppm
077-57A Room 170 Sink Southwest	6/26/2016 20:51	7/7/2016 00:25	10353872113	Lead	1	15	ppb
077-58A Room 170 Sink Northwest	6/26/2016 20:54	7/7/2016 11:02	10353872115	Copper	0.8	1.3	ppm
077-58A Room 170 Sink Northwest	6/26/2016 20:54	7/7/2016 00:27	10353872115	Lead	2	15	ppb

Portland Public Schools
Lead and Copper Water Sample Results
A (First Draw) Sample Data
Roseway Heights School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
077-59A Room 170 Sink Northeast	6/26/2016 20:56	7/7/2016 11:04	10353872117	Copper	0.7	1.3	ppm
077-59A Room 170 Sink Northeast	6/26/2016 20:56	7/7/2016 00:28	10353872117	Lead	1	15	ppb
077-60A Room 170 Eyewash Station Northeast	6/26/2016 21:18	7/7/2016 11:05	10353872119	Copper	1.30	1.3	ppm
077-60A Room 170 Eyewash Station Northeast	6/26/2016 21:18	7/7/2016 00:29	10353872119	Lead	151	15	ppb
077-61A Room 157 Gymnasium Drinking Fountain	6/26/2016 20:07	7/7/2016 07:41	10353872121	Copper	0.4	1.3	ppm
077-61A Room 157 Gymnasium Drinking Fountain	6/26/2016 20:07	7/7/2016 07:41	10353872121	Lead	5	15	ppb
077-62A Room 154 Boys Locker Room Sink	6/26/2016 20:11	7/7/2016 07:46	10353872123	Copper	0.4	1.3	ppm
077-62A Room 154 Boys Locker Room Sink	6/26/2016 20:11	7/7/2016 07:46	10353872123	Lead	4	15	ppb
077-63A Room 155 C Boys Sink	6/26/2016 20:08	7/8/2016 07:37	10353872125	Copper	1.5	1.3	ppm
077-63A Room 155 C Boys Sink	6/26/2016 20:08	7/7/2016 17:14	10353872125	Lead	45	15	ppb
077-64A Room 155 C Boys Shower	6/26/2016 20:10	7/7/2016 07:48	10353872127	Copper	0.5	1.3	ppm
077-64A Room 155 C Boys Shower	6/26/2016 20:10	7/7/2016 07:48	10353872127	Lead	13	15	ppb
077-65A Room 145 Girls Locker Room Sink	6/26/2016 20:24	7/7/2016 07:49	10353872129	Copper	0.3	1.3	ppm
077-65A Room 145 Girls Locker Room Sink	6/26/2016 20:24	7/7/2016 07:49	10353872129	Lead	1	15	ppb
077-66A Room 145 Girls Locker Room Shower (1)	6/26/2016 20:16	7/7/2016 11:11	10353872131	Copper	0.8	1.3	ppm
077-66A Room 145 Girls Locker Room Shower (1)	6/26/2016 20:16	7/7/2016 07:50	10353872131	Lead	42	15	ppb
077-67A Room 145 Girls Locker Room Shower (2)	6/26/2016 20:18	7/6/2016 22:09	10353872133	Copper	0.4	1.3	ppm
077-67A Room 145 Girls Locker Room Shower (2)	6/26/2016 20:18	7/6/2016 22:09	10353872133	Lead	6	15	ppb
077-68A Room 145 Girls Locker Room Shower (3)	6/26/2016 20:20	7/7/2016 10:45	10353872135	Copper	0.6	1.3	ppm
077-68A Room 145 Girls Locker Room Shower (3)	6/26/2016 20:20	7/6/2016 22:10	10353872135	Lead	75	15	ppb
077-69A Room 145 Girls Locker Room Shower (4)	6/26/2016 20:22	7/6/2016 22:12	10353872137	Copper	0.2	1.3	ppm
077-69A Room 145 Girls Locker Room Shower (4)	6/26/2016 20:22	7/6/2016 22:12	10353872137	Lead	3	15	ppb
077-70A Room 145B Girls Locker Room Sink	6/26/2016 20:16	7/6/2016 22:13	10353872139	Copper	0.3	1.3	ppm
077-70A Room 145B Girls Locker Room Sink	6/26/2016 20:16	7/6/2016 22:13	10353872139	Lead	2	15	ppb
077-71A Room 145B Girls Locker Room Shower	6/26/2016 20:18	7/7/2016 10:46	10353872141	Copper	0.5	1.3	ppm
077-71A Room 145B Girls Locker Room Shower	6/26/2016 20:18	7/6/2016 22:14	10353872141	Lead	12	15	ppb
077-72A Room 145 Custodian Sink	6/26/2016 20:27	7/7/2016 10:47	10353872143	Copper	1.0	1.3	ppm
077-72A Room 145 Custodian Sink	6/26/2016 20:27	7/6/2016 22:16	10353872143	Lead	11	15	ppb
077-73A Basement Custodian Sink	6/26/2016 19:53	7/6/2016 22:19	10353872145	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sample Results
A (First Draw) Sample Data
Roseway Heights School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
077-73A Basement Custodian Sink	6/26/2016 19:53	7/6/2016 22:19	10353872145	Lead	3	15	ppb
077-74A Basement Staff Restroom Sink	6/26/2016 19:55	7/6/2016 22:20	10353872147	Copper	0.3	1.3	ppm
077-74A Basement Staff Restroom Sink	6/26/2016 19:55	7/6/2016 22:20	10353872147	Lead	4	15	ppb
077-75A Basement Room 007 Sink (1)	6/26/2016 19:59	7/6/2016 22:21	10353872149	Copper	0.4	1.3	ppm
077-75A Basement Room 007 Sink (1)	6/26/2016 19:59	7/6/2016 22:21	10353872149	Lead	3	15	ppb
077-76A Basement Room 007 Sink (2)	6/26/2016 19:58	7/6/2016 22:25	10353872151	Copper	0.2	1.3	ppm
077-76A Basement Room 007 Sink (2)	6/26/2016 19:58	7/6/2016 22:25	10353872151	Lead	0	15	ppb
077-77A Basement Room 007 Sink (3)	6/26/2016 19:54	7/6/2016 22:27	10353872153	Copper	0.3	1.3	ppm
077-77A Basement Room 007 Sink (3)	6/26/2016 19:54	7/6/2016 22:27	10353872153	Lead	1	15	ppb
077-78A Basement Room 007 Eyewash Station	6/26/2016 19:56	7/7/2016 10:49	10353872155	Copper	1.5	1.3	ppm
077-78A Basement Room 007 Eyewash Station	6/26/2016 19:56	7/6/2016 22:28	10353872155	Lead	89	15	ppb
077-79A 2nd Floor Room 251 Custodial Sink West	6/26/2016 21:28	7/6/2016 22:30	10353872157	Copper	0.3	1.3	ppm
077-79A 2nd Floor Room 251 Custodial Sink West	6/26/2016 21:28	7/6/2016 22:30	10353872157	Lead	14	15	ppb
077-80A 2nd Floor Hallway Drinking Fountain West	6/26/2016 21:31	7/7/2016 10:50	10353872159	Copper	0.5	1.3	ppm
077-80A 2nd Floor Hallway Drinking Fountain West	6/26/2016 21:31	7/6/2016 22:31	10353872159	Lead	1	15	ppb
077-81A 2nd Floor Girls Restroom Sink South	6/26/2016 21:32	7/6/2016 22:37	10353872161	Copper	0.1	1.3	ppm
077-81A 2nd Floor Girls Restroom Sink South	6/26/2016 21:32	7/6/2016 22:37	10353872161	Lead	3	15	ppb
077-82A 2nd Floor Girls Restroom Sink North	6/26/2016 21:34	7/6/2016 22:45	10353872163	Copper	0.3	1.3	ppm
077-82A 2nd Floor Girls Restroom Sink North	6/26/2016 21:34	7/6/2016 22:45	10353872163	Lead	5	15	ppb
077-83A 2nd Floor Boys Restroom Sink South	6/26/2016 21:40	7/6/2016 22:46	10353872165	Copper	0.3	1.3	ppm
077-83A 2nd Floor Boys Restroom Sink South	6/26/2016 21:40	7/6/2016 22:46	10353872165	Lead	2	15	ppb
077-84A 2nd Floor Boys Restroom Sink North	6/26/2016 21:38	7/6/2016 22:48	10353872167	Copper	0.3	1.3	ppm
077-84A 2nd Floor Boys Restroom Sink North	6/26/2016 21:38	7/6/2016 22:48	10353872167	Lead	3	15	ppb
077-85A 2nd Floor Hallway Drinking Fountain	6/26/2016 21:46	7/6/2016 22:49	10353872169	Copper	0.3	1.3	ppm
077-85A 2nd Floor Hallway Drinking Fountain	6/26/2016 21:46	7/6/2016 22:49	10353872169	Lead	3	15	ppb
077-86A 2nd Floor Room 222 Sink	6/26/2016 21:50	7/6/2016 22:50	10353872171	Copper	0.3	1.3	ppm
077-86A 2nd Floor Room 222 Sink	6/26/2016 21:50	7/6/2016 22:50	10353872171	Lead	38	15	ppb
077-87A 2nd Floor Room 225 Drinking Fountain	6/26/2016 21:49	7/7/2016 17:18	10353872173	Copper	0.0	1.3	ppm
077-87A 2nd Floor Room 225 Drinking Fountain	6/26/2016 21:49	7/7/2016 17:18	10353872173	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sample Results
A (First Draw) Sample Data
Roseway Heights School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
077-88A 2nd Floor Room 225 Sink	6/26/2016 21:47	7/6/2016 22:52	10353872175	Copper	0.2	1.3	ppm
077-88A 2nd Floor Room 225 Sink	6/26/2016 21:47	7/6/2016 22:52	10353872175	Lead	42	15	ppb
077-89A 2nd Floor Custodial Closet Center	6/26/2016 21:55	7/6/2016 22:53	10353872177	Copper	0.2	1.3	ppm
077-89A 2nd Floor Custodial Closet Center	6/26/2016 21:55	7/6/2016 22:53	10353872177	Lead	7	15	ppb
077-90A 2nd Floor Boys Restroom Sink Center	6/26/2016 21:59	7/6/2016 22:54	10353872179	Copper	0.1	1.3	ppm
077-90A 2nd Floor Boys Restroom Sink Center	6/26/2016 21:59	7/6/2016 22:54	10353872179	Lead	18	15	ppb
077-91A 2nd Floor Boys Restroom Sink Center	6/26/2016 22:01	7/6/2016 22:56	10353872181	Copper	0.4	1.3	ppm
077-91A 2nd Floor Boys Restroom Sink Center	6/26/2016 22:01	7/6/2016 22:56	10353872181	Lead	7	15	ppb
077-92A 2nd Floor Boys Restroom Sink Center	6/26/2016 22:00	7/7/2016 11:12	10353872183	Copper	0.6	1.3	ppm
077-92A 2nd Floor Boys Restroom Sink Center	6/26/2016 22:00	7/7/2016 07:52	10353872183	Lead	8	15	ppb
077-93A 2nd Floor Girls Restroom Sink (1)	6/26/2016 22:04	7/7/2016 07:33	10353872185	Copper	0.2	1.3	ppm
077-93A 2nd Floor Girls Restroom Sink (1)	6/26/2016 22:04	7/7/2016 07:33	10353872185	Lead	8	15	ppb
077-94A 2nd Floor Girls Restroom Sink (2)	6/26/2016 22:06	7/7/2016 08:00	10353872187	Copper	0.3	1.3	ppm
077-94A 2nd Floor Girls Restroom Sink (2)	6/26/2016 22:06	7/7/2016 08:00	10353872187	Lead	16	15	ppb
077-95A 2nd Floor Room 214 Staff Room	6/26/2016 21:57	7/7/2016 08:01	10353872189	Copper	0.4	1.3	ppm
077-95A 2nd Floor Room 214 Staff Room	6/26/2016 21:57	7/7/2016 08:01	10353872189	Lead	41	15	ppb
077-96A 2nd Floor Library Sink	6/26/2016 22:12	7/7/2016 11:13	10353872191	Copper	0.6	1.3	ppm
077-96A 2nd Floor Library Sink	6/26/2016 22:12	7/7/2016 08:03	10353872191	Lead	3	15	ppb
077-97A 2nd Floor Girls Restroom East Sink	6/26/2016 22:44	7/7/2016 08:04	10353872193	Copper	0.1	1.3	ppm
077-97A 2nd Floor Girls Restroom East Sink	6/26/2016 22:44	7/7/2016 08:04	10353872193	Lead	17	15	ppb
077-98A 2nd Floor Custodian Sink East	6/26/2016 22:15	7/7/2016 08:05	10353872195	Copper	0.3	1.3	ppm
077-98A 2nd Floor Custodian Sink East	6/26/2016 22:15	7/7/2016 08:05	10353872195	Lead	13	15	ppb
077-99A 2nd Floor Boys Restroom Sink East	6/26/2016 22:39	7/7/2016 08:07	10353872197	Copper	0.4	1.3	ppm
077-99A 2nd Floor Boys Restroom Sink East	6/26/2016 22:39	7/7/2016 08:07	10353872197	Lead	31	15	ppb
077-100A 1st Floor Restroom 119	6/26/2016 22:42	7/7/2016 11:15	10353872199	Copper	0.7	1.3	ppm
077-100A 1st Floor Restroom 119	6/26/2016 22:42	7/7/2016 08:08	10353872199	Lead	2	15	ppb
077-101A Exterior Spigot West Side Off Room 175	6/26/2016 23:08	7/7/2016 10:39	10353872201	Copper	0.5	1.3	ppm
077-101A Exterior Spigot West Side Off Room 175	6/26/2016 23:08	7/6/2016 21:26	10353872201	Lead	3	15	ppb
077-102A Exterior Spigot West Side North Off Room 181	6/26/2016 23:04	7/6/2016 21:28	10353872203	Copper	0.4	1.3	ppm

Portland Public Schools
Lead and Copper Water Sample Results
A (First Draw) Sample Data
Roseway Heights School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
077-102A Exterior Spigot West Side North Off Room 181	6/26/2016 23:04	7/6/2016 21:28	10353872203	Lead	30	15	ppb
077-103A Exterior Spigot South West	6/26/2016 23:12	7/7/2016 10:40	10353872205	Copper	0.5	1.3	ppm
077-103A Exterior Spigot South West	6/26/2016 23:12	7/6/2016 21:29	10353872205	Lead	1	15	ppb
077-104A Exterior Spigot South East	6/26/2016 22:56	7/7/2016 10:42	10353872207	Copper	0.5	1.3	ppm
077-104A Exterior Spigot South East	6/26/2016 22:56	7/6/2016 21:30	10353872207	Lead	2	15	ppb
077-106A Small Gymnasium Drinking Fountain	6/26/2016 20:37	7/6/2016 21:32	10353872209	Copper	0.2	1.3	ppm
077-106A Small Gymnasium Drinking Fountain	6/26/2016 20:37	7/6/2016 21:32	10353872209	Lead	6	15	ppb
077-105A 2nd Floor Girls Restroom Spigot	6/26/2016 21:37	7/8/2016 07:39	10353872211	Copper	3.1	1.3	ppm
077-105A 2nd Floor Girls Restroom Spigot	6/26/2016 21:37	7/7/2016 17:21	10353872211	Lead	237	15	ppb
077-107A 2nd Floor Boys Restroom Spigot	6/26/2016 21:41	7/8/2016 07:40	10353872213	Copper	6.3	1.3	ppm
077-107A 2nd Floor Boys Restroom Spigot	6/26/2016 21:41	7/7/2016 17:23	10353872213	Lead	320	15	ppb
077-108A 2nd Floor Room 214 Drinking Fountain	6/26/2016 21:55	7/7/2016 10:43	10353872215	Copper	0.5	1.3	ppm
077-108A 2nd Floor Room 214 Drinking Fountain	6/26/2016 21:55	7/6/2016 21:35	10353872215	Lead	5	15	ppb
077-109A 2nd Floor Boys Restroom Spigot	6/26/2016 22:02	7/8/2016 07:41	10353872217	Copper	15.9	1.3	ppm
077-109A 2nd Floor Boys Restroom Spigot	6/26/2016 22:02	7/8/2016 07:41	10353872217	Lead	1800	15	ppb
077-110A 2nd Floor Girls Restroom Spigot	6/26/2016 22:06	7/8/2016 07:43	10353872219	Copper	7.3	1.3	ppm
077-110A 2nd Floor Girls Restroom Spigot	6/26/2016 22:06	7/8/2016 07:43	10353872219	Lead	2320	15	ppb
077-111A 2nd Floor Boys Restroom Spigot	6/26/2016 22:41	7/8/2016 07:44	10353872221	Copper	0.7	1.3	ppm
077-111A 2nd Floor Boys Restroom Spigot	6/26/2016 22:41	7/7/2016 17:27	10353872221	Lead	91	15	ppb
077-112A 2nd Floor Girls Restroom Spigot	6/26/2016 22:46	7/8/2016 07:46	10353872223	Copper	2.2	1.3	ppm
077-112A 2nd Floor Girls Restroom Spigot	6/26/2016 22:46	7/7/2016 17:28	10353872223	Lead	245	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.