

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Scott Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
080-01A Boiler Room - Sink Faucet	6/27/2016 19:59	7/6/2016 08:24	10353864001	Copper	0.1	1.3	ppm
080-01A Boiler Room - Sink Faucet	6/27/2016 19:59	7/6/2016 08:24	10353864001	Lead	0	15	ppb
080-02A Boiler Room - Spigot (1)	6/27/2016 20:01	7/1/2016 08:54	10353864003	Copper	0.1	1.3	ppm
080-02A Boiler Room - Spigot (1)	6/27/2016 20:01	7/1/2016 08:54	10353864003	Lead	19	15	ppb
080-03A Boiler Room - Spigot (2)	6/27/2016 20:03	7/6/2016 08:29	10353864005	Copper	0.1	1.3	ppm
080-03A Boiler Room - Spigot (2)	6/27/2016 20:03	7/6/2016 08:29	10353864005	Lead	21	15	ppb
080-04A Boiler Room - Spigot (3)	6/27/2016 20:05	7/1/2016 08:59	10353864007	Copper	0.0	1.3	ppm
080-04A Boiler Room - Spigot (3)	6/27/2016 20:05	7/1/2016 08:59	10353864007	Lead	3	15	ppb
080-05A Boiler Room - Spigot (4)	6/27/2016 20:07	7/6/2016 08:30	10353864009	Copper	0.4	1.3	ppm
080-05A Boiler Room - Spigot (4)	6/27/2016 20:07	7/6/2016 08:30	10353864009	Lead	114	15	ppb
080-06A Boiler Room - Spigot (5)	6/27/2016 20:08	7/7/2016 12:02	10353864011	Copper	0.3	1.3	ppm
080-06A Boiler Room - Spigot (5)	6/27/2016 20:08	7/7/2016 12:02	10353864011	Lead	19	15	ppb
080-07A Boiler Room - Spigot (6)	6/27/2016 20:08	7/7/2016 14:18	10353864013	Copper	9.3	1.3	ppm
080-07A Boiler Room - Spigot (6)	6/27/2016 20:08	7/6/2016 08:32	10353864013	Lead	275	15	ppb
080-08A Boiler Room Hall to Kitchen - Sink Faucet	6/27/2016 20:14	7/1/2016 09:03	10353864015	Copper	0.2	1.3	ppm
080-08A Boiler Room Hall to Kitchen - Sink Faucet	6/27/2016 20:14	7/1/2016 09:03	10353864015	Lead	1	15	ppb
080-09A Kitchen - Dish Sink	6/27/2016 20:15	7/6/2016 08:33	10353864017	Copper	0.2	1.3	ppm
080-09A Kitchen - Dish Sink	6/27/2016 20:15	7/6/2016 08:33	10353864017	Lead	6	15	ppb
080-10A Kitchen - Hand Sink	6/27/2016 20:17	7/1/2016 09:04	10353864019	Copper	0.1	1.3	ppm
080-10A Kitchen - Hand Sink	6/27/2016 20:17	7/1/2016 09:04	10353864019	Lead	3	15	ppb
080-11A Kitchen - Food Preparation Sink	6/27/2016 20:19	7/1/2016 09:06	10353864021	Copper	0.1	1.3	ppm
080-11A Kitchen - Food Preparation Sink	6/27/2016 20:19	7/1/2016 09:06	10353864021	Lead	3	15	ppb
080-12A Kitchen - Food Preparation Sink Sprayer	6/27/2016 20:21	7/6/2016 08:37	10353864023	Copper	0.0	1.3	ppm
080-12A Kitchen - Food Preparation Sink Sprayer	6/27/2016 20:21	7/6/2016 08:37	10353864023	Lead	1	15	ppb
080-13A Kitchen Bathroom - Sink Faucet	6/27/2016 20:23	7/1/2016 09:07	10353864025	Copper	0.1	1.3	ppm
080-13A Kitchen Bathroom - Sink Faucet	6/27/2016 20:23	7/1/2016 09:07	10353864025	Lead	14	15	ppb
080-14A Cafeteria - Drinking Fountain	6/27/2016 20:23	7/6/2016 08:38	10353864027	Copper	0.0	1.3	ppm
080-14A Cafeteria - Drinking Fountain	6/27/2016 20:23	7/6/2016 08:38	10353864027	Lead	6	15	ppb
080-15A Storage Room (by offices)	6/27/2016 20:30	7/1/2016 09:08	10353864029	Copper	0.3	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Scott Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
080-15A Storage Room (by offices)	6/27/2016 20:30	7/1/2016 09:08	10353864029	Lead	9	15	ppb
080-16A Restroom by 207 - Sink Faucet	6/27/2016 20:31	7/1/2016 09:10	10353864031	Copper	0.2	1.3	ppm
080-16A Restroom by 207 - Sink Faucet	6/27/2016 20:31	7/1/2016 09:10	10353864031	Lead	13	15	ppb
080-17A Hall - Drinking Fountain	6/27/2016 20:32	7/1/2016 09:11	10353864033	Copper	0.4	1.3	ppm
080-17A Hall - Drinking Fountain	6/27/2016 20:32	7/1/2016 09:11	10353864033	Lead	5	15	ppb
080-18A Custodial Closet by Boys Bathroom - Sink Faucet	6/27/2016 20:35	7/6/2016 08:39	10353864035	Copper	0.1	1.3	ppm
080-18A Custodial Closet by Boys Bathroom - Sink Faucet	6/27/2016 20:35	7/6/2016 08:39	10353864035	Lead	11	15	ppb
080-19A Boys Bathroom - Sink Faucet	6/27/2016 20:36	7/1/2016 09:12	10353864037	Copper	0.2	1.3	ppm
080-19A Boys Bathroom - Sink Faucet	6/27/2016 20:36	7/1/2016 09:12	10353864037	Lead	11	15	ppb
080-20A Boys Bathroom - Water Spigot	6/27/2016 20:38	7/7/2016 14:19	10353864039	Copper	1.0	1.3	ppm
080-20A Boys Bathroom - Water Spigot	6/27/2016 20:38	7/6/2016 08:40	10353864039	Lead	308	15	ppb
080-21A Room 207 - Drinking Fountain	6/27/2016 20:41	7/1/2016 09:14	10353864041	Copper	0.0	1.3	ppm
080-21A Room 207 - Drinking Fountain	6/27/2016 20:41	7/1/2016 09:14	10353864041	Lead	14.8	15	ppb
080-22A Room 207 - Sink Faucet	6/27/2016 20:43	7/1/2016 09:19	10353864043	Copper	0.3	1.3	ppm
080-22A Room 207 - Sink Faucet	6/27/2016 20:43	7/1/2016 09:19	10353864043	Lead	86	15	ppb
080-23A Room 208 - Drinking Fountain	6/27/2016 20:44	7/1/2016 09:20	10353864045	Copper	0.0	1.3	ppm
080-23A Room 208 - Drinking Fountain	6/27/2016 20:44	7/1/2016 09:20	10353864045	Lead	12	15	ppb
080-24A Room 208 - Sink Faucet	6/27/2016 20:46	7/1/2016 09:21	10353864047	Copper	0.1	1.3	ppm
080-24A Room 208 - Sink Faucet	6/27/2016 20:46	7/1/2016 09:21	10353864047	Lead	15.0	15	ppb
080-25A Room 205 - Drinking Fountain	6/27/2016 20:48	7/1/2016 09:23	10353864049	Copper	0.0	1.3	ppm
080-25A Room 205 - Drinking Fountain	6/27/2016 20:48	7/1/2016 09:23	10353864049	Lead	2	15	ppb
080-26A Room 205 - Sink Faucet	6/27/2016 20:48	7/6/2016 08:42	10353864051	Copper	0.1	1.3	ppm
080-26A Room 205 - Sink Faucet	6/27/2016 20:48	7/6/2016 08:42	10353864051	Lead	7	15	ppb
080-27A Room 206 - Drinking Fountain	6/27/2016 20:50	7/1/2016 09:24	10353864053	Copper	0.0	1.3	ppm
080-27A Room 206 - Drinking Fountain	6/27/2016 20:50	7/1/2016 09:24	10353864053	Lead	8	15	ppb
080-28A Room 206 - Sink Faucet	6/27/2016 20:50	7/6/2016 08:43	10353864055	Copper	0.2	1.3	ppm
080-28A Room 206 - Sink Faucet	6/27/2016 20:50	7/6/2016 08:43	10353864055	Lead	6	15	ppb
080-29A Room 203 - Drinking Fountain	6/27/2016 20:52	7/1/2016 09:25	10353864057	Copper	0.0	1.3	ppm
080-29A Room 203 - Drinking Fountain	6/27/2016 20:52	7/1/2016 09:25	10353864057	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Scott Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
080-30A Room 203 - Sink Faucet	6/27/2016 20:52	7/1/2016 09:26	10353864059	Copper	0.0	1.3	ppm
080-30A Room 203 - Sink Faucet	6/27/2016 20:52	7/1/2016 09:26	10353864059	Lead	5	15	ppb
080-31A Room 204 - Drinking Fountain	6/27/2016 20:54	7/1/2016 09:28	10353864061	Copper	0.0	1.3	ppm
080-31A Room 204 - Drinking Fountain	6/27/2016 20:54	7/1/2016 09:28	10353864061	Lead	10	15	ppb
080-32A Room 204 - Sink Faucet	6/27/2016 20:56	7/1/2016 09:29	10353864063	Copper	0.1	1.3	ppm
080-32A Room 204 - Sink Faucet	6/27/2016 20:56	7/1/2016 09:29	10353864063	Lead	21	15	ppb
080-33A Girls Bathroom - Sink Faucet (1)	6/27/2016 21:00	7/6/2016 08:45	10353864065	Copper	0.3	1.3	ppm
080-33A Girls Bathroom - Sink Faucet (1)	6/27/2016 21:00	7/6/2016 08:45	10353864065	Lead	4	15	ppb
080-34A Girls Bathroom - Sink Faucet (2)	6/27/2016 21:00	7/1/2016 09:35	10353864067	Copper	0.1	1.3	ppm
080-34A Girls Bathroom - Sink Faucet (2)	6/27/2016 21:00	7/1/2016 09:35	10353864067	Lead	5	15	ppb
080-35A Girls Bathroom - Water Spigot	6/27/2016 21:00	7/7/2016 14:23	10353864069	Copper	2.8	1.3	ppm
080-35A Girls Bathroom - Water Spigot	6/27/2016 21:00	7/6/2016 08:46	10353864069	Lead	206	15	ppb
080-36A Custodial Closet - Sink Faucet	6/27/2016 21:04	7/6/2016 08:48	10353864071	Copper	0.1	1.3	ppm
080-36A Custodial Closet - Sink Faucet	6/27/2016 21:04	7/6/2016 08:48	10353864071	Lead	79	15	ppb
080-37A Hall - Drinking Fountain by Girls Bathroom	6/27/2016 21:06	7/1/2016 09:41	10353864073	Copper	0.0	1.3	ppm
080-37A Hall - Drinking Fountain by Girls Bathroom	6/27/2016 21:06	7/1/2016 09:41	10353864073	Lead	7	15	ppb
080-38A Room 201 - Drinking Fountain	6/27/2016 21:08	7/6/2016 18:04	10353864075	Copper	0.0	1.3	ppm
080-38A Room 201 - Drinking Fountain	6/27/2016 21:08	7/6/2016 18:04	10353864075	Lead	18	15	ppb
080-39A Room 201 - Sink Faucet	6/27/2016 21:10	7/1/2016 09:42	10353864077	Copper	0.1	1.3	ppm
080-39A Room 201 - Sink Faucet	6/27/2016 21:10	7/1/2016 09:42	10353864077	Lead	13	15	ppb
080-40A Room 201 - Bathroom - Sink Faucet	6/27/2016 21:12	7/6/2016 18:05	10353864079	Copper	0.3	1.3	ppm
080-40A Room 201 - Bathroom - Sink Faucet	6/27/2016 21:12	7/6/2016 18:05	10353864079	Lead	25	15	ppb
080-41A Room 202 - Drinking Fountain	6/27/2016 21:14	7/1/2016 07:32	10353864081	Copper	0.0	1.3	ppm
080-41A Room 202 - Drinking Fountain	6/27/2016 21:14	7/1/2016 07:32	10353864081	Lead	12	15	ppb
080-42A Room 202 - Sink Faucet	6/27/2016 21:16	7/1/2016 07:38	10353864083	Copper	0.1	1.3	ppm
080-42A Room 202 - Sink Faucet	6/27/2016 21:16	7/1/2016 07:38	10353864083	Lead	10	15	ppb
080-43A Room 300 - Bathroom - Sink Faucet	6/27/2016 21:19	7/1/2016 07:39	10353864085	Copper	0.2	1.3	ppm
080-43A Room 300 - Bathroom - Sink Faucet	6/27/2016 21:19	7/1/2016 07:39	10353864085	Lead	6	15	ppb
080-44A Room 300 Office - Sink Faucet	6/27/2016 21:21	7/1/2016 07:40	10353864087	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Scott Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
080-44A Room 300 Office - Sink Faucet	6/27/2016 21:21	7/1/2016 07:40	10353864087	Lead	12	15	ppb
080-45A Room Behind Stage - Sink Faucet	6/27/2016 21:25	7/1/2016 07:42	10353864089	Copper	0.1	1.3	ppm
080-45A Room Behind Stage - Sink Faucet	6/27/2016 21:25	7/1/2016 07:42	10353864089	Lead	16	15	ppb
080-46A Gymnasium - Drinking Fountain	6/27/2016 21:27	7/1/2016 07:45	10353864091	Copper	0.0	1.3	ppm
080-46A Gymnasium - Drinking Fountain	6/27/2016 21:27	7/1/2016 07:45	10353864091	Lead	6	15	ppb
080-47A Bathroom by Laundry (backstage)	6/27/2016 21:29	7/1/2016 07:47	10353864093	Copper	0.2	1.3	ppm
080-47A Bathroom by Laundry (backstage)	6/27/2016 21:29	7/1/2016 07:47	10353864093	Lead	8	15	ppb
080-48A Hall - Center by Boys Bathroom - Drinking Fountain	6/27/2016 21:33	7/6/2016 18:06	10353864095	Copper	0.1	1.3	ppm
080-48A Hall - Center by Boys Bathroom - Drinking Fountain	6/27/2016 21:33	7/6/2016 18:06	10353864095	Lead	25	15	ppb
080-49A Boys Bathroom - Sink Faucet	6/27/2016 21:35	7/1/2016 07:48	10353864097	Copper	0.1	1.3	ppm
080-49A Boys Bathroom - Sink Faucet	6/27/2016 21:35	7/1/2016 07:48	10353864097	Lead	14	15	ppb
080-50A Room 402 - Drinking Fountain	6/27/2016 21:38	7/1/2016 07:49	10353864099	Copper	0.0	1.3	ppm
080-50A Room 402 - Drinking Fountain	6/27/2016 21:38	7/1/2016 07:49	10353864099	Lead	5	15	ppb
080-51A Room 402 - Sink Faucet	6/27/2016 21:40	7/6/2016 18:08	10353864101	Copper	0.1	1.3	ppm
080-51A Room 402 - Sink Faucet	6/27/2016 21:40	7/6/2016 18:08	10353864101	Lead	21	15	ppb
080-52A Room 401 - Sink Faucet	6/27/2016 21:43	7/1/2016 07:50	10353864103	Copper	0.1	1.3	ppm
080-52A Room 401 - Sink Faucet	6/27/2016 21:43	7/1/2016 07:50	10353864103	Lead	8	15	ppb
080-53A Girls Bathroom - Sink Faucet (1)	6/27/2016 21:46	7/1/2016 07:52	10353864105	Copper	0.3	1.3	ppm
080-53A Girls Bathroom - Sink Faucet (1)	6/27/2016 21:46	7/1/2016 07:52	10353864105	Lead	17	15	ppb
080-54A Girls Bathroom - Sink Faucet (2)	6/27/2016 21:48	7/6/2016 18:09	10353864107	Copper	0.1	1.3	ppm
080-54A Girls Bathroom - Sink Faucet (2)	6/27/2016 21:48	7/6/2016 18:09	10353864107	Lead	10	15	ppb
080-55A Custodial Closet - Sink Faucet	6/27/2016 21:50	7/6/2016 18:10	10353864109	Copper	0.1	1.3	ppm
080-55A Custodial Closet - Sink Faucet	6/27/2016 21:50	7/6/2016 18:10	10353864109	Lead	14	15	ppb
080-56A Room 404 - Sink Faucet (1)	6/27/2016 21:53	7/1/2016 07:54	10353864111	Copper	0.1	1.3	ppm
080-56A Room 404 - Sink Faucet (1)	6/27/2016 21:53	7/1/2016 07:54	10353864111	Lead	14.8	15	ppb
080-57A Room 404 - Sink Faucet (2)	6/27/2016 21:53	7/6/2016 20:33	10353864113	Copper	0.1	1.3	ppm
080-57A Room 404 - Sink Faucet (2)	6/27/2016 21:53	7/6/2016 20:33	10353864113	Lead	16	15	ppb
080-58A Room 404 - Sink Faucet (3)	6/27/2016 21:53	7/6/2016 20:34	10353864115	Copper	0.1	1.3	ppm
080-58A Room 404 - Sink Faucet (3)	6/27/2016 21:53	7/6/2016 20:34	10353864115	Lead	22	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Scott Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
080-59A Hall by 401 - Drinking Fountain	6/27/2016 21:56	7/1/2016 07:56	10353864117	Copper	0.1	1.3	ppm
080-59A Hall by 401 - Drinking Fountain	6/27/2016 21:56	7/1/2016 07:56	10353864117	Lead	13	15	ppb
080-60A Room 406 - Sink Faucet	6/27/2016 21:58	7/1/2016 07:57	10353864119	Copper	0.1	1.3	ppm
080-60A Room 406 - Sink Faucet	6/27/2016 21:58	7/1/2016 07:57	10353864119	Lead	8	15	ppb
080-61A Room 405 - Sink Faucet	6/27/2016 22:00	7/1/2016 08:03	10353864121	Copper	0.1	1.3	ppm
080-61A Room 405 - Sink Faucet	6/27/2016 22:00	7/1/2016 08:03	10353864121	Lead	8	15	ppb
080-62A 300 - Bathroom - Sink Faucet (1)	6/27/2016 22:02	7/6/2016 20:35	10353864123	Copper	0.1	1.3	ppm
080-62A 300 - Bathroom - Sink Faucet (1)	6/27/2016 22:02	7/6/2016 20:35	10353864123	Lead	24	15	ppb
080-63A 300 - Bathroom - Sink Faucet (2)	6/27/2016 22:04	7/1/2016 08:05	10353864125	Copper	0.1	1.3	ppm
080-63A 300 - Bathroom - Sink Faucet (2)	6/27/2016 22:04	7/1/2016 08:05	10353864125	Lead	14.7	15	ppb
080-64A Room 300 - Lounge	6/27/2016 22:06	7/1/2016 08:06	10353864127	Copper	0.1	1.3	ppm
080-64A Room 300 - Lounge	6/27/2016 22:06	7/1/2016 08:06	10353864127	Lead	9	15	ppb
080-65A Room 301 - Drinking Fountain	6/27/2016 22:10	7/1/2016 08:07	10353864129	Copper	0.0	1.3	ppm
080-65A Room 301 - Drinking Fountain	6/27/2016 22:10	7/1/2016 08:07	10353864129	Lead	7	15	ppb
080-66A Room 301 - Sink Faucet	6/27/2016 22:12	7/1/2016 08:08	10353864131	Copper	0.1	1.3	ppm
080-66A Room 301 - Sink Faucet	6/27/2016 22:12	7/1/2016 08:08	10353864131	Lead	9	15	ppb
080-67A Girls Bathroom - Sink Faucet (1)	6/27/2016 22:14	7/1/2016 08:10	10353864133	Copper	0.1	1.3	ppm
080-67A Girls Bathroom - Sink Faucet (1)	6/27/2016 22:14	7/1/2016 08:10	10353864133	Lead	4	15	ppb
080-68A Girls Bathroom - Sink Faucet (2)	6/27/2016 22:16	7/6/2016 20:37	10353864135	Copper	0.2	1.3	ppm
080-68A Girls Bathroom - Sink Faucet (2)	6/27/2016 22:16	7/6/2016 20:37	10353864135	Lead	9	15	ppb
080-69A Room 302 Drinking Fountain	6/27/2016 22:19	7/1/2016 08:11	10353864137	Copper	0.0	1.3	ppm
080-69A Room 302 Drinking Fountain	6/27/2016 22:19	7/1/2016 08:11	10353864137	Lead	8	15	ppb
080-70A Room 302 Sink Faucet	6/27/2016 22:21	7/1/2016 08:19	10353864139	Copper	0.1	1.3	ppm
080-70A Room 302 Sink Faucet	6/27/2016 22:21	7/1/2016 08:19	10353864139	Lead	10	15	ppb
080-71A Room 304 - Drinking Fountain	6/27/2016 22:23	7/1/2016 11:08	10353864141	Copper	0.0	1.3	ppm
080-71A Room 304 - Drinking Fountain	6/27/2016 22:23	7/1/2016 11:08	10353864141	Lead	4	15	ppb
080-72A Room 304 - Sink Faucet	6/27/2016 22:26	7/1/2016 11:05	10353864143	Copper	0.1	1.3	ppm
080-72A Room 304 - Sink Faucet	6/27/2016 22:26	7/1/2016 11:05	10353864143	Lead	9	15	ppb
080-73A Room 303 - Drinking Fountain	6/27/2016 22:28	7/1/2016 11:07	10353864145	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Scott Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
080-73A Room 303 - Drinking Fountain	6/27/2016 22:28	7/1/2016 11:07	10353864145	Lead	3	15	ppb
080-74A Room 303 - Sink Faucet	6/27/2016 22:30	7/1/2016 11:16	10353864147	Copper	0.1	1.3	ppm
080-74A Room 303 - Sink Faucet	6/27/2016 22:30	7/1/2016 11:16	10353864147	Lead	8	15	ppb
080-75A Hall Custodial Closet - Sink Faucet	6/27/2016 22:33	7/6/2016 20:38	10353864149	Copper	0.2	1.3	ppm
080-75A Hall Custodial Closet - Sink Faucet	6/27/2016 22:33	7/6/2016 20:38	10353864149	Lead	8	15	ppb
080-76A Boys Bathroom - Sink Faucet (1)	6/27/2016 22:35	7/1/2016 11:18	10353864151	Copper	0.2	1.3	ppm
080-76A Boys Bathroom - Sink Faucet (1)	6/27/2016 22:35	7/1/2016 11:18	10353864151	Lead	8	15	ppb
080-77A Boys Bathroom - Sink Faucet (2)	6/27/2016 22:37	7/7/2016 16:14	10353864153	Copper	0.2	1.3	ppm
080-77A Boys Bathroom - Sink Faucet (2)	6/27/2016 22:37	7/7/2016 16:14	10353864153	Lead	10	15	ppb
080-78A Room 305 - Drinking Fountain	6/27/2016 22:40	7/1/2016 11:19	10353864155	Copper	0.0	1.3	ppm
080-78A Room 305 - Drinking Fountain	6/27/2016 22:40	7/1/2016 11:19	10353864155	Lead	6	15	ppb
080-79A Room 305 - Sink Faucet	6/27/2016 22:42	7/1/2016 11:20	10353864157	Copper	0.2	1.3	ppm
080-79A Room 305 - Sink Faucet	6/27/2016 22:42	7/1/2016 11:20	10353864157	Lead	19	15	ppb
080-80A Room 306 - Drinking Fountain	6/27/2016 22:45	7/1/2016 11:22	10353864159	Copper	0.0	1.3	ppm
080-80A Room 306 - Drinking Fountain	6/27/2016 22:45	7/1/2016 11:22	10353864159	Lead	3	15	ppb
080-81A Room 306 - Sink Faucet	6/27/2016 22:47	7/1/2016 11:23	10353864161	Copper	0.0	1.3	ppm
080-81A Room 306 - Sink Faucet	6/27/2016 22:47	7/1/2016 11:23	10353864161	Lead	3	15	ppb
080-82A Room 307 - Drinking Fountain	6/27/2016 22:50	7/1/2016 11:24	10353864163	Copper	0.0	1.3	ppm
080-82A Room 307 - Drinking Fountain	6/27/2016 22:50	7/1/2016 11:24	10353864163	Lead	5	15	ppb
080-83A Room 307 - Sink Faucet	6/27/2016 22:52	7/1/2016 11:26	10353864165	Copper	0.0	1.3	ppm
080-83A Room 307 - Sink Faucet	6/27/2016 22:52	7/1/2016 11:26	10353864165	Lead	3	15	ppb
080-84A Industrial Arts - Drinking Fountain	6/27/2016 22:55	7/1/2016 11:28	10353864167	Copper	0.0	1.3	ppm
080-84A Industrial Arts - Drinking Fountain	6/27/2016 22:55	7/1/2016 11:28	10353864167	Lead	7	15	ppb
080-85A Industrial Arts - Bathroom - Sink Faucet	6/27/2016 22:57	7/1/2016 11:33	10353864169	Copper	0.2	1.3	ppm
080-85A Industrial Arts - Bathroom - Sink Faucet	6/27/2016 22:57	7/1/2016 11:33	10353864169	Lead	5	15	ppb
080-86A Industrial Arts - Classroom - Sink Faucet (1)	6/27/2016 23:00	7/1/2016 11:34	10353864171	Copper	0.4	1.3	ppm
080-86A Industrial Arts - Classroom - Sink Faucet (1)	6/27/2016 23:00	7/1/2016 11:34	10353864171	Lead	4	15	ppb
080-87A Industrial Arts - Classroom - Sink Faucet (2)	6/27/2016 23:02	7/1/2016 12:49	10353864173	Copper	0.5	1.3	ppm
080-87A Industrial Arts - Classroom - Sink Faucet (2)	6/27/2016 23:02	7/1/2016 11:35	10353864173	Lead	9	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Scott Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
080-88A Annex Room 105 - Sink Faucet (1)	6/27/2016 23:05	7/1/2016 11:37	10353864175	Copper	0.0	1.3	ppm
080-88A Annex Room 105 - Sink Faucet (1)	6/27/2016 23:05	7/1/2016 11:37	10353864175	Lead	5	15	ppb
080-89A Annex Room 105 - Drinking Fountain	6/27/2016 23:07	7/1/2016 11:38	10353864177	Copper	0.0	1.3	ppm
080-89A Annex Room 105 - Drinking Fountain	6/27/2016 23:07	7/1/2016 11:38	10353864177	Lead	2	15	ppb
080-90A Annex Room 105 - Sink Faucet (2)	6/27/2016 23:09	7/1/2016 11:39	10353864179	Copper	0.1	1.3	ppm
080-90A Annex Room 105 - Sink Faucet (2)	6/27/2016 23:09	7/1/2016 11:39	10353864179	Lead	8	15	ppb
080-91A Annex Room 106 - Drinking Fountain	6/27/2016 23:12	7/1/2016 11:41	10353864181	Copper	0.0	1.3	ppm
080-91A Annex Room 106 - Drinking Fountain	6/27/2016 23:12	7/1/2016 11:41	10353864181	Lead	6	15	ppb
080-92A Annex Room 106 - Sink Faucet	6/27/2016 23:14	7/6/2016 20:39	10353864183	Copper	0.2	1.3	ppm
080-92A Annex Room 106 - Sink Faucet	6/27/2016 23:14	7/6/2016 20:39	10353864183	Lead	11	15	ppb
080-93A Annex Room 103 - Drinking Fountain	6/27/2016 23:16	7/1/2016 11:42	10353864185	Copper	0.0	1.3	ppm
080-93A Annex Room 103 - Drinking Fountain	6/27/2016 23:16	7/1/2016 11:42	10353864185	Lead	27	15	ppb
080-94A Annex Room 103 - Sink Faucet	6/27/2016 23:18	7/1/2016 12:00	10353864187	Copper	0.1	1.3	ppm
080-94A Annex Room 103 - Sink Faucet	6/27/2016 23:18	7/1/2016 12:00	10353864187	Lead	9	15	ppb
080-95A Annex Room 104 - Drinking Fountain	6/27/2016 23:21	7/1/2016 12:04	10353864189	Copper	0.0	1.3	ppm
080-95A Annex Room 104 - Drinking Fountain	6/27/2016 23:21	7/1/2016 12:04	10353864189	Lead	16	15	ppb
080-96A Annex - Break Room - Sink Faucet	6/27/2016 23:23	7/1/2016 12:05	10353864191	Copper	0.1	1.3	ppm
080-96A Annex - Break Room - Sink Faucet	6/27/2016 23:23	7/1/2016 12:05	10353864191	Lead	29	15	ppb
080-97A Annex - Faculty Bathroom - Sink Faucet	6/27/2016 23:26	7/1/2016 12:07	10353864193	Copper	0.0	1.3	ppm
080-97A Annex - Faculty Bathroom - Sink Faucet	6/27/2016 23:26	7/1/2016 12:07	10353864193	Lead	4	15	ppb
080-98A Annex - Girls Bathroom - Sink Faucet (1)	6/27/2016 23:30	7/6/2016 20:42	10353864195	Copper	0.2	1.3	ppm
080-98A Annex - Girls Bathroom - Sink Faucet (1)	6/27/2016 23:30	7/6/2016 20:42	10353864195	Lead	6	15	ppb
080-99A Annex - Girls Bathroom - Sink Faucet (2)	6/27/2016 23:32	7/6/2016 20:43	10353864197	Copper	0.2	1.3	ppm
080-99A Annex - Girls Bathroom - Sink Faucet (2)	6/27/2016 23:32	7/6/2016 20:43	10353864197	Lead	17	15	ppb
080-100A Annex - Girls Bathroom - Water Spigot	6/27/2016 23:35	7/6/2016 20:45	10353864199	Copper	0.2	1.3	ppm
080-100A Annex - Girls Bathroom - Water Spigot	6/27/2016 23:35	7/7/2016 14:14	10353864199	Lead	997	15	ppb
080-101A Annex - Custodial - Sink Faucet	6/27/2016 23:37	7/6/2016 20:49	10353864201	Copper	0.1	1.3	ppm
080-101A Annex - Custodial - Sink Faucet	6/27/2016 23:37	7/6/2016 20:49	10353864201	Lead	10	15	ppb
080-102A Annex - Across from Girls Bathroom	6/27/2016 23:39	7/1/2016 12:50	10353864203	Copper	0.5	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Scott Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
080-102A Annex - Across from Girls Bathroom	6/27/2016 23:39	7/1/2016 12:08	10353864203	Lead	417	15	ppb
080-103A Annex - Boys Bathroom - Sink Faucet (1)	6/27/2016 23:41	7/6/2016 20:50	10353864205	Copper	0.2	1.3	ppm
080-103A Annex - Boys Bathroom - Sink Faucet (1)	6/27/2016 23:41	7/6/2016 20:50	10353864205	Lead	4	15	ppb
080-104A Annex - Boys Bathroom - Sink Faucet (2)	6/27/2016 23:43	7/1/2016 12:09	10353864207	Copper	0.2	1.3	ppm
080-104A Annex - Boys Bathroom - Sink Faucet (2)	6/27/2016 23:43	7/1/2016 12:09	10353864207	Lead	21	15	ppb
080-105A Annex - Boys Bathroom - Water Spigot	6/27/2016 23:45	7/6/2016 20:52	10353864209	Copper	0.1	1.3	ppm
080-105A Annex - Boys Bathroom - Water Spigot	6/27/2016 23:45	7/7/2016 14:15	10353864209	Lead	4330	15	ppb
080-106A Annex - Room 102 - Sink Faucet	6/27/2016 23:47	7/1/2016 12:11	10353864211	Copper	0.1	1.3	ppm
080-106A Annex - Room 102 - Sink Faucet	6/27/2016 23:47	7/1/2016 12:11	10353864211	Lead	46	15	ppb
080-107A Annex - Room 102 - Drinking Fountain	6/27/2016 23:49	7/1/2016 12:14	10353864213	Copper	0.0	1.3	ppm
080-107A Annex - Room 102 - Drinking Fountain	6/27/2016 23:49	7/1/2016 12:14	10353864213	Lead	7	15	ppb
080-108A Annex - Room 101 - Sink Faucet	6/27/2016 23:51	7/1/2016 12:15	10353864215	Copper	0.0	1.3	ppm
080-108A Annex - Room 101 - Sink Faucet	6/27/2016 23:51	7/1/2016 12:15	10353864215	Lead	3	15	ppb
080-109A Annex - Room 101 - Drinking Fountain	6/27/2016 23:53	7/1/2016 12:16	10353864217	Copper	0.1	1.3	ppm
080-109A Annex - Room 101 - Drinking Fountain	6/27/2016 23:53	7/1/2016 12:16	10353864217	Lead	11	15	ppb
080-110A Annex - Outside - Water Spigot (1)	6/27/2016 23:58	7/6/2016 20:53	10353864219	Copper	0.2	1.3	ppm
080-110A Annex - Outside - Water Spigot (1)	6/27/2016 23:58	7/6/2016 20:53	10353864219	Lead	19	15	ppb
080-111A Outside - Water Spigot (1)	6/27/2016 00:05	7/6/2016 20:54	10353864221	Copper	0.4	1.3	ppm
080-111A Outside - Water Spigot (1)	6/27/2016 00:05	7/6/2016 20:54	10353864221	Lead	65	15	ppb
080-112A Outside - Water Spigot (2)	6/27/2016 00:08	7/7/2016 14:17	10353864223	Copper	0.8	1.3	ppm
080-112A Outside - Water Spigot (2)	6/27/2016 00:08	7/6/2016 20:56	10353864223	Lead	79	15	ppb
080-113A Outside - Water Spigot (3)	6/27/2016 00:12	7/1/2016 11:50	10353864225	Copper	0.0	1.3	ppm
080-113A Outside - Water Spigot (3)	6/27/2016 00:12	7/1/2016 11:50	10353864225	Lead	63	15	ppb
080-114A Outside - Water Spigot (4)	6/27/2016 00:16	7/1/2016 11:56	10353864227	Copper	0.3	1.3	ppm
080-114A Outside - Water Spigot (4)	6/27/2016 00:16	7/1/2016 11:56	10353864227	Lead	131	15	ppb
080-115A Outside - Water Spigot (5)	6/27/2016 00:21	7/1/2016 11:57	10353864229	Copper	0.0	1.3	ppm
080-115A Outside - Water Spigot (5)	6/27/2016 00:21	7/1/2016 11:57	10353864229	Lead	9	15	ppb
080-116A Outside - Water Spigot (6)	6/27/2016 00:34	7/1/2016 11:58	10353864231	Copper	0.0	1.3	ppm
080-116A Outside - Water Spigot (6)	6/27/2016 00:34	7/1/2016 11:58	10353864231	Lead	5	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Scott Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
EPA Action Level for Lead of 15 ppb							
EPA Action Level for Copper of 1.3 ppm							

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.