

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Sellwood Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action	Units
081 - 01A Room 105 Sink Faucet	6/26/2016 12:39:00 AM	7/6/2016 1:57:00 PM	BB67284	Copper	0.2	1.3	ppm
081 - 01A Room 105 Sink Faucet	6/26/2016 12:39:00 AM	7/6/2016 1:57:00 PM	BB67284	Lead	25	15	ppb
081 - 02A Room 103 Sink Faucet	6/26/2016 12:41:00 AM	7/6/2016 1:59:00 PM	BB67285	Copper	0.1	1.3	ppm
081 - 02A Room 103 Sink Faucet	6/26/2016 12:41:00 AM	7/6/2016 1:59:00 PM	BB67285	Lead	71	15	ppb
081 - 03A Janitor Closet Sink Faucet	6/26/2016 12:43:00 AM	7/6/2016 2:02:00 PM	BB67286	Copper	0.1	1.3	ppm
081 - 03A Janitor Closet Sink Faucet	6/26/2016 12:43:00 AM	7/6/2016 2:02:00 PM	BB67286	Lead	14	15	ppb
081 - 04A Hallway Drinking Fountain 1	6/26/2016 12:45:00 AM	7/6/2016 2:04:00 PM	BB67287	Copper	0.0	1.3	ppm
081 - 04A Hallway Drinking Fountain 1	6/26/2016 12:45:00 AM	7/6/2016 2:04:00 PM	BB67287	Lead	3	15	ppb
081 - 05A Hallway Drinking Fountain 2	6/26/2016 12:47:00 AM	7/6/2016 2:07:00 PM	BB67288	Copper	0.0	1.3	ppm
081 - 05A Hallway Drinking Fountain 2	6/26/2016 12:47:00 AM	7/6/2016 2:07:00 PM	BB67288	Lead	3	15	ppb
081 - 06A Boys Bathroom Sink Faucet 1	6/26/2016 12:49:00 AM	7/6/2016 2:15:00 PM	BB67289	Copper	0.2	1.3	ppm
081 - 06A Boys Bathroom Sink Faucet 1	6/26/2016 12:49:00 AM	7/6/2016 2:15:00 PM	BB67289	Lead	9	15	ppb
081 - 07A Boys Bathroom Sink Faucet 2	6/26/2016 12:49:00 AM	7/6/2016 2:17:00 PM	BB67290	Copper	0.0	1.3	ppm
081 - 07A Boys Bathroom Sink Faucet 2	6/26/2016 12:49:00 AM	7/6/2016 2:17:00 PM	BB67290	Lead	6	15	ppb
081 - 08A Boys Bathroom Sink Faucet 3	6/26/2016 12:51:00 AM	7/6/2016 2:47:00 PM	BB67291	Copper	0.5	1.3	ppm
081 - 08A Boys Bathroom Sink Faucet 3	6/26/2016 12:51:00 AM	7/6/2016 2:47:00 PM	BB67291	Lead	10	15	ppb
081 - 09A Cafeteria Drinking Fountain	6/26/2016 12:53:00 AM	7/6/2016 2:50:00 PM	BB67292	Copper	0.7	1.3	ppm
081 - 09A Cafeteria Drinking Fountain	6/26/2016 12:53:00 AM	7/6/2016 2:50:00 PM	BB67292	Lead	0	15	ppb
081 - 10A Cafeteria Drinking Fountain Bottle Fill	6/26/2016 12:55:00 AM	7/6/2016 2:52:00 PM	BB67293	Copper	0.7	1.3	ppm
081 - 10A Cafeteria Drinking Fountain Bottle Fill	6/26/2016 12:55:00 AM	7/6/2016 2:52:00 PM	BB67293	Lead	0	15	ppb
081 - 11A Kitchen Sink Faucet 1	6/26/2016 12:57:00 AM	7/6/2016 2:55:00 PM	BB67294	Copper	0.2	1.3	ppm
081 - 11A Kitchen Sink Faucet 1	6/26/2016 12:57:00 AM	7/6/2016 2:55:00 PM	BB67294	Lead	3	15	ppb
081 - 12A Kitchen Sink Sprayer	6/26/2016 1:00:00 AM	7/6/2016 2:57:00 PM	BB67295	Copper	0.2	1.3	ppm
081 - 12A Kitchen Sink Sprayer	6/26/2016 1:00:00 AM	7/6/2016 2:57:00 PM	BB67295	Lead	4	15	ppb
081 - 13A Kitchen Sink Faucet 2	6/26/2016 1:00:00 AM	7/6/2016 3:00:00 PM	BB67296	Copper	0.2	1.3	ppm
081 - 13A Kitchen Sink Faucet 2	6/26/2016 1:00:00 AM	7/6/2016 3:00:00 PM	BB67296	Lead	2	15	ppb
081 - 14A Janitor Closet Sink Faucet	6/26/2016 1:02:00 AM	7/6/2016 3:03:00 PM	BB67297	Copper	0.5	1.3	ppm
081 - 14A Janitor Closet Sink Faucet	6/26/2016 1:02:00 AM	7/6/2016 3:03:00 PM	BB67297	Lead	5	15	ppb
081 - 15A Restroom Sink Faucet	6/26/2016 1:04:00 AM	7/6/2016 3:05:00 PM	BB67298	Copper	0.6	1.3	ppm
081 - 15A Restroom Sink Faucet	6/26/2016 1:04:00 AM	7/6/2016 3:05:00 PM	BB67298	Lead	5	15	ppb
081 - 16A Girls Restroom Sink Faucet 1	6/26/2016 1:06:00 AM	7/6/2016 3:18:00 PM	BB67299	Copper	0.7	1.3	ppm
081 - 16A Girls Restroom Sink Faucet 1	6/26/2016 1:06:00 AM	7/6/2016 3:18:00 PM	BB67299	Lead	9	15	ppb
081 - 17A Girls Restroom Sink Faucet 2	6/26/2016 1:08:00 AM	7/11/2016 9:34:00 AM	BB67300	Copper	0.2	1.3	ppm
081 - 17A Girls Restroom Sink Faucet 2	6/26/2016 1:08:00 AM	7/11/2016 9:34:00 AM	BB67300	Lead	36	15	ppb
081 - 18A Room 119 Sink Faucet 1	6/26/2016 1:11:00 AM	7/6/2016 3:21:00 PM	BB67301	Copper	0.1	1.3	ppm
081 - 18A Room 119 Sink Faucet 1	6/26/2016 1:11:00 AM	7/6/2016 3:21:00 PM	BB67301	Lead	33	15	ppb
081 - 19A Room 119 Sink Faucet 2	6/26/2016 1:13:00 AM	7/6/2016 3:23:00 PM	BB67302	Copper	0.2	1.3	ppm
081 - 19A Room 119 Sink Faucet 2	6/26/2016 1:13:00 AM	7/6/2016 3:23:00 PM	BB67302	Lead	175	15	ppb
081 - 20A Room 119 Sink Faucet 3	6/26/2016 1:15:00 AM	7/6/2016 3:26:00 PM	BB67303	Copper	0.2	1.3	ppm
081 - 20A Room 119 Sink Faucet 3	6/26/2016 1:15:00 AM	7/6/2016 3:26:00 PM	BB67303	Lead	140	15	ppb
081 - 21A Hallway Drinking Fountain 1	6/26/2016 1:18:00 AM	7/2/2016 9:31:00 AM	BB67304	Copper	0.1	1.3	ppm
081 - 21A Hallway Drinking Fountain 1	6/26/2016 1:18:00 AM	7/2/2016 9:31:00 AM	BB67304	Lead	11	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Sellwood Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action	Units
081 - 22A Hallway Drinking Fountain 2	6/26/2016 1:18:00 AM	7/2/2016 9:34:00 AM	BB67305	Copper	0.0	1.3	ppm
081 - 22A Hallway Drinking Fountain 2	6/26/2016 1:18:00 AM	7/2/2016 9:34:00 AM	BB67305	Lead	9	15	ppb
081 - 23A Custodial Sink Faucet	6/26/2016 1:21:00 AM	7/2/2016 9:37:00 AM	BB67306	Copper	0.1	1.3	ppm
081 - 23A Custodial Sink Faucet	6/26/2016 1:21:00 AM	7/2/2016 9:37:00 AM	BB67306	Lead	3	15	ppb
081 - 24A Room 127 Sink Faucet	6/26/2016 1:23:00 AM	7/2/2016 9:40:00 AM	BB67307	Copper	0.2	1.3	ppm
081 - 24A Room 127 Sink Faucet	6/26/2016 1:23:00 AM	7/2/2016 9:40:00 AM	BB67307	Lead	24	15	ppb
081 - 25A Room 226 Media Sink Faucet	6/26/2016 1:35:00 AM	7/2/2016 9:43:00 AM	BB67308	Copper	0.2	1.3	ppm
081 - 25A Room 226 Media Sink Faucet	6/26/2016 1:35:00 AM	7/2/2016 9:43:00 AM	BB67308	Lead	50	15	ppb
081 - 26A Room 229 Sink Faucet	6/26/2016 1:37:00 AM	7/2/2016 9:58:00 AM	BB67309	Copper	0.1	1.3	ppm
081 - 26A Room 229 Sink Faucet	6/26/2016 1:37:00 AM	7/2/2016 9:58:00 AM	BB67309	Lead	6	15	ppb
081 - 27A Custodial Sink Faucet	6/26/2016 1:39:00 AM	7/2/2016 10:01:00 AM	BB67310	Copper	0.2	1.3	ppm
081 - 27A Custodial Sink Faucet	6/26/2016 1:39:00 AM	7/2/2016 10:01:00 AM	BB67310	Lead	1	15	ppb
081 - 28A Hallway Drinking Fountain 1	6/26/2016 1:42:00 AM	7/2/2016 10:04:00 AM	BB67311	Copper	0.0	1.3	ppm
081 - 28A Hallway Drinking Fountain 1	6/26/2016 1:42:00 AM	7/2/2016 10:04:00 AM	BB67311	Lead	11	15	ppb
081 - 29A Hallway Drinking Fountain 2	6/26/2016 1:44:00 AM	7/2/2016 10:07:00 AM	BB67312	Copper	0.0	1.3	ppm
081 - 29A Hallway Drinking Fountain 2	6/26/2016 1:44:00 AM	7/2/2016 10:07:00 AM	BB67312	Lead	11	15	ppb
081 - 30A Room 227B Sink Faucet	6/26/2016 1:47:00 AM	7/2/2016 10:10:00 AM	BB67313	Copper	0.6	1.3	ppm
081 - 30A Room 227B Sink Faucet	6/26/2016 1:47:00 AM	7/2/2016 10:10:00 AM	BB67313	Lead	5	15	ppb
081 - 31A Room 227 (Nurse) Sink Faucet	6/26/2016 1:50:00 AM	7/2/2016 10:13:00 AM	BB67314	Copper	0.1	1.3	ppm
081 - 31A Room 227 (Nurse) Sink Faucet	6/26/2016 1:50:00 AM	7/2/2016 10:13:00 AM	BB67314	Lead	9	15	ppb
081 - 32A Girls Restroom Sink Faucet 1	6/26/2016 1:53:00 AM	7/2/2016 10:16:00 AM	BB67315	Copper	0.1	1.3	ppm
081 - 32A Girls Restroom Sink Faucet 1	6/26/2016 1:53:00 AM	7/2/2016 10:16:00 AM	BB67315	Lead	7	15	ppb
081 - 33A Girls Restroom Sink Faucet 2	6/26/2016 1:55:00 AM	7/2/2016 10:19:00 AM	BB67316	Copper	0.5	1.3	ppm
081 - 33A Girls Restroom Sink Faucet 2	6/26/2016 1:55:00 AM	7/2/2016 10:19:00 AM	BB67316	Lead	8	15	ppb
081 - 34A Girls Restroom Water Spigot	6/26/2016 1:57:00 AM	7/2/2016 10:22:00 AM	BB67317	Copper	0.0	1.3	ppm
081 - 34A Girls Restroom Water Spigot	6/26/2016 1:57:00 AM	7/2/2016 10:22:00 AM	BB67317	Lead	7	15	ppb
081 - 35A Staff Restroom Sink Faucet	6/26/2016 2:00:00 AM	7/2/2016 10:25:00 AM	BB67318	Copper	0.2	1.3	ppm
081 - 35A Staff Restroom Sink Faucet	6/26/2016 2:00:00 AM	7/2/2016 10:25:00 AM	BB67318	Lead	7	15	ppb
081 - 36A Room 205B Sink Faucet	6/26/2016 2:03:00 AM	7/2/2016 10:46:00 AM	BB67319	Copper	0.4	1.3	ppm
081 - 36A Room 205B Sink Faucet	6/26/2016 2:03:00 AM	7/2/2016 10:46:00 AM	BB67319	Lead	9	15	ppb
081 - 37A Hallway Drinking Fountain 1	6/26/2016 2:06:00 AM	7/2/2016 10:50:00 AM	BB67320	Copper	0.0	1.3	ppm
081 - 37A Hallway Drinking Fountain 1	6/26/2016 2:06:00 AM	7/2/2016 10:50:00 AM	BB67320	Lead	2	15	ppb
081 - 38A Hallway Drinking Fountain 2	6/26/2016 2:09:00 AM	7/2/2016 10:52:00 AM	BB67321	Copper	0.0	1.3	ppm
081 - 38A Hallway Drinking Fountain 2	6/26/2016 2:09:00 AM	7/2/2016 10:52:00 AM	BB67321	Lead	2	15	ppb
081 - 39A Boys Restroom Sink Faucet 1	6/26/2016 2:13:00 AM	7/2/2016 10:56:00 AM	BB67322	Copper	0.3	1.3	ppm
081 - 39A Boys Restroom Sink Faucet 1	6/26/2016 2:13:00 AM	7/2/2016 10:56:00 AM	BB67322	Lead	7	15	ppb
081 - 40A Boys Restroom Sink Faucet 2	6/26/2016 2:15:00 AM	7/2/2016 10:59:00 AM	BB67323	Copper	0.4	1.3	ppm
081 - 40A Boys Restroom Sink Faucet 2	6/26/2016 2:15:00 AM	7/2/2016 10:59:00 AM	BB67323	Lead	12	15	ppb
081 - 41A Boys Restroom Sink Faucet 3	6/26/2016 2:17:00 AM	7/2/2016 11:02:00 AM	BB67324	Copper	0.1	1.3	ppm
081 - 41A Boys Restroom Sink Faucet 3	6/26/2016 2:17:00 AM	7/2/2016 11:02:00 AM	BB67324	Lead	35	15	ppb
081 - 42A Boys Restroom Sink Faucet 4	6/26/2016 2:23:00 AM	7/2/2016 11:05:00 AM	BB67325	Copper	0.5	1.3	ppm
081 - 42A Boys Restroom Sink Faucet 4	6/26/2016 2:23:00 AM	7/2/2016 11:05:00 AM	BB67325	Lead	26	15	ppb
081 - 43A Boys Restroom Sink Faucet 5	6/26/2016 2:25:00 AM	7/2/2016 11:08:00 AM	BB67326	Copper	0.4	1.3	ppm
081 - 43A Boys Restroom Sink Faucet 5	6/26/2016 2:25:00 AM	7/2/2016 11:08:00 AM	BB67326	Lead	46	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Sellwood Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action	Units
081 - 44A Boys Restroom Sink Faucet 6	6/26/2016 2:27:00 AM	7/2/2016 11:11:00 AM	AI BB67327	Copper	0.7	1.3	ppm
081 - 44A Boys Restroom Sink Faucet 6	6/26/2016 2:27:00 AM	7/2/2016 11:11:00 AM	AI BB67327	Lead	3	15	ppb
081 - 45A Janitor Closet Sink Faucet	6/26/2016 2:30:00 AM	7/2/2016 11:14:00 AM	AI BB67328	Copper	0.1	1.3	ppm
081 - 45A Janitor Closet Sink Faucet	6/26/2016 2:30:00 AM	7/2/2016 11:14:00 AM	AI BB67328	Lead	9	15	ppb
081 - 46A Room 309 Sink Faucet	6/26/2016 2:32:00 AM	7/2/2016 11:29:00 AM	AI BB67329	Copper	0.7	1.3	ppm
081 - 46A Room 309 Sink Faucet	6/26/2016 2:32:00 AM	7/2/2016 11:29:00 AM	AI BB67329	Lead	5	15	ppb
081 - 47A Girls Restroom Sink Faucet 1	6/26/2016 2:36:00 AM	7/2/2016 11:32:00 AM	AI BB67330	Copper	0.2	1.3	ppm
081 - 47A Girls Restroom Sink Faucet 1	6/26/2016 2:36:00 AM	7/2/2016 11:32:00 AM	AI BB67330	Lead	16	15	ppb
081 - 48A Girls Restroom Sink Faucet 2	6/26/2016 2:38:00 AM	7/2/2016 11:35:00 AM	AI BB67331	Copper	0.3	1.3	ppm
081 - 48A Girls Restroom Sink Faucet 2	6/26/2016 2:38:00 AM	7/2/2016 11:35:00 AM	AI BB67331	Lead	11	15	ppb
081 - 49A Girls Restroom Water Spigot	6/26/2016 2:40:00 AM	7/2/2016 11:38:00 AM	AI BB67332	Copper	0.3	1.3	ppm
081 - 49A Girls Restroom Water Spigot	6/26/2016 2:40:00 AM	7/2/2016 11:38:00 AM	AI BB67332	Lead	7	15	ppb
081 - 50A Room 323 Sink Faucet	6/26/2016 2:43:00 AM	7/2/2016 11:41:00 AM	AI BB67333	Copper	0.1	1.3	ppm
081 - 50A Room 323 Sink Faucet	6/26/2016 2:43:00 AM	7/2/2016 11:41:00 AM	AI BB67333	Lead	7	15	ppb
081 - 51A Room 323 Sink Faucet	6/26/2016 2:45:00 AM	7/2/2016 11:44:00 AM	AI BB67334	Copper	0.0	1.3	ppm
081 - 51A Room 323 Sink Faucet	6/26/2016 2:45:00 AM	7/2/2016 11:44:00 AM	AI BB67334	Lead	14	15	ppb
081 - 52A Hallway Drinking Fountain 1	6/26/2016 2:48:00 AM	7/2/2016 11:47:00 AM	AI BB67335	Copper	0.1	1.3	ppm
081 - 52A Hallway Drinking Fountain 1	6/26/2016 2:48:00 AM	7/2/2016 11:47:00 AM	AI BB67335	Lead	7	15	ppb
081 - 53A Hallway Drinking Fountain 2	6/26/2016 2:50:00 AM	7/2/2016 11:50:00 AM	AI BB67336	Copper	0.0	1.3	ppm
081 - 53A Hallway Drinking Fountain 2	6/26/2016 2:50:00 AM	7/2/2016 11:50:00 AM	AI BB67336	Lead	10	15	ppb
081 - 54A Janitor Closet Sink Faucet	6/26/2016 2:53:00 AM	7/2/2016 11:53:00 AM	AI BB67337	Copper	0.0	1.3	ppm
081 - 54A Janitor Closet Sink Faucet	6/26/2016 2:53:00 AM	7/2/2016 11:53:00 AM	AI BB67337	Lead	7	15	ppb
081 - 55A Hallway Drinking Fountain 1	6/26/2016 2:57:00 AM	7/2/2016 12:54:00 PM	PI BB67338	Copper	0.9	1.3	ppm
081 - 55A Hallway Drinking Fountain 1	6/26/2016 2:57:00 AM	7/2/2016 11:56:00 AM	AI BB67338	Lead	1	15	ppb
081 - 56A Hallway Drinking Fountain 2	6/26/2016 3:00:00 AM	7/2/2016 12:17:00 PM	PI BB67339	Copper	0.6	1.3	ppm
081 - 56A Hallway Drinking Fountain 2	6/26/2016 3:00:00 AM	7/2/2016 12:17:00 PM	PI BB67339	Lead	4	15	ppb
081 - 57A Boys Restroom (Staff) Sink Faucet 1	6/26/2016 3:02:00 AM	7/2/2016 12:20:00 PM	PI BB67340	Copper	0.7	1.3	ppm
081 - 57A Boys Restroom (Staff) Sink Faucet 1	6/26/2016 3:02:00 AM	7/2/2016 12:20:00 PM	PI BB67340	Lead	9	15	ppb
081 - 58A Boys Restroom (Staff) Sink Faucet 2	6/26/2016 3:03:00 AM	7/2/2016 12:23:00 PM	PI BB67341	Copper	0.9	1.3	ppm
081 - 58A Boys Restroom (Staff) Sink Faucet 2	6/26/2016 3:03:00 AM	7/2/2016 12:23:00 PM	PI BB67341	Lead	25	15	ppb
081 - 59A Boys Restroom (Staff) Sink Faucet 3	6/26/2016 3:07:00 AM	7/2/2016 12:26:00 PM	PI BB67342	Copper	0.8	1.3	ppm
081 - 59A Boys Restroom (Staff) Sink Faucet 3	6/26/2016 3:07:00 AM	7/2/2016 12:26:00 PM	PI BB67342	Lead	7	15	ppb
081 - 60A Boys Restroom (Staff) Sink Faucet 4	6/26/2016 3:09:00 AM	7/2/2016 12:29:00 PM	PI BB67343	Copper	0.9	1.3	ppm
081 - 60A Boys Restroom (Staff) Sink Faucet 4	6/26/2016 3:09:00 AM	7/2/2016 12:29:00 PM	PI BB67343	Lead	7	15	ppb
081 - 61A Boys Restroom (Staff) Sink Faucet 5	6/26/2016 3:11:00 AM	7/2/2016 12:32:00 PM	PI BB67344	Copper	0.7	1.3	ppm
081 - 61A Boys Restroom (Staff) Sink Faucet 5	6/26/2016 3:11:00 AM	7/2/2016 12:32:00 PM	PI BB67344	Lead	2	15	ppb
081 - 62A Boys Restroom (Staff) Water Spigot	6/26/2016 3:13:00 AM	7/2/2016 12:35:00 PM	PI BB67345	Copper	0.8	1.3	ppm
081 - 62A Boys Restroom (Staff) Water Spigot	6/26/2016 3:13:00 AM	7/2/2016 12:35:00 PM	PI BB67345	Lead	1	15	ppb
081 - 63A Girls Restroom (Staff) Sink Faucet 1	6/26/2016 3:16:00 AM	7/2/2016 12:57:00 PM	PI BB67346	Copper	0.9	1.3	ppm
081 - 63A Girls Restroom (Staff) Sink Faucet 1	6/26/2016 3:16:00 AM	7/2/2016 12:39:00 PM	PI BB67346	Lead	16	15	ppb
081 - 64A Girls Restroom (Staff) Sink Faucet 2	6/26/2016 3:18:00 AM	7/2/2016 12:41:00 PM	PI BB67347	Copper	0.6	1.3	ppm
081 - 64A Girls Restroom (Staff) Sink Faucet 2	6/26/2016 3:18:00 AM	7/2/2016 12:41:00 PM	PI BB67347	Lead	1	15	ppb
081 - 65A Girls Restroom (Staff) Sink Faucet 3	6/26/2016 3:20:00 AM	7/2/2016 1:00:00 PM	BB67348	Copper	0.9	1.3	ppm
081 - 65A Girls Restroom (Staff) Sink Faucet 3	6/26/2016 3:20:00 AM	7/2/2016 12:45:00 PM	PI BB67348	Lead	9	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Sellwood Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
081 - 66A Girls Restroom (Staff) Sink Faucet 4	6/26/2016 3:22:00 AM	7/7/2016 5:22:00 PM	BB67349	Copper	0.9	1.3	ppm
081 - 66A Girls Restroom (Staff) Sink Faucet 4	6/26/2016 3:22:00 AM	7/7/2016 5:22:00 PM	BB67349	Lead	10	15	ppb
081 - 67A Girls Restroom (Staff) Sink Faucet 5	6/26/2016 3:24:00 AM	7/7/2016 5:25:00 PM	BB67350	Copper	0.9	1.3	ppm
081 - 67A Girls Restroom (Staff) Sink Faucet 5	6/26/2016 3:24:00 AM	7/7/2016 5:25:00 PM	BB67350	Lead	12	15	ppb
081 - 68A Girls Restroom (Staff) Water Spigot	6/26/2016 3:27:00 AM	7/11/2016 9:51:00 AM	BB67351	Copper	2.0	1.3	ppm
081 - 68A Girls Restroom (Staff) Water Spigot	6/26/2016 3:27:00 AM	7/11/2016 9:51:00 AM	BB67351	Lead	135	15	ppb
081 - 69A Janitor Closet Sink Faucet	6/26/2016 3:30:00 AM	7/7/2016 5:28:00 PM	BB67352	Copper	0.2	1.3	ppm
081 - 69A Janitor Closet Sink Faucet	6/26/2016 3:30:00 AM	7/7/2016 5:28:00 PM	BB67352	Lead	1	15	ppb
081 - 70A Boys Locker Room Sink Faucet 1	6/26/2016 3:32:00 AM	7/7/2016 5:31:00 PM	BB67353	Copper	0.7	1.3	ppm
081 - 70A Boys Locker Room Sink Faucet 1	6/26/2016 3:32:00 AM	7/7/2016 5:31:00 PM	BB67353	Lead	32	15	ppb
081 - 71A Boys Locker Room Sink Faucet 2	6/26/2016 3:34:00 AM	7/7/2016 5:34:00 PM	BB67354	Copper	0.5	1.3	ppm
081 - 71A Boys Locker Room Sink Faucet 2	6/26/2016 3:34:00 AM	7/7/2016 5:34:00 PM	BB67354	Lead	3	15	ppb
081 - 72A Boys Locker Room Water Spigot	6/26/2016 3:37:00 AM	7/7/2016 5:37:00 PM	BB67355	Copper	0.5	1.3	ppm
081 - 72A Boys Locker Room Water Spigot	6/26/2016 3:37:00 AM	7/7/2016 5:37:00 PM	BB67355	Lead	39	15	ppb
081 - 73A Boys Locker Room Shower 1	6/26/2016 3:40:00 AM	7/7/2016 5:58:00 PM	BB67356	Copper	0.2	1.3	ppm
081 - 73A Boys Locker Room Shower 1	6/26/2016 3:40:00 AM	7/7/2016 5:58:00 PM	BB67356	Lead	0	15	ppb
081 - 74A Boys Locker Room Shower 2	6/26/2016 3:42:00 AM	7/7/2016 6:01:00 PM	BB67357	Copper	0.2	1.3	ppm
081 - 74A Boys Locker Room Shower 2	6/26/2016 3:42:00 AM	7/7/2016 6:01:00 PM	BB67357	Lead	0	15	ppb
081 - 77A Girls Locker Room Water Spigot	6/26/2016 3:47:00 AM	7/11/2016 9:54:00 AM	BB67360	Copper	1.34	1.3	ppm
081 - 77A Girls Locker Room Water Spigot	6/26/2016 3:47:00 AM	7/11/2016 9:54:00 AM	BB67360	Lead	203	15	ppb
081 - 78A Girls Locker Room Shower 1	6/26/2016 3:49:00 AM	7/7/2016 7:26:00 PM	BB67361	Copper	1.1	1.3	ppm
081 - 78A Girls Locker Room Shower 1	6/26/2016 3:49:00 AM	7/7/2016 7:26:00 PM	BB67361	Lead	103	15	ppb
081 - 79A Girls Locker Room Shower 2	6/26/2016 3:49:00 AM	7/7/2016 4:30:00 PM	BB67362	Copper	0.5	1.3	ppm
081 - 79A Girls Locker Room Shower 2	6/26/2016 3:49:00 AM	7/7/2016 4:30:00 PM	BB67362	Lead	2	15	ppb
081 - 80A Girls Locker Room Shower 3	6/26/2016 3:51:00 AM	7/7/2016 4:33:00 PM	BB67363	Copper	0.5	1.3	ppm
081 - 80A Girls Locker Room Shower 3	6/26/2016 3:51:00 AM	7/7/2016 4:33:00 PM	BB67363	Lead	3	15	ppb
081 - 81A Coaches Room Sink Faucet	6/26/2016 3:55:00 AM	7/7/2016 4:36:00 PM	BB67364	Copper	0.7	1.3	ppm
081 - 81A Coaches Room Sink Faucet	6/26/2016 3:55:00 AM	7/7/2016 4:36:00 PM	BB67364	Lead	8	15	ppb
081 - 82A Coaches Room Shower	6/26/2016 3:57:00 AM	7/7/2016 4:39:00 PM	BB67365	Copper	0.5	1.3	ppm
081 - 82A Coaches Room Shower	6/26/2016 3:57:00 AM	7/7/2016 4:39:00 PM	BB67365	Lead	67	15	ppb
081 - 83A Room 135 Sink Faucet 1	6/26/2016 4:00:00 AM	7/7/2016 4:42:00 PM	BB67366	Copper	0.6	1.3	ppm
081 - 83A Room 135 Sink Faucet 1	6/26/2016 4:00:00 AM	7/7/2016 4:42:00 PM	BB67366	Lead	2	15	ppb
081 - 84A Room 135 Sink Faucet 2	6/26/2016 4:02:00 AM	7/7/2016 4:45:00 PM	BB67367	Copper	0.4	1.3	ppm
081 - 84A Room 135 Sink Faucet 2	6/26/2016 4:02:00 AM	7/7/2016 4:45:00 PM	BB67367	Lead	5	15	ppb
081 - 85A Room 135 Sink Faucet 3	6/26/2016 4:04:00 AM	7/7/2016 4:48:00 PM	BB67368	Copper	0.6	1.3	ppm
081 - 85A Room 135 Sink Faucet 3	6/26/2016 4:04:00 AM	7/7/2016 4:48:00 PM	BB67368	Lead	8	15	ppb
081 - 86A Room 135 Drinking Fountain	6/26/2016 4:08:00 AM	7/7/2016 4:51:00 PM	BB67369	Copper	0.6	1.3	ppm
081 - 86A Room 135 Drinking Fountain	6/26/2016 4:08:00 AM	7/7/2016 4:51:00 PM	BB67369	Lead	1	15	ppb
081 - 87A Room 145 Sink Faucet	6/26/2016 4:11:00 AM	7/7/2016 4:55:00 PM	BB67370	Copper	0.7	1.3	ppm
081 - 87A Room 145 Sink Faucet	6/26/2016 4:11:00 AM	7/7/2016 4:55:00 PM	BB67370	Lead	5	15	ppb
081 - 89A Gym Drinking Fountain	6/26/2016 4:18:00 AM	7/7/2016 7:08:00 PM	BB67371	Copper	1.0	1.3	ppm
081 - 89A Gym Drinking Fountain	6/26/2016 4:18:00 AM	7/7/2016 5:10:00 PM	BB67371	Lead	1	15	ppb
081 - 90A Weight Room Sink Faucet	6/26/2016 4:24:00 AM	7/7/2016 5:13:00 PM	BB67372	Copper	0.2	1.3	ppm
081 - 90A Weight Room Sink Faucet	6/26/2016 4:24:00 AM	7/7/2016 7:17:00 PM	BB67372	Lead	105	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Sellwood Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
081 - 91A Exterior Water Spigot 1	6/26/2016 4:28:00 AM	7/7/2016 5:16:00 PM	BB67373	Copper	0.1	1.3	ppm
081 - 91A Exterior Water Spigot 1	6/26/2016 4:28:00 AM	7/7/2016 7:20:00 PM	BB67373	Lead	194	15	ppb
081 - 92A Exterior Water Spigot 2	6/26/2016 4:33:00 AM	7/7/2016 5:19:00 PM	BB67374	Copper	0.9	1.3	ppm
081 - 92A Exterior Water Spigot 2	6/26/2016 4:33:00 AM	7/7/2016 7:23:00 PM	BB67374	Lead	105	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.