

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Skyline Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
083-01A Room 110 Sink Faucet	6/24/2016 8:30:00 AM	6/25/2016 12:28:00 PM	BB66528	Copper	0.1	1.3	ppm
083-01A Room 110 Sink Faucet	6/24/2016 8:30:00 AM	6/25/2016 12:28:00 PM	BB66528	Lead	17	15	ppb
083-02A Room 110 Drinking Fountain	6/24/2016 8:31:00 AM	6/25/2016 12:32:00 PM	BB66529	Copper	0.1	1.3	ppm
083-02A Room 110 Drinking Fountain	6/24/2016 8:31:00 AM	6/25/2016 12:32:00 PM	BB66529	Lead	2	15	ppb
083-03A Room 110 Bathroom Sink Faucet	6/24/2016 8:32:00 AM	6/25/2016 12:35:00 PM	BB66530	Copper	0.5	1.3	ppm
083-03A Room 110 Bathroom Sink Faucet	6/24/2016 8:32:00 AM	6/25/2016 12:35:00 PM	BB66530	Lead	27	15	ppb
083-04A Room 109 Sink Faucet (1)	6/24/2016 8:38:00 AM	6/25/2016 12:38:00 PM	BB66531	Copper	0.1	1.3	ppm
083-04A Room 109 Sink Faucet (1)	6/24/2016 8:38:00 AM	6/25/2016 12:38:00 PM	BB66531	Lead	19	15	ppb
083-05A Room 109 Drinking Fountain	6/24/2016 8:38:00 AM	6/25/2016 12:41:00 PM	BB66532	Copper	0.1	1.3	ppm
083-05A Room 109 Drinking Fountain	6/24/2016 8:38:00 AM	6/25/2016 12:41:00 PM	BB66532	Lead	2	15	ppb
083-06A Room 109 Sink Faucet (2)	6/24/2016 8:40:00 AM	6/25/2016 12:44:00 PM	BB66533	Copper	0.1	1.3	ppm
083-06A Room 109 Sink Faucet (2)	6/24/2016 8:40:00 AM	6/25/2016 12:44:00 PM	BB66533	Lead	6	15	ppb
083-07A Room 107 Sink Faucet (1)	6/24/2016 8:37:00 AM	6/25/2016 12:47:00 PM	BB66534	Copper	0.5	1.3	ppm
083-07A Room 107 Sink Faucet (1)	6/24/2016 8:37:00 AM	6/25/2016 12:47:00 PM	BB66534	Lead	4	15	ppb
083-08A Room 107 Sink Faucet (2)	6/24/2016 8:37:00 AM	6/25/2016 12:50:00 PM	BB66535	Copper	0.4	1.3	ppm
083-08A Room 107 Sink Faucet (2)	6/24/2016 8:37:00 AM	6/25/2016 12:50:00 PM	BB66535	Lead	2	15	ppb
083-09A Room 107 Sink Faucet (3)	6/24/2016 8:39:00 AM	6/25/2016 12:53:00 PM	BB66536	Copper	0.3	1.3	ppm
083-09A Room 107 Sink Faucet (3)	6/24/2016 8:39:00 AM	6/25/2016 12:53:00 PM	BB66536	Lead	3	15	ppb
083-10A Room 107 Sink Faucet (4)	6/24/2016 8:39:00 AM	6/25/2016 12:56:00 PM	BB66537	Copper	0.1	1.3	ppm
083-10A Room 107 Sink Faucet (4)	6/24/2016 8:39:00 AM	6/25/2016 12:56:00 PM	BB66537	Lead	2	15	ppb
083-11A Girls Bathroom Sink Faucet	6/24/2016 8:45:00 AM	6/25/2016 1:20:00 PM	BB66538	Copper	0.1	1.3	ppm
083-11A Girls Bathroom Sink Faucet	6/24/2016 8:45:00 AM	6/25/2016 1:20:00 PM	BB66538	Lead	1	15	ppb
083-12A Boys Bathroom Sink Faucet (1)	6/24/2016 8:49:00 AM	6/25/2016 1:23:00 PM	BB66539	Copper	0.5	1.3	ppm
083-12A Boys Bathroom Sink Faucet (1)	6/24/2016 8:49:00 AM	6/25/2016 1:23:00 PM	BB66539	Lead	2	15	ppb
083-13A Boys Bathroom Sink Faucet (2)	6/24/2016 8:49:00 AM	6/25/2016 1:26:00 PM	BB66540	Copper	0.2	1.3	ppm
083-13A Boys Bathroom Sink Faucet (2)	6/24/2016 8:49:00 AM	6/25/2016 1:26:00 PM	BB66540	Lead	9	15	ppb
083-14A Adult Bathroom Sink Faucet	6/24/2016 8:48:00 AM	6/25/2016 1:29:00 PM	BB66541	Copper	0.2	1.3	ppm
083-14A Adult Bathroom Sink Faucet	6/24/2016 8:48:00 AM	6/25/2016 1:29:00 PM	BB66541	Lead	1	15	ppb
083-15A Water Dispenser by Adult Bathroom	6/24/2016 8:46:00 AM	6/25/2016 1:32:00 PM	BB66542	Copper	0.0	1.3	ppm
083-15A Water Dispenser by Adult Bathroom	6/24/2016 8:46:00 AM	6/25/2016 1:32:00 PM	BB66542	Lead	0	15	ppb
083-16A Kitchen Sink Sprayer	6/24/2016 8:52:00 AM	6/25/2016 1:35:00 PM	BB66543	Copper	0.4	1.3	ppm
083-16A Kitchen Sink Sprayer	6/24/2016 8:52:00 AM	6/25/2016 1:35:00 PM	BB66543	Lead	7	15	ppb
083-17A Kitchen Sink Faucet	6/24/2016 8:54:00 AM	6/25/2016 1:38:00 PM	BB66544	Copper	0.4	1.3	ppm
083-17A Kitchen Sink Faucet	6/24/2016 8:54:00 AM	6/25/2016 1:38:00 PM	BB66544	Lead	3	15	ppb
083-18A Drinking Fountain by Room 102A	6/24/2016 8:56:00 AM	6/25/2016 1:41:00 PM	BB66545	Copper	0.5	1.3	ppm
083-18A Drinking Fountain by Room 102A	6/24/2016 8:56:00 AM	6/25/2016 1:41:00 PM	BB66545	Lead	3	15	ppb
083-19A Room 103 Sink Faucet	6/24/2016 8:58:00 AM	6/25/2016 1:44:00 PM	BB66546	Copper	0.4	1.3	ppm
083-19A Room 103 Sink Faucet	6/24/2016 8:58:00 AM	6/25/2016 1:44:00 PM	BB66546	Lead	19	15	ppb
083-20A Room 103 Drinking Fountain	6/24/2016 8:58:00 AM	6/25/2016 1:47:00 PM	BB66547	Copper	0.0	1.3	ppm
083-20A Room 103 Drinking Fountain	6/24/2016 8:58:00 AM	6/25/2016 1:47:00 PM	BB66547	Lead	2	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Skyline Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
083-21A Room 103 Sink Faucet (1)	6/24/2016 9:01:00 AM	6/25/2016 2:03:00 PM	BB66548	Copper	0.1	1.3	ppm
083-21A Room 103 Sink Faucet (1)	6/24/2016 9:01:00 AM	6/25/2016 2:03:00 PM	BB66548	Lead	4	15	ppb
083-22A Room 103 Sink Faucet (2)	6/24/2016 9:01:00 AM	6/25/2016 2:05:00 PM	BB66549	Copper	0.5	1.3	ppm
083-22A Room 103 Sink Faucet (2)	6/24/2016 9:01:00 AM	6/25/2016 2:05:00 PM	BB66549	Lead	5	15	ppb
083-23A Drinking Fountain by Room 104	6/24/2016 9:04:00 AM	6/25/2016 2:09:00 PM	BB66550	Copper	0.0	1.3	ppm
083-23A Drinking Fountain by Room 104	6/24/2016 9:04:00 AM	6/25/2016 2:09:00 PM	BB66550	Lead	12	15	ppb
083-24A Boiler Room Sink Faucet	6/24/2016 9:04:00 AM	6/25/2016 2:12:00 PM	BB66551	Copper	0.0	1.3	ppm
083-24A Boiler Room Sink Faucet	6/24/2016 9:04:00 AM	6/25/2016 2:12:00 PM	BB66551	Lead	1	15	ppb
083-25A Room 217 Sink Faucet	6/24/2016 9:08:00 AM	6/25/2016 2:15:00 PM	BB66552	Copper	0.1	1.3	ppm
083-25A Room 217 Sink Faucet	6/24/2016 9:08:00 AM	6/25/2016 2:15:00 PM	BB66552	Lead	3	15	ppb
083-26A Room 217 Drinking Fountain	6/24/2016 9:08:00 AM	6/25/2016 2:18:00 PM	BB66553	Copper	0.0	1.3	ppm
083-26A Room 217 Drinking Fountain	6/24/2016 9:08:00 AM	6/25/2016 2:18:00 PM	BB66553	Lead	2	15	ppb
083-27A Room 217 Bathroom Sink Faucet	6/24/2016 9:08:00 AM	6/25/2016 2:21:00 PM	BB66554	Copper	0.1	1.3	ppm
083-27A Room 271 Bathroom Sink Faucet	6/24/2016 9:08:00 AM	6/25/2016 2:21:00 PM	BB66554	Lead	1	15	ppb
083-28A Room 215 Sink Faucet	6/24/2016 9:11:00 AM	6/25/2016 2:24:00 PM	BB66555	Copper	0.1	1.3	ppm
083-28A Room 215 Sink Faucet	6/24/2016 9:11:00 AM	6/25/2016 2:24:00 PM	BB66555	Lead	2	15	ppb
083-29A Room 215 Drinking Fountain	6/24/2016 9:11:00 AM	6/25/2016 2:27:00 PM	BB66556	Copper	0.0	1.3	ppm
083-29A Room 215 Drinking Fountain	6/24/2016 9:11:00 AM	6/25/2016 2:27:00 PM	BB66556	Lead	1	15	ppb
083-30A Room 215 Bathroom Sink Faucet	6/24/2016 9:11:00 AM	6/25/2016 2:30:00 PM	BB66557	Copper	0.1	1.3	ppm
083-30A Room 215 Bathroom Sink Faucet	6/24/2016 9:11:00 AM	6/25/2016 2:30:00 PM	BB66557	Lead	3	15	ppb
083-31A Boys Bathroom Sink Faucet (1)	6/24/2016 9:13:00 AM	6/25/2016 2:51:00 PM	BB66558	Copper	0.1	1.3	ppm
083-31A Boys Bathroom Sink Faucet (1)	6/24/2016 9:13:00 AM	6/25/2016 2:51:00 PM	BB66558	Lead	3	15	ppb
083-32A Boys Bathroom Sink Faucet (2)	6/24/2016 9:14:00 AM	6/25/2016 2:54:00 PM	BB66559	Copper	0.0	1.3	ppm
083-32A Boys Bathroom Sink Faucet (2)	6/24/2016 9:14:00 AM	6/25/2016 2:54:00 PM	BB66559	Lead	3	15	ppb
083-33A Boys Bathroom Sink Faucet (3)	6/24/2016 9:13:00 AM	6/25/2016 2:57:00 PM	BB66560	Copper	0.0	1.3	ppm
083-33A Boys Bathroom Sink Faucet (3)	6/24/2016 9:13:00 AM	6/25/2016 2:57:00 PM	BB66560	Lead	3	15	ppb
083-34A Staff Bathroom Sink Faucet	6/24/2016 9:16:00 AM	6/25/2016 3:00:00 PM	BB66561	Copper	0.2	1.3	ppm
083-34A Staff Bathroom Sink Faucet	6/24/2016 9:16:00 AM	6/25/2016 3:00:00 PM	BB66561	Lead	14	15	ppb
083-35A Custodial Slop Sink Faucet	6/24/2016 9:16:00 AM	6/25/2016 3:03:00 PM	BB66562	Copper	0.1	1.3	ppm
083-35A Custodial Slop Sink Faucet	6/24/2016 9:16:00 AM	6/25/2016 3:03:00 PM	BB66562	Lead	2	15	ppb
083-36A Girls Bathroom Sink Faucet (1)	6/24/2016 9:20:00 AM	6/25/2016 3:06:00 PM	BB66563	Copper	0.2	1.3	ppm
083-36A Girls Bathroom Sink Faucet (1)	6/24/2016 9:20:00 AM	6/25/2016 3:06:00 PM	BB66563	Lead	12	15	ppb
083-37A Girls Bathroom Sink Faucet (2)	6/24/2016 9:21:00 AM	6/25/2016 3:09:00 PM	BB66564	Copper	0.1	1.3	ppm
083-37A Girls Bathroom Sink Faucet (2)	6/24/2016 9:21:00 AM	6/25/2016 3:09:00 PM	BB66564	Lead	4	15	ppb
083-38A Drinking Fountain by Girls Bathroom	6/24/2016 9:22:00 AM	6/25/2016 3:12:00 PM	BB66565	Copper	0.0	1.3	ppm
083-38A Drinking Fountain by Girls Bathroom	6/24/2016 9:22:00 AM	6/25/2016 3:12:00 PM	BB66565	Lead	1	15	ppb
083-39A Room 205 Sink Faucet	6/24/2016 9:23:00 AM	6/25/2016 3:15:00 PM	BB66566	Copper	0.1	1.3	ppm
083-39A Room 205 Sink Faucet	6/24/2016 9:23:00 AM	6/25/2016 3:15:00 PM	BB66566	Lead	9	15	ppb
083-40A Drinking Fountain by Room 201	6/24/2016 9:24:00 AM	6/25/2016 3:18:00 PM	BB66567	Copper	0.0	1.3	ppm
083-40A Drinking Fountain by Room 201	6/24/2016 9:24:00 AM	6/25/2016 3:18:00 PM	BB66567	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Skyline Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
083-41A Gym Drinking Fountain	6/24/2016 9:24:00 AM	6/25/2016 3:34:00 PM	BB66568	Copper	0.6	1.3	ppm
083-41A Gym Drinking Fountain	6/24/2016 9:24:00 AM	6/25/2016 3:34:00 PM	BB66568	Lead	3	15	ppb
083-42A Exterior Drinking Fountain by Gym	6/24/2016 9:32:00 AM	6/25/2016 3:37:00 PM	BB66569	Copper	0.7	1.3	ppm
083-42A Exterior Drinking Fountain by Gym	6/24/2016 9:32:00 AM	6/25/2016 3:37:00 PM	BB66569	Lead	2	15	ppb
083-43A Exterior Spigot by Drinking Fountain	6/24/2016 9:38:00 AM	6/25/2016 3:40:00 PM	BB66570	Copper	0.4	1.3	ppm
083-43A Exterior Spigot by Drinking Fountain	6/24/2016 9:38:00 AM	6/25/2016 3:40:00 PM	BB66570	Lead	3	15	ppb
083-44A Exterior Spigot in Front of School	6/24/2016 9:30:00 AM	6/25/2016 3:43:00 PM	BB66571	Copper	0.0	1.3	ppm
083-44A Exterior Spigot in Front of School	6/24/2016 9:30:00 AM	6/25/2016 3:43:00 PM	BB66571	Lead	4	15	ppb

EPA Action Level for Lead of 15 ppb	ND = Non detect
EPA Action Level for Copper of 1.3 ppm	

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.