

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Terwilliger Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Levels	Units
097 - 01A Room 4 Sink Faucet	6/25/2016 12:42:00 PM	6/30/2016 12:29:00 PM	BB66693	Copper	0.1	1.3	ppm
097 - 01A Room 4 Sink Faucet	6/25/2016 12:42:00 PM	6/30/2016 12:29:00 PM	BB66693	Lead	8	15	ppb
097 - 02A Room 9 Sink Faucet	6/25/2016 12:48:00 PM	6/30/2016 12:32:00 PM	BB66694	Copper	0.2	1.3	ppm
097 - 02A Room 9 Sink Faucet	6/25/2016 12:48:00 PM	6/30/2016 12:32:00 PM	BB66694	Lead	8	15	ppb
097 - 03A Boiler Room Sink Faucet	6/25/2016 11:57:00 AM	6/30/2016 12:35:00 PM	BB66695	Copper	0.0	1.3	ppm
097 - 03A Boiler Room Sink Faucet	6/25/2016 11:57:00 AM	6/30/2016 12:35:00 PM	BB66695	Lead	6	15	ppb
097 - 04A Room 6 Sink Faucet	6/25/2016 12:02:00 PM	6/30/2016 12:38:00 PM	BB66696	Copper	0.3	1.3	ppm
097 - 04A Room 6 Sink Faucet	6/25/2016 12:02:00 PM	6/30/2016 12:38:00 PM	BB66696	Lead	4	15	ppb
097 - 05A Boys Bathroom Sink Faucet (1)	6/25/2016 12:03:00 PM	6/30/2016 12:41:00 PM	BB66697	Copper	0.2	1.3	ppm
097 - 05A Boys Bathroom Sink Faucet (1)	6/25/2016 12:03:00 PM	6/30/2016 12:41:00 PM	BB66697	Lead	2	15	ppb
097 - 06A Boys Bathroom Sink Faucet (2)	6/25/2016 12:04:00 PM	6/30/2016 12:44:00 PM	BB66698	Copper	0.2	1.3	ppm
097 - 06A Boys Bathroom Sink Faucet (2)	6/25/2016 12:04:00 PM	6/30/2016 12:44:00 PM	BB66698	Lead	2	15	ppb
097 - 07A Boys Bathroom Sink Faucet (3)	6/25/2016 12:06:00 PM	6/30/2016 12:47:00 PM	BB66699	Copper	0.2	1.3	ppm
097 - 07A Boys Bathroom Sink Faucet (3)	6/25/2016 12:06:00 PM	6/30/2016 12:47:00 PM	BB66699	Lead	3	15	ppb
097 - 08A Boys Bathroom Spigot	6/25/2016 12:07:00 PM	7/5/2016 6:18:00 PM	BB66700	Copper	9.3	1.3	ppm
097 - 08A Boys Bathroom Sink Spigot	6/25/2016 12:07:00 PM	7/5/2016 6:18:00 PM	BB66700	Lead	13000	15	ppb
097 - 09A Custodial Slop Sink	6/25/2016 12:12:00 PM	6/30/2016 12:50:00 PM	BB66701	Copper	0.0	1.3	ppm
097 - 09A Custodial Slop Sink	6/25/2016 12:12:00 PM	6/30/2016 12:50:00 PM	BB66701	Lead	3	15	ppb
097 - 10A Corridor Drinking Fountain (1)	6/25/2016 12:13:00 PM	7/5/2016 2:07:00 PM	BB66702	Copper	0.8	1.3	ppm
097 - 10A Corridor Drinking Fountain (1)	6/25/2016 12:13:00 PM	7/5/2016 2:07:00 PM	BB66702	Lead	205	15	ppb
097 - 11A Corridor Drinking Fountain (2)	6/25/2016 12:13:00 PM	7/5/2016 2:29:00 PM	BB66703	Copper	0.6	1.3	ppm
097 - 11A Corridor Drinking Fountain (2)	6/25/2016 12:13:00 PM	7/5/2016 2:29:00 PM	BB66703	Lead	817	15	ppb
097 - 12A Kitchen Sprayer	6/25/2016 12:16:00 PM	6/30/2016 12:53:00 PM	BB66704	Copper	0.1	1.3	ppm
097 - 12A Kitchen Sprayer	6/25/2016 12:16:00 PM	6/30/2016 12:53:00 PM	BB66704	Lead	8	15	ppb
097 - 13A Kitchen Dish Sink Faucet	6/25/2016 12:17:00 PM	6/30/2016 12:56:00 PM	BB66705	Copper	0.1	1.3	ppm
097 - 13A Kitchen Dish Sink Faucet	6/25/2016 12:17:00 PM	6/30/2016 12:56:00 PM	BB66705	Lead	2	15	ppb
097 - 14A Kitchen Sink Faucet	6/25/2016 12:19:00 PM	6/30/2016 1:17:00 PM	BB66706	Copper	0.0	1.3	ppm
097 - 14A Kitchen Sink Faucet	6/25/2016 12:19:00 PM	6/30/2016 1:17:00 PM	BB66706	Lead	1	15	ppb
097 - 15A Kitchen Sink Faucet Hose	6/25/2016 12:20:00 PM	6/30/2016 1:20:00 PM	BB66707	Copper	0.1	1.3	ppm
097 - 15A Kitchen Sink Faucet Hose	6/25/2016 12:20:00 PM	6/30/2016 1:20:00 PM	BB66707	Lead	1	15	ppb
097 - 16A Staff Bathroom Sink Faucet	6/25/2016 12:22:00 PM	6/30/2016 1:23:00 PM	BB66708	Copper	0.1	1.3	ppm
097 - 16A Staff Bathroom Sink Faucet	6/25/2016 12:22:00 PM	6/30/2016 1:23:00 PM	BB66708	Lead	7	15	ppb
097 - 17A Corridor Drinking Fountain (1)	6/25/2016 12:25:00 PM	7/5/2016 7:23:00 PM	BB66709	Copper	4.3	1.3	ppm
097 - 17A Corridor Drinking Fountain (1)	6/25/2016 12:25:00 PM	7/5/2016 7:23:00 PM	BB66709	Lead	1440	15	ppb
097 - 18A Corridor Drinking Fountain (2)	6/25/2016 12:27:00 PM	7/5/2016 6:50:00 PM	BB66710	Copper	4.1	1.3	ppm
097 - 18A Corridor Drinking Fountain (2)	6/25/2016 12:27:00 PM	7/5/2016 6:50:00 PM	BB66710	Lead	1850	15	ppb
097 - 19A Adult Bathroom Sink Faucet	6/25/2016 12:28:00 PM	6/30/2016 1:45:00 PM	BB66711	Copper	0.2	1.3	ppm
097 - 19A Adult Bathroom Sink Faucet	6/25/2016 12:28:00 PM	6/30/2016 1:45:00 PM	BB66711	Lead	16	15	ppb
097 - 20A Girls Bathroom Sink Faucet (1)	6/25/2016 12:30:00 PM	6/30/2016 1:48:00 PM	BB66712	Copper	0.1	1.3	ppm
097 - 20A Girls Bathroom Sink Faucet (1)	6/25/2016 12:30:00 PM	6/30/2016 1:48:00 PM	BB66712	Lead	2	15	ppb
097 - 21A Girls Bathroom Sink Faucet (2)	6/25/2016 12:30:00 PM	6/30/2016 1:54:00 PM	BB66713	Copper	0.1	1.3	ppm
097 - 21A Girls Bathroom Sink Faucet (2)	6/25/2016 12:30:00 PM	6/30/2016 1:54:00 PM	BB66713	Lead	5	15	ppb
097 - 22A Girls Bathroom Sink Faucet (3)	6/25/2016 12:31:00 PM	6/30/2016 1:58:00 PM	BB66714	Copper	0.1	1.3	ppm
097 - 22A Girls Bathroom Sink Faucet (3)	6/25/2016 12:31:00 PM	6/30/2016 1:58:00 PM	BB66714	Lead	3	15	ppb
097 - 23A Janitor Slop Sink	6/25/2016 12:33:00 PM	6/30/2016 2:01:00 PM	BB66715	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Terwilliger Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Levels	Units
097 - 23A Janitor Slop Sink	6/25/2016 12:33:00 PM	6/30/2016 2:01:00 PM	BB66715	Lead	23	15	ppb
097 - 24A Industrial Arts Sink Faucet	6/25/2016 12:36:00 PM	6/30/2016 2:04:00 PM	BB66716	Copper	0.1	1.3	ppm
097 - 24A Industrial Arts Sink Faucet	6/25/2016 12:36:00 PM	6/30/2016 2:04:00 PM	BB66716	Lead	35	15	ppb
097 - 25A Room 3 Sink Faucet	6/25/2016 12:38:00 PM	6/30/2016 2:07:00 PM	BB66717	Copper	0.1	1.3	ppm
097 - 25A Room 3 Sink Faucet	6/25/2016 12:38:00 PM	6/30/2016 2:07:00 PM	BB66717	Lead	19	15	ppb
097 - 26A Room 2 Sink Faucet	6/25/2016 12:41:00 PM	6/30/2016 2:22:00 PM	BB66718	Copper	0.2	1.3	ppm
097 - 26A Room 2 Sink Faucet	6/25/2016 12:41:00 PM	6/30/2016 2:22:00 PM	BB66718	Lead	1	15	ppb
097 - 27A Staff Workroom Sink Faucet	6/25/2016 12:45:00 PM	6/30/2016 2:25:00 PM	BB66719	Copper	0.0	1.3	ppm
097 - 27A Staff Workroom Sink Faucet	6/25/2016 12:45:00 PM	6/30/2016 2:25:00 PM	BB66719	Lead	8	15	ppb
097 - 28A Exterior Spigot (1)	6/25/2016 12:53:00 PM	7/5/2016 2:40:00 PM	BB66720	Copper	0.7	1.3	ppm
097 - 28A Exterior Spigot (1)	6/25/2016 12:53:00 PM	7/5/2016 2:40:00 PM	BB66720	Lead	89	15	ppb
097 - 29A Exterior Spigot (2)	6/25/2016 1:02:00 PM	6/30/2016 2:28:00 PM	BB66721	Copper	0.0	1.3	ppm
097 - 29A Exterior Spigot (2)	6/25/2016 1:02:00 PM	6/30/2016 2:28:00 PM	BB66721	Lead	19	15	ppb
097 - 30A Exterior Spigot (3)	6/25/2016 12:58:00 PM	6/30/2016 2:31:00 PM	BB66722	Copper	0.0	1.3	ppm
097 - 30A Exterior Spigot (3)	6/25/2016 12:58:00 PM	6/30/2016 2:31:00 PM	BB66722	Lead	11	15	ppb
097 - 31A Exterior Spigot (4)	6/25/2016 1:00:00 PM	6/30/2016 2:34:00 PM	BB66723	Copper	0.0	1.3	ppm
097 - 31A Exterior Spigot (4)	6/25/2016 1:00:00 PM	6/30/2016 2:34:00 PM	BB66723	Lead	40	15	ppb
097 - 32A Exterior Spigot (5)	6/25/2016 1:12:00 PM	7/8/2016 9:48:00 AM	BB66724	Copper	1.6	1.3	ppm
097 - 32A Exterior Spigot (5)	6/25/2016 1:12:00 PM	7/8/2016 9:48:00 AM	BB66724	Lead	483	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.