

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Vernon Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
086-01A Boiler Room Sink Faucet by Main Entrance	7/2/16 12:04	7/14/16 11:08	607051101	Copper	0.2	1.3	ppm
086-01A Boiler Room Sink Faucet by Main Entrance	7/2/16 12:04	7/14/16 11:08	607051101	Lead	1	15	ppb
086-02A Custodial Slop Sink next to Cafe	7/2/16 12:06	7/14/16 11:08	607051102	Copper	0.3	1.3	ppm
086-02A Custodial Slop Sink next to Cafe	7/2/16 12:06	7/14/16 11:08	607051102	Lead	3	15	ppb
086-03A Kitchen Sink Faucet (1)	7/2/16 12:09	7/14/16 11:08	607051103	Copper	0.2	1.3	ppm
086-03A Kitchen Sink Faucet (1)	7/2/16 12:09	7/14/16 11:08	607051103	Lead	1	15	ppb
086-04A Kitchen Sink Faucet (2)	7/2/16 12:11	7/14/16 11:08	607051104	Copper	0.4	1.3	ppm
086-04A Kitchen Sink Faucet (2)	7/2/16 12:11	7/14/16 11:08	607051104	Lead	0	15	ppb
086-05A Kitchen Sink Faucet (3)	7/2/16 12:12	7/14/16 11:08	607051105	Copper	0.2	1.3	ppm
086-05A Kitchen Sink Faucet (3)	7/2/16 12:12	7/14/16 11:08	607051105	Lead	1	15	ppb
086-06A Kitchen Bathroom Sink Faucet	7/2/16 12:13	7/14/16 11:08	607051106	Copper	0.2	1.3	ppm
086-06A Kitchen Bathroom Sink Faucet	7/2/16 12:13	7/14/16 11:08	607051106	Lead	1	15	ppb
086-07A Cafe Drinking Fountain by Exit	7/2/16 12:15	7/14/16 11:08	607051107	Copper	0.4	1.3	ppm
086-07A Cafe Drinking Fountain by Exit	7/2/16 12:15	7/14/16 11:08	607051107	Lead	1	15	ppb
086-08A Girls Restroom Sink Faucet (1)	7/2/16 12:18	7/14/16 11:08	607051108	Copper	0.2	1.3	ppm
086-08A Girls Restroom Sink Faucet (1)	7/2/16 12:18	7/14/16 11:08	607051108	Lead	2	15	ppb
086-09A Girls Restroom Sink Faucet (2)	7/2/16 12:20	7/14/16 11:08	607051109	Copper	0.2	1.3	ppm
086-09A Girls Restroom Sink Faucet (2)	7/2/16 12:20	7/14/16 11:08	607051109	Lead	2	15	ppb
086-10A Room F-1 Sink Faucet	7/2/16 12:22	7/14/16 11:08	607051110	Copper	0.4	1.3	ppm
086-10A Room F-1 Sink Faucet	7/2/16 12:22	7/14/16 11:08	607051110	Lead	3	15	ppb
086-11A Room C-1 Custodial Hose	7/2/16 12:24	7/15/16 13:51	607051111	Copper	0.2	1.3	ppm
086-11A Room C-1 Custodial Hose	7/2/16 12:24	7/15/16 13:51	607051111	Lead	4	15	ppb
086-12A Boys Restroom Sink Faucet (1)	7/2/16 12:26	7/15/16 13:51	607051112	Copper	0.2	1.3	ppm
086-12A Boys Restroom Sink Faucet (1)	7/2/16 12:26	7/15/16 13:51	607051112	Lead	4	15	ppb
086-13A Boys Restroom Sink Faucet (2)	7/2/16 12:28	7/15/16 13:51	607051113	Copper	0.3	1.3	ppm
086-13A Boys Restroom Sink Faucet (2)	7/2/16 12:28	7/15/16 13:51	607051113	Lead	3	15	ppb
086-14A Hallway Drinking Fountain (1) Boys Restroom	7/2/16 12:28	7/15/16 15:19	607051114	Copper	3.1	1.3	ppm
086-14A Hallway Drinking Fountain (1) Boys Restroom	7/2/16 12:28	7/15/16 13:51	607051114	Lead	7	15	ppb
086-15A Hallway Drinking Fountain (2) Boys Restroom	7/2/16 12:29	7/15/16 13:51	607051115	Copper	0.8	1.3	ppm
086-15A Hallway Drinking Fountain (2) Boys Restroom	7/2/16 12:29	7/15/16 13:51	607051115	Lead	1	15	ppb
086-16A Room 103 Sink Faucet	7/2/16 12:30	7/15/16 13:51	607051116	Copper	0.6	1.3	ppm
086-16A Room 103 Sink Faucet	7/2/16 12:30	7/15/16 13:51	607051116	Lead	1	15	ppb
086-17A Room 102 Sink Faucet	7/2/16 12:32	7/15/16 13:51	607051117	Copper	0.5	1.3	ppm
086-17A Room 102 Sink Faucet	7/2/16 12:32	7/15/16 13:51	607051117	Lead	3	15	ppb
086-18A Room 102 Drinking Fountain	7/2/16 12:35	7/15/16 13:51	607051118	Copper	0.8	1.3	ppm
086-18A Room 102 Drinking Fountain	7/2/16 12:35	7/15/16 13:51	607051118	Lead	3	15	ppb
086-19A Room 101 Sink Faucet	7/2/16 12:36	7/15/16 13:51	607051119	Copper	0.6	1.3	ppm
086-19A Room 101 Sink Faucet	7/2/16 12:36	7/15/16 13:51	607051119	Lead	4	15	ppb
086-20A Room 101 Drinking Fountain	7/2/16 12:39	7/15/16 13:51	607051120	Copper	0.8	1.3	ppm
086-20A Room 101 Drinking Fountain	7/2/16 12:39	7/15/16 13:51	607051120	Lead	1	15	ppb
086-21A Gym Drinking Fountain	7/2/16 12:42	7/15/16 15:18	607051121	Copper	2.6	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Vernon Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
086-21A Gym Drinking Fountain	7/2/16 12:42	7/15/16 13:53	607051121	Lead	26	15	ppb
086-22A Room 104-G inside Gym	7/2/16 12:40	7/15/16 14:02	607051122	Copper	0.8	1.3	ppm
086-22A Room 104-G inside Gym	7/2/16 12:40	7/15/16 14:02	607051122	Lead	6	15	ppb
086-23A Office Sink Faucet next to Trophies	7/2/16 12:48	7/15/16 14:03	607051123	Copper	0.3	1.3	ppm
086-23A Office Sink Faucet next to Trophies	7/2/16 12:48	7/15/16 14:03	607051123	Lead	3	15	ppb
086-24A Office Restroom Sink Faucet	7/2/16 12:50	7/15/16 14:03	607051124	Copper	0.3	1.3	ppm
086-24A Office Restroom Sink Faucet	7/2/16 12:50	7/15/16 14:03	607051124	Lead	1	15	ppb
086-25A Hallway Drinking Fountain outside Room 108	7/2/16 12:50	7/15/16 14:03	607051125	Copper	0.5	1.3	ppm
086-25A Hallway Drinking Fountain outside Room 108	7/2/16 12:50	7/15/16 14:03	607051125	Lead	0	15	ppb
086-26A Hallway between Rooms 108 & 109 Sink Faucet	7/2/16 12:53	7/15/16 14:03	607051126	Copper	0.5	1.3	ppm
086-26A Hallway between Rooms 108 & 109 Sink Faucet	7/2/16 12:53	7/15/16 14:03	607051126	Lead	1	15	ppb
086-27A between Room 106 & Room 107 Sink Faucet	7/2/16 12:56	7/15/16 14:03	607051127	Copper	0.4	1.3	ppm
086-27A between Room 106 & Room 107 Sink Faucet	7/2/16 12:56	7/15/16 14:03	607051127	Lead	5	15	ppb
086-28A Room between Room 112 & Room 113 Sink Faucet	7/2/16 12:56	7/15/16 14:03	607051128	Copper	0.4	1.3	ppm
086-28A Room between Room 112 & Room 113 Sink Faucet	7/2/16 12:56	7/15/16 14:03	607051128	Lead	3	15	ppb
086-29A Room between Room 114 & Room 115 Sink Faucet	7/2/16 13:00	7/15/16 14:03	607051129	Copper	0.5	1.3	ppm
086-29A Room between Room 114 & Room 115 Sink Faucet	7/2/16 13:00	7/15/16 14:03	607051129	Lead	2	15	ppb
086-30A Room 116 Eye Wash	7/2/16 12:59	7/15/16 14:03	607051130	Copper	0.4	1.3	ppm
086-30A Room 116 Eye Wash	7/2/16 12:59	7/15/16 14:03	607051130	Lead	3	15	ppb
086-31A Room 116 Sink Faucet (1)	7/2/16 13:00	7/15/16 14:03	607051131	Copper	0.4	1.3	ppm
086-31A Room 116 Sink Faucet (1)	7/2/16 13:00	7/15/16 14:03	607051131	Lead	0	15	ppb
086-32A Room 116 Sink Faucet (2)	7/2/16 13:04	7/15/16 14:03	607051132	Copper	0.4	1.3	ppm
086-32A Room 116 Sink Faucet (2)	7/2/16 13:04	7/15/16 14:03	607051132	Lead	0	15	ppb
086-33A Room 117 Eyewash	7/2/16 13:07	7/15/16 14:03	607051133	Copper	0.4	1.3	ppm
086-33A Room 117 Eyewash	7/2/16 13:07	7/15/16 14:03	607051133	Lead	2	15	ppb
086-34A Room 117 Sink Faucet (1)	7/2/16 13:10	7/15/16 14:03	607051134	Copper	0.2	1.3	ppm
086-34A Room 117 Sink Faucet (1)	7/2/16 13:10	7/15/16 14:03	607051134	Lead	0	15	ppb
086-35A Room 117 Drinking Fountain	7/2/16 13:12	7/15/16 14:03	607051135	Copper	0.3	1.3	ppm
086-35A Room 117 Drinking Fountain	7/2/16 13:12	7/15/16 14:03	607051135	Lead	0	15	ppb
086-36A Room C-2, Slop Sink next to Restroom	7/2/16 13:12	7/15/16 14:03	607051136	Copper	0.4	1.3	ppm
086-36A Room C-2, Slop Sink next to Restroom	7/2/16 13:12	7/15/16 14:03	607051136	Lead	16	15	ppb
086-37A Boys Restroom Sink Faucet (1), Room B-2	7/2/16 13:17	7/15/16 14:03	607051137	Copper	0.2	1.3	ppm
086-37A Boys Restroom Sink Faucet (1), Room B-2	7/2/16 13:17	7/15/16 14:03	607051137	Lead	0	15	ppb
086-38A Boys Restroom Sink Faucet (2)	7/2/16 13:19	7/15/16 14:03	607051138	Copper	0.3	1.3	ppm
086-38A Boys Restroom Sink Faucet (2)	7/2/16 13:19	7/15/16 14:03	607051138	Lead	1	15	ppb
086-39A Boys Restroom Spigot	7/2/16 13:20	7/15/16 14:03	607051139	Copper	0.9	1.3	ppm
086-39A Boys Restroom Spigot	7/2/16 13:20	7/15/16 14:03	607051139	Lead	170	15	ppb
086-40A Girls Restroom, Room G-2 Sink Faucet (1)	7/2/16 13:25	7/15/16 14:03	607051140	Copper	0.2	1.3	ppm
086-40A Girls Restroom, Room G-2 Sink Faucet (1)	7/2/16 13:25	7/15/16 14:03	607051140	Lead	1	15	ppb
086-41A Girls Restroom, Room G-2 Sink Faucet (2)	7/2/16 13:27	7/15/16 14:03	607051141	Copper	0.3	1.3	ppm
086-41A Girls Restroom, Room G-2 Sink Faucet (2)	7/2/16 13:27	7/15/16 14:03	607051141	Lead	1	15	ppb
086-42A Girls Restroom, Room G-2 Spigot	7/2/16 13:29	7/14/16 11:09	607051142	Copper	4.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Vernon Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
086-42A Girls Restroom, Room G-2 Spigot	7/2/16 13:29	7/14/16 11:05	607051142	Lead	689	15	ppb
086-43A Room F-2, Restroom Sink Faucet next to other Restroom	7/2/16 13:28	7/15/16 14:03	607051143	Copper	0.3	1.3	ppm
086-43A Room F-2, Restroom Sink Faucet next to other Restroom	7/2/16 13:28	7/15/16 14:03	607051143	Lead	7	15	ppb
086-44A Hallway Drinking Fountain (1) next to Stairs	7/2/16 13:32	7/15/16 14:03	607051144	Copper	0.5	1.3	ppm
086-44A Hallway Drinking Fountain (1) next to Stairs	7/2/16 13:32	7/15/16 14:03	607051144	Lead	1	15	ppb
086-45A Hallway Drinking Fountain (2) next to Stairs	7/2/16 13:34	7/15/16 14:03	607051145	Copper	0.3	1.3	ppm
086-45A Hallway Drinking Fountain (2) next to Stairs	7/2/16 13:34	7/15/16 14:03	607051145	Lead	0	15	ppb
086-46A Hallway Drinking Fountain (1) next to Library	7/2/16 13:36	7/15/16 14:03	607051146	Copper	0.6	1.3	ppm
086-46A Hallway Drinking Fountain (1) next to Library	7/2/16 13:36	7/15/16 14:03	607051146	Lead	1	15	ppb
086-47A Hallway Drinking Fountain (2) next to Library	7/2/16 13:37	7/15/16 14:03	607051147	Copper	0.2	1.3	ppm
086-47A Hallway Drinking Fountain (2) next to Library	7/2/16 13:37	7/15/16 14:03	607051147	Lead	1	15	ppb
086-48A Room 216, to the inside Library	7/2/16 13:44	7/15/16 14:03	607051148	Copper	0.6	1.3	ppm
086-48A Room 216, to the inside Library	7/2/16 13:44	7/15/16 14:03	607051148	Lead	8	15	ppb
086-49A Boys Restroom, Room B-4 Sink Faucet (1)	7/2/16 13:43	7/15/16 14:03	607051149	Copper	0.3	1.3	ppm
086-49A Boys Restroom, Room B-4 Sink Faucet (1)	7/2/16 13:43	7/15/16 14:03	607051149	Lead	2	15	ppb
086-50A Boys Restroom, Room B-4 Sink Faucet (2)	7/2/16 13:45	7/15/16 14:03	607051150	Copper	0.4	1.3	ppm
086-50A Boys Restroom, Room B-4 Sink Faucet (2)	7/2/16 13:45	7/15/16 14:03	607051150	Lead	2	15	ppb
086-51A Boys Restroom, Room B-4 Sink Faucet (3)	7/2/16 13:46	7/15/16 14:03	607051151	Copper	0.4	1.3	ppm
086-51A Boys Restroom, Room B-4 Sink Faucet (3)	7/2/16 13:46	7/15/16 14:03	607051151	Lead	5	15	ppb
086-52A Room C-4, Custodial Closet Hose	7/2/16 13:47	7/15/16 14:04	607051152	Copper	0.3	1.3	ppm
086-52A Room C-4, Custodial Closet Hose	7/2/16 13:47	7/15/16 14:04	607051152	Lead	6	15	ppb
086-53A Girls Restroom, Room G-4 Sink Faucet (1)	7/2/16 13:49	7/15/16 14:04	607051153	Copper	0.2	1.3	ppm
086-53A Girls Restroom, Room G-4 Sink Faucet (1)	7/2/16 13:49	7/15/16 14:04	607051153	Lead	6	15	ppb
086-54A Girls Restroom, Room G-4 Sink Faucet (2)	7/2/16 13:49	7/15/16 14:04	607051154	Copper	0.3	1.3	ppm
086-54A Girls Restroom, Room G-4 Sink Faucet (2)	7/2/16 13:49	7/15/16 14:04	607051154	Lead	1	15	ppb
086-55A Room between 214 & Room 215, Sink Faucet Purge	7/2/16 13:56	7/15/16 14:04	607051155	Copper	0.4	1.3	ppm
086-55A Room between 214 & Room 215, Sink Faucet Purge	7/2/16 13:56	7/15/16 14:04	607051155	Lead	3	15	ppb
086-56A Room F-4 across from Room 215, Sink Faucet	7/2/16 13:51	7/15/16 14:04	607051156	Copper	0.3	1.3	ppm
086-56A Room F-4 across from Room 215, Sink Faucet	7/2/16 13:51	7/15/16 14:04	607051156	Lead	12	15	ppb
086-57A Room 213 Sink Faucet	7/2/16 13:52	7/15/16 14:04	607051157	Copper	0.3	1.3	ppm
086-57A Room 213 Sink Faucet	7/2/16 13:52	7/15/16 14:04	607051157	Lead	4	15	ppb
086-58A Room between Room 208 & Room 209 Sink Faucet	7/2/16 13:55	7/15/16 14:04	607051158	Copper	0.5	1.3	ppm
086-58A Room between Room 208 & Room 209 Sink Faucet	7/2/16 13:55	7/15/16 14:04	607051158	Lead	2	15	ppb
086-59A Room 206 Sink Faucet	7/2/16 13:59	7/15/16 14:04	607051159	Copper	0.3	1.3	ppm
086-59A Room 206 Sink Faucet	7/2/16 13:59	7/15/16 14:04	607051159	Lead	0	15	ppb
086-60A Room F-3 across from Room 208, Sink Faucet	7/2/16 13:59	7/15/16 14:04	607051160	Copper	0.4	1.3	ppm
086-60A Room F-3 across from Room 208, Sink Faucet	7/2/16 13:59	7/15/16 14:04	607051160	Lead	3	15	ppb
086-61A Room C-3, Custodial Hose	7/2/16 14:02	7/15/16 14:04	607051161	Copper	0.3	1.3	ppm
086-61A Room C-3, Custodial Hose	7/2/16 14:02	7/15/16 14:04	607051161	Lead	2	15	ppb
086-62A Girls Restroom, Room G-3, Sink Faucet (1)	7/2/16 14:03	7/15/16 14:04	607051162	Copper	0.4	1.3	ppm
086-62A Girls Restroom, Room G-3, Sink Faucet (1)	7/2/16 14:03	7/15/16 14:04	607051162	Lead	4	15	ppb
086-63A Girls Restroom, Room G-3, Sink Faucet (2)	7/2/16 14:05	7/15/16 14:04	607051163	Copper	0.4	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Vernon Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
086-63A Girls Restroom, Room G-3, Sink Faucet (2)	7/2/16 14:05	7/15/16 14:04	607051163	Lead	3	15	ppb
086-64A Boys Restroom, Room B-3, Sink Faucet (1)	7/2/16 14:05	7/15/16 14:04	607051164	Copper	0.3	1.3	ppm
086-64A Boys Restroom, Room B-3, Sink Faucet (1)	7/2/16 14:05	7/15/16 14:04	607051164	Lead	3	15	ppb
086-65A Boys Restroom, Room B-3, Sink Faucet (2)	7/2/16 14:07	7/15/16 14:04	607051165	Copper	0.3	1.3	ppm
086-65A Boys Restroom, Room B-3, Sink Faucet (2)	7/2/16 14:07	7/15/16 14:04	607051165	Lead	7	15	ppb
086-66A Boys Restroom, Room B-3, Sink Faucet (3)	7/2/16 14:09	7/15/16 14:04	607051166	Copper	0.3	1.3	ppm
086-66A Boys Restroom, Room B-3, Sink Faucet (3)	7/2/16 14:09	7/15/16 14:04	607051166	Lead	2	15	ppb
086-67A Hallway Drinking Fountain (1) next to Stairs	7/2/16 14:11	7/15/16 14:04	607051167	Copper	0.5	1.3	ppm
086-67A Hallway Drinking Fountain (1) next to Stairs	7/2/16 14:11	7/15/16 14:04	607051167	Lead	1	15	ppb
086-68A Hallway Drinking Fountain (2) next to Stairs	7/2/16 14:13	7/15/16 14:04	607051168	Copper	0.3	1.3	ppm
086-68A Hallway Drinking Fountain (2) next to Stairs	7/2/16 14:13	7/15/16 14:04	607051168	Lead	1	15	ppb
086-69A Room 203 Sink Faucet	7/2/16 14:16	7/15/16 14:04	607051169	Copper	0.5	1.3	ppm
086-69A Room 203 Sink Faucet	7/2/16 14:16	7/15/16 14:04	607051169	Lead	4	15	ppb
086-70A Room 202 Sink Faucet	7/2/16 14:16	7/15/16 14:04	607051170	Copper	0.4	1.3	ppm
086-70A Room 202 Sink Faucet	7/2/16 14:16	7/15/16 14:04	607051170	Lead	5	15	ppb
086-71A Room 202 Drinking Fountain	7/2/16 14:19	7/15/16 14:04	607051171	Copper	0.7	1.3	ppm
086-71A Room 202 Drinking Fountain	7/2/16 14:19	7/15/16 14:04	607051171	Lead	4	15	ppb
086-72A Room 201 Sink Faucet	7/2/16 14:19	7/15/16 14:05	607051172	Copper	0.5	1.3	ppm
086-72A Room 201 Sink Faucet	7/2/16 14:19	7/15/16 14:05	607051172	Lead	4	15	ppb
086-73A Room 201 Drinking Fountain	7/2/16 14:21	7/15/16 14:05	607051173	Copper	0.7	1.3	ppm
086-73A Room 201 Drinking Fountain	7/2/16 14:21	7/15/16 14:05	607051173	Lead	1	15	ppb
086-74A Portable 07 Sink Faucet	7/2/16 14:44	7/15/16 14:05	607051174	Copper	0.2	1.3	ppm
086-74A Portable 07 Sink Faucet	7/2/16 14:44	7/15/16 14:05	607051174	Lead	15.0	15	ppb
086-75A Portable 07 Drinking Fountain	7/2/16 14:45	7/15/16 14:05	607051175	Copper	0.1	1.3	ppm
086-75A Portable 07 Drinking Fountain	7/2/16 14:45	7/15/16 14:05	607051175	Lead	3	15	ppb
086-77A Girls Restroom Sink Faucet, outside P7	7/2/16 14:50	7/15/16 14:05	607051176	Copper	0.1	1.3	ppm
086-77A Girls Restroom Sink Faucet, outside P7	7/2/16 14:50	7/15/16 14:05	607051176	Lead	14	15	ppb
086-78A Portable 9 Sink Faucet	7/2/16 14:53	7/15/16 14:05	607051177	Copper	0.1	1.3	ppm
086-78A Portable 9 Sink Faucet	7/2/16 14:53	7/15/16 14:05	607051177	Lead	10	15	ppb
086-79A Portable 9 Drinking Fountain	7/2/16 14:54	7/15/16 14:05	607051178	Copper	0.1	1.3	ppm
086-79A Portable 9 Drinking Fountain	7/2/16 14:54	7/15/16 14:05	607051178	Lead	12	15	ppb
086-80A Boys Restroom Sink Faucet, outside P9	7/2/16 15:03	7/15/16 14:05	607051179	Copper	0.0	1.3	ppm
086-80A Boys Restroom Sink Faucet, outside P9	7/2/16 15:03	7/15/16 14:05	607051179	Lead	14	15	ppb
086-81A Girls Restroom Sink Faucet, outside P9	7/2/16 14:59	7/15/16 14:05	607051180	Copper	0.1	1.3	ppm
086-81A Girls Restroom Sink Faucet, outside P9	7/2/16 14:59	7/15/16 14:05	607051180	Lead	23	15	ppb
086-82A Garden Hose 1 Spigot (1)	7/2/16 15:18	7/15/16 14:05	607051181	Copper	0.2	1.3	ppm
086-82A Garden Hose 1 Spigot (1)	7/2/16 15:18	7/15/16 14:05	607051181	Lead	57	15	ppb
086-83A Spigot (2) outside Room 116	7/2/16 15:20	7/15/16 14:05	607051182	Copper	0.1	1.3	ppm
086-83A Spigot (2) outside Room 116	7/2/16 15:20	7/15/16 14:05	607051182	Lead	111	15	ppb
086-84A Spigot (3) outside Room 115	7/2/16 15:23	7/15/16 14:05	607051183	Copper	0.0	1.3	ppm
086-84A Spigot (3) outside Room 115	7/2/16 15:23	7/15/16 14:05	607051183	Lead	19	15	ppb
086-85A Spigot (4) outside Room 109	7/2/16 15:25	7/15/16 14:05	607051184	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Vernon Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
086-85A Spigot (4) outside Room 109	7/2/16 15:25	7/15/16 14:05	607051184	Lead	29	15	ppb
086-86A Spigot (5) outside Room 108	7/2/16 15:28	7/15/16 14:05	607051185	Copper	0.3	1.3	ppm
086-86A Spigot (5) outside Room 108	7/2/16 15:28	7/15/16 14:05	607051185	Lead	82	15	ppb
086-87A Spigot (6) by Portables/Gym	7/2/16 15:31	7/15/16 14:05	607051186	Copper	0.1	1.3	ppm
086-87A Spigot (6) by Portables/Gym	7/2/16 15:31	7/15/16 14:05	607051186	Lead	47	15	ppb
086-76A Boys Restroom Sink Faucet outside P7	7/2/16 15:09	7/15/16 14:05	607051187	Copper	0.1	1.3	ppm
086-76A Boys Restroom Sink Faucet outside P7	7/2/16 15:09	7/15/16 14:05	607051187	Lead	36	15	ppb

EPA Action Level for Lead of 15 ppb	ND = Non detect
EPA Action Level for Copper of 1.3 ppm	

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.