

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Vestal Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
087-01A Boiler Room Sink Faucet	6/30/2016 16:57	7/5/2016	36397	Copper	ND	1.3	ppm
087-01A Boiler Room Sink Faucet	6/30/2016 16:57	7/5/2016	36397	Lead	4	15	ppb
087-02A Kitchen White Hand Wash Sink Faucet	6/30/2016 17:00	7/5/2016	36399	Copper	ND	1.3	ppm
087-02A Kitchen White Hand Wash Sink Faucet	6/30/2016 17:00	7/5/2016	36399	Lead	3	15	ppb
087-03A Kitchen Sprayer on Floor	6/30/2016 17:01	7/5/2016	36401	Copper	ND	1.3	ppm
087-03A Kitchen Sprayer on Floor	6/30/2016 17:01	7/5/2016	36401	Lead	26	15	ppb
087-04A Kitchen Sprayer at Sanitize Sink	6/30/2016 17:03	7/5/2016	36403	Copper	ND	1.3	ppm
087-04A Kitchen Sprayer at Sanitize Sink	6/30/2016 17:03	7/5/2016	36403	Lead	5	15	ppb
087-05A Kitchen Sanitize Sink Faucet	6/30/2016 17:04	7/5/2016	36405	Copper	ND	1.3	ppm
087-05A Kitchen Sanitize Sink Faucet	6/30/2016 17:04	7/5/2016	36405	Lead	6	15	ppb
087-06A Kitchen Bathroom Sink Faucet	6/30/2016 17:04	7/5/2016	36407	Copper	ND	1.3	ppm
087-06A Kitchen Bathroom Sink Faucet	6/30/2016 17:04	7/5/2016	36407	Lead	3	15	ppb
087-07A Kitchen Custodial Sink Faucet	6/30/2016 17:07	7/5/2016	36409	Copper	ND	1.3	ppm
087-07A Kitchen Custodial Sink Faucet	6/30/2016 17:07	7/5/2016	36409	Lead	2	15	ppb
087-08A Kitchen Dishwash Sprayer	6/30/2016 17:06	7/5/2016	36411	Copper	ND	1.3	ppm
087-08A Kitchen Dishwash Sprayer	6/30/2016 17:06	7/5/2016	36411	Lead	2	15	ppb
087-09A Rm 113 Sink Faucet	6/30/2016 17:10	7/5/2016	36413	Copper	ND	1.3	ppm
087-09A Rm 113 Sink Faucet	6/30/2016 17:10	7/5/2016	36413	Lead	13	15	ppb
087-10A Rm 113 Drinking Fountain	6/30/2016 17:10	7/5/2016	36415	Copper	0.1	1.3	ppm
087-10A Rm 113 Drinking Fountain	6/30/2016 17:10	7/5/2016	36415	Lead	2	15	ppb
087-11A Rm 112 Sink Faucet	6/30/2016 17:13	7/5/2016	36417	Copper	ND	1.3	ppm
087-11A Rm 112 Sink Faucet	6/30/2016 17:13	7/5/2016	36417	Lead	19	15	ppb
087-12A Rm 112 Drinking Fountain	6/30/2016 17:14	7/5/2016	36419	Copper	ND	1.3	ppm
087-12A Rm 112 Drinking Fountain	6/30/2016 17:14	7/5/2016	36419	Lead	2	15	ppb
087-13A Rm 111 Sink Faucet	6/30/2016 17:13	7/5/2016	36421	Copper	ND	1.3	ppm
087-13A Rm 111 Sink Faucet	6/30/2016 17:13	7/5/2016	36421	Lead	3	15	ppb
087-14A Rm 111 Drinking Fountain	6/30/2016 17:14	7/5/2016	36423	Copper	ND	1.3	ppm
087-14A Rm 111 Drinking Fountain	6/30/2016 17:14	7/5/2016	36423	Lead	2	15	ppb
087-15A Rm 112 Bathroom Sink	6/30/2016 17:15	7/5/2016	36425	Copper	ND	1.3	ppm
087-15A Rm 112 Bathroom Sink	6/30/2016 17:15	7/5/2016	36425	Lead	12	15	ppb
087-16A Rm 110 Sink Faucet	6/30/2016 17:16	7/5/2016	36427	Copper	ND	1.3	ppm
087-16A Rm 110 Sink Faucet	6/30/2016 17:16	7/5/2016	36427	Lead	5	15	ppb
087-17A Rm 110 Drinking Fountain	6/30/2016 17:17	7/5/2016	36429	Copper	ND	1.3	ppm
087-17A Rm 110 Drinking Fountain	6/30/2016 17:17	7/5/2016	36429	Lead	6	15	ppb
087-18A Boys Bathroom Sink Faucet Left	6/30/2016 17:17	7/5/2016	36431	Copper	ND	1.3	ppm
087-18A Boys Bathroom Sink Faucet Left	6/30/2016 17:17	7/5/2016	36431	Lead	8	15	ppb
087-19A Boys Bathroom Sink Faucet Right	6/30/2016 17:18	7/5/2016	36433	Copper	0.1	1.3	ppm
087-19A Boys Bathroom Sink Faucet Right	6/30/2016 17:18	7/5/2016	36433	Lead	180	15	ppb
087-20A Boys Bathroom Spigot	6/30/2016 17:19	7/5/2016	36435	Copper	ND	1.3	ppm
087-20A Boys Bathroom Spigot	6/30/2016 17:19	7/5/2016	36435	Lead	11	15	ppb
087-21A Custodial #2 Sink Faucet	6/30/2016 17:22	7/5/2016	36437	Copper	ND	1.3	ppm
087-21A Custodial #2 Sink Faucet	6/30/2016 17:22	7/5/2016	36437	Lead	9	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Vestal Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
087-22A Nurses Office Sink Faucet	6/30/2016 17:24	7/5/2016	36439	Copper	ND	1.3	ppm
087-22A Nurses Office Sink Faucet	6/30/2016 17:24	7/5/2016	36439	Lead	21	15	ppb
087-23A Girls Bathroom Sink Faucet Left	6/30/2016 17:23	7/5/2016	36441	Copper	ND	1.3	ppm
087-23A Girls Bathroom Sink Faucet Left	6/30/2016 17:23	7/5/2016	36441	Lead	5	15	ppb
087-24A Girls Bathroom Sink Faucet Middle	6/30/2016 17:24	7/5/2016	36443	Copper	ND	1.3	ppm
087-24A Girls Bathroom Sink Faucet Middle	6/30/2016 17:24	7/5/2016	36443	Lead	6	15	ppb
087-25A Girls Bathroom Sink Faucet Right	6/30/2016 17:25	7/5/2016	36445	Copper	ND	1.3	ppm
087-25A Girls Bathroom Sink Faucet Right	6/30/2016 17:25	7/5/2016	36445	Lead	6	15	ppb
087-26A Girls Bathroom Spigot	6/30/2016 17:26	7/5/2016	36447	Copper	ND	1.3	ppm
087-26A Girls Bathroom Spigot	6/30/2016 17:26	7/5/2016	36447	Lead	41	15	ppb
087-27A Counselor Sink Faucet	6/30/2016 17:28	7/5/2016	36449	Copper	ND	1.3	ppm
087-27A Counselor Sink Faucet	6/30/2016 17:28	7/5/2016	36449	Lead	7	15	ppb
087-28A Principal's Office Bathroom Sink Faucet	6/30/2016 17:29	7/5/2016	36451	Copper	ND	1.3	ppm
087-28A Principal's Office Bathroom Sink Faucet	6/30/2016 17:29	7/5/2016	36451	Lead	20	15	ppb
087-29A Drinking Fountain Next to Gym Left	6/30/2016 17:31	7/5/2016	36453	Copper	ND	1.3	ppm
087-29A Drinking Fountain Next to Gym Left	6/30/2016 17:31	7/5/2016	36453	Lead	1	15	ppb
087-30A Drinking Fountain Next to Gym Right	6/30/2016 17:32	7/5/2016	36455	Copper	ND	1.3	ppm
087-30A Drinking Fountain Next to Gym Right	6/30/2016 17:32	7/5/2016	36455	Lead	ND	15	ppb
087-31A Faculty Bathroom Sink Faucet	6/30/2016 17:33	7/5/2016	36457	Copper	0.4	1.3	ppm
087-31A Faculty Bathroom Sink Faucet	6/30/2016 17:33	7/5/2016	36457	Lead	5	15	ppb
087-32A Girls Bathroom Sink Faucet Left	6/30/2016 17:37	7/5/2016	36459	Copper	ND	1.3	ppm
087-32A Girls Bathroom Sink Faucet Left	6/30/2016 17:37	7/5/2016	36459	Lead	4	15	ppb
087-33A Girls Bathroom Sink Faucet Middle	6/30/2016 17:35	7/5/2016	36461	Copper	0.1	1.3	ppm
087-33A Girls Bathroom Sink Faucet Middle	6/30/2016 17:35	7/5/2016	36461	Lead	8	15	ppb
087-34A Girls Bathroom Sink Faucet Right	6/30/2016 17:37	7/6/2016	36463	Copper	ND	1.3	ppm
087-34A Girls Bathroom Sink Faucet Right	6/30/2016 17:37	7/6/2016	36463	Lead	6	15	ppb
087-35A Girls Bathroom Spigot	6/30/2016 17:37	7/6/2016	36465	Copper	ND	1.3	ppm
087-35A Girls Bathroom Spigot	6/30/2016 17:37	7/6/2016	36465	Lead	13	15	ppb
087-37A Rm 104 Sink Faucet	6/30/2016 17:38	7/6/2016	36469	Copper	ND	1.3	ppm
087-37A Rm 104 Sink Faucet	6/30/2016 17:38	7/6/2016	36469	Lead	10	15	ppb
087-38A Rm 104 Drinking Fountain	6/30/2016 17:38	7/6/2016	36471	Copper	ND	1.3	ppm
087-38A Rm 104 Drinking Fountain	6/30/2016 17:38	7/6/2016	36471	Lead	3	15	ppb
087-39A Rm 103 Sink Faucet	6/30/2016 17:42	7/6/2016	36473	Copper	ND	1.3	ppm
087-39A Rm 103 Sink Faucet	6/30/2016 17:42	7/6/2016	36473	Lead	2	15	ppb
087-40A Rm 103 Drinking Fountain	6/30/2016 17:43	7/6/2016	36475	Copper	ND	1.3	ppm
087-40A Rm 103 Drinking Fountain	6/30/2016 17:43	7/6/2016	36475	Lead	3	15	ppb
087-41A Drinking Fountain Outside 102 Left	6/30/2016 17:45	7/6/2016	36477	Copper	ND	1.3	ppm
087-41A Drinking Fountain Outside 102 Left	6/30/2016 17:45	7/6/2016	36477	Lead	2	15	ppb
087-42A Drinking Fountain Outside 102 Right	6/30/2016 17:46	7/5/2016	36479	Copper	ND	1.3	ppm
087-42A Drinking Fountain Outside 102 Right	6/30/2016 17:46	7/5/2016	36479	Lead	ND	15	ppb
087-43A Boys Bathroom Sink Faucet Left	6/30/2016 17:47	7/5/2016	36481	Copper	ND	1.3	ppm
087-43A Boys Bathroom Sink Faucet Left	6/30/2016 17:47	7/5/2016	36481	Lead	10	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Vestal Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
087-44A Boys Bathroom Sink Faucet Middle	6/30/2016 17:48	7/5/2016	36483	Copper	ND	1.3	ppm
087-44A Boys Bathroom Sink Faucet Middle	6/30/2016 17:48	7/5/2016	36483	Lead	16	15	ppb
087-45A Boys Bathroom Sink Faucet Right	6/30/2016 17:50	7/5/2016	36485	Copper	ND	1.3	ppm
087-45A Boys Bathroom Sink Faucet Right	6/30/2016 17:50	7/5/2016	36485	Lead	7	15	ppb
087-46A Boys Bathroom Spigot	6/30/2016 17:52	7/5/2016	36487	Copper	ND	1.3	ppm
087-46A Boys Bathroom Spigot	6/30/2016 17:52	7/5/2016	36487	Lead	20	15	ppb
087-47A Rm 101 Sink Faucet	6/30/2016 17:52	7/5/2016	36489	Copper	ND	1.3	ppm
087-47A Rm 101 Sink Faucet	6/30/2016 17:52	7/5/2016	36489	Lead	8	15	ppb
087-48A Rm 101 Drinking Fountain	6/30/2016 17:53	7/5/2016	36491	Copper	ND	1.3	ppm
087-48A Rm 101 Drinking Fountain	6/30/2016 17:53	7/5/2016	36491	Lead	6	15	ppb
087-49A Rm 100 Sink Faucet	6/30/2016 17:54	7/5/2016	36493	Copper	ND	1.3	ppm
087-49A Rm 100 Sink Faucet	6/30/2016 17:54	7/5/2016	36493	Lead	7	15	ppb
087-50A Rm 100 Drinking Fountain	6/30/2016 17:55	7/5/2016	36495	Copper	ND	1.3	ppm
087-50A Rm 100 Drinking Fountain	6/30/2016 17:55	7/5/2016	36495	Lead	10	15	ppb
087-51A Rm 202 Sink Faucet	6/30/2016 18:06	7/5/2016	36497	Copper	ND	1.3	ppm
087-51A Rm 202 Sink Faucet	6/30/2016 18:06	7/5/2016	36497	Lead	3	15	ppb
087-52A Rm 202 Drinking Fountain	6/30/2016 18:07	7/5/2016	36499	Copper	ND	1.3	ppm
087-52A Rm 202 Drinking Fountain	6/30/2016 18:07	7/5/2016	36499	Lead	ND	15	ppb
087-53A Boys Bathroom Sink Faucet Left	6/30/2016 18:09	7/5/2016	36501	Copper	ND	1.3	ppm
087-53A Boys Bathroom Sink Faucet Left	6/30/2016 18:09	7/5/2016	36501	Lead	9	15	ppb
087-54A Boys Bathroom Sink Faucet Middle	6/30/2016 18:10	7/5/2016	36503	Copper	ND	1.3	ppm
087-54A Boys Bathroom Sink Faucet Middle	6/30/2016 18:10	7/5/2016	36503	Lead	9	15	ppb
087-55A Boys Bathroom Sink Faucet Right	6/30/2016 18:11	7/5/2016	36505	Copper	ND	1.3	ppm
087-55A Boys Bathroom Sink Faucet Right	6/30/2016 18:11	7/5/2016	36505	Lead	11	15	ppb
087-56A Boys Bathroom Spigot	6/30/2016 18:12	7/5/2016	36507	Copper	ND	1.3	ppm
087-56A Boys Bathroom Spigot	6/30/2016 18:12	7/5/2016	36507	Lead	19	15	ppb
087-57A Drinking Fountain Outside 202 Left	6/30/2016 18:12	7/5/2016	36509	Copper	ND	1.3	ppm
087-57A Drinking Fountain Outside 202 Left	6/30/2016 18:12	7/5/2016	36509	Lead	ND	15	ppb
087-58A Drinking Fountain Outside 202 Right	6/30/2016 18:13	7/5/2016	36511	Copper	ND	1.3	ppm
087-58A Drinking Fountain Outside 202 Right	6/30/2016 18:13	7/5/2016	36511	Lead	5	15	ppb
087-59A Custodial #3 Sink Faucet	6/30/2016 18:15	7/6/2016	36513	Copper	ND	1.3	ppm
087-59A Custodial #3 Sink Faucet	6/30/2016 18:15	7/6/2016	36513	Lead	5	15	ppb
087-60A Girls Bathroom Sink Faucet Left	6/30/2016 18:17	7/6/2016	36515	Copper	ND	1.3	ppm
087-60A Girls Bathroom Sink Faucet Left	6/30/2016 18:17	7/6/2016	36515	Lead	3	15	ppb
087-61A Girls Bathroom Sink Faucet Middle	6/30/2016 18:18	7/6/2016	36517	Copper	ND	1.3	ppm
087-61A Girls Bathroom Sink Faucet Middle	6/30/2016 18:18	7/6/2016	36517	Lead	6	15	ppb
087-62A Girls Bathroom Sink Faucet Right	6/30/2016 18:19	7/6/2016	36519	Copper	ND	1.3	ppm
087-62A Girls Bathroom Sink Faucet Right	6/30/2016 18:19	7/6/2016	36519	Lead	5	15	ppb
087-63A Girls Bathroom Spigot	6/30/2016 18:20	7/6/2016	36521	Copper	ND	1.3	ppm
087-63A Girls Bathroom Spigot	6/30/2016 18:20	7/6/2016	36521	Lead	45	15	ppb
087-64A Drinking Fountain Outside 208 Left	6/30/2016 18:21	7/6/2016	36523	Copper	ND	1.3	ppm
087-64A Drinking Fountain Outside 208 Left	6/30/2016 18:21	7/6/2016	36523	Lead	14	15	ppb
087-65A Drinking Fountain Outside 208 Right	6/30/2016 18:22	7/6/2016	36525	Copper	ND	1.3	ppm
087-65A Drinking Fountain Outside 208 Right	6/30/2016 18:22	7/6/2016	36525	Lead	14	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Vestal Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
087-66A Drinking Fountain Outside 209 Left	6/30/2016 18:24	7/6/2016	36527	Copper	ND	1.3	ppm
087-66A Drinking Fountain Outside 209 Left	6/30/2016 18:24	7/6/2016	36527	Lead	7	15	ppb
087-67A Drinking Fountain Outside 209 Right	6/30/2016 18:25	7/6/2016	36529	Copper	ND	1.3	ppm
087-67A Drinking Fountain Outside 209 Right	6/30/2016 18:25	7/6/2016	36529	Lead	8	15	ppb
087-68A Faculty/AP Sink Faucet	6/30/2016 18:26	7/6/2016	36531	Copper	ND	1.3	ppm
087-68A Faculty/AP Sink Faucet	6/30/2016 18:26	7/6/2016	36531	Lead	7	15	ppb
087-69A Girls Bathroom Sink Faucet Left	6/30/2016 18:27	7/6/2016	36533	Copper	ND	1.3	ppm
087-69A Girls Bathroom Sink Faucet Left	6/30/2016 18:27	7/6/2016	36533	Lead	6	15	ppb
087-70A Girls Bathroom Sink Faucet Middle	6/30/2016 18:28	7/6/2016	36535	Copper	ND	1.3	ppm
087-70A Girls Bathroom Sink Faucet Middle	6/30/2016 18:28	7/6/2016	36535	Lead	6	15	ppb
087-71A Girls Bathroom Sink Faucet Right	6/30/2016 18:29	7/6/2016	36537	Copper	ND	1.3	ppm
087-71A Girls Bathroom Sink Faucet Right	6/30/2016 18:29	7/6/2016	36537	Lead	6	15	ppb
087-72A Girls Bathroom Spigot	6/30/2016 18:30	7/6/2016	36539	Copper	ND	1.3	ppm
087-72A Girls Bathroom Spigot	6/30/2016 18:30	7/6/2016	36539	Lead	21	15	ppb
087-73A Custodial #4 Sink Faucet	6/30/2016 18:31	7/6/2016	36541	Copper	ND	1.3	ppm
087-73A Custodial #4 Sink Faucet	6/30/2016 18:31	7/6/2016	36541	Lead	6	15	ppb
087-74A Rm 213 Sink Faucet	6/30/2016 18:52	7/6/2016	36543	Copper	ND	1.3	ppm
087-74A Rm 213 Sink Faucet	6/30/2016 18:52	7/6/2016	36543	Lead	4	15	ppb
087-75A Rm 213 Drinking Fountain	6/30/2016 18:53	7/6/2016	36545	Copper	ND	1.3	ppm
087-75A Rm 213 Drinking Fountain	6/30/2016 18:53	7/6/2016	36545	Lead	4	15	ppb
087-76A Drinking Fountain Outside 213 Left	6/30/2016 18:54	7/6/2016	36547	Copper	ND	1.3	ppm
087-76A Drinking Fountain Outside 213 Left	6/30/2016 18:54	7/6/2016	36547	Lead	5	15	ppb
087-77A Drinking Fountain Outside 213 Right	6/30/2016 18:55	7/6/2016	36549	Copper	ND	1.3	ppm
087-77A Drinking Fountain Outside 213 Right	6/30/2016 18:55	7/6/2016	36549	Lead	4	15	ppb
087-78A Boys Bathroom Sink Faucet Left	6/30/2016 18:56	7/6/2016	36551	Copper	ND	1.3	ppm
087-78A Boys Bathroom Sink Faucet Left	6/30/2016 18:56	7/6/2016	36551	Lead	12	15	ppb
087-79A Boys Bathroom Sink Faucet Middle	6/30/2016 18:57	7/6/2016	36553	Copper	ND	1.3	ppm
087-79A Boys Bathroom Sink Faucet Middle	6/30/2016 18:57	7/6/2016	36553	Lead	5	15	ppb
087-80A Boys Bathroom Sink Faucet Right	6/30/2016 18:58	7/6/2016	36555	Copper	ND	1.3	ppm
087-80A Boys Bathroom Sink Faucet Right	6/30/2016 18:58	7/6/2016	36555	Lead	5	15	ppb
087-81A Boys Bathroom Spigot	6/30/2016 18:41	7/6/2016	36557	Copper	ND	1.3	ppm
087-81A Boys Bathroom Spigot	6/30/2016 18:41	7/6/2016	36557	Lead	6	15	ppb
087-82A Rm 215 Sink Faucet	6/30/2016 18:43	7/6/2016	36559	Copper	ND	1.3	ppm
087-82A Rm 215 Sink Faucet	6/30/2016 18:43	7/6/2016	36559	Lead	3	15	ppb
087-83A Rm 215 Drinking Fountain	6/30/2016 18:44	7/6/2016	36561	Copper	ND	1.3	ppm
087-83A Rm 215 Drinking Fountain	6/30/2016 18:44	7/6/2016	36561	Lead	1	15	ppb
087-84A Portable #1 Sink Faucet	6/30/2016 19:18	7/6/2016	36563	Copper	0.2	1.3	ppm
087-84A Portable #1 Sink Faucet	6/30/2016 19:18	7/6/2016	36563	Lead	2	15	ppb
087-85A Portable #2 Girls Sink Faucet	6/30/2016 19:12	7/6/2016	36565	Copper	ND	1.3	ppm
087-85A Portable #2 Girls Sink Faucet	6/30/2016 19:12	7/6/2016	36565	Lead	2	15	ppb
087-86A Portable #2 Boys Sink Faucet	6/30/2016 19:15	7/6/2016	36567	Copper	ND	1.3	ppm
087-86A Portable #2 Boys Sink Faucet	6/30/2016 19:15	7/6/2016	36567	Lead	1	15	ppb
087-87A Portable #2 Teachers Sink Faucet	6/30/2016 19:13	7/6/2016	36569	Copper	ND	1.3	ppm
087-87A Portable #2 Teachers Sink Faucet	6/30/2016 19:13	7/6/2016	36569	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Vestal Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
087-88A Portable #2 Drinking Fountain	6/30/2016 19:15	7/6/2016	36571	Copper	ND	1.3	ppm
087-88A Portable #2 Drinking Fountain	6/30/2016 19:15	7/6/2016	36571	Lead	2	15	ppb
087-89A Portable #3 Left Bathroom Sink Faucet	6/30/2016 19:08	7/6/2016	36573	Copper	ND	1.3	ppm
087-89A Portable #3 Left Bathroom Sink Faucet	6/30/2016 19:08	7/6/2016	36573	Lead	12	15	ppb
087-90A Portable #3 Right Bathroom Sink Faucet	6/30/2016 19:08	7/6/2016	36575	Copper	ND	1.3	ppm
087-90A Portable #3 Right Bathroom Sink Faucet	6/30/2016 19:08	7/6/2016	36575	Lead	14	15	ppb
087-91A Outside Spigot Near Portable #1	6/30/2016 19:20	7/6/2016	36577	Copper	ND	1.3	ppm
087-91A Outside Spigot Near Portable #1	6/30/2016 19:20	7/6/2016	36577	Lead	2	15	ppb
087-92A Outside Spigot Near Bball Court South	6/30/2016 19:22	7/6/2016	36579	Copper	ND	1.3	ppm
087-92A Outside Spigot Near Bball Court South	6/30/2016 19:22	7/6/2016	36579	Lead	104	15	ppb
087-93A Outside Spigot Near Bball Court North	6/30/2016 19:25	7/6/2016	36581	Copper	ND	1.3	ppm
087-93A Outside Spigot Near Bball Court North	6/30/2016 19:25	7/6/2016	36581	Lead	29	15	ppb
087-94A Outside Spigot North Side	6/30/2016 19:27	7/6/2016	36583	Copper	ND	1.3	ppm
087-94A Outside Spigot North Side	6/30/2016 19:27	7/6/2016	36583	Lead	55	15	ppb
087-95A Outside Spigot Front of School North	6/30/2016 19:31	7/6/2016	36585	Copper	ND	1.3	ppm
087-95A Outside Spigot Front of School North	6/30/2016 19:31	7/6/2016	36585	Lead	9	15	ppb
087-96A Outside Spigot Front of School South	6/30/2016 19:34	7/6/2016	36587	Copper	ND	1.3	ppm
087-96A Outside Spigot Front of School South	6/30/2016 19:34	7/6/2016	36587	Lead	11	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.