

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
West Sylvan Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
088-01A 165 Sink Faucet	6/29/2016 08:20	7/8/2016 09:12	10354327001	Copper	0.0	1.3	ppm
088-01A 165 Sink Faucet	6/29/2016 08:20	7/8/2016 09:12	10354327001	Lead	1	15	ppb
088-02A 172 Sink Faucet	6/29/2016 08:44	7/8/2016 09:17	10354327003	Copper	0.3	1.3	ppm
088-02A 172 Sink Faucet	6/29/2016 08:44	7/8/2016 09:17	10354327003	Lead	3	15	ppb
088-03A 170 Sink Faucet	6/29/2016 09:03	7/8/2016 09:19	10354327005	Copper	0.2	1.3	ppm
088-03A 170 Sink Faucet	6/29/2016 09:03	7/8/2016 09:19	10354327005	Lead	7	15	ppb
088-04A Hallway Drinking Fountain	6/29/2016 08:46	7/8/2016 09:20	10354327007	Copper	0.0	1.3	ppm
088-04A Hallway Drinking Fountain	6/29/2016 08:46	7/8/2016 09:20	10354327007	Lead	27	15	ppb
088-05A 166 Sink Faucet (1)	6/29/2016 08:29	7/8/2016 09:22	10354327009	Copper	0.2	1.3	ppm
088-05A 166 Sink Faucet (1)	6/29/2016 08:29	7/8/2016 09:22	10354327009	Lead	8	15	ppb
088-06A 166 Sink Faucet (2)	6/29/2016 08:32	7/8/2016 09:23	10354327011	Copper	0.1	1.3	ppm
088-06A 166 Sink Faucet (2)	6/29/2016 08:32	7/8/2016 09:23	10354327011	Lead	2	15	ppb
088-07A 164 Sink Faucet (1)	6/29/2016 08:50	7/8/2016 09:24	10354327013	Copper	0.3	1.3	ppm
088-07A 164 Sink Faucet (1)	6/29/2016 08:50	7/8/2016 09:24	10354327013	Lead	9	15	ppb
088-08A 164 Sink Faucet (2)	6/29/2016 08:56	7/8/2016 09:41	10354327015	Copper	0.1	1.3	ppm
088-08A 164 Sink Faucet (2)	6/29/2016 08:56	7/8/2016 09:41	10354327015	Lead	14	15	ppb
088-09A 164 Drinking Fountain	6/29/2016 08:53	7/8/2016 09:42	10354327017	Copper	0.1	1.3	ppm
088-09A 164 Drinking Fountain	6/29/2016 08:53	7/8/2016 09:42	10354327017	Lead	9	15	ppb
088-10A 161 Sink Faucet	6/29/2016 08:38	7/8/2016 09:43	10354327019	Copper	0.1	1.3	ppm
088-10A 161 Sink Faucet	6/29/2016 08:38	7/8/2016 09:43	10354327019	Lead	14	15	ppb
088-11A 159 Sink Faucet	6/29/2016 08:41	7/8/2016 09:45	10354327021	Copper	0.1	1.3	ppm
088-11A 159 Sink Faucet	6/29/2016 08:41	7/8/2016 09:45	10354327021	Lead	16	15	ppb
088-12A 32 Sink Faucet	6/29/2016 09:15	7/8/2016 10:04	10354327023	Copper	0.5	1.3	ppm
088-12A 32 Sink Faucet	6/29/2016 09:15	7/8/2016 09:47	10354327023	Lead	19	15	ppb
088-13A 20 Sink Faucet	6/29/2016 09:05	7/8/2016 09:49	10354327025	Copper	0.4	1.3	ppm
088-13A 20 Sink Faucet	6/29/2016 09:05	7/8/2016 09:49	10354327025	Lead	12	15	ppb
088-14A 21 Sink Faucet	6/29/2016 09:04	7/8/2016 09:52	10354327027	Copper	0.3	1.3	ppm
088-14A 21 Sink Faucet	6/29/2016 09:04	7/8/2016 09:52	10354327027	Lead	27	15	ppb
088-15A Hallway Drinking Fountain	6/29/2016 08:46	7/8/2016 09:53	10354327029	Copper	0.0	1.3	ppm
088-15A Hallway Drinking Fountain	6/29/2016 08:46	7/8/2016 09:53	10354327029	Lead	16	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
West Sylvan Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
088-16A 158 Sink Faucet	6/29/2016 08:50	7/8/2016 09:55	10354327031	Copper	0.1	1.3	ppm
088-16A 158 Sink Faucet	6/29/2016 08:50	7/8/2016 09:55	10354327031	Lead	54	15	ppb
088-17A 157 Sink Faucet	6/29/2016 09:00	7/8/2016 09:59	10354327033	Copper	0.2	1.3	ppm
088-17A 157 Sink Faucet	6/29/2016 09:00	7/8/2016 09:59	10354327033	Lead	68	15	ppb
088-18A 156 Sink Faucet	6/29/2016 08:52	7/8/2016 10:00	10354327035	Copper	0.2	1.3	ppm
088-18A 156 Sink Faucet	6/29/2016 08:52	7/8/2016 10:00	10354327035	Lead	47	15	ppb
088-19A 155 Sink Faucet	6/29/2016 08:55	7/8/2016 10:02	10354327037	Copper	0.1	1.3	ppm
088-19A 155 Sink Faucet	6/29/2016 08:55	7/8/2016 10:02	10354327037	Lead	17	15	ppb
088-20A Girls Bathroom Sink Faucet	6/29/2016 09:07	7/8/2016 10:03	10354327039	Copper	0.3	1.3	ppm
088-20A Girls Bathroom Sink Faucet	6/29/2016 09:07	7/8/2016 10:03	10354327039	Lead	11	15	ppb
088-21A Boys Bathroom Sink Faucet	6/29/2016 08:57	7/8/2016 12:14	10354327041	Copper	0.6	1.3	ppm
088-21A Boys Bathroom Sink Faucet	6/29/2016 08:57	7/8/2016 11:41	10354327041	Lead	6	15	ppb
088-22A 24 Sink Faucet	6/29/2016 09:10	7/8/2016 11:33	10354327043	Copper	0.3	1.3	ppm
088-22A 24 Sink Faucet	6/29/2016 09:10	7/8/2016 11:33	10354327043	Lead	22	15	ppb
088-23A 25 Sink Faucet	6/29/2016 09:14	7/8/2016 11:34	10354327045	Copper	0.3	1.3	ppm
088-23A 25 Sink Faucet	6/29/2016 09:14	7/8/2016 11:34	10354327045	Lead	4	15	ppb
088-24A 23 Sink Faucet	6/29/2016 08:59	7/8/2016 11:35	10354327047	Copper	0.2	1.3	ppm
088-24A 23 Sink Faucet	6/29/2016 08:59	7/8/2016 11:35	10354327047	Lead	2	15	ppb
088-25A 22 Sink Faucet	6/29/2016 09:01	7/8/2016 11:37	10354327049	Copper	0.3	1.3	ppm
088-25A 22 Sink Faucet	6/29/2016 09:01	7/8/2016 11:37	10354327049	Lead	40	15	ppb
088-26A 19 Sink Faucet	6/29/2016 09:19	7/7/2016 11:39	10354327051	Copper	0.4	1.3	ppm
088-26A 19 Sink Faucet	6/29/2016 09:19	7/7/2016 11:39	10354327051	Lead	8	15	ppb
088-27A 18 Sink Faucet	6/29/2016 09:32	7/7/2016 14:52	10354327053	Copper	0.7	1.3	ppm
088-27A 18 Sink Faucet	6/29/2016 09:32	7/7/2016 11:40	10354327053	Lead	29	15	ppb
088-28A Girls Bathroom Sink Faucet (1)	6/29/2016 09:25	7/8/2016 11:38	10354327055	Copper	0.3	1.3	ppm
088-28A Girls Bathroom Sink Faucet (1)	6/29/2016 09:25	7/8/2016 11:38	10354327055	Lead	7	15	ppb
088-29A Girls Bathroom Sink Faucet (2)	6/29/2016 09:26	7/7/2016 14:53	10354327057	Copper	0.7	1.3	ppm
088-29A Girls Bathroom Sink Faucet (2)	6/29/2016 09:26	7/7/2016 11:41	10354327057	Lead	34	15	ppb
088-30A 13 Sink Faucet	6/29/2016 10:03	7/7/2016 14:54	10354327059	Copper	0.6	1.3	ppm
088-30A 13 Sink Faucet	6/29/2016 10:03	7/7/2016 11:46	10354327059	Lead	55	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
West Sylvan Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
088-31A 12 Sink Faucet	6/29/2016 09:59	7/8/2016 11:40	10354327061	Copper	0.3	1.3	ppm
088-31A 12 Sink Faucet	6/29/2016 09:59	7/8/2016 11:40	10354327061	Lead	17	15	ppb
088-32A 16 Sink Faucet	6/29/2016 09:58	7/8/2016 11:49	10354327063	Copper	0.2	1.3	ppm
088-32A 16 Sink Faucet	6/29/2016 09:58	7/8/2016 11:49	10354327063	Lead	7	15	ppb
088-33A Hallway Drinking Fountain	6/29/2016 09:56	7/8/2016 11:50	10354327065	Copper	0.3	1.3	ppm
088-33A Hallway Drinking Fountain	6/29/2016 09:56	7/8/2016 11:50	10354327065	Lead	2	15	ppb
088-34A 11 Sink Faucet	6/29/2016 09:55	7/8/2016 11:53	10354327067	Copper	0.4	1.3	ppm
088-34A 11 Sink Faucet	6/29/2016 09:55	7/8/2016 11:53	10354327067	Lead	18	15	ppb
088-35A 10 Sink Faucet	6/29/2016 09:50	7/8/2016 11:54	10354327069	Copper	0.3	1.3	ppm
088-35A 10 Sink Faucet	6/29/2016 09:50	7/8/2016 11:54	10354327069	Lead	21	15	ppb
088-36A 15 Sink Faucet	6/29/2016 09:48	7/8/2016 11:56	10354327071	Copper	0.3	1.3	ppm
088-36A 15 Sink Faucet	6/29/2016 09:48	7/8/2016 11:56	10354327071	Lead	8	15	ppb
088-37A Boys Bathroom Sink Faucet (1)	6/29/2016 09:50	7/8/2016 12:16	10354327073	Copper	0.9	1.3	ppm
088-37A Boys Bathroom Sink Faucet (1)	6/29/2016 09:50	7/8/2016 11:57	10354327073	Lead	173	15	ppb
088-38A Boys Bathroom Sink Faucet (2)	6/29/2016 09:52	7/8/2016 11:59	10354327075	Copper	0.3	1.3	ppm
088-38A Boys Bathroom Sink Faucet (2)	6/29/2016 09:52	7/8/2016 11:59	10354327075	Lead	9	15	ppb
088-39A 137 Sink Faucet Library	6/29/2016 10:11	7/8/2016 12:18	10354327077	Copper	0.7	1.3	ppm
088-39A 137 Sink Faucet Library	6/29/2016 10:11	7/8/2016 12:00	10354327077	Lead	40	15	ppb
088-40A Hallway Drinking Fountain	6/29/2016 09:20	7/8/2016 12:01	10354327079	Copper	0.3	1.3	ppm
088-40A Hallway Drinking Fountain	6/29/2016 09:20	7/8/2016 12:01	10354327079	Lead	14.7	15	ppb
088-41A 148 Sink Faucet (1)	6/29/2016 10:08	7/8/2016 13:24	10354327081	Copper	0.3	1.3	ppm
088-41A 148 Sink Faucet (1)	6/29/2016 10:08	7/8/2016 13:24	10354327081	Lead	5	15	ppb
088-42A 148 Sink Faucet (2)	6/29/2016 10:24	7/8/2016 13:53	10354327083	Copper	0.5	1.3	ppm
088-42A 148 Sink Faucet (2)	6/29/2016 10:24	7/8/2016 13:23	10354327083	Lead	12	15	ppb
088-43A 140 Sink Faucet	6/29/2016 10:16	7/8/2016 13:55	10354327085	Copper	0.7	1.3	ppm
088-43A 140 Sink Faucet	6/29/2016 10:16	7/8/2016 13:33	10354327085	Lead	9	15	ppb
088-44A 140A Sink Faucet	6/29/2016 10:22	7/8/2016 13:34	10354327087	Copper	0.3	1.3	ppm
088-44A 140A Sink Faucet	6/29/2016 10:22	7/8/2016 13:34	10354327087	Lead	64	15	ppb
088-45A 138 Sink Faucet	6/29/2016 10:10	7/8/2016 13:35	10354327089	Copper	0.3	1.3	ppm
088-45A 138 Sink Faucet	6/29/2016 10:10	7/8/2016 13:35	10354327089	Lead	14.8	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
West Sylvan Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
088-46A 134 Sink Faucet	6/29/2016 10:14	7/7/2016 14:56	10354327091	Copper	1.30	1.3	ppm
088-46A 134 Sink Faucet	6/29/2016 10:14	7/7/2016 11:47	10354327091	Lead	12	15	ppb
088-47A 132 Sink Faucet	6/29/2016 10:17	7/7/2016 14:57	10354327093	Copper	0.7	1.3	ppm
088-47A 132 Sink Faucet	6/29/2016 10:17	7/7/2016 11:48	10354327093	Lead	6	15	ppb
088-48A Hallway Drinking Fountain	6/29/2016 10:28	7/8/2016 13:56	10354327095	Copper	0.7	1.3	ppm
088-48A Hallway Drinking Fountain	6/29/2016 10:28	7/8/2016 13:37	10354327095	Lead	3	15	ppb
088-49A 131 Sink Faucet	6/29/2016 10:32	7/8/2016 13:38	10354327097	Copper	0.3	1.3	ppm
088-49A 131 Sink Faucet	6/29/2016 10:32	7/8/2016 13:38	10354327097	Lead	13	15	ppb
088-50A Boys Bathroom Sink Faucet	6/29/2016 10:30	7/8/2016 13:57	10354327099	Copper	1.0	1.3	ppm
088-50A Boys Bathroom Sink Faucet	6/29/2016 10:30	7/8/2016 13:39	10354327099	Lead	3	15	ppb
088-51A 129 Sink Faucet	6/29/2016 10:35	7/8/2016 13:41	10354327101	Copper	0.3	1.3	ppm
088-51A 129 Sink Faucet	6/29/2016 10:35	7/8/2016 13:41	10354327101	Lead	18	15	ppb
088-52A Womens Sink Faucet	6/29/2016 10:32	7/8/2016 13:42	10354327103	Copper	0.4	1.3	ppm
088-52A Womens Sink Faucet	6/29/2016 10:32	7/8/2016 13:42	10354327103	Lead	6	15	ppb
088-53A 176 Shower (1)	6/29/2016 11:58	7/8/2016 13:46	10354327105	Copper	0.2	1.3	ppm
088-53A 176 Shower (1)	6/29/2016 11:58	7/8/2016 13:46	10354327105	Lead	76	15	ppb
088-54A 176 Shower (2)	6/29/2016 11:56	7/7/2016 14:58	10354327107	Copper	0.9	1.3	ppm
088-54A 176 Shower (2)	6/29/2016 11:56	7/7/2016 14:58	10354327107	Lead	483	15	ppb
088-55A 176 Shower (3)	6/29/2016 12:01	7/7/2016 14:59	10354327109	Copper	0.5	1.3	ppm
088-55A 176 Shower (3)	6/29/2016 12:01	7/7/2016 11:50	10354327109	Lead	255	15	ppb
088-56A 176 Shower (4)	6/29/2016 12:08	7/8/2016 13:49	10354327111	Copper	0.1	1.3	ppm
088-56A 176 Shower (4)	6/29/2016 12:08	7/8/2016 13:49	10354327111	Lead	14.5	15	ppb
088-57A 176 Shower (5)	6/29/2016 12:07	7/8/2016 13:51	10354327113	Copper	0.1	1.3	ppm
088-57A 176 Shower (5)	6/29/2016 12:07	7/8/2016 13:51	10354327113	Lead	53	15	ppb
088-58A 176 Shower (6)	6/29/2016 12:05	7/8/2016 13:52	10354327115	Copper	0.1	1.3	ppm
088-58A 176 Shower (6)	6/29/2016 12:05	7/8/2016 13:52	10354327115	Lead	30	15	ppb
088-59A 176 Drinking Fountain	6/29/2016 12:05	7/8/2016 19:00	10354327117	Copper	0.0	1.3	ppm
088-59A 176 Drinking Fountain	6/29/2016 12:05	7/8/2016 19:00	10354327117	Lead	0	15	ppb
088-60A 176 Sink Faucet (1)	6/29/2016 12:07	7/8/2016 14:05	10354327119	Copper	0.2	1.3	ppm
088-60A 176 Sink Faucet (1)	6/29/2016 12:07	7/8/2016 14:05	10354327119	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
West Sylvan Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
088-61A 176 Sink Faucet (2)	6/29/2016 12:13	7/8/2016 12:08	10354327121	Copper	0.2	1.3	ppm
088-61A 176 Sink Faucet (2)	6/29/2016 12:13	7/8/2016 12:08	10354327121	Lead	5	15	ppb
088-62A 185 Sink Faucet	6/29/2016 12:10	7/8/2016 12:22	10354327123	Copper	0.1	1.3	ppm
088-62A 185 Sink Faucet	6/29/2016 12:10	7/8/2016 12:22	10354327123	Lead	6	15	ppb
088-63A Gymnasium Drinking Fountain	6/29/2016 12:10	7/8/2016 12:48	10354327125	Copper	0.6	1.3	ppm
088-63A Gymnasium Drinking Fountain	6/29/2016 12:10	7/8/2016 12:23	10354327125	Lead	2	15	ppb
088-64A 172 Shower (1)	6/29/2016 12:25	7/8/2016 12:25	10354327127	Copper	0.2	1.3	ppm
088-64A 172 Shower (1)	6/29/2016 12:25	7/8/2016 12:25	10354327127	Lead	6	15	ppb
088-65A 172 Shower (2)	6/29/2016 12:26	7/8/2016 12:26	10354327129	Copper	0.1	1.3	ppm
088-65A 172 Shower (2)	6/29/2016 12:26	7/8/2016 12:26	10354327129	Lead	30	15	ppb
088-66A 172 Shower (3)	6/29/2016 12:28	7/8/2016 12:27	10354327131	Copper	0.1	1.3	ppm
088-66A 172 Shower (3)	6/29/2016 12:28	7/8/2016 12:27	10354327131	Lead	87	15	ppb
088-67A 172 Shower (4)	6/29/2016 12:30	7/8/2016 12:29	10354327133	Copper	0.2	1.3	ppm
088-67A 172 Shower (4)	6/29/2016 12:30	7/8/2016 12:29	10354327133	Lead	94	15	ppb
088-68A 172 Shower (5)	6/29/2016 12:31	7/8/2016 12:30	10354327135	Copper	0.1	1.3	ppm
088-68A 172 Shower (5)	6/29/2016 12:31	7/8/2016 12:30	10354327135	Lead	53	15	ppb
088-69A 172 Shower (6)	6/29/2016 12:30	7/8/2016 19:03	10354327137	Copper	0.7	1.3	ppm
088-69A 172 Shower (6)	6/29/2016 12:30	7/8/2016 17:52	10354327137	Lead	75	15	ppb
088-70A 172 Shower (7)	6/29/2016 12:27	7/8/2016 19:05	10354327139	Copper	1.1	1.3	ppm
088-70A 172 Shower (7)	6/29/2016 12:27	7/8/2016 17:58	10354327139	Lead	26	15	ppb
088-71A 172 Drinking Fountain	6/29/2016 12:33	7/8/2016 12:32	10354327141	Copper	0.1	1.3	ppm
088-71A 172 Drinking Fountain	6/29/2016 12:33	7/8/2016 12:32	10354327141	Lead	8	15	ppb
088-72A 172 Sink Faucet (1)	6/29/2016 12:37	7/8/2016 12:33	10354327143	Copper	0.2	1.3	ppm
088-72A 172 Sink Faucet (1)	6/29/2016 12:37	7/8/2016 12:33	10354327143	Lead	6	15	ppb
088-73A 172 Sink Faucet (2)	6/29/2016 12:39	7/8/2016 12:34	10354327145	Copper	0.2	1.3	ppm
088-73A 172 Sink Faucet (2)	6/29/2016 12:39	7/8/2016 12:34	10354327145	Lead	3	15	ppb
088-74A 172 Water Spigot	6/29/2016 12:36	7/8/2016 17:59	10354327147	Copper	0.4	1.3	ppm
088-74A 172 Water Spigot	6/29/2016 12:36	7/8/2016 17:59	10354327147	Lead	223	15	ppb
088-75A 180 Sink Faucet	6/29/2016 12:52	7/8/2016 12:50	10354327149	Copper	0.5	1.3	ppm
088-75A 180 Sink Faucet	6/29/2016 12:52	7/8/2016 12:40	10354327149	Lead	8	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
West Sylvan Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
088-77A 9 Sink Faucet (1)	6/29/2016 09:42	7/8/2016 12:51	10354327151	Copper	0.5	1.3	ppm
088-77A 9 Sink Faucet (1)	6/29/2016 09:42	7/8/2016 12:41	10354327151	Lead	3	15	ppb
088-78A 9 Sink Faucet (2)	6/29/2016 09:32	7/8/2016 12:55	10354327153	Copper	0.7	1.3	ppm
088-78A 9 Sink Faucet (2)	6/29/2016 09:32	7/8/2016 12:43	10354327153	Lead	13	15	ppb
088-79A 100 Sink Faucet	6/29/2016 11:40	7/8/2016 12:44	10354327155	Copper	0.1	1.3	ppm
088-79A 100 Sink Faucet	6/29/2016 11:40	7/8/2016 12:44	10354327155	Lead	7	15	ppb
088-80A 101A Sink Faucet	6/29/2016 11:59	7/8/2016 12:46	10354327157	Copper	0.1	1.3	ppm
088-80A 101A Sink Faucet	6/29/2016 11:59	7/8/2016 12:46	10354327157	Lead	14	15	ppb
088-81A Drinking Fountain by 101	6/29/2016 11:46	7/8/2016 12:47	10354327159	Copper	0.1	1.3	ppm
088-81A Drinking Fountain by 101	6/29/2016 11:46	7/8/2016 12:47	10354327159	Lead	8	15	ppb
088-82A Cafeteria Sink Faucet (1)	6/29/2016 11:46	7/8/2016 14:45	10354327161	Copper	0.3	1.3	ppm
088-82A Cafeteria Sink Faucet (1)	6/29/2016 11:46	7/8/2016 14:45	10354327161	Lead	8	15	ppb
088-83A Cafeteria Sink Faucet (2)	6/29/2016 11:49	7/8/2016 14:54	10354327163	Copper	0.4	1.3	ppm
088-83A Cafeteria Sink Faucet (2)	6/29/2016 11:49	7/8/2016 14:54	10354327163	Lead	57	15	ppb
088-84A Cafeteria Sink Faucet (3)	6/29/2016 11:50	7/8/2016 19:07	10354327165	Copper	0.5	1.3	ppm
088-84A Cafeteria Sink Faucet (3)	6/29/2016 11:50	7/8/2016 18:01	10354327165	Lead	20	15	ppb
088-85A Cafeteria Sink Faucet (4)	6/29/2016 11:52	7/8/2016 19:08	10354327167	Copper	1.30	1.3	ppm
088-85A Cafeteria Sink Faucet (4)	6/29/2016 11:52	7/8/2016 18:02	10354327167	Lead	12	15	ppb
088-86A Cafeteria Sink Faucet (5)	6/29/2016 11:49	7/8/2016 19:10	10354327169	Copper	1.1	1.3	ppm
088-86A Cafeteria Sink Faucet (5)	6/29/2016 11:49	7/8/2016 18:03	10354327169	Lead	26	15	ppb
088-87A Sink Faucet by 105	6/29/2016 11:41	7/8/2016 14:56	10354327171	Copper	0.1	1.3	ppm
088-87A Sink Faucet by 105	6/29/2016 11:41	7/8/2016 14:56	10354327171	Lead	25	15	ppb
088-88A 106 Sink Faucet	6/29/2016 11:34	7/8/2016 14:57	10354327173	Copper	0.2	1.3	ppm
088-88A 106 Sink Faucet	6/29/2016 11:34	7/8/2016 14:57	10354327173	Lead	36	15	ppb
088-89A 108 Sink Faucet	6/29/2016 11:32	7/8/2016 14:58	10354327175	Copper	0.1	1.3	ppm
088-89A 108 Sink Faucet	6/29/2016 11:32	7/8/2016 14:58	10354327175	Lead	12	15	ppb
088-90A 112 Sink Faucet (1)	6/29/2016 11:33	7/8/2016 19:11	10354327177	Copper	1.0	1.3	ppm
088-90A 112 Sink Faucet (1)	6/29/2016 11:33	7/8/2016 18:05	10354327177	Lead	132	15	ppb
088-91A 112 Sink Faucet (2)	6/29/2016 11:35	7/8/2016 15:00	10354327179	Copper	0.1	1.3	ppm
088-91A 112 Sink Faucet (2)	6/29/2016 11:35	7/8/2016 15:00	10354327179	Lead	11	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
West Sylvan Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
088-92A 110 Sink Faucet	6/29/2016 11:30	7/8/2016 15:01	10354327181	Copper	0.1	1.3	ppm
088-92A 110 Sink Faucet	6/29/2016 11:30	7/8/2016 15:01	10354327181	Lead	5	15	ppb
088-93A 113 Sink Faucet	6/29/2016 11:30	7/8/2016 15:02	10354327183	Copper	0.1	1.3	ppm
088-93A 113 Sink Faucet	6/29/2016 11:30	7/8/2016 15:02	10354327183	Lead	61	15	ppb
088-94A 114 Sink Faucet	6/29/2016 11:26	7/8/2016 15:04	10354327185	Copper	0.1	1.3	ppm
088-94A 114 Sink Faucet	6/29/2016 11:26	7/8/2016 15:04	10354327185	Lead	6	15	ppb
088-95A 115 Sink Faucet	6/29/2016 11:28	7/8/2016 15:08	10354327187	Copper	0.1	1.3	ppm
088-95A 115 Sink Faucet	6/29/2016 11:28	7/8/2016 15:08	10354327187	Lead	16	15	ppb
088-96A 116 Sink Faucet	6/29/2016 11:23	7/8/2016 15:09	10354327189	Copper	0.1	1.3	ppm
088-96A 116 Sink Faucet	6/29/2016 11:23	7/8/2016 15:09	10354327189	Lead	34	15	ppb
088-97A 118 Sink Faucet (1)	6/29/2016 11:15	7/8/2016 15:10	10354327191	Copper	0.4	1.3	ppm
088-97A 118 Sink Faucet (1)	6/29/2016 11:15	7/8/2016 15:10	10354327191	Lead	10	15	ppb
088-98A 118 Eyewash	6/29/2016 11:17	7/8/2016 16:00	10354327193	Copper	0.5	1.3	ppm
088-98A 118 Eyewash	6/29/2016 11:17	7/8/2016 15:12	10354327193	Lead	14	15	ppb
088-99A 118 Sink Faucet (2)	6/29/2016 11:18	7/8/2016 15:13	10354327195	Copper	0.2	1.3	ppm
088-99A 118 Sink Faucet (2)	6/29/2016 11:18	7/8/2016 15:13	10354327195	Lead	50	15	ppb
088-100A 118 Sink Faucet (3)	6/29/2016 11:22	7/8/2016 15:16	10354327197	Copper	0.1	1.3	ppm
088-100A 118 Sink Faucet (3)	6/29/2016 11:22	7/8/2016 15:16	10354327197	Lead	22	15	ppb
088-101A 118 Sink Faucet (4)	6/29/2016 11:20	7/8/2016 15:18	10354327199	Copper	0.2	1.3	ppm
088-101A 118 Sink Faucet (4)	6/29/2016 11:20	7/8/2016 15:18	10354327199	Lead	77	15	ppb
088-102A 118 Sink Faucet (5)	6/29/2016 11:20	7/8/2016 14:10	10354327201	Copper	0.3	1.3	ppm
088-102A 118 Sink Faucet (5)	6/29/2016 11:20	7/8/2016 14:10	10354327201	Lead	61	15	ppb
088-103A 119 Sink Faucet	6/29/2016 11:05	7/8/2016 14:07	10354327203	Copper	0.3	1.3	ppm
088-103A 119 Sink Faucet	6/29/2016 11:05	7/8/2016 14:07	10354327203	Lead	55	15	ppb
088-104A 119 Drinking Fountain	6/29/2016 11:06	7/8/2016 14:08	10354327205	Copper	0.1	1.3	ppm
088-104A 119 Drinking Fountain	6/29/2016 11:06	7/8/2016 14:08	10354327205	Lead	6	15	ppb
088-105A 120 Sink Faucet (1)	6/29/2016 10:53	7/8/2016 18:09	10354327207	Copper	0.3	1.3	ppm
088-105A 120 Sink Faucet (1)	6/29/2016 10:53	7/8/2016 18:09	10354327207	Lead	52	15	ppb
088-106A 120 Eyewash	6/29/2016 10:53	7/8/2016 14:47	10354327209	Copper	0.9	1.3	ppm
088-106A 120 Eyewash	6/29/2016 10:53	7/8/2016 14:18	10354327209	Lead	11	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
West Sylvan Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
088-107A 120 Sink Faucet (2)	6/29/2016 10:56	7/8/2016 18:10	10354327211	Copper	0.1	1.3	ppm
088-107A 120 Sink Faucet (2)	6/29/2016 10:56	7/8/2016 18:10	10354327211	Lead	68	15	ppb
088-108A 120 Sink Faucet (3)	6/29/2016 10:57	7/8/2016 14:19	10354327213	Copper	0.1	1.3	ppm
088-108A 120 Sink Faucet (3)	6/29/2016 10:57	7/8/2016 14:19	10354327213	Lead	51	15	ppb
088-109A 120 Sink Faucet (4)	6/29/2016 10:58	7/8/2016 14:21	10354327215	Copper	0.3	1.3	ppm
088-109A 120 Sink Faucet (4)	6/29/2016 10:58	7/8/2016 14:21	10354327215	Lead	16	15	ppb
088-110A 120 Sink Faucet (5)	6/29/2016 11:04	7/8/2016 15:19	10354327217	Copper	0.5	1.3	ppm
088-110A 120 Sink Faucet (5)	6/29/2016 11:04	7/8/2016 14:22	10354327217	Lead	27	15	ppb
088-111A 124 Sink Faucet (1)	6/29/2016 11:15	7/8/2016 18:12	10354327219	Copper	0.1	1.3	ppm
088-111A 124 Sink Faucet (1)	6/29/2016 11:15	7/8/2016 18:12	10354327219	Lead	30	15	ppb
088-112A 124 Sink Faucet (2)	6/29/2016 11:15	7/8/2016 14:23	10354327221	Copper	0.1	1.3	ppm
088-112A 124 Sink Faucet (2)	6/29/2016 11:15	7/8/2016 14:23	10354327221	Lead	32	15	ppb
088-113A 124 Sink Faucet (3)	6/29/2016 11:11	7/8/2016 14:25	10354327223	Copper	0.2	1.3	ppm
088-113A 124 Sink Faucet (3)	6/29/2016 11:11	7/8/2016 14:25	10354327223	Lead	17	15	ppb
088-114A 124 Sink Faucet (4)	6/29/2016 11:07	7/8/2016 14:27	10354327225	Copper	0.1	1.3	ppm
088-114A 124 Sink Faucet (4)	6/29/2016 11:07	7/8/2016 14:27	10354327225	Lead	26	15	ppb
088-115A 124 Sink Faucet (5)	6/29/2016 11:07	7/8/2016 14:29	10354327227	Copper	0.2	1.3	ppm
088-115A 124 Sink Faucet (5)	6/29/2016 11:07	7/8/2016 14:29	10354327227	Lead	44	15	ppb
088-116A 124 Eyewash	6/29/2016 11:11	7/8/2016 14:31	10354327229	Copper	0.4	1.3	ppm
088-116A 124 Eyewash	6/29/2016 11:11	7/8/2016 14:31	10354327229	Lead	33	15	ppb
088-117A 125 Sink Faucet (1)	6/29/2016 10:52	7/8/2016 14:38	10354327231	Copper	0.3	1.3	ppm
088-117A 125 Sink Faucet (1)	6/29/2016 10:52	7/8/2016 14:38	10354327231	Lead	26	15	ppb
088-118A 125 Eyewash	6/29/2016 10:53	7/8/2016 14:39	10354327233	Copper	0.1	1.3	ppm
088-118A 125 Eyewash	6/29/2016 10:53	7/8/2016 14:39	10354327233	Lead	22	15	ppb
088-119A 125 Sink Faucet (2)	6/29/2016 10:57	7/8/2016 14:40	10354327235	Copper	0.3	1.3	ppm
088-119A 125 Sink Faucet (2)	6/29/2016 10:57	7/8/2016 14:40	10354327235	Lead	11	15	ppb
088-120A 125 Sink Faucet (3)	6/29/2016 10:59	7/8/2016 14:42	10354327237	Copper	0.3	1.3	ppm
088-120A 125 Sink Faucet (3)	6/29/2016 10:59	7/8/2016 14:42	10354327237	Lead	34	15	ppb
088-121A 125 Sink Faucet (4)	6/29/2016 11:01	7/8/2016 15:20	10354327239	Copper	0.6	1.3	ppm
088-121A 125 Sink Faucet (4)	6/29/2016 11:01	7/8/2016 14:43	10354327239	Lead	39	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
West Sylvan Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
088-122A 126 Sink Faucet (1)	6/29/2016 10:36	7/8/2016 16:01	10354327241	Copper	0.6	1.3	ppm
088-122A 126 Sink Faucet (1)	6/29/2016 10:36	7/8/2016 15:27	10354327241	Lead	20	15	ppb
088-123A 126 Eyewash	6/29/2016 10:38	7/8/2016 15:32	10354327243	Copper	0.2	1.3	ppm
088-123A 126 Eyewash	6/29/2016 10:38	7/8/2016 15:32	10354327243	Lead	17	15	ppb
088-124A 126 Sink Faucet (2)	6/29/2016 10:40	7/8/2016 16:04	10354327245	Copper	0.5	1.3	ppm
088-124A 126 Sink Faucet (2)	6/29/2016 10:40	7/8/2016 15:34	10354327245	Lead	10	15	ppb
088-125A 126 Sink Faucet (3)	6/29/2016 10:42	7/8/2016 16:05	10354327247	Copper	0.5	1.3	ppm
088-125A 126 Sink Faucet (3)	6/29/2016 10:42	7/8/2016 15:35	10354327247	Lead	9	15	ppb
088-126A 126 Sink Faucet (4)	6/29/2016 10:47	7/8/2016 15:37	10354327249	Copper	0.2	1.3	ppm
088-126A 126 Sink Faucet (4)	6/29/2016 10:47	7/8/2016 15:37	10354327249	Lead	4	15	ppb
088-127A 126 Sink Faucet (5)	6/29/2016 10:49	7/8/2016 15:41	10354327251	Copper	0.1	1.3	ppm
088-127A 126 Sink Faucet (5)	6/29/2016 10:49	7/8/2016 15:41	10354327251	Lead	11	15	ppb
088-128A 127 Sink Faucet (1)	6/29/2016 10:47	7/8/2016 15:42	10354327253	Copper	0.1	1.3	ppm
088-128A 127 Sink Faucet (1)	6/29/2016 10:47	7/8/2016 15:42	10354327253	Lead	67	15	ppb
088-129A 127 Sink Faucet (2)	6/29/2016 10:43	7/8/2016 15:43	10354327255	Copper	0.1	1.3	ppm
088-129A 127 Sink Faucet (2)	6/29/2016 10:43	7/8/2016 15:43	10354327255	Lead	2	15	ppb
088-130A 127 Sink Faucet (3)	6/29/2016 10:44	7/8/2016 15:45	10354327257	Copper	0.2	1.3	ppm
088-130A 127 Sink Faucet (3)	6/29/2016 10:44	7/8/2016 15:45	10354327257	Lead	3	15	ppb
088-131A 127 Sink Faucet (4)	6/29/2016 10:40	7/8/2016 15:46	10354327259	Copper	0.2	1.3	ppm
088-131A 127 Sink Faucet (4)	6/29/2016 10:40	7/8/2016 15:46	10354327259	Lead	5	15	ppb
088-132A 127 Sink Faucet (5)	6/29/2016 10:39	7/8/2016 16:06	10354327261	Copper	0.6	1.3	ppm
088-132A 127 Sink Faucet (5)	6/29/2016 10:39	7/8/2016 15:48	10354327261	Lead	5	15	ppb
088-133A 127 Eyewash	6/29/2016 10:40	7/8/2016 16:08	10354327263	Copper	3.7	1.3	ppm
088-133A 127 Eyewash	6/29/2016 10:40	7/8/2016 15:50	10354327263	Lead	20	15	ppb
088-134A 128 Sink Faucet (1)	6/29/2016 10:30	7/8/2016 16:09	10354327265	Copper	0.6	1.3	ppm
088-134A 128 Sink Faucet (1)	6/29/2016 10:30	7/8/2016 15:52	10354327265	Lead	142	15	ppb
088-135A 128 Sink Faucet (2)	6/29/2016 10:32	7/8/2016 16:10	10354327267	Copper	0.8	1.3	ppm
088-135A 128 Sink Faucet (2)	6/29/2016 10:32	7/8/2016 16:10	10354327267	Lead	522	15	ppb
088-136A 130 Sink Faucet (1)	6/29/2016 10:28	7/8/2016 18:31	10354327269	Copper	0.5	1.3	ppm
088-136A 130 Sink Faucet (1)	6/29/2016 10:28	7/8/2016 16:17	10354327269	Lead	10	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
West Sylvan Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
088-137A 130 Sink Faucet (2)	6/29/2016 13:08	7/8/2016 16:19	10354327271	Copper	0.4	1.3	ppm
088-137A 130 Sink Faucet (2)	6/29/2016 13:08	7/8/2016 16:19	10354327271	Lead	16	15	ppb
088-138A Outside Water Spigot (1)	6/29/2016 12:50	7/8/2016 16:20	10354327273	Copper	0.5	1.3	ppm
088-138A Outside Water Spigot (1)	6/29/2016 12:50	7/8/2016 16:20	10354327273	Lead	5	15	ppb
088-139A Outside Water Spigot (2)	6/29/2016 12:54	7/8/2016 19:15	10354327275	Copper	6.0	1.3	ppm
088-139A Outside Water Spigot (2)	6/29/2016 12:54	7/8/2016 19:15	10354327275	Lead	4630	15	ppb
088-140A Outside Water Spigot (3)	6/29/2016 12:56	7/8/2016 19:18	10354327277	Copper	2.1	1.3	ppm
088-140A Outside Water Spigot (3)	6/29/2016 12:56	7/8/2016 18:16	10354327277	Lead	434	15	ppb
088-141A Outside Water Spigot (4)	6/29/2016 12:58	7/8/2016 19:19	10354327279	Copper	4.7	1.3	ppm
088-141A Outside Water Spigot (4)	6/29/2016 12:58	7/8/2016 18:17	10354327279	Lead	453	15	ppb
088-142A Outside Water Spigot (5)	6/29/2016 13:02	7/8/2016 16:56	10354327281	Copper	0.1	1.3	ppm
088-142A Outside Water Spigot (5)	6/29/2016 13:02	7/8/2016 16:56	10354327281	Lead	16	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.