

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Whitman Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
089-01A Boiler Room Sink Faucet	6/28/16 20:12	7/14/16 9:56	606300601	Copper	0.0	1.3	ppm
089-01A Boiler Room Sink Faucet	6/28/16 20:12	7/14/16 9:56	606300601	Lead	1	15	ppb
089-02A Boiler Room Water Spigot	6/28/16 20:12	7/14/16 9:56	606300602	Copper	0.0	1.3	ppm
089-02A Boiler Room Water Spigot	6/28/16 20:12	7/14/16 9:56	606300602	Lead	439	15	ppb
089-03A Boiler Room Main Level Sink Faucet	6/28/16 20:18	7/14/16 9:56	606300603	Copper	0.0	1.3	ppm
089-03A Boiler Room Main Level Sink Faucet	6/28/16 20:18	7/14/16 9:56	606300603	Lead	6	15	ppb
089-04A Cafe Drinking Fountain (1)	6/28/16 20:21	7/14/16 9:56	606300604	Copper	0.0	1.3	ppm
089-04A Cafe Drinking Fountain (1)	6/28/16 20:21	7/14/16 9:56	606300604	Lead	23	15	ppb
089-05A Cafe Drinking Fountain (2)	6/28/16 20:23	7/14/16 9:56	606300605	Copper	0.0	1.3	ppm
089-05A Cafe Drinking Fountain (2)	6/28/16 20:23	7/14/16 9:56	606300605	Lead	13	15	ppb
089-06A Kitchen Sink Faucet Dish	6/28/16 20:25	7/14/16 9:56	606300606	Copper	0.4	1.3	ppm
089-06A Kitchen Sink Faucet Dish	6/28/16 20:25	7/14/16 9:56	606300606	Lead	47	15	ppb
089-07A Kitchen Bathroom Sink Faucet	6/28/16 20:28	7/14/16 9:56	606300607	Copper	0.1	1.3	ppm
089-07A Kitchen Bathroom Sink Faucet	6/28/16 20:28	7/14/16 9:56	606300607	Lead	16	15	ppb
089-08A Kitchen Hand Wash Sink Faucet	6/28/16 20:27	7/14/16 9:56	606300608	Copper	0.1	1.3	ppm
089-08A Kitchen Hand Wash Sink Faucet	6/28/16 20:27	7/14/16 9:56	606300608	Lead	12	15	ppb
089-09A Kitchen Food Prep Sink Faucet	6/28/16 20:30	7/14/16 9:56	606300609	Copper	0.1	1.3	ppm
089-09A Kitchen Food Prep Sink Faucet	6/28/16 20:30	7/14/16 9:56	606300609	Lead	10	15	ppb
089-10A Classroom 1 Sink Faucet	6/28/16 20:34	7/14/16 9:56	606300610	Copper	0.1	1.3	ppm
089-10A Classroom 1 Sink Faucet	6/28/16 20:34	7/14/16 9:56	606300610	Lead	11	15	ppb
089-11A Classroom 1 Drinking Fountain	6/28/16 20:35	7/14/16 9:57	606300611	Copper	0.0	1.3	ppm
089-11A Classroom 1 Drinking Fountain	6/28/16 20:35	7/14/16 9:57	606300611	Lead	6	15	ppb
089-12A Gymnasium Drinking Fountain	6/28/16 20:38	7/14/16 9:57	606300612	Copper	0.0	1.3	ppm
089-12A Gymnasium Drinking Fountain	6/28/16 20:38	7/14/16 9:57	606300612	Lead	12	15	ppb
089-13A Physical Education Office	6/28/16 20:42	7/14/16 9:57	606300613	Copper	0.0	1.3	ppm
089-13A Physical Education Office	6/28/16 20:42	7/14/16 9:57	606300613	Lead	16	15	ppb
089-14A Boys Bathroom Sink Faucet (1)	6/28/16 20:47	7/14/16 9:57	606300614	Copper	0.1	1.3	ppm
089-14A Boys Bathroom Sink Faucet (1)	6/28/16 20:47	7/14/16 9:57	606300614	Lead	37	15	ppb
089-15A Boys Bathroom Sink Faucet (2)	6/28/16 20:49	7/14/16 9:57	606300615	Copper	0.1	1.3	ppm
089-15A Boys Bathroom Sink Faucet (2)	6/28/16 20:49	7/14/16 9:57	606300615	Lead	40	15	ppb
089-16A Boys Bathroom Water Spigot	6/28/16 20:49	7/14/16 9:57	606300616	Copper	0.3	1.3	ppm
089-16A Boys Bathroom Water Spigot	6/28/16 20:49	7/14/16 9:57	606300616	Lead	34	15	ppb
089-17A Girls Bathroom Sink Faucet (1)	6/28/16 20:53	7/14/16 9:57	606300617	Copper	0.0	1.3	ppm
089-17A Girls Bathroom Sink Faucet (1)	6/28/16 20:53	7/14/16 9:57	606300617	Lead	13	15	ppb
089-18A Girls Bathroom Sink Faucet (2)	6/28/16 20:54	7/14/16 9:57	606300618	Copper	0.1	1.3	ppm
089-18A Girls Bathroom Sink Faucet (2)	6/28/16 20:54	7/14/16 9:57	606300618	Lead	26	15	ppb
089-19A Girls Bathroom Water Spigot	6/28/16 20:56	7/14/16 9:57	606300619	Copper	0.2	1.3	ppm
089-19A Girls Bathroom Water Spigot	6/28/16 20:56	7/14/16 9:57	606300619	Lead	28	15	ppb
089-20A Classroom 9 Sink Faucet	6/28/16 20:58	7/14/16 9:57	606300620	Copper	0.1	1.3	ppm
089-20A Classroom 9 Sink Faucet	6/28/16 20:58	7/14/16 9:57	606300620	Lead	60	15	ppb
089-21A Classroom 8 Drinking Fountain	6/28/16 21:00	7/14/16 9:57	606300621	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Whitman Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
089-21A Classroom 8 Drinking Fountain	6/28/16 21:00	7/14/16 9:57	606300621	Lead	9	15	ppb
089-22A Classroom 8 Sink Faucet	6/28/16 21:01	7/14/16 9:57	606300622	Copper	0.0	1.3	ppm
089-22A Classroom 8 Sink Faucet	6/28/16 21:01	7/14/16 9:57	606300622	Lead	34	15	ppb
089-23A Classroom 7 Sink Faucet	6/28/16 21:03	7/14/16 9:57	606300623	Copper	0.0	1.3	ppm
089-23A Classroom 7 Sink Faucet	6/28/16 21:03	7/14/16 9:57	606300623	Lead	25	15	ppb
089-24A Classroom 7 Drinking Fountain	6/28/16 21:04	7/14/16 9:57	606300624	Copper	0.0	1.3	ppm
089-24A Classroom 7 Drinking Fountain	6/28/16 21:04	7/14/16 9:57	606300624	Lead	12	15	ppb
089-25A Classroom 6 Sink Faucet	6/28/16 21:05	7/14/16 9:57	606300625	Copper	0.0	1.3	ppm
089-25A Classroom 6 Sink Faucet	6/28/16 21:05	7/14/16 9:57	606300625	Lead	22	15	ppb
089-26A Classroom 6 Hallway	6/28/16 21:07	7/14/16 9:57	606300626	Copper	ND	1.3	ppm
089-26A Classroom 6 Hallway	6/28/16 21:07	7/14/16 9:57	606300626	Lead	3	15	ppb
089-27A Classroom 5 Sink Faucet	6/28/16 21:10	7/14/16 9:57	606300627	Copper	0.1	1.3	ppm
089-27A Classroom 5 Sink Faucet	6/28/16 21:10	7/14/16 9:57	606300627	Lead	42	15	ppb
089-28A Classroom 5 Drinking Fountain	6/28/16 21:11	7/14/16 9:57	606300628	Copper	0.0	1.3	ppm
089-28A Classroom 5 Drinking Fountain	6/28/16 21:11	7/14/16 9:57	606300628	Lead	8	15	ppb
089-29A Classroom 4 Sink Faucet	6/28/16 21:15	7/14/16 9:58	606300629	Copper	0.1	1.3	ppm
089-29A Classroom 4 Sink Faucet	6/28/16 21:15	7/14/16 9:58	606300629	Lead	14	15	ppb
089-30A Classroom 4 Drinking Fountain	6/28/16 21:17	7/14/16 10:02	606300630	Copper	0.0	1.3	ppm
089-30A Classroom 4 Drinking Fountain	6/28/16 21:17	7/14/16 10:02	606300630	Lead	4	15	ppb
089-31A Men's Bath Sink Faucet (1)	6/28/16 21:18	7/14/16 10:02	606300631	Copper	0.2	1.3	ppm
089-31A Men's Bath Sink Faucet (1)	6/28/16 21:18	7/14/16 10:02	606300631	Lead	14.9	15	ppb
089-32A Mens Bath Sink Faucet (2)	6/28/16 21:19	7/14/16 10:02	606300632	Copper	0.1	1.3	ppm
089-32A Mens Bath Sink Faucet (2)	6/28/16 21:19	7/14/16 10:02	606300632	Lead	19	15	ppb
089-33A Men's Bath Water Spigot	6/28/16 21:21	7/14/16 10:02	606300633	Copper	0.2	1.3	ppm
089-33A Men's Bath Water Spigot	6/28/16 21:21	7/14/16 10:02	606300633	Lead	18	15	ppb
089-34A Custodial Sink Faucet Room 2	6/28/16 21:19	7/14/16 10:02	606300634	Copper	0.0	1.3	ppm
089-34A Custodial Sink Faucet Room 2	6/28/16 21:19	7/14/16 10:02	606300634	Lead	18	15	ppb
089-35A Classroom 3 Sink Faucet	6/28/16 21:25	7/14/16 10:02	606300635	Copper	0.1	1.3	ppm
089-35A Classroom 3 Sink Faucet	6/28/16 21:25	7/14/16 10:02	606300635	Lead	22	15	ppb
089-36A Classroom 3 Drinking Fountain	6/28/16 21:26	7/14/16 10:02	606300636	Copper	0.0	1.3	ppm
089-36A Classroom 3 Drinking Fountain	6/28/16 21:26	7/14/16 10:02	606300636	Lead	1	15	ppb
089-37A Hallway Drinking Fountain	6/28/16 21:28	7/9/16 16:20	606300637	Copper	0.0	1.3	ppm
089-37A Hallway Drinking Fountain	6/28/16 21:28	7/9/16 16:20	606300637	Lead	25	15	ppb
089-38A Classroom 2 Sink Faucet	6/28/16 21:29	7/14/16 10:02	606300638	Copper	0.0	1.3	ppm
089-38A Classroom 2 Sink Faucet	6/28/16 21:29	7/14/16 10:02	606300638	Lead	19	15	ppb
089-39A Boys Bath Sink Faucet (1)	6/28/16 21:33	7/14/16 10:02	606300639	Copper	0.1	1.3	ppm
089-39A Boys Bath Sink Faucet (1)	6/28/16 21:33	7/14/16 10:02	606300639	Lead	10	15	ppb
089-40A Boys Bath Sink Faucet (2)	6/28/16 21:35	7/14/16 10:02	606300640	Copper	0.0	1.3	ppm
089-40A Boys Bath Sink Faucet (2)	6/28/16 21:35	7/14/16 10:02	606300640	Lead	2	15	ppb
089-41A Boys Bath Water Spigot	6/28/16 21:37	7/14/16 10:02	606300641	Copper	0.6	1.3	ppm
089-41A Boys Bath Water Spigot	6/28/16 21:37	7/14/16 10:02	606300641	Lead	54	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Whitman Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
089-42A Girls Bath Sink Faucet	6/28/16 21:39	7/14/16 10:02	606300642	Copper	0.1	1.3	ppm
089-42A Girls Bath Sink Faucet	6/28/16 21:39	7/14/16 10:02	606300642	Lead	6	15	ppb
089-43A Girls Bath Water Spigot	6/28/16 21:40	7/9/16 16:20	606300643	Copper	0.9	1.3	ppm
089-43A Girls Bath Water Spigot	6/28/16 21:40	7/9/16 16:20	606300643	Lead	205	15	ppb
089-44A Custodial 1 Sink Faucet	6/28/16 21:44	7/14/16 10:02	606300644	Copper	0.3	1.3	ppm
089-44A Custodial 1 Sink Faucet	6/28/16 21:44	7/14/16 10:02	606300644	Lead	17	15	ppb
089-45A Hallway Drinking Fountain (by C1)	6/28/16 21:48	7/14/16 10:03	606300645	Copper	0.0	1.3	ppm
089-45A Hallway Drinking Fountain (by C1)	6/28/16 21:48	7/14/16 10:03	606300645	Lead	31	15	ppb
089-46A Store Room 1 Sink Faucet	6/28/16 21:49	7/14/16 10:03	606300646	Copper	0.1	1.3	ppm
089-46A Store Room 1 Sink Faucet	6/28/16 21:49	7/14/16 10:03	606300646	Lead	47	15	ppb
089-47A Nurses Office Sink Faucet	6/28/16 21:52	7/9/16 16:20	606300647	Copper	1.4	1.3	ppm
089-47A Nurses Office Sink Faucet	6/28/16 21:52	7/9/16 16:20	606300647	Lead	21	15	ppb
089-48A Library 25 Sink Faucet	6/28/16 21:55	7/14/16 10:03	606300648	Copper	0.1	1.3	ppm
089-48A Library 25 Sink Faucet	6/28/16 21:55	7/14/16 10:03	606300648	Lead	13	15	ppb
089-49A Library Bath Sink Faucet	6/28/16 21:58	7/14/16 10:03	606300649	Copper	0.2	1.3	ppm
089-49A Library Bath Sink Faucet	6/28/16 21:58	7/14/16 10:03	606300649	Lead	61	15	ppb
089-50A Library Bath Water Spigot	6/28/16 21:59	7/14/16 10:03	606300650	Copper	0.4	1.3	ppm
089-50A Library Bath Water Spigot	6/28/16 21:59	7/14/16 10:03	606300650	Lead	78	15	ppb
089-51A Room 24 Bath Sink Faucet	6/28/16 22:04	7/14/16 10:03	606300651	Copper	0.2	1.3	ppm
089-51A Room 24 Bath Sink Faucet	6/28/16 22:04	7/14/16 10:03	606300651	Lead	34	15	ppb
089-52A Room 24 Sink Faucet	6/28/16 22:04	7/14/16 10:03	606300652	Copper	0.1	1.3	ppm
089-52A Room 24 Sink Faucet	6/28/16 22:04	7/14/16 10:03	606300652	Lead	4	15	ppb
089-53A Room 24 Drinking Fountain	6/28/16 22:06	7/14/16 10:03	606300653	Copper	0.1	1.3	ppm
089-53A Room 24 Drinking Fountain	6/28/16 22:06	7/14/16 10:03	606300653	Lead	4	15	ppb
089-54A Staff Unisex Sink Faucet	6/28/16 22:08	7/14/16 10:03	606300654	Copper	0.1	1.3	ppm
089-54A Staff Unisex Sink Faucet	6/28/16 22:08	7/14/16 10:03	606300654	Lead	7	15	ppb
089-55A Staff Unisex Water Spigot	6/28/16 22:09	7/9/16 16:20	606300655	Copper	0.4	1.3	ppm
089-55A Staff Unisex Water Spigot	6/28/16 22:09	7/9/16 16:20	606300655	Lead	181	15	ppb
089-56A Custodial Room 3 Sink Faucet	6/28/16 22:08	7/14/16 10:03	606300656	Copper	0.0	1.3	ppm
089-56A Custodial Room 3 Sink Faucet	6/28/16 22:08	7/14/16 10:03	606300656	Lead	3	15	ppb
089-57A Boys Bath Sink Faucet (1)	6/28/16 22:14	7/14/16 10:03	606300657	Copper	0.1	1.3	ppm
089-57A Boys Bath Sink Faucet (1)	6/28/16 22:14	7/14/16 10:03	606300657	Lead	6	15	ppb
089-58A Boys Bath Sink Faucet (2)	6/28/16 22:15	7/14/16 10:03	606300658	Copper	0.1	1.3	ppm
089-58A Boys Bath Sink Faucet (2)	6/28/16 22:15	7/14/16 10:03	606300658	Lead	5	15	ppb
089-59A Boys Bath Water Spigot	6/28/16 22:16	7/14/16 10:03	606300659	Copper	0.5	1.3	ppm
089-59A Boys Bath Water Spigot	6/28/16 22:16	7/14/16 10:03	606300659	Lead	72	15	ppb
089-60A Girls Bath Sink Faucet (1)	6/28/16 22:21	7/14/16 10:03	606300660	Copper	0.1	1.3	ppm
089-60A Girls Bath Sink Faucet (1)	6/28/16 22:21	7/14/16 10:03	606300660	Lead	3	15	ppb
089-61A Girls Bath Sink Faucet (2)	6/28/16 22:22	7/14/16 10:03	606300661	Copper	0.1	1.3	ppm
089-61A Girls Bath Sink Faucet (2)	6/28/16 22:22	7/14/16 10:03	606300661	Lead	5	15	ppb
089-62A Girls Bath Water Spigot	6/28/16 22:23	7/9/16 16:11	606300662	Copper	0.3	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Whitman Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
089-62A Girls Bath Water Spigot	6/28/16 22:23	7/9/16 16:11	606300662	Lead	225	15	ppb
089-63A Hallway Drinking Fountain	6/28/16 22:29	7/14/16 10:03	606300663	Copper	0.0	1.3	ppm
089-63A Hallway Drinking Fountain	6/28/16 22:29	7/14/16 10:03	606300663	Lead	14.7	15	ppb
089-64A Classroom 22 Sink Faucet	6/28/16 22:32	7/14/16 10:03	606300664	Copper	0.1	1.3	ppm
089-64A Classroom 22 Sink Faucet	6/28/16 22:32	7/14/16 10:03	606300664	Lead	4	15	ppb
089-65A Classroom 23 Sink Faucet	6/28/16 22:37	7/14/16 10:03	606300665	Copper	0.1	1.3	ppm
089-65A Classroom 23 Sink Faucet	6/28/16 22:37	7/14/16 10:03	606300665	Lead	9	15	ppb
089-66A Classroom 23 Drinking Fountain	6/28/16 22:37	7/14/16 10:03	606300666	Copper	0.1	1.3	ppm
089-66A Classroom 23 Drinking Fountain	6/28/16 22:37	7/14/16 10:03	606300666	Lead	3	15	ppb
089-67A Classroom 20 Sink Faucet	6/28/16 22:42	7/14/16 10:03	606300667	Copper	0.1	1.3	ppm
089-67A Classroom 20 Sink Faucet	6/28/16 22:42	7/14/16 10:03	606300667	Lead	12	15	ppb
089-68A Classroom 20 Drinking Fountain	6/28/16 22:42	7/14/16 10:03	606300668	Copper	0.0	1.3	ppm
089-68A Classroom 20 Drinking Fountain	6/28/16 22:42	7/14/16 10:03	606300668	Lead	6	15	ppb
089-69A Classroom 21 Sink Faucet	6/28/16 22:45	7/14/16 10:03	606300669	Copper	0.1	1.3	ppm
089-69A Classroom 21 Sink Faucet	6/28/16 22:45	7/14/16 10:03	606300669	Lead	23	15	ppb
089-70A Classroom 21 Drinking Fountain	6/28/16 22:46	7/14/16 10:03	606300670	Copper	0.0	1.3	ppm
089-70A Classroom 21 Drinking Fountain	6/28/16 22:46	7/14/16 10:03	606300670	Lead	5	15	ppb
089-71A Classroom 19 Sink Faucet	6/28/16 22:49	7/14/16 10:03	606300671	Copper	0.0	1.3	ppm
089-71A Classroom 19 Sink Faucet	6/28/16 22:49	7/14/16 10:03	606300671	Lead	2	15	ppb
089-72A Classroom 19 Drinking Fountain	6/28/16 22:50	7/14/16 10:03	606300672	Copper	0.0	1.3	ppm
089-72A Classroom 19 Drinking Fountain	6/28/16 22:50	7/14/16 10:03	606300672	Lead	2	15	ppb
089-73A Classroom 18 Sink Faucet	6/28/16 22:53	7/14/16 10:03	606300673	Copper	0.1	1.3	ppm
089-73A Classroom 18 Sink Faucet	6/28/16 22:53	7/14/16 10:03	606300673	Lead	1	15	ppb
089-74A Classroom 18 Drinking Fountain	6/28/16 22:53	7/14/16 10:03	606300674	Copper	0.0	1.3	ppm
089-74A Classroom 18 Drinking Fountain	6/28/16 22:53	7/14/16 10:03	606300674	Lead	3	15	ppb
089-75A Boys Bath Sink Faucet	6/28/16 22:57	7/14/16 10:03	606300675	Copper	0.1	1.3	ppm
089-75A Boys Bath Sink Faucet	6/28/16 22:57	7/14/16 10:03	606300675	Lead	5	15	ppb
089-76A Boys Bath Sink Faucet	6/28/16 22:59	7/14/16 10:04	606300676	Copper	0.1	1.3	ppm
089-76A Boys Bath Sink Faucet	6/28/16 22:59	7/14/16 10:04	606300676	Lead	21	15	ppb
089-77A Boys Bath Water Spigot	6/28/16 23:00	7/14/16 11:06	606300677	Copper	1.7	1.3	ppm
089-77A Boys Bath Water Spigot	6/28/16 23:00	7/14/16 10:04	606300677	Lead	57	15	ppb
089-78A Hall outside 17 Drinking Fountain	6/28/16 22:57	7/14/16 10:04	606300678	Copper	0.0	1.3	ppm
089-78A Hall outside 17 Drinking Fountain	6/28/16 22:57	7/14/16 10:04	606300678	Lead	30	15	ppb
089-79A Classroom 17 Sink Faucet	6/28/16 23:03	7/14/16 10:04	606300679	Copper	0.1	1.3	ppm
089-79A Classroom 17 Sink Faucet	6/28/16 23:03	7/14/16 10:04	606300679	Lead	4	15	ppb
089-80A Classroom 17 Drinking Fountain	6/28/16 23:04	7/14/16 10:04	606300680	Copper	0.0	1.3	ppm
089-80A Classroom 17 Drinking Fountain	6/28/16 23:04	7/14/16 10:04	606300680	Lead	5	15	ppb
089-81A Girls Bath Sink Faucet (1)	6/28/16 23:07	7/14/16 10:04	606300681	Copper	0.1	1.3	ppm
089-81A Girls Bath Sink Faucet (1)	6/28/16 23:07	7/14/16 10:04	606300681	Lead	5	15	ppb
089-82A Girls Bath Sink Faucet (2)	6/28/16 23:08	7/14/16 10:37	606300682	Copper	0.1	1.3	ppm
089-82A Girls Bath Sink Faucet (2)	6/28/16 23:08	7/14/16 10:37	606300682	Lead	5	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Whitman Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
089-83A Girls Bath Water Spigot	6/28/16 23:09	7/14/16 10:37	606300683	Copper	0.1	1.3	ppm
089-83A Girls Bath Water Spigot	6/28/16 23:09	7/14/16 10:37	606300683	Lead	18	15	ppb
089-84A Classroom 15 Sink Faucet	6/28/16 23:15	7/14/16 10:37	606300684	Copper	0.1	1.3	ppm
089-84A Classroom 15 Sink Faucet	6/28/16 23:15	7/14/16 10:37	606300684	Lead	3	15	ppb
089-85A Classroom 15 Drinking Fountain	6/28/16 23:15	7/14/16 10:37	606300685	Copper	0.0	1.3	ppm
089-85A Classroom 15 Drinking Fountain	6/28/16 23:15	7/14/16 10:37	606300685	Lead	4	15	ppb
089-86A Classroom 16 Sink Faucet	6/28/16 23:16	7/14/16 10:37	606300686	Copper	0.1	1.3	ppm
089-86A Classroom 16 Sink Faucet	6/28/16 23:16	7/14/16 10:37	606300686	Lead	3	15	ppb
089-87A Classroom 16 Drinking Fountain	6/28/16 23:16	7/14/16 10:37	606300687	Copper	0.0	1.3	ppm
089-87A Classroom 16 Drinking Fountain	6/28/16 23:16	7/14/16 10:37	606300687	Lead	2	15	ppb
089-88A Classroom 14 Sink Faucet	6/28/16 23:20	7/14/16 10:37	606300688	Copper	0.1	1.3	ppm
089-88A Classroom 14 Sink Faucet	6/28/16 23:20	7/14/16 10:37	606300688	Lead	7	15	ppb
089-89A Classroom 14 Drinking Fountain	6/28/16 23:20	7/14/16 10:37	606300689	Copper	0.0	1.3	ppm
089-89A Classroom 14 Drinking Fountain	6/28/16 23:20	7/14/16 10:37	606300689	Lead	ND	15	ppb
089-90A Classroom 13 Sink Faucet	6/28/16 23:30	7/14/16 10:37	606300690	Copper	0.2	1.3	ppm
089-90A Classroom 13 Sink Faucet	6/28/16 23:30	7/14/16 10:37	606300690	Lead	16	15	ppb
089-91A Boys Bath Sink Faucet (1)	6/28/16 23:33	7/14/16 10:37	606300691	Copper	0.1	1.3	ppm
089-91A Boys Bath Sink Faucet (1)	6/28/16 23:33	7/14/16 10:37	606300691	Lead	11	15	ppb
089-92A Boys Bath Sink Faucet (2)	6/28/16 23:33	7/14/16 10:37	606300692	Copper	0.2	1.3	ppm
089-92A Boys Bath Sink Faucet (2)	6/28/16 23:33	7/14/16 10:37	606300692	Lead	7	15	ppb
089-93A Boys Bath Water Spigot	6/28/16 23:36	7/14/16 10:37	606300693	Copper	0.3	1.3	ppm
089-93A Boys Bath Water Spigot	6/28/16 23:36	7/14/16 10:37	606300693	Lead	37	15	ppb
089-94A outside 12 Drinking Fountain	6/28/16 23:39	7/14/16 10:37	606300694	Copper	0.0	1.3	ppm
089-94A outside 12 Drinking Fountain	6/28/16 23:39	7/14/16 10:37	606300694	Lead	2	15	ppb
089-95A Custodial Room 4 Sink Faucet	6/28/16 23:41	7/14/16 10:37	606300695	Copper	0.1	1.3	ppm
089-95A Custodial Room 4 Sink Faucet	6/28/16 23:41	7/14/16 10:37	606300695	Lead	1	15	ppb
089-96A Girls Bath Sink Faucet	6/28/16 23:42	7/14/16 10:37	606300696	Copper	0.1	1.3	ppm
089-96A Girls Bath Sink Faucet	6/28/16 23:42	7/14/16 10:37	606300696	Lead	6	15	ppb
089-97A Girls Bath Water Spigot	6/28/16 23:44	7/14/16 10:37	606300697	Copper	0.2	1.3	ppm
089-97A Girls Bath Water Spigot	6/28/16 23:44	7/14/16 10:37	606300697	Lead	30	15	ppb
089-98A Classroom 12 Sink Faucet (1)	6/28/16 23:46	7/14/16 10:37	606300698	Copper	0.1	1.3	ppm
089-98A Classroom 12 Sink Faucet (1)	6/28/16 23:46	7/14/16 10:37	606300698	Lead	5	15	ppb
089-99A Classroom 12 Sink Faucet (2)	6/28/16 23:48	7/14/16 10:37	606300699	Copper	0.1	1.3	ppm
089-99A Classroom 12 Sink Faucet (2)	6/28/16 23:48	7/14/16 10:37	606300699	Lead	4	15	ppb
089-100A Classroom 11 Sink Faucet	6/28/16 23:46	7/14/16 10:37	6.063E+09	Copper	0.1	1.3	ppm
089-100A Classroom 11 Sink Faucet	6/28/16 23:46	7/14/16 10:37	6.063E+09	Lead	16	15	ppb
089-101A Classroom 11 Drinking Fountain	6/28/16 23:48	7/14/16 10:37	6.063E+09	Copper	0.0	1.3	ppm
089-101A Classroom 11 Drinking Fountain	6/28/16 23:48	7/14/16 10:37	6.063E+09	Lead	ND	15	ppb
089-102A Classroom 10 Sink Faucet	6/28/16 23:49	7/14/16 10:38	6.063E+09	Copper	0.1	1.3	ppm
089-102A Classroom 10 Sink Faucet	6/28/16 23:49	7/14/16 10:38	6.063E+09	Lead	2	15	ppb
089-103A Outside Water Spigot 1	6/28/16 12:18	7/14/16 10:38	6.063E+09	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Whitman Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
089-103A Outside Water Spigot 1	6/28/16 12:18	7/14/16 10:38	6.063E+09	Lead	10	15	ppb
089-104A Outside Water Spigot 2	6/28/16 12:16	7/14/16 10:38	6.063E+09	Copper	0.1	1.3	ppm
089-104A Outside Water Spigot 2	6/28/16 12:16	7/14/16 10:38	6.063E+09	Lead	10	15	ppb
089-105A Outside Water Spigot 3	6/28/16 12:14	7/14/16 10:38	6.063E+09	Copper	0.0	1.3	ppm
089-105A Outside Water Spigot 3	6/28/16 12:14	7/14/16 10:38	6.063E+09	Lead	3	15	ppb
089-106A outside Water Spigot 4	6/28/16 12:09	7/9/16 16:12	6.063E+09	Copper	0.2	1.3	ppm
089-106A outside Water Spigot 4	6/28/16 12:09	7/9/16 16:12	6.063E+09	Lead	141	15	ppb
089-107A outside Water Spigot 5	6/28/16 12:07	7/14/16 10:38	6.063E+09	Copper	0.0	1.3	ppm
089-107A outside Water Spigot 5	6/28/16 12:07	7/14/16 10:38	6.063E+09	Lead	8	15	ppb
089-108A outside Water Spigot 6	6/28/16 12:37	7/14/16 10:38	6.063E+09	Copper	0.0	1.3	ppm
089-108A Outside Water Spigot 6	6/28/16 12:37	7/14/16 10:38	6.063E+09	Lead	13	15	ppb
089-109A Outside Water Spigot 7	6/28/16 12:34	7/14/16 10:38	6.063E+09	Copper	0.0	1.3	ppm
089-109A Outside Water Spigot 7	6/28/16 12:34	7/14/16 10:38	6.063E+09	Lead	38	15	ppb
089-110A Outside Water Spigot 8	6/28/16 12:30	7/14/16 10:38	6.063E+09	Copper	0.2	1.3	ppm
089-110A Outside Water Spigot 8	6/28/16 12:30	7/14/16 10:38	6.063E+09	Lead	49	15	ppb
089-111A Outside Water Spigot 9	6/28/16 12:28	7/14/16 10:38	6.063E+09	Copper	0.0	1.3	ppm
089-111A Outside Water Spigot 9	6/28/16 12:28	7/14/16 10:38	6.063E+09	Lead	33	15	ppb
089-112A Outside Water Spigot 10	6/28/16 12:26	7/9/16 16:16	6.063E+09	Copper	0.2	1.3	ppm
089-112A Outside Water Spigot 10	6/28/16 12:26	7/9/16 16:16	6.063E+09	Lead	142	15	ppb
089-113A Outside Water Spigot 11	6/28/16 12:23	7/14/16 10:38	6.063E+09	Copper	0.0	1.3	ppm
089-113A Outside Water Spigot 11	6/28/16 12:23	7/14/16 10:38	6.063E+09	Lead	1	15	ppb
089-114A Outside Water Spigot 12	6/28/16 12:20	7/14/16 10:38	6.063E+09	Copper	0.0	1.3	ppm
089-114A Outside Water Spigot 12	6/28/16 12:20	7/14/16 10:38	6.063E+09	Lead	14	15	ppb
EPA Action Level for Lead of 15 ppb					ND = Non detect		
EPA Action Level for Copper of 1.3 ppm							

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.