

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilcox Elementary School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
090-01A	Boiler Room Sink Faucet	6/22/16 8:10	7/19/2016	1606E04-01A	Copper	ND	1.3	ppm
090-01A	Boiler Room Sink Faucet	6/22/16 8:10	7/19/2016	1606E04-01A	Lead	4	15	ppb
090-02A	Coffee Room Sink Faucet	6/22/16 8:13	7/19/2016	1606E04-02A	Copper	ND	1.3	ppm
090-02A	Coffee Room Sink Faucet	6/22/16 8:13	7/19/2016	1606E04-02A	Lead	2	15	ppb
090-03A	Room 3 Sink Faucet	6/22/16 8:25	7/19/2016	1606E04-03A	Copper	ND	1.3	ppm
090-03A	Room 3 Sink Faucet	6/22/16 8:25	7/19/2016	1606E04-03A	Lead	34	15	ppb
090-04A	Room 3 Drinking Fountain	6/22/16 8:27	7/19/2016	1606E04-04A	Copper	ND	1.3	ppm
090-04A	Room 3 Drinking Fountain	6/22/16 8:27	7/19/2016	1606E04-04A	Lead	ND	15	ppb
090-05A	Room 2 Sink Faucet	6/22/16 8:20	7/19/2016	1606E04-05A	Copper	ND	1.3	ppm
090-05A	Room 2 Sink Faucet	6/22/16 8:20	7/19/2016	1606E04-05A	Lead	23	15	ppb
090-06A	Room 2 Sink Faucet	6/22/16 8:15	7/19/2016	1606E04-06A	Copper	ND	1.3	ppm
090-06A	Room 2 Sink Faucet	6/22/16 8:15	7/19/2016	1606E04-06A	Lead	110	15	ppb
090-07A	Room 16 Sink Faucet	6/22/16 8:16	7/19/2016	1606E04-07A	Copper	ND	1.3	ppm
090-07A	Room 16 Sink Faucet	6/22/16 8:16	7/19/2016	1606E04-07A	Lead	11	15	ppb
090-08A	Boys Bathroom Sink Faucet 1	6/22/16 8:21	7/19/2016	1606E04-08A	Copper	0.1	1.3	ppm
090-08A	Boys Bathroom Sink Faucet 1	6/22/16 8:21	7/19/2016	1606E04-08A	Lead	10	15	ppb
090-09A	Boys Bathroom Sink Faucet 2	6/22/16 8:24	7/19/2016	1606E04-09A	Copper	ND	1.3	ppm
090-09A	Boys Bathroom Sink Faucet 2	6/22/16 8:24	7/19/2016	1606E04-09A	Lead	7	15	ppb
090-10A	Boys Bathroom Sink Faucet 3	6/22/16 8:26	7/19/2016	1606E04-10A	Copper	0.1	1.3	ppm
090-10A	Boys Bathroom Sink Faucet 3	6/22/16 8:26	7/19/2016	1606E04-10A	Lead	8	15	ppb
090-11A	Boys Bathroom Sink Faucet 4	6/22/16 8:28	7/19/2016	1606E04-11A	Copper	ND	1.3	ppm
090-11A	Boys Bathroom Sink Faucet 4	6/22/16 8:28	7/19/2016	1606E04-11A	Lead	21	15	ppb
090-12A	Boys Bathroom Sink Faucet 5	6/22/16 8:30	7/19/2016	1606E04-12A	Copper	ND	1.3	ppm
090-12A	Boys Bathroom Sink Faucet 5	6/22/16 8:30	7/19/2016	1606E04-12A	Lead	8	15	ppb
090-13A	Hallway Drinking Fountain	6/22/16 8:38	7/19/2016	1606E04-13A	Copper	ND	1.3	ppm
090-13A	Hallway Drinking Fountain	6/22/16 8:38	7/19/2016	1606E04-13A	Lead	7	15	ppb
090-14A	Girls Bathroom Bathroom Sink Faucet	6/22/16 8:32	7/19/2016	1606E04-14A	Copper	0.1	1.3	ppm
090-14A	Girls Bathroom Bathroom Sink Faucet	6/22/16 8:32	7/19/2016	1606E04-14A	Lead	38	15	ppb
090-15A	Girls Bathroom Bathroom Sink Faucet	6/22/16 8:34	7/19/2016	1606E04-15A	Copper	ND	1.3	ppm
090-15A	Girls Bathroom Bathroom Sink Faucet	6/22/16 8:34	7/19/2016	1606E04-15A	Lead	35	15	ppb
090-16A	Girls Bathroom Bathroom Sink Faucet	6/22/16 8:36	7/19/2016	1606E04-16A	Copper	ND	1.3	ppm
090-16A	Girls Bathroom Bathroom Sink Faucet 1	6/22/16 8:36	7/19/2016	1606E04-16A	Lead	27	15	ppb
090-17A	Girls Bathroom Bathroom Sink Faucet 1	6/22/16 8:38	7/19/2016	1606E04-17A	Copper	0.1	1.3	ppm
090-17A	Girls Bathroom Bathroom Sink Faucet 2	6/22/16 8:38	7/19/2016	1606E04-17A	Lead	38	15	ppb
090-18A	Girls Bathroom Bathroom Sink Faucet 2	6/22/16 8:40	7/19/2016	1606E04-18A	Copper	ND	1.3	ppm
090-18A	Girls Bathroom Bathroom Sink Faucet 2	6/22/16 8:40	7/19/2016	1606E04-18A	Lead	34	15	ppb
090-19A	Restroom Sink Faucet	6/22/16 8:42	7/19/2016	1606E04-19A	Copper	ND	1.3	ppm
090-19A	Restroom Sink Faucet	6/22/16 8:42	7/19/2016	1606E04-19A	Lead	11	15	ppb
090-20A	Room 4 Sink Faucet	6/22/16 8:50	7/19/2016	1606E04-20A	Copper	ND	1.3	ppm
090-20A	Room 4 Sink Faucet	6/22/16 8:50	7/19/2016	1606E04-20A	Lead	39	15	ppb
090-21A	Room 4 Drinking Fountain	6/22/16 8:52	7/19/2016	1606E04-21A	Copper	ND	1.3	ppm
090-21A	Room 4 Drinking Fountain	6/22/16 8:52	7/19/2016	1606E04-21A	Lead	ND	15	ppb
090-22A	Room 5 Sink Faucet	6/22/16 8:55	7/19/2016	1606E04-22A	Copper	ND	1.3	ppm
090-22A	Room 5 Sink Faucet	6/22/16 8:55	7/19/2016	1606E04-22A	Lead	49	15	ppb
090-23A	Room 5 Drinking Fountain	6/22/16 8:58	7/20/2016	1606E04-23A	Copper	1.7	1.3	ppm
090-23A	Room 5 Drinking Fountain	6/22/16 8:58	7/19/2016	1606E04-23A	Lead	57	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilcox Elementary School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
090-24A	Room 11 Sink Faucet	6/22/16 8:48	7/19/2016	1606E04-24A	Copper	0.1		1.3 ppm
090-24A	Room 11 Sink Faucet	6/22/16 8:48	7/20/2016	1606E04-24A	Lead	370	15 ppb	
090-25A	Room 11 Drinking Fountain	6/22/16 8:50	7/19/2016	1606E04-25A	Copper	ND		1.3 ppm
090-25A	Room 11 Drinking Fountain	6/22/16 8:50	7/19/2016	1606E04-25A	Lead	6	15 ppb	
090-26A	Room 10 Sink Faucet	6/22/16 8:56	7/19/2016	1606E04-26A	Copper	ND		1.3 ppm
090-26A	Room 10 Sink Faucet	6/22/16 8:56	7/19/2016	1606E04-26A	Lead	54	15 ppb	
090-27A	Room 10 Drinking Fountain	6/22/16 8:58	7/19/2016	1606E04-27A	Copper	ND		1.3 ppm
090-27A	Room 10 Drinking Fountain	6/22/16 8:58	7/19/2016	1606E04-27A	Lead	ND	15 ppb	
090-28A	Room 9 Sink Faucet	6/22/16 9:04	7/19/2016	1606E04-28A	Copper	ND		1.3 ppm
090-28A	Room 9 Sink Faucet	6/22/16 9:04	7/19/2016	1606E04-28A	Lead	66	15 ppb	
090-29A	Room 9 Drinking Fountain	6/22/16 9:05	7/19/2016	1606E04-29A	Copper	ND		1.3 ppm
090-29A	Room 9 Drinking Fountain	6/22/16 9:05	7/19/2016	1606E04-29A	Lead	36	15 ppb	
090-30A	Room 8 Sink Faucet	6/22/16 9:03	7/19/2016	1606E04-30A	Copper	0.2		1.3 ppm
090-30A	Room 8 Sink Faucet	6/22/16 9:03	7/19/2016	1606E04-30A	Lead	22	15 ppb	
090-31A	Room 8 Drinking Fountain	6/22/16 9:05	7/19/2016	1606E04-31A	Copper	ND		1.3 ppm
090-31A	Room 8 Drinking Fountain	6/22/16 9:05	7/19/2016	1606E04-31A	Lead	58	15 ppb	
090-32A	Portable Sink Faucet	6/22/16 9:15	7/19/2016	1606E04-32A	Copper	ND		1.3 ppm
090-32A	Portable Sink Faucet	6/22/16 9:15	7/19/2016	1606E04-32A	Lead	2	15 ppb	
090-33A	Portable Bathroom Sink Faucet	6/22/16 9:25	7/19/2016	1606E04-33A	Copper	0.2		1.3 ppm
090-33A	Portable Bathroom Sink Faucet	6/22/16 9:25	7/19/2016	1606E04-33A	Lead	3	15 ppb	
090-34A	Portable Bathroom Sink Faucet	6/22/16 9:28	7/19/2016	1606E04-34A	Copper	0.3		1.3 ppm
090-34A	Portable Bathroom Sink Faucet	6/22/16 9:28	7/19/2016	1606E04-34A	Lead	9	15 ppb	
090-35A	Outside Water Spigot	6/22/16 9:50	7/19/2016	1606E04-35A	Copper	0.4		1.3 ppm
090-35A	Outside Water Spigot	6/22/16 9:50	7/19/2016	1606E04-35A	Lead	16	15 ppb	

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.