

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-01A 36 Custodial Sink Faucet	6/28/16 18:32	7/5/16 11:01	6.06E+08	Copper	0.1	1.3	ppm
091-01A 36 Custodial Sink Faucet	6/28/16 18:32	7/5/16 11:01	6.06E+08	Lead	3	15	ppb
091-02A 36 Custodial Shower	6/28/16 18:33	7/9/16 15:56	6.06E+08	Copper	0.2	1.3	ppm
091-02A 36 Custodial Shower	6/28/16 18:33	7/9/16 15:56	6.06E+08	Lead	26	15	ppb
091-03A Drinking Fountain Outside of 34/36	6/28/16 18:38	7/5/16 11:02	6.06E+08	Copper	0.0	1.3	ppm
091-03A Drinking Fountain Outside of 34/36	6/28/16 18:38	7/5/16 11:02	6.06E+08	Lead	5	15	ppb
091-04A 35 Book Room Sink Faucet	6/28/16 18:44	7/5/16 11:03	6.06E+08	Copper	0.0	1.3	ppm
091-04A 35 Book Room Sink Faucet	6/28/16 18:44	7/5/16 11:03	6.06E+08	Lead	2	15	ppb
091-05A 34 Custodial Lunch Room. Sink Faucet	6/28/16 18:44	7/5/16 11:03	6.06E+08	Copper	0.3	1.3	ppm
091-05A 34 Custodial Lunch Room. Sink Faucet	6/28/16 18:44	7/5/16 11:03	6.06E+08	Lead	8	15	ppb
091-06A 38 Custodial Sink Faucet	6/28/16 18:47	7/5/16 11:03	6.06E+08	Copper	0.1	1.3	ppm
091-06A 38 Custodial Sink Faucet	6/28/16 18:47	7/5/16 11:03	6.06E+08	Lead	4	15	ppb
091-07A Locker Room Spigot near Towel Room D	6/28/16 18:50	7/5/16 11:03	6.06E+08	Copper	0.1	1.3	ppm
091-07A Locker Room Spigot near Towel Room D	6/28/16 18:50	7/5/16 11:03	6.06E+08	Lead	7	15	ppb
091-08A Locker Room Sink Faucet (1)	6/28/16 18:53	7/5/16 11:03	6.06E+08	Copper	0.1	1.3	ppm
091-08A Locker Room Sink Faucet (1)	6/28/16 18:53	7/5/16 11:03	6.06E+08	Lead	4	15	ppb
091-09A Locker Room Sink Faucet (2)	6/28/16 18:54	7/5/16 11:03	6.06E+08	Copper	0.2	1.3	ppm
091-09A Locker Room Sink Faucet (2)	6/28/16 18:54	7/5/16 11:03	6.06E+08	Lead	2	15	ppb
091-10A Locker Room Spigot near 40	6/28/16 18:56	7/9/16 15:55	6.06E+08	Copper	0.3	1.3	ppm
091-10A Locker Room Spigot near 40	6/28/16 18:56	7/9/16 15:55	6.06E+08	Lead	93	15	ppb
091-11A Drinking Fountain near 40	6/28/16 18:58	7/5/16 11:03	6.06E+08	Copper	0.1	1.3	ppm
091-11A Drinking Fountain near 40	6/28/16 18:58	7/5/16 11:03	6.06E+08	Lead	4	15	ppb
091-12A 40 Sink Faucet	6/28/16 19:00	7/5/16 11:04	6.06E+08	Copper	0.1	1.3	ppm
091-12A 40 Sink Faucet	6/28/16 19:00	7/5/16 11:04	6.06E+08	Lead	3	15	ppb
091-13A 40 Shower	6/28/16 19:01	7/5/16 11:08	6.06E+08	Copper	0.1	1.3	ppm
091-13A 40 Shower	6/28/16 19:01	7/5/16 11:08	6.06E+08	Lead	2	15	ppb
091-14A 40 Coaches Dressing Room Sink Faucet	6/28/16 19:03	7/5/16 11:08	6.06E+08	Copper	0.0	1.3	ppm
091-14A 40 Coaches Dressing Room Sink Faucet	6/28/16 19:03	7/5/16 11:08	6.06E+08	Lead	35	15	ppb
091-15A 40 Coaches Dressing Room Shower (1)	6/28/16 19:05	7/5/16 11:08	6.06E+08	Copper	0.6	1.3	ppm
091-15A 40 Coaches Dressing Room Shower (1)	6/28/16 19:05	7/5/16 11:08	6.06E+08	Lead	13	15	ppb
091-16A 40 Coaches Dressing Room Shower (2)	6/28/16 19:06	7/5/16 11:08	6.06E+08	Copper	0.3	1.3	ppm
091-16A 40 Coaches Dressing Room Shower (2)	6/28/16 19:06	7/5/16 11:08	6.06E+08	Lead	65	15	ppb
091-17A Locker Room Shower (1)	6/28/16 19:09	7/5/16 11:08	6.06E+08	Copper	0.5	1.3	ppm
091-17A Locker Room Shower (left to right clockwise)	6/28/16 19:09	7/5/16 11:08	6.06E+08	Lead	2	15	ppb
091-18A Locker Room Shower (left to right clockwise)	6/28/16 19:11	7/5/16 11:08	6.06E+08	Copper	0.5	1.3	ppm
091-18A Locker Room Shower (1)	6/28/16 19:11	7/5/16 11:08	6.06E+08	Lead	2	15	ppb
091-19A Locker Room Shower (2)	6/28/16 19:13	7/5/16 11:08	6.06E+08	Copper	0.5	1.3	ppm
091-19A Locker Room Shower (2)	6/28/16 19:13	7/5/16 11:08	6.06E+08	Lead	3	15	ppb
091-20A Locker Room Shower (3)	6/28/16 19:14	7/5/16 11:08	6.06E+08	Copper	0.5	1.3	ppm
091-20A Locker Room Shower (3)	6/28/16 19:14	7/5/16 11:08	6.06E+08	Lead	3	15	ppb
091-21A Locker Room Shower (4)	6/28/16 19:16	7/5/16 11:08	6.06E+08	Copper	0.5	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-21A Locker Room Shower (4)	6/28/16 19:16	7/5/16 11:08	6.06E+08	Lead	3	15	ppb
091-22A Locker Room Shower (5)	6/28/16 19:18	7/5/16 11:08	6.06E+08	Copper	0.5	1.3	ppm
091-22A Locker Room Shower (5)	6/28/16 19:18	7/5/16 11:08	6.06E+08	Lead	4	15	ppb
091-23A Boys Locker Room Shower (1)	6/28/16 19:19	7/5/16 11:09	6.06E+08	Copper	0.5	1.3	ppm
091-23A Boys Locker Room Shower (1)	6/28/16 19:19	7/5/16 11:09	6.06E+08	Lead	3	15	ppb
091-24A Boys Locker Room Shower (2)	6/28/16 19:24	7/5/16 11:09	6.06E+08	Copper	0.4	1.3	ppm
091-24A Boys Locker Room Shower (2)	6/28/16 19:24	7/5/16 11:09	6.06E+08	Lead	3	15	ppb
091-25A Boys Locker Room Shower (3)	6/28/16 19:23	7/5/16 11:09	6.06E+08	Copper	0.4	1.3	ppm
091-25A Boys Locker Room Shower (3)	6/28/16 19:23	7/5/16 11:09	6.06E+08	Lead	4	15	ppb
091-26A Boys Locker Room Shower (4)	6/28/16 19:26	7/5/16 11:09	6.06E+08	Copper	0.4	1.3	ppm
091-26A Boys Locker Room Shower (4)	6/28/16 19:26	7/5/16 11:09	6.06E+08	Lead	2	15	ppb
091-27A Boys Locker Room Shower (5)	6/28/16 19:27	7/5/16 11:09	6.06E+08	Copper	0.4	1.3	ppm
091-27A Boys Locker Room Shower (5)	6/28/16 19:27	7/5/16 11:09	6.06E+08	Lead	2	15	ppb
091-28A Boys Locker Room Shower (6)	6/28/16 19:28	7/5/16 11:09	6.06E+08	Copper	0.3	1.3	ppm
091-28A Boys Locker Room Shower (6)	6/28/16 19:28	7/5/16 11:09	6.06E+08	Lead	2	15	ppb
091-29A Boys Locker Room Shower (7)	6/28/16 19:29	7/5/16 11:09	6.06E+08	Copper	0.3	1.3	ppm
091-29A Boys Locker Room Shower (7)	6/28/16 19:29	7/5/16 11:09	6.06E+08	Lead	3	15	ppb
091-30A Boys Locker Room Shower (8)	6/28/16 19:31	7/5/16 11:09	6.06E+08	Copper	0.2	1.3	ppm
091-30A Boys Locker Room Shower (8)	6/28/16 19:31	7/5/16 11:09	6.06E+08	Lead	3	15	ppb
091-31A CoEd Training Room Sink Faucet	6/28/16 19:32	7/5/16 11:09	6.06E+08	Copper	0.1	1.3	ppm
091-31A CoEd Training Room Sink Faucet	6/28/16 19:32	7/5/16 11:09	6.06E+08	Lead	3	15	ppb
091-32A CoEd Training Room Ice Maker	6/28/16 19:35	7/5/16 11:10	6.06E+08	Copper	0.0	1.3	ppm
091-32A CoEd Training Room Ice Maker	6/28/16 19:35	7/5/16 11:10	6.06E+08	Lead	ND	15	ppb
091-33A CoEd Training Room Tub	6/28/16 19:36	7/11/16 12:23	6.06E+08	Copper	0.1	1.3	ppm
091-33A CoEd Training Room Tub	6/28/16 19:36	7/11/16 12:23	6.06E+08	Lead	10	15	ppb
091-34A Girls Locker Room Drinking Fountain	6/28/16 19:40	7/11/16 12:23	6.06E+08	Copper	0.1	1.3	ppm
091-34A Girls Locker Room Drinking Fountain	6/28/16 19:40	7/11/16 12:23	6.06E+08	Lead	15.4	15	ppb
091-35A Girls Locker Room Office Sink Faucet by shower	6/28/16 19:42	7/11/16 12:23	6.06E+08	Copper	0.1	1.3	ppm
091-35A Girls Locker Room Office Sink Faucet by shower	6/28/16 19:42	7/11/16 12:23	6.06E+08	Lead	18	15	ppb
091-36A Girls Locker Room Office Shower	6/28/16 19:44	7/11/16 12:23	6.06E+08	Copper	0.4	1.3	ppm
091-36A Girls Locker Room Office Shower	6/28/16 19:44	7/11/16 12:23	6.06E+08	Lead	11	15	ppb
091-37A Girls Locker Room Office Sink Faucet	6/28/16 19:45	7/11/16 12:23	6.06E+08	Copper	0.0	1.3	ppm
091-37A Girls Locker Room Office Sink Faucet	6/28/16 19:45	7/11/16 12:23	6.06E+08	Lead	66	15	ppb
091-38A Girls Locker Room Sink Faucet (1)	6/28/16 19:46	7/12/16 8:12	6.06E+08	Copper	0.1	1.3	ppm
091-38A Girls Locker Room Sink Faucet (1)	6/28/16 19:46	7/12/16 8:12	6.06E+08	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-39A Girls Locker Room Sink Faucet (2)	6/28/16 19:42	7/12/16 8:12	6.06E+08	Copper	0.1	1.3	ppm
091-39A Girls Locker Room Sink Faucet (2)	6/28/16 19:42	7/12/16 8:12	6.06E+08	Lead	8	15	ppb
091-40A Girls Locker Room Showers (1)	6/28/16 19:48	7/12/16 8:12	6.06E+08	Copper	0.2	1.3	ppm
091-40A Girls Locker Room Showers (1)	6/28/16 19:48	7/12/16 8:12	6.06E+08	Lead	2	15	ppb
091-41A Girls Locker Room Showers (2)	6/28/16 19:49	7/12/16 8:12	6.06E+08	Copper	0.3	1.3	ppm
091-41A Girls Locker Room Showers (2)	6/28/16 19:49	7/12/16 8:12	6.06E+08	Lead	3	15	ppb
091-42A Girls Locker Room Showers (3)	6/28/16 19:54	7/12/16 8:12	6.06E+08	Copper	0.2	1.3	ppm
091-42A Girls Locker Room Showers (3)	6/28/16 19:54	7/12/16 8:12	6.06E+08	Lead	3	15	ppb
091-43A Girls Locker Room Showers (4)	6/28/16 19:53	7/12/16 8:12	6.06E+08	Copper	0.2	1.3	ppm
091-43A Girls Locker Room Showers (4)	6/28/16 19:53	7/12/16 8:12	6.06E+08	Lead	3	15	ppb
091-44A Girls Locker Room Showers (5)	6/28/16 19:55	7/12/16 8:12	6.06E+08	Copper	0.3	1.3	ppm
091-44A Girls Locker Room Showers (5)	6/28/16 19:55	7/12/16 8:12	6.06E+08	Lead	3	15	ppb
091-45A Girls Locker Room Showers (6)	6/28/16 19:56	7/12/16 8:12	6.06E+08	Copper	0.3	1.3	ppm
091-45A Girls Locker Room Showers (6)	6/28/16 19:56	7/12/16 8:12	6.06E+08	Lead	3	15	ppb
091-46A Girls Locker Room Showers (7)	6/28/16 19:57	7/12/16 8:12	6.06E+08	Copper	0.3	1.3	ppm
091-46A Girls Locker Room Showers (7)	6/28/16 19:57	7/12/16 8:12	6.06E+08	Lead	3	15	ppb
091-47A Girls Locker Room Showers (8)	6/28/16 19:59	7/12/16 8:12	6.06E+08	Copper	0.3	1.3	ppm
091-47A Girls Locker Room Showers (8)	6/28/16 19:59	7/12/16 8:12	6.06E+08	Lead	3	15	ppb
091-48A Girls Locker Room Showers (9)	6/28/16 20:01	7/12/16 8:13	6.06E+08	Copper	0.3	1.3	ppm
091-48A Girls Locker Room Showers (9)	6/28/16 20:01	7/12/16 8:13	6.06E+08	Lead	3	15	ppb
091-49A Girls Locker Room Showers (10)	6/28/16 20:02	7/12/16 8:13	6.06E+08	Copper	0.3	1.3	ppm
091-49A Girls Locker Room Showers (10)	6/28/16 20:02	7/12/16 8:13	6.06E+08	Lead	3	15	ppb
091-50A Girls Locker Room Showers (11)	6/28/16 20:03	7/12/16 8:13	6.06E+08	Copper	0.3	1.3	ppm
091-50A Girls Locker Room Showers (11)	6/28/16 20:03	7/12/16 8:13	6.06E+08	Lead	2	15	ppb
091-51A Girls Locker Room Showers (12)	6/28/16 20:04	7/12/16 8:13	6.06E+08	Copper	0.3	1.3	ppm
091-51A Girls Locker Room Showers (12)	6/28/16 20:04	7/12/16 8:13	6.06E+08	Lead	3	15	ppb
091-52A Girls Locker Room Showers (13)	6/28/16 20:05	7/12/16 8:13	6.06E+08	Copper	0.3	1.3	ppm
091-52A Girls Locker Room Showers (13)	6/28/16 20:05	7/12/16 8:13	6.06E+08	Lead	3	15	ppb
091-53A Girls Locker Room Showers (14)	6/28/16 20:07	7/12/16 8:13	6.06E+08	Copper	0.3	1.3	ppm
091-53A Girls Locker Room Showers (14)	6/28/16 20:07	7/12/16 8:13	6.06E+08	Lead	4	15	ppb
091-54A Girls Locker Room Showers (15)	6/28/16 20:09	7/12/16 8:13	6.06E+08	Copper	0.3	1.3	ppm
091-54A Girls Locker Room Showers (15)	6/28/16 20:09	7/12/16 8:13	6.06E+08	Lead	3	15	ppb
091-55A Girls Locker Room Showers (16)	6/28/16 20:10	7/12/16 8:13	6.06E+08	Copper	0.3	1.3	ppm
091-55A Girls Locker Room Showers (16)	6/28/16 20:10	7/12/16 8:13	6.06E+08	Lead	4	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-56A Girls Locker Room Showers (17)	6/28/16 20:11	7/12/16 8:13	6.06E+08	Copper	0.3	1.3	ppm
091-56A Girls Locker Room Showers (17)	6/28/16 20:11	7/12/16 8:13	6.06E+08	Lead	4	15	ppb
091-57A Girls Locker Room Showers (18)	6/28/16 20:11	7/12/16 8:13	6.06E+08	Copper	0.3	1.3	ppm
091-57A Girls Locker Room Showers (18)	6/28/16 20:11	7/12/16 8:13	6.06E+08	Lead	3	15	ppb
091-58A Girls Locker Room Showers (19)	6/28/16 20:12	7/12/16 8:13	6.06E+08	Copper	0.3	1.3	ppm
091-58A Girls Locker Room Showers (19)	6/28/16 20:12	7/12/16 8:13	6.06E+08	Lead	5	15	ppb
091-59A Girls Locker Room Showers (20)	6/28/16 20:12	7/12/16 8:13	6.06E+08	Copper	0.3	1.3	ppm
091-59A Girls Locker Room Showers (20)	6/28/16 20:12	7/12/16 8:13	6.06E+08	Lead	5	15	ppb
091-60A Girls Locker Room Showers (21)	6/28/16 20:13	7/12/16 8:13	6.06E+08	Copper	0.4	1.3	ppm
091-60A Girls Locker Room Showers (21)	6/28/16 20:13	7/12/16 8:13	6.06E+08	Lead	3	15	ppb
091-61A Girls Locker Room Showers (22)	6/28/16 20:14	7/12/16 8:13	6.06E+08	Copper	0.4	1.3	ppm
091-61A Girls Locker Room Showers (22)	6/28/16 20:14	7/12/16 8:13	6.06E+08	Lead	8	15	ppb
091-62A Girls Locker Room Showers (23)	6/28/16 20:14	7/12/16 8:13	6.06E+08	Copper	0.4	1.3	ppm
091-62A Girls Locker Room Showers (23)	6/28/16 20:14	7/12/16 8:13	6.06E+08	Lead	6	15	ppb
091-63A Girls Locker Room Spigot	6/28/16 20:16	7/9/16 15:56	6.06E+08	Copper	0.2	1.3	ppm
091-63A Girls Locker Room Spigot	6/28/16 20:16	7/9/16 15:56	6.06E+08	Lead	115	15	ppb
091-64A Wrestling Room Drinking Fountain	6/28/16 20:18	7/12/16 8:13	6.06E+08	Copper	0.0	1.3	ppm
091-64A Wrestling Room Drinking Fountain	6/28/16 20:18	7/12/16 8:13	6.06E+08	Lead	29	15	ppb
091-65A Apparatus Room Drinking Fountain	6/28/16 20:29	7/12/16 8:13	6.06E+08	Copper	0.0	1.3	ppm
091-65A Apparatus Room Drinking Fountain	6/28/16 20:29	7/12/16 8:13	6.06E+08	Lead	10	15	ppb
091-66A 39 Matron Sink Faucet	6/28/16 20:33	7/12/16 8:13	6.06E+08	Copper	0.1	1.3	ppm
091-66A 39 Matron Sink Faucet	6/28/16 20:33	7/12/16 8:13	6.06E+08	Lead	27	15	ppb
091-67A 2nd Drinking Fountain Apparatus Room (1)	6/28/16 20:31	7/12/16 8:13	6.06E+08	Copper	0.0	1.3	ppm
091-67A 2nd Drinking Fountain Apparatus Room (1)	6/28/16 20:31	7/12/16 8:13	6.06E+08	Lead	9	15	ppb
091-68A Irrigation Pump Room Sink Faucet (outside pool)	6/28/16 20:40	7/9/16 15:56	6.06E+08	Copper	0.4	1.3	ppm
091-68A Irrigation Pump Room Sink Faucet (outside pool)	6/28/16 20:40	7/9/16 15:56	6.06E+08	Lead	350	15	ppb
091-69A Room 21 Girls Bathroom Sink Faucet	6/28/16 20:45	7/12/16 8:13	6.06E+08	Copper	0.2	1.3	ppm
091-69A Room 21 Girls Bathroom Sink Faucet	6/28/16 20:45	7/12/16 8:13	6.06E+08	Lead	4	15	ppb
091-70A 22 Custodial Sink Faucet	6/28/16 20:47	7/12/16 8:14	6.06E+08	Copper	0.1	1.3	ppm
091-70A 22 Custodial Sink Faucet	6/28/16 20:47	7/12/16 8:14	6.06E+08	Lead	3	15	ppb
091-71A 23 Boys Restroom Sink Faucet (1)	6/28/16 20:48	7/12/16 8:14	6.06E+08	Copper	0.1	1.3	ppm
091-71A 23 Boys Restroom Sink Faucet (1)	6/28/16 20:48	7/12/16 8:14	6.06E+08	Lead	6	15	ppb
091-72A 23 Boys Restroom Sink Faucet (2)	6/28/16 20:49	7/12/16 8:14	6.06E+08	Copper	0.1	1.3	ppm
091-72A 23 Boys Restroom Sink Faucet (2)	6/28/16 20:49	7/12/16 8:14	6.06E+08	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-73A 23 Boys Restroom Sink Faucet (3)	6/28/16 20:54	7/12/16 8:14	6.06E+08	Copper	0.1	1.3	ppm
091-73A 23 Boys Restroom Sink Faucet (3)	6/28/16 20:54	7/12/16 8:14	6.06E+08	Lead	5	15	ppb
091-74A 23 Boys Restroom Sink Faucet (4)	6/28/16 20:51	7/12/16 8:14	6.06E+08	Copper	0.1	1.3	ppm
091-74A 23 Boys Restroom Sink Faucet (4)	6/28/16 20:51	7/12/16 8:14	6.06E+08	Lead	18	15	ppb
091-75A 23 Boys Restroom Sink Faucet (5)	6/28/16 20:52	7/12/16 8:14	6.06E+08	Copper	0.0	1.3	ppm
091-75A 23 Boys Restroom Sink Faucet (5)	6/28/16 20:52	7/12/16 8:14	6.06E+08	Lead	4	15	ppb
091-76A 23 Boys Restroom Sink Faucet (6)	6/28/16 20:53	7/12/16 8:14	6.06E+08	Copper	0.1	1.3	ppm
091-76A 23 Boys Restroom Sink Faucet (6)	6/28/16 20:53	7/12/16 8:14	6.06E+08	Lead	11	15	ppb
091-77A 23 Boys Restroom Spigot	6/28/16 20:55	7/12/16 8:14	6.06E+08	Copper	1.7	1.3	ppm
091-77A 23 Boys Restroom Spigot	6/28/16 20:55	7/12/16 8:14	6.06E+08	Lead	56	15	ppb
091-78A Drinking Fountain Math Hall by 30 (1)	6/28/16 20:58	7/12/16 8:14	6.06E+08	Copper	0.0	1.3	ppm
091-78A Drinking Fountain Math Hall by 30 (1)	6/28/16 20:58	7/12/16 8:14	6.06E+08	Lead	6	15	ppb
091-79A Drinking Fountain Math Hall by 30 (2)	6/28/16 20:59	7/12/16 8:14	6.06E+08	Copper	0.0	1.3	ppm
091-79A Drinking Fountain Math Hall by 30 (2)	6/28/16 20:59	7/12/16 8:14	6.06E+08	Lead	7	15	ppb
091-80A Drinking Fountain Math Hall (3)	6/28/16 21:00	7/12/16 8:14	6.06E+08	Copper	0.0	1.3	ppm
091-80A Drinking Fountain Math Hall (3)	6/28/16 21:00	7/12/16 8:14	6.06E+08	Lead	3	15	ppb
091-81A Drinking Fountain Math Hall by 21 (1)	6/28/16 21:02	7/12/16 8:14	6.06E+08	Copper	0.0	1.3	ppm
091-81A Drinking Fountain Math Hall by 21 (1)	6/28/16 21:02	7/12/16 8:14	6.06E+08	Lead	2	15	ppb
091-82A Drinking Fountain Math Hall by 21 (2)	6/28/16 21:03	7/12/16 8:14	6.06E+08	Copper	0.0	1.3	ppm
091-82A Drinking Fountain Math Hall by 21 (2)	6/28/16 21:03	7/12/16 8:14	6.06E+08	Lead	2	15	ppb
091-83A Drinking Fountain Math Hall by 21 (3)	6/28/16 21:04	7/12/16 8:14	6.06E+08	Copper	0.0	1.3	ppm
091-83A Drinking Fountain Math Hall by 21 (3)	6/28/16 21:04	7/12/16 8:14	6.06E+08	Lead	2	15	ppb
091-84A Drinking Fountain Math Hall by 21 (4)	6/28/16 21:05	7/12/16 8:14	6.06E+08	Copper	0.0	1.3	ppm
091-84A Drinking Fountain Math Hall by 21 (4)	6/28/16 21:05	7/12/16 8:14	6.06E+08	Lead	2	15	ppb
091-85A 20 Girls Bathroom Sink Faucet (1)	6/28/16 21:06	7/12/16 8:14	6.06E+08	Copper	0.1	1.3	ppm
091-85A 20 Girls Bathroom Sink Faucet (1)	6/28/16 21:06	7/12/16 8:14	6.06E+08	Lead	3	15	ppb
091-86A 20 Girls Bathroom Sink Faucet (2)	6/28/16 21:07	7/12/16 8:14	6.06E+08	Copper	0.1	1.3	ppm
091-86A 20 Girls Bathroom Sink Faucet (2)	6/28/16 21:07	7/12/16 8:14	6.06E+08	Lead	9	15	ppb
091-87A 20 Girls Bathroom Sink Faucet (3)	6/28/16 21:08	7/12/16 8:14	6.06E+08	Copper	0.1	1.3	ppm
091-87A 20 Girls Bathroom Sink Faucet (3)	6/28/16 21:08	7/12/16 8:14	6.06E+08	Lead	11	15	ppb
091-88A 20 Girls Bathroom Sink Faucet (4)	6/28/16 21:09	7/12/16 8:14	6.06E+08	Copper	0.1	1.3	ppm
091-88A 20 Girls Bathroom Sink Faucet (4)	6/28/16 21:09	7/12/16 8:14	6.06E+08	Lead	7	15	ppb
091-89A 20 Girls Bathroom Sink Faucet (5)	6/28/16 21:09	7/12/16 8:14	6.06E+08	Copper	0.1	1.3	ppm
091-89A 20 Girls Bathroom Sink Faucet (5)	6/28/16 21:09	7/12/16 8:14	6.06E+08	Lead	14	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-90A 20 Girls Bathroom Sink Faucet (6)	6/28/16 21:10	7/12/16 8:14	6.06E+08	Copper	0.1	1.3	ppm
091-90A 20 Girls Bathroom Sink Faucet (6)	6/28/16 21:10	7/12/16 8:14	6.06E+08	Lead	18	15	ppb
091-91A 20 Girls Bathroom Spigot	6/28/16 21:12	7/9/16 15:56	6.06E+08	Copper	0.8	1.3	ppm
091-91A 20 Girls Bathroom Spigot	6/28/16 21:12	7/9/16 15:56	6.06E+08	Lead	35	15	ppb
091-92A Room 18 Athletic Training Sink Faucet (1)	6/28/16 21:22	7/12/16 8:14	6.06E+08	Copper	0.1	1.3	ppm
091-92A Room 18 Athletic Training Sink Faucet (1)	6/28/16 21:22	7/12/16 8:14	6.06E+08	Lead	10	15	ppb
091-93A Room 18 Athletic Training Sink Faucet (2)	6/28/16 21:23	7/12/16 8:14	6.06E+08	Copper	0.7	1.3	ppm
091-93A Room 18 Athletic Training Sink Faucet (2)	6/28/16 21:23	7/12/16 8:14	6.06E+08	Lead	47	15	ppb
091-94A Room 18 Athletic Training Ice Maker	6/28/16 21:25	7/12/16 8:14	6.06E+08	Copper	0.0	1.3	ppm
091-94A Room 18 Athletic Training Ice Maker	6/28/16 21:25	7/12/16 8:14	6.06E+08	Lead	ND	15	ppb
091-95A Cafeteria Dish Return Sink Faucet	6/28/16 21:27	7/9/16 15:56	6.06E+08	Copper	0.7	1.3	ppm
091-95A Cafeteria Dish Return Sink Faucet	6/28/16 21:27	7/9/16 15:56	6.06E+08	Lead	632	15	ppb
091-96A Kitchen Custodial Sink Faucet	6/28/16 21:29	7/12/16 8:15	6.06E+08	Copper	0.3	1.3	ppm
091-96A Kitchen Custodial Sink Faucet	6/28/16 21:29	7/12/16 8:15	6.06E+08	Lead	9	15	ppb
091-97A Kitchen White Handwash Sink Faucet	6/28/16 21:31	7/12/16 8:15	6.06E+08	Copper	0.4	1.3	ppm
091-97A Kitchen White Handwash Sink Faucet	6/28/16 21:31	7/12/16 8:15	6.06E+08	Lead	6	15	ppb
091-98A Kitchen Metal Single Island Sink Faucet	6/28/16 21:33	7/12/16 8:15	6.06E+08	Copper	0.2	1.3	ppm
091-98A Kitchen Metal Single Island Sink Faucet	6/28/16 21:33	7/12/16 8:15	6.06E+08	Lead	3	15	ppb
091-99A Kitchen Cafe Womens Restroom Sink Faucet	6/28/16 21:34	7/12/16 8:15	6.06E+08	Copper	0.3	1.3	ppm
091-99A Kitchen Cafe Womens Restroom Sink Faucet	6/28/16 21:34	7/12/16 8:15	6.06E+08	Lead	11	15	ppb
091-100A Kitchen Hand Spigot	6/28/16 21:35	7/12/16 8:15	6.06E+09	Copper	0.1	1.3	ppm
091-100A Kitchen Hand Spigot	6/28/16 21:35	7/12/16 8:15	6.06E+09	Lead	54	15	ppb
091-101A Kitchen Sanitize Sink Faucet (1)	6/28/16 21:36	7/12/16 8:15	6.06E+09	Copper	0.4	1.3	ppm
091-101A Kitchen Sanitize Sink Faucet (1)	6/28/16 21:36	7/12/16 8:15	6.06E+09	Lead	21	15	ppb
091-102A Kitchen Sanitize Sink Faucet (2)	6/28/16 21:38	7/9/16 18:36	6.06E+09	Copper	0.5	1.3	ppm
091-102A Kitchen Sanitize Sink Faucet (2)	6/28/16 21:38	7/9/16 18:36	6.06E+09	Lead	55	15	ppb
091-103A Kitchen Rinse Sink Faucet	6/28/16 21:40	7/9/16 18:36	6.06E+09	Copper	0.1	1.3	ppm
091-103A Kitchen Rinse Sink Faucet	6/28/16 21:40	7/9/16 18:36	6.06E+09	Lead	14.8	15	ppb
091-104A Kitchen Wash Sink Faucet	6/28/16 21:43	7/9/16 18:36	6.06E+09	Copper	0.1	1.3	ppm
091-104A Kitchen Wash Sink Faucet	6/28/16 21:43	7/9/16 18:36	6.06E+09	Lead	2	15	ppb
091-105A Kitchen Food Prep Sprayer	6/28/16 21:44	7/9/16 18:36	6.06E+09	Copper	0.1	1.3	ppm
091-105A Kitchen Food Prep Sprayer	6/28/16 21:44	7/9/16 18:36	6.06E+09	Lead	8	15	ppb
091-106A Kitchen Food Prep Sink Faucet	6/28/16 21:45	7/9/16 18:36	6.06E+09	Copper	0.0	1.3	ppm
091-106A Kitchen Food Prep Sink Faucet	6/28/16 21:45	7/9/16 18:36	6.06E+09	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-107A Cafeteria Drinking Fountain	6/28/16 21:51	7/9/16 18:36	6.06E+09	Copper	0.0	1.3	ppm
091-107A Cafeteria Drinking Fountain	6/28/16 21:51	7/9/16 18:36	6.06E+09	Lead	20	15	ppb
091-108A 15 Metal Shop Sink Faucet (1)	6/28/16 21:56	7/11/16 11:17	6.06E+09	Copper	0.0	1.3	ppm
091-108A 15 Metal Shop Sink Faucet (1)	6/28/16 21:56	7/11/16 11:17	6.06E+09	Lead	3	15	ppb
091-109A 15 Metal Shop Sink Faucet (2)	6/28/16 21:58	7/9/16 18:36	6.06E+09	Copper	0.1	1.3	ppm
091-109A 15 Metal Shop Sink Faucet (2)	6/28/16 21:58	7/9/16 18:36	6.06E+09	Lead	5	15	ppb
091-110A 15 Metal Shop Drinking Fountain	6/28/16 21:59	7/9/16 18:38	6.06E+09	Copper	0.1	1.3	ppm
091-110A 15 Metal Shop Drinking Fountain	6/28/16 21:59	7/9/16 18:38	6.06E+09	Lead	2	15	ppb
091-111A 9 Wood Work Sink Faucet (1)	6/28/16 22:02	7/9/16 18:38	6.06E+09	Copper	0.1	1.3	ppm
091-111A 9 Wood Work Sink Faucet (1)	6/28/16 22:02	7/9/16 18:38	6.06E+09	Lead	4	15	ppb
091-112A 9 Wood Work Sink Faucet (2)	6/28/16 22:03	7/9/16 18:38	6.06E+09	Copper	0.0	1.3	ppm
091-112A 9 Wood Work Sink Faucet (2)	6/28/16 22:03	7/9/16 18:38	6.06E+09	Lead	1	15	ppb
091-113A 9 Wood Work Drinking Fountain	6/28/16 22:05	7/9/16 15:54	6.06E+09	Copper	0.1	1.3	ppm
091-113A 9 Wood Work Drinking Fountain	6/28/16 22:05	7/9/16 15:54	6.06E+09	Lead	7	15	ppb
091-114A 9 Wood Work Sprayer	6/28/16 22:06	7/9/16 18:38	6.06E+09	Copper	0.1	1.3	ppm
091-114A 9 Wood Work Sprayer	6/28/16 22:06	7/9/16 18:38	6.06E+09	Lead	17	15	ppb
091-115A 8 Room Sink Faucet	6/28/16 22:11	7/9/16 18:38	6.06E+09	Copper	0.1	1.3	ppm
091-115A 8 Room Sink Faucet	6/28/16 22:11	7/9/16 18:38	6.06E+09	Lead	10	15	ppb
091-116A 10 Custodial Sink Faucet	6/28/16 22:12	7/9/16 18:38	6.06E+09	Copper	0.0	1.3	ppm
091-116A 10 Custodial Sink Faucet	6/28/16 22:12	7/9/16 18:38	6.06E+09	Lead	7	15	ppb
091-117A 7 Photo Sink Faucet (1)	6/28/16 22:13	7/12/16 8:15	6.06E+09	Copper	0.2	1.3	ppm
091-117A 7 Photo Sink Faucet (1)	6/28/16 22:13	7/12/16 8:15	6.06E+09	Lead	31	15	ppb
091-118A 7 Photo Drinking Fountain	6/28/16 22:14	7/12/16 8:15	6.06E+09	Copper	1.9	1.3	ppm
091-118A 7 Photo Drinking Fountain	6/28/16 22:14	7/12/16 8:15	6.06E+09	Lead	50	15	ppb
091-119A 7 Photo Sink Faucet (2)	6/28/16 22:15	7/12/16 8:15	6.06E+09	Copper	0.1	1.3	ppm
091-119A 7 Photo Sink Faucet (2)	6/28/16 22:15	7/12/16 8:15	6.06E+09	Lead	12	15	ppb
091-120A Drinking Fountain Outside 7	6/28/16 22:18	7/12/16 8:15	6.06E+09	Copper	0.0	1.3	ppm
091-120A Drinking Fountain Outside 7	6/28/16 22:18	7/12/16 8:15	6.06E+09	Lead	1	15	ppb
091-121A 6 Boys Dressing Room Sink Faucet	6/28/16 22:21	7/12/16 8:15	6.06E+09	Copper	0.0	1.3	ppm
091-121A 6 Boys Dressing Room Sink Faucet	6/28/16 22:21	7/12/16 8:15	6.06E+09	Lead	63	15	ppb
091-122A 4 Facility Men Bathroom Sink Faucet	6/28/16 22:23	7/12/16 8:15	6.06E+09	Copper	0.1	1.3	ppm
091-122A 4 Facility Men Bathroom Sink Faucet	6/28/16 22:23	7/12/16 8:15	6.06E+09	Lead	7	15	ppb
091-123A 3 Girls Bathroom Sink Faucet	6/28/16 22:24	7/12/16 8:15	6.06E+09	Copper	0.1	1.3	ppm
091-123A 3 Girls Bathroom Sink Faucet	6/28/16 22:24	7/12/16 8:15	6.06E+09	Lead	19	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-124A 2 Girls Dressing Room Sink Faucet	6/28/16 22:25	7/12/16 8:15	6.06E+09	Copper	0.0	1.3	ppm
091-124A 2 Girls Dressing Room Sink Faucet	6/28/16 22:25	7/12/16 8:15	6.06E+09	Lead	40	15	ppb
091-125A Gym (1st Floor) Drinking Fountain East (1)	6/28/16 22:39	7/12/16 8:15	6.06E+09	Copper	0.0	1.3	ppm
091-125A Gym (1st Floor) Drinking Fountain East (1)	6/28/16 22:39	7/12/16 8:15	6.06E+09	Lead	6	15	ppb
091-126A Gym (1st Floor) Drinking Fountain West (1)	6/28/16 22:40	7/12/16 8:15	6.06E+09	Copper	0.1	1.3	ppm
091-126A Gym (1st Floor) Drinking Fountain West (1)	6/28/16 22:40	7/12/16 8:15	6.06E+09	Lead	12	15	ppb
091-127A Gym (1st Floor) Drinking Fountain West (2)	6/28/16 22:42	7/12/16 8:16	6.06E+09	Copper	0.1	1.3	ppm
091-127A Gym (1st Floor) Drinking Fountain West (2)	6/28/16 22:42	7/12/16 8:16	6.06E+09	Lead	7	15	ppb
091-128A Gym (1st Floor) Drinking Fountain East (2)	6/28/16 22:43	7/5/16 14:54	6.06E+09	Copper	0.1	1.3	ppm
091-128A Gym (1st Floor) Drinking Fountain East (2)	6/28/16 22:43	7/5/16 14:54	6.06E+09	Lead	4	15	ppb
091-129A Boys Locker Room Stairwell Sink Faucet	6/28/16 22:42	7/5/16 14:55	6.06E+09	Copper	0.0	1.3	ppm
091-129A Boys Locker Room Stairwell Sink Faucet	6/28/16 22:42	7/5/16 14:55	6.06E+09	Lead	16	15	ppb
091-130A Drinking Fountain outside 138 Bottle Fill	6/28/16 22:50	7/5/16 14:55	6.06E+09	Copper	1.5	1.3	ppm
091-130A Drinking Fountain outside 138 Bottle Fill	6/28/16 22:50	7/5/16 14:55	6.06E+09	Lead	ND	15	ppb
091-131A Drinking Fountain outside 138	6/28/16 22:52	7/5/16 14:55	6.06E+09	Copper	1.1	1.3	ppm
091-131A Drinking Fountain outside 138	6/28/16 22:52	7/5/16 14:55	6.06E+09	Lead	ND	15	ppb
091-132A Unisex Bathroom next to 124 Sink Faucet	6/28/16 22:54	7/5/16 14:55	6.06E+09	Copper	0.2	1.3	ppm
091-132A Unisex Bathroom next to 124 Sink Faucet	6/28/16 22:54	7/5/16 14:55	6.06E+09	Lead	13	15	ppb
091-133A 124 Custodial Sink Faucet	6/28/16 22:59	7/5/16 14:55	6.06E+09	Copper	0.0	1.3	ppm
091-133A 124 Custodial Sink Faucet	6/28/16 22:59	7/5/16 14:55	6.06E+09	Lead	6	15	ppb
091-134A 125 Boys Restroom Sink Faucet (1)	6/28/16 23:00	7/9/16 15:56	6.06E+09	Copper	0.3	1.3	ppm
091-134A 125 Boys Restroom Sink Faucet (1)	6/28/16 23:00	7/9/16 15:56	6.06E+09	Lead	10	15	ppb
091-135A 125 Boys Restroom Sink Faucet (2)	6/28/16 23:01	7/5/16 14:55	6.06E+09	Copper	0.2	1.3	ppm
091-135A 125 Boys Restroom Sink Faucet (2)	6/28/16 23:01	7/5/16 14:55	6.06E+09	Lead	9	15	ppb
091-136A 125 Boys Restroom Sink Faucet (3)	6/28/16 23:02	7/5/16 14:55	6.06E+09	Copper	0.2	1.3	ppm
091-136A 125 Boys Restroom Sink Faucet (3)	6/28/16 23:02	7/5/16 14:55	6.06E+09	Lead	5	15	ppb
091-137A 125 Boys Restroom Sink Faucet (4)	6/28/16 23:03	7/5/16 14:55	6.06E+09	Copper	0.1	1.3	ppm
091-137A 125 Boys Restroom Sink Faucet (4)	6/28/16 23:03	7/5/16 14:55	6.06E+09	Lead	9	15	ppb
091-138A 125 Boys Restroom Sink Faucet (5)	6/28/16 23:03	7/5/16 14:55	6.06E+09	Copper	0.1	1.3	ppm
091-138A 125 Boys Restroom Sink Faucet (5)	6/28/16 23:03	7/5/16 14:55	6.06E+09	Lead	5	15	ppb
091-139A 125 Boys Restroom Sink Faucet (6)	6/28/16 23:04	7/5/16 14:55	6.06E+09	Copper	0.2	1.3	ppm
091-139A 125 Boys Restroom Sink Faucet (6)	6/28/16 23:04	7/5/16 14:55	6.06E+09	Lead	5	15	ppb
091-140A 125 Boys Restroom Spigot	6/28/16 23:04	7/9/16 15:57	6.06E+09	Copper	0.9	1.3	ppm
091-140A 125 Boys Restroom Spigot	6/28/16 23:04	7/9/16 15:57	6.06E+09	Lead	145	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-141A Drinking Fountain outside 131 (1)	6/28/16 23:08	7/5/16 14:55	6.06E+09	Copper	0.2	1.3	ppm
091-141A Drinking Fountain outside 131 (1)	6/28/16 23:08	7/5/16 14:55	6.06E+09	Lead	5	15	ppb
091-142A Drinking Fountain outside 131 (2)	6/28/16 23:09	7/5/16 14:55	6.06E+09	Copper	0.1	1.3	ppm
091-142A Drinking Fountain outside 131 (2)	6/28/16 23:09	7/5/16 14:55	6.06E+09	Lead	6	15	ppb
091-143A Drinking Fountain outside 131 (3)	6/28/16 23:10	7/5/16 14:55	6.06E+09	Copper	0.1	1.3	ppm
091-143A Drinking Fountain outside 131 (3)	6/28/16 23:10	7/5/16 14:55	6.06E+09	Lead	4	15	ppb
091-144A Classroom 132 Sink Faucet (west wall, window)	6/28/16 23:14	7/5/16 14:55	6.06E+09	Copper	0.5	1.3	ppm
091-144A Classroom 132 Sink Faucet (west wall, window)	6/28/16 23:14	7/5/16 14:55	6.06E+09	Lead	63	15	ppb
091-145A Classroom 132 Sink Faucet (north wall, east)	6/28/16 23:15	7/5/16 14:55	6.06E+09	Copper	0.7	1.3	ppm
091-145A Classroom 132 Sink Faucet (north wall, east)	6/28/16 23:15	7/5/16 14:55	6.06E+09	Lead	69	15	ppb
091-146A 122 Girls Restroom Sink Faucet (1)	6/28/16 23:18	7/5/16 14:56	6.06E+09	Copper	0.1	1.3	ppm
091-146A 122 Girls Restroom Sink Faucet (1)	6/28/16 23:18	7/5/16 14:56	6.06E+09	Lead	11	15	ppb
091-147A 122 Girls Restroom Sink Faucet (2)	6/28/16 23:19	7/5/16 14:56	6.06E+09	Copper	0.1	1.3	ppm
091-147A 122 Girls Restroom Sink Faucet (2)	6/28/16 23:19	7/5/16 14:56	6.06E+09	Lead	5	15	ppb
091-148A 122 Girls Restroom Sink Faucet (3)	6/28/16 23:20	7/5/16 14:56	6.06E+09	Copper	0.1	1.3	ppm
091-148A 122 Girls Restroom Sink Faucet (3)	6/28/16 23:20	7/5/16 14:56	6.06E+09	Lead	5	15	ppb
091-149A 122 Girls Restroom Sink Faucet (4)	6/28/16 23:20	7/5/16 14:56	6.06E+09	Copper	0.1	1.3	ppm
091-149A 122 Girls Restroom Sink Faucet (4)	6/28/16 23:20	7/5/16 14:56	6.06E+09	Lead	5	15	ppb
091-150A 122 Girls Restroom Sink Faucet (5)	6/28/16 23:21	7/5/16 14:56	6.06E+09	Copper	0.0	1.3	ppm
091-150A 122 Girls Restroom Sink Faucet (5)	6/28/16 23:21	7/5/16 14:56	6.06E+09	Lead	11	15	ppb
091-151A 122 Girls Restroom Sink Faucet (6)	6/28/16 23:22	7/5/16 14:56	6.06E+09	Copper	0.0	1.3	ppm
091-151A 122 Girls Restroom Sink Faucet (6)	6/28/16 23:22	7/5/16 14:56	6.06E+09	Lead	9	15	ppb
091-152A 122 Girls Restroom Spigot	6/28/16 23:24	7/9/16 15:57	6.06E+09	Copper	0.6	1.3	ppm
091-152A 122 Girls Restroom Spigot	6/28/16 23:24	7/9/16 15:57	6.06E+09	Lead	26	15	ppb
091-154A Sink Faucet (Room 142)	6/28/16 23:28	7/5/16 14:56	6.06E+09	Copper	0.3	1.3	ppm
091-154A Sink Faucet (Room 142)	6/28/16 23:28	7/5/16 14:56	6.06E+09	Lead	14	15	ppb
091-155A Sink Faucet (Room 118)	6/28/16 23:31	7/5/16 14:56	6.06E+09	Copper	0.2	1.3	ppm
091-155A Sink Faucet (Room 118)	6/28/16 23:31	7/5/16 14:56	6.06E+09	Lead	7	15	ppb
091-156A 143 Sink Faucet	6/28/16 23:34	7/5/16 14:56	6.06E+09	Copper	0.2	1.3	ppm
091-156A 143 Sink Faucet	6/28/16 23:34	7/5/16 14:56	6.06E+09	Lead	20	15	ppb
091-157A 141 Sink Faucet	6/28/16 23:35	7/5/16 14:56	6.06E+09	Copper	0.2	1.3	ppm
091-157A 141 Sink Faucet	6/28/16 23:35	7/5/16 14:56	6.06E+09	Lead	34	15	ppb
091-158A 115 Womens Bathroom Sink Faucet	6/28/16 23:39	7/5/16 14:56	6.06E+09	Copper	0.1	1.3	ppm
091-158A 115 Womens Bathroom Sink Faucet	6/28/16 23:39	7/5/16 14:56	6.06E+09	Lead	4	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-159A 113 Girls Bathroom Sink Faucet (1)	6/28/16 23:44	7/5/16 14:57	6.06E+09	Copper	0.0	1.3	ppm
091-159A 113 Girls Bathroom Sink Faucet (1)	6/28/16 23:44	7/5/16 14:57	6.06E+09	Lead	11	15	ppb
091-160A 113 Girls Bathroom Sink Faucet (2)	6/28/16 23:45	7/5/16 14:57	6.06E+09	Copper	0.1	1.3	ppm
091-160A 113 Girls Bathroom Sink Faucet (2)	6/28/16 23:45	7/5/16 14:57	6.06E+09	Lead	4	15	ppb
091-161A 113 Girls Bathroom Sink Faucet (3)	6/28/16 23:46	7/5/16 14:57	6.06E+09	Copper	0.1	1.3	ppm
091-161A 113 Girls Bathroom Sink Faucet (3)	6/28/16 23:46	7/5/16 14:57	6.06E+09	Lead	7	15	ppb
091-162A 113 Girls Bathroom Sink Faucet (4)	6/28/16 23:47	7/5/16 14:57	6.06E+09	Copper	0.0	1.3	ppm
091-162A 113 Girls Bathroom Sink Faucet (4)	6/28/16 23:47	7/5/16 14:57	6.06E+09	Lead	4	15	ppb
091-163A 113 Girls Bathroom Sink Faucet (5)	6/28/16 23:48	7/5/16 14:57	6.06E+09	Copper	0.0	1.3	ppm
091-163A 113 Girls Bathroom Sink Faucet (5)	6/28/16 23:48	7/5/16 14:57	6.06E+09	Lead	4	15	ppb
091-164A 113 Girls Bathroom Sink Faucet (6)	6/28/16 23:49	7/5/16 14:57	6.06E+09	Copper	0.2	1.3	ppm
091-164A 113 Girls Bathroom Sink Faucet (6)	6/28/16 23:49	7/5/16 14:57	6.06E+09	Lead	5	15	ppb
091-165A 113 Girls Bathroom Spigot	6/28/16 23:50	7/9/16 15:57	6.06E+09	Copper	0.6	1.3	ppm
091-165A 113 Girls Bathroom Spigot	6/28/16 23:50	7/9/16 15:57	6.06E+09	Lead	21	15	ppb
091-166A Drinking Fountain near 145 (1)	6/28/16 23:52	7/5/16 14:57	6.06E+09	Copper	0.1	1.3	ppm
091-166A Drinking Fountain near 145 (1)	6/28/16 23:52	7/5/16 14:57	6.06E+09	Lead	7	15	ppb
091-167A Drinking Fountain near 145 (2)	6/28/16 23:53	7/5/16 14:57	6.06E+09	Copper	0.1	1.3	ppm
091-167A Drinking Fountain near 145 (2)	6/28/16 23:53	7/5/16 14:57	6.06E+09	Lead	8	15	ppb
091-168A Drinking Fountain near 145 (3)	6/28/16 23:53	7/5/16 14:57	6.06E+09	Copper	0.1	1.3	ppm
091-168A Drinking Fountain near 145 (3)	6/28/16 23:53	7/5/16 14:57	6.06E+09	Lead	5	15	ppb
091-169A Drinking Fountain near 145 (4)	6/28/16 23:54	7/9/16 18:12	6.06E+09	Copper	0.1	1.3	ppm
091-169A Drinking Fountain near 145 (4)	6/28/16 23:54	7/9/16 18:12	6.06E+09	Lead	8	15	ppb
091-170A 112 Unisex Bathroom Sink Faucet	6/28/16 23:54	7/9/16 18:12	6.06E+09	Copper	0.4	1.3	ppm
091-170A 112 Unisex Bathroom Sink Faucet	6/28/16 23:54	7/9/16 18:12	6.06E+09	Lead	4	15	ppb
091-171A 111 Custodial Sink Faucet	6/28/16 23:54	7/9/16 18:12	6.06E+09	Copper	0.1	1.3	ppm
091-171A 111 Custodial Sink Faucet	6/28/16 23:54	7/9/16 18:12	6.06E+09	Lead	1	15	ppb
091-172A 110 Boys Bathroom Sink Faucet (1)	6/28/16 23:55	7/9/16 18:12	6.06E+09	Copper	0.0	1.3	ppm
091-172A 110 Boys Bathroom Sink Faucet (1)	6/28/16 23:55	7/9/16 18:12	6.06E+09	Lead	7	15	ppb
091-173A 110 Boys Bathroom Sink Faucet (2)	6/28/16 23:56	7/9/16 18:12	6.06E+09	Copper	0.0	1.3	ppm
091-173A 110 Boys Bathroom Sink Faucet (2)	6/28/16 23:56	7/9/16 18:12	6.06E+09	Lead	8	15	ppb
091-174A 110 Boys Bathroom Sink Faucet (3)	6/28/16 23:56	7/9/16 18:12	6.06E+09	Copper	0.1	1.3	ppm
091-174A 110 Boys Bathroom Sink Faucet (3)	6/28/16 23:56	7/9/16 18:12	6.06E+09	Lead	22	15	ppb
091-175A 110 Boys Bathroom Sink Faucet (4)	6/28/16 23:57	7/9/16 18:12	6.06E+09	Copper	0.1	1.3	ppm
091-175A 110 Boys Bathroom Sink Faucet (4)	6/28/16 23:57	7/9/16 18:12	6.06E+09	Lead	9	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-176A 110 Boys Bathroom Sink Faucet (5)	6/28/16 23:58	7/9/16 18:12	6.06E+09	Copper	0.1	1.3	ppm
091-176A 110 Boys Bathroom Sink Faucet (5)	6/28/16 23:58	7/9/16 18:12	6.06E+09	Lead	7	15	ppb
091-177A 110 Boys Bathroom Sink Faucet (6)	6/28/16 23:58	7/9/16 18:12	6.06E+09	Copper	0.1	1.3	ppm
091-177A 110 Boys Bathroom Sink Faucet (6)	6/28/16 23:58	7/9/16 18:12	6.06E+09	Lead	9	15	ppb
091-178A 110 Boys Bathroom Spigot	6/28/16 23:59	7/9/16 16:00	6.06E+09	Copper	0.6	1.3	ppm
091-178A 110 Boys Bathroom Spigot	6/28/16 23:59	7/9/16 16:00	6.06E+09	Lead	33	15	ppb
091-179A Work Room Sink Faucet	6/29/16 0:04	7/9/16 18:12	6.06E+09	Copper	0.0	1.3	ppm
091-179A Work Room Sink Faucet	6/29/16 0:04	7/9/16 18:12	6.06E+09	Lead	28	15	ppb
091-180A Stage Drinking Fountain	6/29/16 0:05	7/9/16 18:13	6.06E+09	Copper	0.0	1.3	ppm
091-180A Stage Drinking Fountain	6/29/16 0:05	7/9/16 18:13	6.06E+09	Lead	8	15	ppb
091-181A 145 Faculty Sink Faucet	6/29/16 0:10	7/9/16 18:13	6.06E+09	Copper	0.0	1.3	ppm
091-181A 145 Faculty Sink Faucet	6/29/16 0:10	7/9/16 18:13	6.06E+09	Lead	3	15	ppb
091-182A Nurse Sink Faucet	6/29/16 0:10	7/9/16 18:13	6.06E+09	Copper	0.1	1.3	ppm
091-182A Nurse Sink Faucet	6/29/16 0:10	7/9/16 18:13	6.06E+09	Lead	18	15	ppb
091-183A Nurse Eyewash	6/29/16 0:11	7/9/16 18:13	6.06E+09	Copper	0.3	1.3	ppm
091-183A Nurse Eyewash	6/29/16 0:11	7/9/16 18:13	6.06E+09	Lead	120	15	ppb
091-184A Stage Custodial Sink Faucet	6/29/16 0:05	7/9/16 18:13	6.06E+09	Copper	0.5	1.3	ppm
091-184A Stage Custodial Sink Faucet	6/29/16 0:05	7/9/16 18:13	6.06E+09	Lead	11	15	ppb
091-185A Office Sink Faucet	6/29/16 0:13	7/9/16 18:13	6.06E+09	Copper	0.1	1.3	ppm
091-185A Office Sink Faucet	6/29/16 0:13	7/9/16 18:13	6.06E+09	Lead	22	15	ppb
091-186A Drinking Fountain Foyer (west)	6/29/16 0:13	7/9/16 18:13	6.06E+09	Copper	0.0	1.3	ppm
091-186A Drinking Fountain Foyer (west)	6/29/16 0:13	7/9/16 18:13	6.06E+09	Lead	44	15	ppb
091-187A Drinking Fountain Foyer (east)	6/29/16 0:16	7/9/16 18:13	6.06E+09	Copper	0.1	1.3	ppm
091-187A Drinking Fountain Foyer (east)	6/29/16 0:16	7/9/16 18:13	6.06E+09	Lead	14	15	ppb
091-188A Room 241 far left Island Sink Faucet (1)	6/29/16 1:46	7/9/16 18:13	6.06E+09	Copper	0.2	1.3	ppm
091-188A Room 241 far left Island Sink Faucet (1)	6/29/16 1:46	7/9/16 18:13	6.06E+09	Lead	9	15	ppb
091-189A Room 241 far left Island Sink Faucet (2)	6/29/16 1:47	7/9/16 18:13	6.06E+09	Copper	0.3	1.3	ppm
091-189A Room 241 far left Island Sink Faucet (2)	6/29/16 1:47	7/9/16 18:13	6.06E+09	Lead	14	15	ppb
091-190A Room 241 far left Island Sink Faucet (3)	6/29/16 1:48	7/9/16 18:15	6.06E+09	Copper	0.3	1.3	ppm
091-190A Room 241 far left Island Sink Faucet (3)	6/29/16 1:48	7/9/16 18:15	6.06E+09	Lead	27	15	ppb
091-191A Room 241 far left Island Sink Faucet (4)	6/29/16 1:50	7/9/16 18:15	6.06E+09	Copper	0.3	1.3	ppm
091-191A Room 241 far left Island Sink Faucet (4)	6/29/16 1:50	7/9/16 18:15	6.06E+09	Lead	34	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-192A Room 241 left/middle Island Sink Faucet (1)	6/29/16 1:50	7/9/16 18:15	6.06E+09	Copper	0.2	1.3	ppm
091-192A Room 241 left/middle Island Sink Faucet (1)	6/29/16 1:50	7/9/16 18:15	6.06E+09	Lead	25	15	ppb
091-193A Room 241 left/middle Island Sink Faucet (2)	6/29/16 1:50	7/9/16 18:15	6.06E+09	Copper	0.3	1.3	ppm
091-193A Room 241 left/middle Island Sink Faucet (2)	6/29/16 1:50	7/9/16 18:15	6.06E+09	Lead	26	15	ppb
091-194A Room 241 left/middle Island Sink Faucet (3)	6/29/16 1:50	7/9/16 18:15	6.06E+09	Copper	0.3	1.3	ppm
091-194A Room 241 left/middle Island Sink Faucet (3)	6/29/16 1:50	7/9/16 18:15	6.06E+09	Lead	22	15	ppb
091-195A Room 241 left/middle Island Sink 4 Faucet (4)	6/29/16 1:50	7/9/16 18:15	6.06E+09	Copper	0.3	1.3	ppm
091-195A Room 241 left/middle Island Sink Faucet (4)	6/29/16 1:50	7/9/16 18:15	6.06E+09	Lead	27	15	ppb
091-196A Room 241 Sink Faucet against Window	6/29/16 1:52	7/9/16 18:15	6.06E+09	Copper	0.2	1.3	ppm
091-196A Room 241 Sink Faucet against Window	6/29/16 1:52	7/9/16 18:15	6.06E+09	Lead	3	15	ppb
091-197A Room 241 right Island Sink Faucet	6/29/16 1:53	7/9/16 18:15	6.06E+09	Copper	0.1	1.3	ppm
091-197A Room 241 right Island Sink Faucet	6/29/16 1:53	7/9/16 18:15	6.06E+09	Lead	67	15	ppb
091-198A Room 241 Eyewash	6/29/16 1:53	7/9/16 18:15	6.06E+09	Copper	0.3	1.3	ppm
091-198A Room 241 Eyewash	6/29/16 1:53	7/9/16 18:15	6.06E+09	Lead	49	15	ppb
091-199A Room 241 Sink Faucet	6/29/16 1:54	7/9/16 18:15	6.06E+09	Copper	0.3	1.3	ppm
091-199A Room 241 Sink Faucet	6/29/16 1:54	7/9/16 18:15	6.06E+09	Lead	42	15	ppb
091-200A Room 241 Eyewash	6/29/16 1:55	7/9/16 18:16	6.06E+09	Copper	0.0	1.3	ppm
091-200A Room 241 Eyewash	6/29/16 1:55	7/9/16 18:16	6.06E+09	Lead	6	15	ppb
091-201A Room 241 Sink Faucet	6/29/16 1:55	7/9/16 18:16	6.06E+09	Copper	0.1	1.3	ppm
091-201A Room 241 Sink Faucet	6/29/16 1:55	7/9/16 18:16	6.06E+09	Lead	4	15	ppb
091-202A Room 241 Hood Sink Sink Faucet	6/29/16 1:57	7/9/16 18:16	6.06E+09	Copper	0.6	1.3	ppm
091-202A Room 241 Hood Sink Sink Faucet	6/29/16 1:57	7/9/16 18:16	6.06E+09	Lead	212	15	ppb
091-203A Drinking Fountain outside 229	6/29/16 1:53	7/9/16 18:16	6.06E+09	Copper	0.8	1.3	ppm
091-203A Drinking Fountain outside 229	6/29/16 1:53	7/9/16 18:16	6.06E+09	Lead	4	15	ppb
091-204A 229 Sink Faucet Bathroom	6/29/16 1:54	7/9/16 18:16	6.06E+09	Copper	0.1	1.3	ppm
091-204A 229 Sink Faucet Bathroom	6/29/16 1:54	7/9/16 18:16	6.06E+09	Lead	7	15	ppb
091-205A 230 Custodial Sink Faucet	6/29/16 1:54	7/9/16 18:16	6.06E+09	Copper	0.1	1.3	ppm
091-205A 230 Custodial Sink Faucet	6/29/16 1:54	7/9/16 18:16	6.06E+09	Lead	18	15	ppb
091-206A 231 Boys Bathroom Sink Faucet (1)	6/29/16 1:56	7/9/16 18:16	6.06E+09	Copper	0.1	1.3	ppm
091-206A 231 Boys Bathroom Sink Faucet (1)	6/29/16 1:56	7/9/16 18:16	6.06E+09	Lead	2	15	ppb
091-207A 231 Boys Bathroom Sink Faucet (2)	6/29/16 1:57	7/9/16 18:16	6.06E+09	Copper	0.1	1.3	ppm
091-207A 231 Boys Bathroom Sink Faucet (2)	6/29/16 1:57	7/9/16 18:16	6.06E+09	Lead	13	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-208A 231 Boys Bathroom Sink Faucet (3)	6/29/16 1:58	7/9/16 18:16	6.06E+09	Copper	0.1	1.3	ppm
091-208A 231 Boys Bathroom Sink Faucet (3)	6/29/16 1:58	7/9/16 18:16	6.06E+09	Lead	10	15	ppb
091-209A 231 Boys Bathroom Sink Faucet (4)	6/29/16 1:57	7/9/16 18:16	6.06E+09	Copper	0.1	1.3	ppm
091-209A 231 Boys Bathroom Sink Faucet (4)	6/29/16 1:57	7/9/16 18:16	6.06E+09	Lead	7	15	ppb
091-210A 231 Boys Bathroom Sink Faucet (5)	6/29/16 1:57	7/9/16 18:16	6.06E+09	Copper	0.1	1.3	ppm
091-210A 231 Boys Bathroom Sink Faucet (5)	6/29/16 1:57	7/9/16 18:16	6.06E+09	Lead	15.1	15	ppb
091-211A 231 Boys Bathroom Sink Faucet (6)	6/29/16 2:00	7/9/16 18:16	6.06E+09	Copper	0.3	1.3	ppm
091-211A 231 Boys Bathroom Sink Faucet (6)	6/29/16 2:00	7/9/16 18:16	6.06E+09	Lead	12	15	ppb
091-212A 231 Boys Bathroom Spigot	6/29/16 2:02	7/11/16 11:16	6.06E+09	Copper	0.2	1.3	ppm
091-212A 231 Boys Bathroom Spigot	6/29/16 2:02	7/11/16 11:16	6.06E+09	Lead	7	15	ppb
091-213A 239 Classroom Sink Faucet (1)	6/29/16 2:03	7/11/16 11:17	6.06E+09	Copper	0.4	1.3	ppm
091-213A 239 Classroom Sink Faucet (1)	6/29/16 2:03	7/11/16 11:17	6.06E+09	Lead	21	15	ppb
091-214A 239 Classroom Sink Faucet (2)	6/29/16 2:04	7/9/16 18:17	6.06E+09	Copper	0.4	1.3	ppm
091-214A 239 Classroom Sink Faucet (2)	6/29/16 2:04	7/9/16 18:17	6.06E+09	Lead	58	15	ppb
091-215A 239 Classroom Sink Faucet (3)	6/29/16 2:04	7/9/16 18:17	6.06E+09	Copper	0.7	1.3	ppm
091-215A 239 Classroom Sink Faucet (3)	6/29/16 2:04	7/9/16 18:17	6.06E+09	Lead	85	15	ppb
091-216A 239 Classroom Sink Faucet (4)	6/29/16 2:05	7/9/16 18:17	6.06E+09	Copper	0.2	1.3	ppm
091-216A 239 Classroom Sink Faucet (4)	6/29/16 2:05	7/9/16 18:17	6.06E+09	Lead	6	15	ppb
091-217A 239 Classroom Sink Faucet (5)	6/29/16 2:05	7/9/16 18:17	6.06E+09	Copper	0.2	1.3	ppm
091-217A 239 Classroom Sink Faucet (5)	6/29/16 2:05	7/9/16 18:17	6.06E+09	Lead	11	15	ppb
091-218A 239 Classroom Sink Faucet (6)	6/29/16 2:05	7/11/16 11:17	6.06E+09	Copper	0.3	1.3	ppm
091-218A 239 Classroom Sink Faucet (6)	6/29/16 2:05	7/11/16 11:17	6.06E+09	Lead	12	15	ppb
091-219A 239 Classroom Sink Faucet (7)	6/29/16 2:06	7/9/16 18:18	6.06E+09	Copper	0.1	1.3	ppm
091-219A 239 Classroom Sink Faucet (7)	6/29/16 2:06	7/9/16 18:18	6.06E+09	Lead	15.0	15	ppb
091-220A 239 Classroom Sink Faucet (8)	6/29/16 2:07	7/9/16 18:20	6.06E+09	Copper	0.2	1.3	ppm
091-220A 239 Classroom Sink Faucet (8)	6/29/16 2:07	7/9/16 18:20	6.06E+09	Lead	22	15	ppb
091-221A 239 Classroom Sink Faucet (9)	6/29/16 2:07	7/9/16 18:20	6.06E+09	Copper	0.2	1.3	ppm
091-221A 239 Classroom Sink Faucet (9)	6/29/16 2:07	7/9/16 18:20	6.06E+09	Lead	29	15	ppb
091-222A 239 Classroom Sink Faucet (10)	6/29/16 2:07	7/9/16 18:20	6.06E+09	Copper	0.2	1.3	ppm
091-222A 239 Classroom Sink Faucet (10)	6/29/16 2:07	7/9/16 18:20	6.06E+09	Lead	14	15	ppb
091-223A 239 Classroom Sink Faucet (11)	6/29/16 2:07	7/9/16 18:20	6.06E+09	Copper	0.3	1.3	ppm
091-223A 239 Classroom Sink Faucet (11)	6/29/16 2:07	7/9/16 18:20	6.06E+09	Lead	36	15	ppb
091-224A 239 Classroom Sink Faucet (12)	6/29/16 2:08	7/9/16 18:20	6.06E+09	Copper	0.3	1.3	ppm
091-224A 239 Classroom Sink Faucet (12)	6/29/16 2:08	7/9/16 18:20	6.06E+09	Lead	45	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-225A 239 Classroom Sink Faucet (13)	6/29/16 2:08	7/9/16 18:20	6.06E+09	Copper	0.3	1.3	ppm
091-225A 239 Classroom Sink Faucet (13)	6/29/16 2:08	7/9/16 18:20	6.06E+09	Lead	27	15	ppb
091-226A 239 Classroom Sink Faucet (14)	6/29/16 2:08	7/9/16 18:20	6.06E+09	Copper	0.4	1.3	ppm
091-226A 239 Classroom Sink Faucet (14)	6/29/16 2:08	7/9/16 18:20	6.06E+09	Lead	38	15	ppb
091-227A 239 Classroom Sink Faucet (15)	6/29/16 2:08	7/9/16 18:20	6.06E+09	Copper	0.4	1.3	ppm
091-227A 239 Classroom Sink Faucet (15)	6/29/16 2:08	7/9/16 18:20	6.06E+09	Lead	21	15	ppb
091-228A 239 Classroom Sink Faucet (16)	6/29/16 2:08	7/9/16 18:20	6.06E+09	Copper	1.1	1.3	ppm
091-228A 239 Classroom Sink Faucet (16)	6/29/16 2:08	7/9/16 18:20	6.06E+09	Lead	30	15	ppb
091-229A 239 Classroom Sink Faucet (17)	6/29/16 2:08	7/9/16 16:00	6.06E+09	Copper	4.3	1.3	ppm
091-229A 239 Classroom Sink Faucet (17)	6/29/16 2:08	7/9/16 16:00	6.06E+09	Lead	2330	15	ppb
091-230A Room 239 Hood Sink Faucet	6/29/16 2:08	7/9/16 18:20	6.06E+09	Copper	0.4	1.3	ppm
091-230A Room 239 Hood Sink Faucet	6/29/16 2:08	7/9/16 18:20	6.06E+09	Lead	18	15	ppb
091-231A Room 232 Sink Faucet (island)	6/29/16 2:10	7/9/16 18:22	6.06E+09	Copper	0.0	1.3	ppm
091-231A Room 232 Sink Faucet (island)	6/29/16 2:10	7/9/16 18:22	6.06E+09	Lead	38	15	ppb
091-232A Room 232 Sink Faucet (1)	6/29/16 2:10	7/9/16 18:22	6.06E+09	Copper	0.1	1.3	ppm
091-232A Room 232 Sink Faucet (1)	6/29/16 2:10	7/9/16 18:22	6.06E+09	Lead	29	15	ppb
091-233A Room 232 Sink Faucet (2)	6/29/16 2:10	7/9/16 18:22	6.06E+09	Copper	0.1	1.3	ppm
091-233A Room 232 Sink Faucet (2)	6/29/16 2:10	7/9/16 18:22	6.06E+09	Lead	37	15	ppb
091-234A Room 232B Sink Faucet	6/29/16 2:10	7/9/16 18:22	6.06E+09	Copper	0.1	1.3	ppm
091-234A Room 232B Sink Faucet	6/29/16 2:10	7/9/16 18:22	6.06E+09	Lead	112	15	ppb
091-235A Room 238 Sink Faucet (island)	6/29/16 2:13	7/9/16 16:00	6.06E+09	Copper	0.5	1.3	ppm
091-235A Room 238 Sink Faucet (island)	6/29/16 2:13	7/9/16 16:00	6.06E+09	Lead	235	15	ppb
091-236A Room 238 Sink Faucet (1)	6/29/16 2:13	7/9/16 18:22	6.06E+09	Copper	0.2	1.3	ppm
091-236A Room 238 Sink Faucet (1)	6/29/16 2:13	7/9/16 18:22	6.06E+09	Lead	184	15	ppb
091-237A Room 238 Sink Faucet (2)	6/29/16 2:13	7/9/16 18:22	6.06E+09	Copper	0.0	1.3	ppm
091-237A Room 238 Sink Faucet (2)	6/29/16 2:13	7/9/16 18:22	6.06E+09	Lead	16	15	ppb
091-238A Room 233 Sink Faucet (island)	6/29/16 2:15	7/9/16 16:01	6.06E+09	Copper	2.1	1.3	ppm
091-238A Room 233 Sink Faucet (island)	6/29/16 2:15	7/9/16 16:01	6.06E+09	Lead	1300	15	ppb
091-239A Room 233 Sink Faucet (3)	6/29/16 2:15	7/9/16 16:01	6.06E+09	Copper	1.2	1.3	ppm
091-239A Room 233 Sink Faucet (3)	6/29/16 2:15	7/9/16 16:01	6.06E+09	Lead	4100	15	ppb
091-240A Room 233 Sink Faucet (2)	6/29/16 2:16	7/9/16 16:01	6.06E+09	Copper	2.4	1.3	ppm
091-240A Room 233 Sink Faucet (2)	6/29/16 2:16	7/9/16 16:01	6.06E+09	Lead	4870	15	ppb
091-241A Room 233 Sink Faucet (1)	6/29/16 2:16	7/9/16 18:22	6.06E+09	Copper	0.0	1.3	ppm
091-241A Room 233 Sink Faucet (1)	6/29/16 2:16	7/9/16 18:22	6.06E+09	Lead	25	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-242A Room 234 Sink Faucet (island)	6/29/16 2:19	7/9/16 18:22	6.06E+09	Copper	0.1	1.3	ppm
091-242A Room 234 Sink Faucet (island)	6/29/16 2:19	7/9/16 18:22	6.06E+09	Lead	64	15	ppb
091-243A Room 234 Sink Faucet (1)	6/29/16 2:19	7/9/16 18:22	6.06E+09	Copper	0.1	1.3	ppm
091-243A Room 234 Sink Faucet (1)	6/29/16 2:19	7/9/16 18:22	6.06E+09	Lead	21	15	ppb
091-244A Room 234 Sink Faucet (2)	6/29/16 2:20	7/9/16 18:22	6.06E+09	Copper	0.0	1.3	ppm
091-244A Room 234 Sink Faucet (2)	6/29/16 2:20	7/9/16 18:22	6.06E+09	Lead	36	15	ppb
091-245A Room 234-235 Connect Sink Faucet	6/29/16 2:20	7/9/16 18:24	6.06E+09	Copper	0.1	1.3	ppm
091-245A Room 234-235 Connect Sink Faucet	6/29/16 2:20	7/9/16 18:24	6.06E+09	Lead	29	15	ppb
091-246A Room 235 Sink Faucet (island)	6/29/16 2:23	7/9/16 18:24	6.06E+09	Copper	0.2	1.3	ppm
091-246A Room 235 Sink Faucet (island)	6/29/16 2:23	7/9/16 18:24	6.06E+09	Lead	179	15	ppb
091-247A Room 235 Sink Faucet (1)	6/29/16 2:23	7/9/16 18:24	6.06E+09	Copper	0.3	1.3	ppm
091-247A Room 235 Sink Faucet (1)	6/29/16 2:23	7/9/16 18:24	6.06E+09	Lead	26	15	ppb
091-248A Room 235 Sink Faucet (2)	6/29/16 2:23	7/9/16 18:24	6.06E+09	Copper	0.1	1.3	ppm
091-248A Room 235 Sink Faucet (2)	6/29/16 2:23	7/9/16 18:24	6.06E+09	Lead	82	15	ppb
091-249A Room 237 Sink Faucet with Eyewash	6/29/16 2:25	7/9/16 18:24	6.06E+09	Copper	0.1	1.3	ppm
091-249A Room 237 Sink Faucet with Eyewash	6/29/16 2:25	7/9/16 18:24	6.06E+09	Lead	55	15	ppb
091-250A Room 237 Eyewash	6/29/16 2:25	7/9/16 18:24	6.06E+09	Copper	0.0	1.3	ppm
091-250A Room 237 Eyewash	6/29/16 2:25	7/9/16 18:24	6.06E+09	Lead	21	15	ppb
091-251A Room 237 Sink Faucet (right)	6/29/16 2:25	7/9/16 18:24	6.06E+09	Copper	0.3	1.3	ppm
091-251A Room 237 Sink Faucet (right)	6/29/16 2:25	7/9/16 18:24	6.06E+09	Lead	383	15	ppb
091-252A Room 237A (storage) Sink Faucet (west)	6/29/16 2:25	7/9/16 18:24	6.06E+09	Copper	0.5	1.3	ppm
091-252A Room 237A (storage) Sink Faucet (west)	6/29/16 2:25	7/9/16 18:24	6.06E+09	Lead	1510	15	ppb
091-253A Room 237A Sink Faucet (east)	6/29/16 2:26	7/9/16 16:18	6.06E+09	Copper	1.2	1.3	ppm
091-253A Room 237A Sink Faucet (east)	6/29/16 2:26	7/9/16 16:18	6.06E+09	Lead	2490	15	ppb
091-254A Room 236 Sink Faucet (island)	6/29/16 2:28	7/9/16 18:24	6.06E+09	Copper	0.1	1.3	ppm
091-254A Room 236 Sink Faucet (island)	6/29/16 2:28	7/9/16 18:24	6.06E+09	Lead	84	15	ppb
091-255A Room 236 Sink Faucet (1)	6/29/16 2:28	7/9/16 18:24	6.06E+09	Copper	0.0	1.3	ppm
091-255A Room 236 Sink Faucet (1)	6/29/16 2:28	7/9/16 18:24	6.06E+09	Lead	50	15	ppb
091-256A Room 236 Sink Faucet (2)	6/29/16 2:28	7/9/16 18:28	6.06E+09	Copper	0.0	1.3	ppm
091-256A Room 236 Sink Faucet (2)	6/29/16 2:28	7/9/16 18:28	6.06E+09	Lead	6	15	ppb
091-257A Drinking Fountain outside 236 (1)	6/29/16 2:31	7/9/16 18:28	6.06E+09	Copper	0.0	1.3	ppm
091-257A Drinking Fountain outside 236 (1)	6/29/16 2:31	7/9/16 18:28	6.06E+09	Lead	8	15	ppb
091-258A Drinking Fountain outside 236 (2)	6/29/16 2:31	7/9/16 18:28	6.06E+09	Copper	0.1	1.3	ppm
091-258A Drinking Fountain outside 236 (2)	6/29/16 2:31	7/9/16 18:28	6.06E+09	Lead	18	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-259A Drinking Fountain outside 236 (3)	6/29/16 2:32	7/9/16 18:28	6.06E+09	Copper	0.0	1.3	ppm
091-259A Drinking Fountain outside 236 (3)	6/29/16 2:32	7/9/16 18:28	6.06E+09	Lead	7	15	ppb
091-260A 228 Girls Bathroom Sink Faucet (1)	6/29/16 2:34	7/9/16 18:28	6.06E+09	Copper	0.1	1.3	ppm
091-260A 228 Girls Bathroom Sink Faucet (1)	6/29/16 2:34	7/9/16 18:28	6.06E+09	Lead	4	15	ppb
091-261A 228 Girls Bathroom Sink Faucet (2)	6/29/16 2:34	7/9/16 18:28	6.06E+09	Copper	0.1	1.3	ppm
091-261A 228 Girls Bathroom Sink Faucet (2)	6/29/16 2:34	7/9/16 18:28	6.06E+09	Lead	12	15	ppb
091-262A 228 Girls Bathroom Sink Faucet (3)	6/29/16 2:34	7/9/16 18:28	6.06E+09	Copper	0.0	1.3	ppm
091-262A 228 Girls Bathroom Sink Faucet (3)	6/29/16 2:34	7/9/16 18:28	6.06E+09	Lead	4	15	ppb
091-263A 228 Girls Bathroom Sink Faucet (4)	6/29/16 2:35	7/9/16 18:28	6.06E+09	Copper	0.0	1.3	ppm
091-263A 228 Girls Bathroom Sink Faucet (4)	6/29/16 2:35	7/9/16 18:28	6.06E+09	Lead	6	15	ppb
091-264A 228 Girls Bathroom Sink Faucet (5)	6/29/16 2:36	7/9/16 18:28	6.06E+09	Copper	0.0	1.3	ppm
091-264A 228 Girls Bathroom Sink Faucet (5)	6/29/16 2:36	7/9/16 18:28	6.06E+09	Lead	6	15	ppb
091-265A 228 Girls Bathroom Sink Faucet (6)	6/29/16 2:36	7/9/16 18:28	6.06E+09	Copper	0.0	1.3	ppm
091-265A 228 Girls Bathroom Sink Faucet (6)	6/29/16 2:36	7/9/16 18:28	6.06E+09	Lead	14	15	ppb
091-266A 228 Girls Bathroom Spigot	6/29/16 2:37	7/9/16 16:19	6.06E+09	Copper	1.8	1.3	ppm
091-266A 228 Girls Bathroom Spigot	6/29/16 2:37	7/9/16 16:19	6.06E+09	Lead	134	15	ppb
091-267A Library Work Room Sink Faucet	6/29/16 2:40	7/9/16 18:29	6.06E+09	Copper	0.1	1.3	ppm
091-267A Library Work Room Sink Faucet	6/29/16 2:40	7/9/16 18:29	6.06E+09	Lead	8	15	ppb
091-268A 219 Girls Bathroom Sink Faucet (1)	6/29/16 2:42	7/9/16 18:29	6.06E+09	Copper	0.0	1.3	ppm
091-268A 219 Girls Bathroom Sink Faucet (1)	6/29/16 2:42	7/9/16 18:29	6.06E+09	Lead	14	15	ppb
091-269A 219 Girls Bathroom Sink Faucet (2)	6/29/16 2:42	7/9/16 18:29	6.06E+09	Copper	0.0	1.3	ppm
091-269A 219 Girls Bathroom Sink Faucet (2)	6/29/16 2:42	7/9/16 18:29	6.06E+09	Lead	14	15	ppb
091-270A 219 Girls Bathroom Sink Faucet (3)	6/29/16 2:42	7/9/16 18:29	6.06E+09	Copper	0.1	1.3	ppm
091-270A 219 Girls Bathroom Sink Faucet (3)	6/29/16 2:42	7/9/16 18:29	6.06E+09	Lead	8	15	ppb
091-271A 219 Girls Bathroom Sink Faucet (4)	6/29/16 2:43	7/9/16 16:19	6.06E+09	Copper	1.0	1.3	ppm
091-271A 219 Girls Bathroom Sink Faucet (4)	6/29/16 2:43	7/9/16 16:19	6.06E+09	Lead	16	15	ppb
091-272A 219 Girls Bathroom Spigot	6/29/16 2:43	7/9/16 18:29	6.06E+09	Copper	0.4	1.3	ppm
091-272A 219 Girls Bathroom Spigot	6/29/16 2:43	7/9/16 18:29	6.06E+09	Lead	17	15	ppb
091-273A Drinking Fountain Outside 245 (1)	6/29/16 2:44	7/9/16 18:29	6.06E+09	Copper	0.6	1.3	ppm
091-273A Drinking Fountain Outside 245 (1)	6/29/16 2:44	7/9/16 18:29	6.06E+09	Lead	10	15	ppb
091-274A Drinking Fountain Outside 245 (2)	6/29/16 2:44	7/9/16 18:29	6.06E+09	Copper	0.7	1.3	ppm
091-274A Drinking Fountain Outside 245 (2)	6/29/16 2:44	7/9/16 18:29	6.06E+09	Lead	6	15	ppb
091-275A Drinking Fountain Outside 245 (3)	6/29/16 2:45	7/9/16 18:29	6.06E+09	Copper	0.7	1.3	ppm
091-275A Drinking Fountain Outside 245 (3)	6/29/16 2:45	7/9/16 18:29	6.06E+09	Lead	5	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-276A Drinking Fountain Outside 245 (4)	6/29/16 2:45	7/9/16 18:29	6.06E+09	Copper	0.3	1.3	ppm
091-276A Drinking Fountain Outside 245 (4)	6/29/16 2:45	7/9/16 18:29	6.06E+09	Lead	4	15	ppb
091-277A Room 218 Sink Faucet	6/29/16 2:46	7/11/16 11:17	6.06E+09	Copper	3.1	1.3	ppm
091-277A Room 218 Sink Faucet	6/29/16 2:46	7/9/16 18:29	6.06E+09	Lead	10	15	ppb
091-278A Room 217 Custodial Sink Faucet	6/29/16 2:46	7/9/16 18:31	6.06E+09	Copper	0.1	1.3	ppm
091-278A Room 217 Custodial Sink Faucet	6/29/16 2:46	7/9/16 18:31	6.06E+09	Lead	9	15	ppb
091-279A 216 Boys Bathroom Sink Faucet (1)	6/29/16 2:48	7/9/16 18:31	6.06E+09	Copper	0.0	1.3	ppm
091-279A 216 Boys Bathroom Sink Faucet (1)	6/29/16 2:48	7/9/16 18:31	6.06E+09	Lead	10	15	ppb
091-280A 216 Boys Bathroom Sink Faucet (2)	6/29/16 2:48	7/9/16 18:31	6.06E+09	Copper	0.0	1.3	ppm
091-280A 216 Boys Bathroom Sink Faucet (2)	6/29/16 2:48	7/9/16 18:31	6.06E+09	Lead	3	15	ppb
091-281A 216 Boys Bathroom Sink Faucet (3)	6/29/16 2:48	7/9/16 18:31	6.06E+09	Copper	0.0	1.3	ppm
091-281A 216 Boys Bathroom Sink Faucet (3)	6/29/16 2:48	7/9/16 18:31	6.06E+09	Lead	16	15	ppb
091-282A 216 Boys Bathroom Sink Faucet (4)	6/29/16 2:49	7/9/16 18:31	6.06E+09	Copper	0.0	1.3	ppm
091-282A 216 Boys Bathroom Sink Faucet (4)	6/29/16 2:49	7/9/16 18:31	6.06E+09	Lead	6	15	ppb
091-283A 216 Boys Bathroom Sink Faucet (5)	6/29/16 2:49	7/9/16 18:31	6.06E+09	Copper	0.2	1.3	ppm
091-283A 216 Boys Bathroom Sink Faucet (5)	6/29/16 2:49	7/9/16 18:31	6.06E+09	Lead	49	15	ppb
091-284A 216 Boys Bathroom Sink Faucet (6)	6/29/16 2:49	7/9/16 18:31	6.06E+09	Copper	0.1	1.3	ppm
091-284A 216 Boys Bathroom Sink Faucet (6)	6/29/16 2:49	7/9/16 18:31	6.06E+09	Lead	32	15	ppb
091-285A 216 Boys Bathroom Spigot	6/29/16 2:51	7/9/16 18:31	6.06E+09	Copper	0.6	1.3	ppm
091-285A 216 Boys Bathroom Spigot	6/29/16 2:51	7/9/16 18:31	6.06E+09	Lead	19	15	ppb
091-286A Room 214 Sink Faucet	6/29/16 2:51	7/9/16 18:31	6.06E+09	Copper	0.7	1.3	ppm
091-286A Room 214 Sink Faucet	6/29/16 2:51	7/9/16 18:31	6.06E+09	Lead	25	15	ppb
091-287A Room 213 Sink Faucet	6/29/16 2:52	7/9/16 18:31	6.06E+09	Copper	0.1	1.3	ppm
091-287A Room 213 Sink Faucet	6/29/16 2:52	7/9/16 18:31	6.06E+09	Lead	4	15	ppb
091-288A Room 207 Sink Faucet (1)	6/29/16 2:56	7/9/16 18:31	6.06E+09	Copper	0.0	1.3	ppm
091-288A Room 207 Sink Faucet (1)	6/29/16 2:56	7/9/16 18:31	6.06E+09	Lead	8	15	ppb
091-289A Room 207 Sink Faucet (2)	6/29/16 2:56	7/9/16 18:31	6.06E+09	Copper	0.1	1.3	ppm
091-289A Room 207 Sink Faucet (2)	6/29/16 2:56	7/9/16 18:31	6.06E+09	Lead	4	15	ppb
091-290A Room 207 Sink Faucet (3)	6/29/16 2:56	7/9/16 18:31	6.06E+09	Copper	0.0	1.3	ppm
091-290A Room 207 Sink Faucet (3)	6/29/16 2:56	7/9/16 18:31	6.06E+09	Lead	2	15	ppb
091-291A 211 Custodial Sink Faucet	6/29/16 2:59	7/9/16 18:31	6.06E+09	Copper	0.0	1.3	ppm
091-291A 211 Custodial Sink Faucet	6/29/16 2:59	7/9/16 18:31	6.06E+09	Lead	2	15	ppb
091-292A 210 Bathroom Sink Faucet	6/29/16 3:01	7/9/16 18:31	6.06E+09	Copper	0.0	1.3	ppm
091-292A 210 Bathroom Sink Faucet	6/29/16 3:01	7/9/16 18:31	6.06E+09	Lead	2	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-293A Drinking Fountain outside 208 (1)	6/29/16 2:59	7/9/16 18:31	6.06E+09	Copper	0.0	1.3	ppm
091-293A Drinking Fountain outside 208 (1)	6/29/16 2:59	7/9/16 18:31	6.06E+09	Lead	27	15	ppb
091-294A Drinking Fountain outside 208 (2)	6/29/16 2:59	7/9/16 18:32	6.06E+09	Copper	0.0	1.3	ppm
091-294A Drinking Fountain outside 208 (2)	6/29/16 2:59	7/9/16 18:32	6.06E+09	Lead	34	15	ppb
091-295A Drinking Fountain outside 208 (3)	6/29/16 3:00	7/9/16 18:32	6.06E+09	Copper	0.0	1.3	ppm
091-295A Drinking Fountain outside 208 (3)	6/29/16 3:00	7/9/16 18:32	6.06E+09	Lead	8	15	ppb
091-296A Drinking Fountain outside 208 (4)	6/29/16 3:00	7/9/16 18:32	6.06E+09	Copper	0.0	1.3	ppm
091-296A Drinking Fountain outside 208 (4)	6/29/16 3:00	7/9/16 18:32	6.06E+09	Lead	5	15	ppb
091-297A Room 208 Sink Faucet	6/29/16 3:03	7/9/16 18:32	6.06E+09	Copper	0.0	1.3	ppm
091-297A Room 208 Sink Faucet	6/29/16 3:03	7/9/16 18:32	6.06E+09	Lead	9	15	ppb
091-298A Room 245 Sink Faucet (2)	6/29/16 3:05	7/9/16 18:32	6.06E+09	Copper	0.0	1.3	ppm
091-298A Room 245 Sink Faucet (2)	6/29/16 3:05	7/9/16 18:32	6.06E+09	Lead	5	15	ppb
091-299A Room 245 Sink Faucet (1)	6/29/16 3:05	7/9/16 18:32	6.06E+09	Copper	0.0	1.3	ppm
091-299A Room 245 Sink Faucet (1)	6/29/16 3:05	7/9/16 18:32	6.06E+09	Lead	3	15	ppb
091-300A Room 245 Drinking Fountain	6/29/16 3:05	7/9/16 18:32	6.06E+09	Copper	0.0	1.3	ppm
091-300A Room 245 Drinking Fountain	6/29/16 3:05	7/9/16 18:32	6.06E+09	Lead	11	15	ppb
091-301A Room 245 Kiln Room Sink Faucet	6/29/16 3:06	7/9/16 18:33	6.06E+09	Copper	0.1	1.3	ppm
091-301A Room 245 Kiln Room Sink Faucet	6/29/16 3:06	7/9/16 18:33	6.06E+09	Lead	9	15	ppb
091-302A Room 246 Sink Faucet	6/29/16 3:11	7/9/16 18:33	6.06E+09	Copper	0.0	1.3	ppm
091-302A Room 246 Sink Faucet	6/29/16 3:11	7/9/16 18:33	6.06E+09	Lead	2	15	ppb
091-303A Dark Room Sink Faucet (1)	6/29/16 3:11	7/9/16 18:33	6.06E+09	Copper	1.7	1.3	ppm
091-303A Dark Room Sink Faucet (1)	6/29/16 3:11	7/9/16 18:33	6.06E+09	Lead	83	15	ppb
091-304A Dark Room Sink Faucet (2)	6/29/16 3:12	7/9/16 18:33	6.06E+09	Copper	0.5	1.3	ppm
091-304A Dark Room Sink Faucet (2)	6/29/16 3:12	7/9/16 18:33	6.06E+09	Lead	29	15	ppb
091-305A Room 247 Sink Faucet	6/29/16 3:14	7/9/16 18:33	6.06E+09	Copper	0.1	1.3	ppm
091-305A Room 247 Sink Faucet	6/29/16 3:14	7/9/16 18:33	6.06E+09	Lead	16	15	ppb
091-306A Room 247 Drinking Fountain	6/29/16 3:15	7/9/16 18:33	6.06E+09	Copper	0.0	1.3	ppm
091-306A Room 247 Drinking Fountain	6/29/16 3:15	7/9/16 18:33	6.06E+09	Lead	92	15	ppb
091-307A Room 247/248 Connect Sink Faucet	6/29/16 3:15	7/9/16 18:33	6.06E+09	Copper	0.1	1.3	ppm
091-307A Room 247/248 Connect Sink Faucet	6/29/16 3:15	7/9/16 18:33	6.06E+09	Lead	39	15	ppb
091-308A Room 248 Sink Faucet	6/29/16 3:16	7/9/16 18:33	6.06E+09	Copper	0.1	1.3	ppm
091-308A Room 248 Sink Faucet	6/29/16 3:16	7/9/16 18:33	6.06E+09	Lead	6	15	ppb
091-309A Outside Spigot (north side by pool)	6/29/16 3:36	7/9/16 18:35	6.06E+09	Copper	0.0	1.3	ppm
091-309A Outside Spigot (north side by pool)	6/29/16 3:36	7/9/16 18:35	6.06E+09	Lead	23	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
091-310A Field House Spigot (west)	6/29/16 3:39	7/9/16 18:35	6.06E+09	Copper	0.1	1.3	ppm
091-310A Field House Spigot (west)	6/29/16 3:39	7/9/16 18:35	6.06E+09	Lead	18	15	ppb
091-311A Field House Spigot (north)	6/29/16 3:41	7/9/16 18:35	6.06E+09	Copper	0.1	1.3	ppm
091-311A Field House Spigot (north)	6/29/16 3:41	7/9/16 18:35	6.06E+09	Lead	5	15	ppb
091-312A Grand Stand Mens Sink Faucet (1)	6/29/16 3:49	7/9/16 18:35	6.06E+09	Copper	0.1	1.3	ppm
091-312A Grand Stand Mens Sink Faucet (1)	6/29/16 3:49	7/9/16 18:35	6.06E+09	Lead	4	15	ppb
091-313A Grand Stand Mens Sink Faucet (2)	6/29/16 3:49	7/9/16 18:35	6.06E+09	Copper	0.1	1.3	ppm
091-313A Grand Stand Mens Sink Faucet (2)	6/29/16 3:49	7/9/16 18:35	6.06E+09	Lead	12	15	ppb
091-314A Grand Stand Mens Spigot	6/29/16 3:54	7/9/16 18:35	6.06E+09	Copper	0.0	1.3	ppm
091-314A Grand Stand Mens Spigot	6/29/16 3:54	7/9/16 18:35	6.06E+09	Lead	6	15	ppb
091-315A Grand Stand Womens Sink Faucet (1)	6/29/16 3:55	7/9/16 18:35	6.06E+09	Copper	0.0	1.3	ppm
091-315A Grand Stand Womens Sink Faucet (1)	6/29/16 3:55	7/9/16 18:35	6.06E+09	Lead	5	15	ppb
091-316A Grand Stand Womens Sink Faucet (2)	6/29/16 3:55	7/9/16 18:35	6.06E+09	Copper	0.0	1.3	ppm
091-316A Grand Stand Womens Sink Faucet (2)	6/29/16 3:55	7/9/16 18:35	6.06E+09	Lead	4	15	ppb
091-317A Grand Stand Womens Spigot	6/29/16 3:56	7/9/16 18:35	6.06E+09	Copper	0.0	1.3	ppm
091-317A Grand Stand Womens Spigot	6/29/16 3:56	7/9/16 18:35	6.06E+09	Lead	7	15	ppb
091-318A Spigot off Water Fountain on Track	6/29/16 4:04	7/9/16 18:35	6.06E+09	Copper	0.1	1.3	ppm
091-318A Spigot off Water Fountain on Track	6/29/16 4:04	7/9/16 18:35	6.06E+09	Lead	4	15	ppb
091-319A Water Fountain off Track	6/29/16 4:04	7/9/16 18:35	6.06E+09	Copper	0.0	1.3	ppm
091-319A Water Fountain off Track	6/29/16 4:04	7/9/16 18:35	6.06E+09	Lead	ND	15	ppb
091-321A Baseball Drinking Fountain	6/29/16 4:13	7/9/16 18:35	6.06E+09	Copper	0.0	1.3	ppm
091-321A Baseball Drinking Fountain	6/29/16 4:13	7/9/16 18:35	6.06E+09	Lead	3	15	ppb
091-322A Outside Spigot (1)	6/29/16 4:21	7/9/16 18:35	6.06E+09	Copper	0.0	1.3	ppm
091-322A Outside Spigot (1)	6/29/16 4:21	7/9/16 18:35	6.06E+09	Lead	3	15	ppb
091-323A Outside Spigot (2)	6/29/16 4:31	7/9/16 18:36	6.06E+09	Copper	0.3	1.3	ppm
091-323A Outside Spigot (2)	6/29/16 4:31	7/9/16 18:36	6.06E+09	Lead	5	15	ppb
091-324A Outside Spigot (3)	6/29/16 4:29	7/9/16 18:36	6.06E+09	Copper	0.0	1.3	ppm
091-324A Outside Spigot (3)	6/29/16 4:29	7/9/16 18:36	6.06E+09	Lead	7	15	ppb
091-320A Ice Maker Baseball Concession	6/29/16 0:01	7/9/16 16:20	6.06E+09	Copper	0.0	1.3	ppm
091-320A Ice Maker Baseball Concession	6/29/16 0:01	7/9/16 16:20	6.06E+09	Lead	25	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Wilson High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
--------------------------------------	--------------------------	-------------------------	-----------------	---------	---------	------------------------	-------

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.