

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Winterhaven School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
092-01A Sink in Boiler Room	6/30/2016 17:14	7/5/2016	36253	Copper	ND	1.3	ppm
092-01A Sink in Boiler Room	6/30/2016 17:14	7/5/2016	36253	Lead	7	15	ppb
092-02A Sink Faucet in Boys Restroom 1st Floor	6/30/2016 17:16	7/5/2016	36255	Copper	0.2	1.3	ppm
092-02A Sink Faucet in Boys Restroom 1st Floor	6/30/2016 17:16	7/5/2016	36255	Lead	15.0	15	ppb
092-03A Sink Faucet in Boys Restroom 1st Floor	6/30/2016 17:17	7/5/2016	36257	Copper	0.3	1.3	ppm
092-03A Sink Faucet in Boys Restroom 1st Floor	6/30/2016 17:17	7/5/2016	36257	Lead	85	15	ppb
092-04A Spigot in Boys Restroom 1st Floor	6/30/2016 17:18	7/5/2016	36259	Copper	0.1	1.3	ppm
092-04A Spigot in Boys Restroom 1st Floor	6/30/2016 17:18	7/5/2016	36259	Lead	10	15	ppb
092-05A Custodial Closet By 1st Floor Restroom Sink Faucet	6/30/2016 17:20	7/5/2016	36261	Copper	ND	1.3	ppm
092-05A Custodial Closet By 1st Floor Restroom Sink Faucet	6/30/2016 17:20	7/5/2016	36261	Lead	8	15	ppb
092-06A Drinking Fountain in Between Restroom 1st Floor	6/30/2016 17:23	7/5/2016	36263	Copper	0.9	1.3	ppm
092-06A Drinking Fountain in Between Restroom 1st Floor	6/30/2016 17:23	7/5/2016	36263	Lead	1	15	ppb
092-07A Bottle Refill by Restroom 1st Floor	6/30/2016 17:25	7/5/2016	36265	Copper	0.9	1.3	ppm
092-07A Bottle Refill by Restroom 1st Floor	6/30/2016 17:25	7/5/2016	36265	Lead	ND	15	ppb
092-08A Staff Restroom 1st Floor	6/30/2016 17:28	7/5/2016	36267	Copper	0.1	1.3	ppm
092-08A Staff Restroom 1st Floor	6/30/2016 17:28	7/5/2016	36267	Lead	16	15	ppb
092-09A Sink Faucet in Girls Restroom 1st Floor	6/30/2016 17:30	7/5/2016	36269	Copper	0.1	1.3	ppm
092-09A Sink Faucet in Girls Restroom 1st Floor	6/30/2016 17:30	7/5/2016	36269	Lead	6	15	ppb
092-10A Sink Faucet in Girls Restroom 1st Floor	6/30/2016 17:31	7/5/2016	36271	Copper	0.1	1.3	ppm
092-10A Sink Faucet in Girls Restroom 1st Floor	6/30/2016 17:31	7/5/2016	36271	Lead	9	15	ppb
092-11A Sink Faucet Inside Room #8	6/30/2016 17:33	7/5/2016	36273	Copper	ND	1.3	ppm
092-11A Sink Faucet Inside Room# 8	6/30/2016 17:33	7/5/2016	36273	Lead	16	15	ppb
092-12A Drinking Fountain in Room #8	6/30/2016 17:33	7/5/2016	36275	Copper	ND	1.3	ppm
092-12A Drinking Fountain in Room #8	6/30/2016 17:33	7/5/2016	36275	Lead	ND	15	ppb
092-13A Sink Faucet in Room #9	6/30/2016 17:35	7/5/2016	36277	Copper	ND	1.3	ppm
092-13A Sink Faucet in Room #9	6/30/2016 17:35	7/5/2016	36277	Lead	27	15	ppb
092-14A Drinking Fountain in Room #9	6/30/2016 17:35	7/5/2016	36279	Copper	ND	1.3	ppm
092-14A Drinking Fountain in Room #9	6/30/2016 17:35	7/5/2016	36279	Lead	8	15	ppb
092-15A Sink Faucet in Room #11	6/30/2016 17:37	7/5/2016	36281	Copper	ND	1.3	ppm
092-15A Sink Faucet in Room #11	6/30/2016 17:37	7/5/2016	36281	Lead	33	15	ppb
092-16A Drinking Fountain in Room #11	6/30/2016 17:38	7/5/2016	36283	Copper	ND	1.3	ppm
092-16A Drinking Fountain in Room #11	6/30/2016 17:38	7/5/2016	36283	Lead	16	15	ppb
092-17A Sink Faucet in Room #10	6/30/2016 17:38	7/5/2016	36285	Copper	ND	1.3	ppm
092-17A Sink Faucet in Room #10	6/30/2016 17:38	7/5/2016	36285	Lead	9	15	ppb
092-18A Drinking Fountain in Room #10	6/30/2016 17:42	7/5/2016	36287	Copper	ND	1.3	ppm
092-18A Drinking Fountain in Room #10	6/30/2016 17:42	7/5/2016	36287	Lead	5	15	ppb
092-19A Sink Faucet in Room #7	6/30/2016 17:42	7/5/2016	36289	Copper	0.3	1.3	ppm
092-19A Sink Faucet in Room #7	6/30/2016 17:42	7/5/2016	36289	Lead	11	15	ppb
092-20A Sink Faucet in Room #7	6/30/2016 17:42	7/5/2016	36291	Copper	0.2	1.3	ppm
092-20A Sink Faucet in Room #7	6/30/2016 17:42	7/5/2016	36291	Lead	11	15	ppb
092-21A Sink Faucet in Room #7	6/30/2016 17:42	7/5/2016	36293	Copper	0.5	1.3	ppm
092-21A Sink Faucet in Room #7	6/30/2016 17:42	7/5/2016	36293	Lead	12	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Winterhaven School

092-22A Sink Faucet in Room #7	6/30/2016 17:42	7/5/2016	36295	Copper	0.5	1.3	ppm
092-22A Sink Faucet in Room #7	6/30/2016 17:42	7/5/2016	36295	Lead	11	15	ppb
092-23A Eye Wash Station in Room #7	6/30/2016 17:43	7/5/2016	36297	Copper	0.1	1.3	ppm
092-23A Eye Wash Station in Room #7	6/30/2016 17:43	7/5/2016	36297	Lead	21	15	ppb
092-24A Sink Faucet in Boys Restroom Outside Room #7	6/30/2016 17:46	7/5/2016	36299	Copper	0.1	1.3	ppm
092-24A Sink Faucet in Boys Restroom Outside Room #7	6/30/2016 17:46	7/5/2016	36299	Lead	10	15	ppb
092-25A Sink Faucet in Boys Restroom Outside Room #7	6/30/2016 17:46	7/5/2016	36301	Copper	ND	1.3	ppm
092-25A Sink Faucet in Boys Restroom Outside Room #7	6/30/2016 17:46	7/5/2016	36301	Lead	6	15	ppb
092-26A Spigot inside Boys Restroom Outside Room #7	6/30/2016 17:48	7/5/2016	36303	Copper	ND	1.3	ppm
092-26A Spigot inside Boys Restroom Outside Room #7	6/30/2016 17:48	7/5/2016	36303	Lead	7	15	ppb
092-27A Drinking Fountain Outside Boys Restroom	6/30/2016 17:51	7/5/2016	36305	Copper	ND	1.3	ppm
092-27A Drinking Fountain Outside Boys Restroom	6/30/2016 17:51	7/5/2016	36305	Lead	4	15	ppb
092-28A Drinking Fountain Outside Boys Restroom	6/30/2016 17:51	7/5/2016	36307	Copper	ND	1.3	ppm
092-28A Drinking Fountain Outside Boys Restroom	6/30/2016 17:51	7/5/2016	36307	Lead	2	15	ppb
092-29A Sink Faucet in janitors Office	6/30/2016 17:53	7/5/2016	36309	Copper	ND	1.3	ppm
092-29A Sink Faucet in janitors Office	6/30/2016 17:53	7/5/2016	36309	Lead	4	15	ppb
092-30A Sink Faucet Inside Room 3	6/30/2016 17:54	7/5/2016	36311	Copper	0.8	1.3	ppm
092-30A Sink Faucet Inside Room 3	6/30/2016 17:54	7/5/2016	36311	Lead	2	15	ppb
092-31A Sink Faucet Inside Room Next to Office	6/30/2016 17:57	7/5/2016	36313	Copper	ND	1.3	ppm
092-31A Sink Faucet Inside Room Next to Office	6/30/2016 17:57	7/5/2016	36313	Lead	4	15	ppb
092-32A Sink Faucet Inside Room #1	6/30/2016 17:58	7/5/2016	36315	Copper	0.4	1.3	ppm
092-32A Sink Faucet Inside Room #1	6/30/2016 17:58	7/5/2016	36315	Lead	6	15	ppb
092-33A Drinking Fountain Next to Sink Restroom	6/30/2016 18:00	7/5/2016	36317	Copper	ND	1.3	ppm
092-33A Drinking Fountain Next to Sink Restroom	6/30/2016 18:00	7/5/2016	36317	Lead	7	15	ppb
092-34A Drinking Fountain Next to Girls Restroom	6/30/2016 18:01	7/5/2016	36319	Copper	ND	1.3	ppm
092-34A Drinking Fountain Next to Girls Restroom	6/30/2016 18:01	7/5/2016	36319	Lead	6	15	ppb
092-35A Sink Faucet in Girls Restroom 1st Floor	6/30/2016 18:02	7/5/2016	36321	Copper	ND	1.3	ppm
092-35A Sink Faucet in Girls Restroom 1st Floor	6/30/2016 18:02	7/5/2016	36321	Lead	2	15	ppb
092-36A Sink Faucet in Girls Restroom 1st Floor	6/30/2016 18:02	7/5/2016	36323	Copper	ND	1.3	ppm
092-36A Sink Faucet in Girls Restroom 1st Floor	6/30/2016 18:02	7/5/2016	36323	Lead	4	15	ppb
092-37A Spigot In Girls Restroom	6/30/2016 18:04	7/5/2016	36325	Copper	0.1	1.3	ppm
092-37A Spigot In Girls Restroom	6/30/2016 18:04	7/5/2016	36325	Lead	7	15	ppb
092-38A Sink Faucet in Nurses Office	6/30/2016 18:06	7/5/2016	36327	Copper	ND	1.3	ppm
092-38A Sink Faucet in Nurses Office	6/30/2016 18:06	7/5/2016	36327	Lead	2	15	ppb
092-39A Sink Faucet in Faculty Room Across Nurse	6/30/2016 18:08	7/5/2016	36329	Copper	ND	1.3	ppm
092-39A Sink Faucet in Faculty Room Across Nurse	6/30/2016 18:08	7/5/2016	36329	Lead	21	15	ppb
092-40A Sink Faucet in Gym Kitchen	6/30/2016 18:11	7/5/2016	36331	Copper	ND	1.3	ppm
092-40A Sink Faucet in Gym Kitchen	6/30/2016 18:11	7/5/2016	36331	Lead	4	15	ppb
092-41A Sink Faucet in Gym Kitchen	6/30/2016 18:11	7/5/2016	36333	Copper	ND	1.3	ppm
092-41A Sink Faucet in Gym Kitchen	6/30/2016 18:11	7/5/2016	36333	Lead	13	15	ppb
092-42A Sink Faucet in Gym Storage Room On Top Faucet	6/30/2016 18:16	7/5/2016	36335	Copper	ND	1.3	ppm
092-42A Sink Faucet in Gym Storage Room On Top Faucet	6/30/2016 18:16	7/5/2016	36335	Lead	20	15	ppb
092-43A Drinking Fountain on 2nd Floor	6/30/2016 18:18	7/5/2016	36337	Copper	ND	1.3	ppm
092-43A Drinking Fountain on 2nd Floor	6/30/2016 18:18	7/5/2016	36337	Lead	3	15	ppb
092-44A Drinking Fountain on 2nd Floor	6/30/2016 18:19	7/5/2016	36339	Copper	ND	1.3	ppm
092-44A Drinking Fountain on 2nd Floor	6/30/2016 18:19	7/5/2016	36339	Lead	4	15	ppb
092-45A Sink Faucet in Girls Restroom 2nd Floor	6/30/2016 18:22	7/5/2016	36341	Copper	ND	1.3	ppm
092-45A Sink Faucet in Girls Restroom 2nd Floor	6/30/2016 18:22	7/5/2016	36341	Lead	4	15	ppb
092-46A Sink Faucet in Girls Restroom 2nd Floor	6/30/2016 18:22	7/5/2016	36343	Copper	ND	1.3	ppm
092-46A Sink Faucet in Girls Restroom 2nd Floor	6/30/2016 18:22	7/5/2016	36343	Lead	5	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Winterhaven School

092-47A Spigot Inside Girls Restroom 2nd Floor	6/30/2016 18:23	7/5/2016	36345	Copper	ND	1.3	ppm
092-47A Spigot Inside Girls Restroom 2nd Floor	6/30/2016 18:23	7/5/2016	36345	Lead	9	15	ppb
092-48A Sink Faucet Inside Room #26	6/30/2016 18:26	7/5/2016	36347	Copper	ND	1.3	ppm
092-48A Sink Faucet Inside Room #26	6/30/2016 18:26	7/5/2016	36347	Lead	6	15	ppb
092-49A Sink Faucet Inside Room #26	6/30/2016 18:27	7/5/2016	36349	Copper	ND	1.3	ppm
092-49A Sink Faucet Inside Room #26	6/30/2016 18:27	7/5/2016	36349	Lead	22	15	ppb
092-50A Sink Faucet in Restroom of Staff Room	6/30/2016 18:29	7/5/2016	36351	Copper	0.1	1.3	ppm
092-50A Sink Faucet in Restroom of Staff Room	6/30/2016 18:29	7/5/2016	36351	Lead	13	15	ppb
092-51A Sink Faucet in Staff Room	6/30/2016 18:31	7/5/2016	36353	Copper	ND	1.3	ppm
092-51A Sink Faucet in Staff Room	6/30/2016 18:31	7/5/2016	36353	Lead	4	15	ppb
092-52A Drinking Fountain Outside Staff Room	6/30/2016 18:33	7/5/2016	36355	Copper	0.7	1.3	ppm
092-52A Drinking Fountain Outside Staff Room	6/30/2016 18:33	7/5/2016	36355	Lead	14	15	ppb
092-53A Bottle Fill Up Outside Staff Room	6/30/2016 18:34	7/5/2016	36357	Copper	0.6	1.3	ppm
092-53A Bottle Fill Up Outside Staff Room	6/30/2016 18:34	7/5/2016	36357	Lead	11	15	ppb
092-54A Sink Faucet in Janitor Closet #26	6/30/2016 18:35	7/5/2016	36359	Copper	ND	1.3	ppm
092-54A Sink Faucet in Janitor Closet #26	6/30/2016 18:35	7/5/2016	36359	Lead	1	15	ppb
092-55A Sink Faucet in Boys Restroom 2nd Floor	6/30/2016 18:38	7/5/2016	36361	Copper	ND	1.3	ppm
092-55A Sink Faucet in Boys Restroom 2nd Floor	6/30/2016 18:38	7/5/2016	36361	Lead	5	15	ppb
092-56A Sink Faucet in Boys Restroom 2nd Floor	6/30/2016 18:39	7/5/2016	36363	Copper	ND	1.3	ppm
092-56A Sink Faucet in Boys Restroom 2nd Floor	6/30/2016 18:39	7/5/2016	36363	Lead	15.0	15	ppb
092-57A Spigot in Boys Restroom 2nd Floor	6/30/2016 18:40	7/5/2016	36365	Copper	ND	1.3	ppm
092-57A Spigot in Boys Restroom 2nd Floor	6/30/2016 18:40	7/5/2016	36365	Lead	183	15	ppb
092-58A Sink Faucet in Room #29 Purse Pt	6/30/2016 18:42	7/5/2016	36367	Copper	ND	1.3	ppm
092-58A Sink Faucet in Room #29 Purse Pt	6/30/2016 18:42	7/5/2016	36367	Lead	12	15	ppb
092-59A Sink Faucet in Portable Bldg	6/30/2016 18:51	7/5/2016	36369	Copper	0.2	1.3	ppm
092-59A Sink Faucet in Portable Bldg	6/30/2016 18:51	7/5/2016	36369	Lead	1	15	ppb
092-60A Sink Faucet in Portable Bldg	6/30/2016 18:51	7/5/2016	36371	Copper	0.1	1.3	ppm
092-60A Sink Faucet in Portable Bldg	6/30/2016 18:51	7/5/2016	36371	Lead	1	15	ppb
092-61A Sink Faucet in Portable Bldg	6/30/2016 18:52	7/5/2016	36373	Copper	ND	1.3	ppm
092-61A Sink Faucet in Portable Bldg	6/30/2016 18:52	7/5/2016	36373	Lead	3	15	ppb
092-62A Spigot Outside Portable Bldg	6/30/2016 19:08	7/5/2016	36375	Copper	ND	1.3	ppm
092-62A Spigot Outside Portable Bldg	6/30/2016 19:08	7/5/2016	36375	Lead	ND	15	ppb
092-63A Spigot Outside Gym	6/30/2016 19:09	7/5/2016	36377	Copper	ND	1.3	ppm
092-63A Spigot Outside Gym	6/30/2016 19:09	7/5/2016	36377	Lead	17	15	ppb
092-64A Spigot Outside Gym	6/30/2016 19:11	7/5/2016	36379	Copper	ND	1.3	ppm
092-64A Spigot Outside Gym	6/30/2016 19:11	7/5/2016	36379	Lead	7	15	ppb
092-65A Spigot Outside SW Side	6/30/2016 19:13	7/5/2016	36381	Copper	ND	1.3	ppm
092-65A Spigot Outside SW Side	6/30/2016 19:13	7/5/2016	36381	Lead	3	15	ppb
092-66A Spigot Outside NW Side	6/30/2016 19:14	7/5/2016	36383	Copper	ND	1.3	ppm
092-66A Spigot Outside NW Side	6/30/2016 19:14	7/5/2016	36383	Lead	6	15	ppb
092-67A Spigot Outside North Side	6/30/2016 19:16	7/6/2016	36385	Copper	ND	1.3	ppm
092-67A Spigot Outside North Side	6/30/2016 19:16	7/6/2016	36385	Lead	29	15	ppb
092-68A Spigot Outside North Side by Garden	6/30/2016 19:18	7/6/2016	36387	Copper	ND	1.3	ppm
092-68A Spigot Outside North Side by Garden	6/30/2016 19:18	7/6/2016	36387	Lead	2	15	ppb
092-69A Spigot outside of East Wing	6/30/2016 19:20	7/6/2016	36389	Copper	ND	1.3	ppm
092-69A Spigot outside of East Wing	6/30/2016 19:20	7/6/2016	36389	Lead	3	15	ppb
092-70A Spigot on S Side of East Wing	6/30/2016 19:21	7/6/2016	36391	Copper	ND	1.3	ppm
092-70A Spigot on S Side of East Wing	6/30/2016 19:21	7/6/2016	36391	Lead	5	15	ppb
092-71A Spigot Outside East Wall	6/30/2016 19:23	7/6/2016	36393	Copper	ND	1.3	ppm
092-71A Spigot Outside East Wall	6/30/2016 19:23	7/6/2016	36393	Lead	22	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Winterhaven School

092-72A Spigot Outside East Wall	6/30/2016 19:25	7/6/2016	36395	Lead	9	15	ppm
092-72A Spigot Outside East Wall	6/30/2016 19:25	7/6/2016	36395	Copper	ND	1.3	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.