

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Woodmere Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	Units
						Action Level	
094-01A Boiler Room Sink Faucet	6/26/2016 09:57	7/6/2016 17:32	10353912001	Copper	0.4	1.3	ppm
094-01A Boiler Room Sink Faucet	6/26/2016 09:57	7/6/2016 17:32	10353912001	Lead	1	15	ppb
094-02A Room 22 Sink Faucet	6/26/2016 10:01	7/6/2016 17:40	10353912003	Copper	0.3	1.3	ppm
094-02A Room 22 Sink Faucet	6/26/2016 10:01	7/6/2016 17:40	10353912003	Lead	3	15	ppb
094-03A Room 6 Sink Faucet	6/26/2016 10:05	7/6/2016 17:42	10353912005	Copper	0.4	1.3	ppm
094-03A Room 6 Sink Faucet	6/26/2016 10:05	7/6/2016 17:42	10353912005	Lead	3	15	ppb
094-04A Room 6 Storage Sink Faucet	6/26/2016 10:09	7/7/2016 09:37	10353912007	Copper	0.9	1.3	ppm
094-04A Room 6 Storage Sink Faucet	6/26/2016 10:09	7/6/2016 17:43	10353912007	Lead	14.7	15	ppb
094-05A Room 6 Drinking Fountain	6/26/2016 10:12	7/6/2016 17:44	10353912009	Copper	0.1	1.3	ppm
094-05A Room 6 Drinking Fountain	6/26/2016 10:12	7/6/2016 17:44	10353912009	Lead	9	15	ppb
094-06A Gymnasium Drinking Fountain	6/26/2016 10:14	7/7/2016 09:38	10353912011	Copper	1.0	1.3	ppm
094-06A Gymnasium Drinking Fountain	6/26/2016 10:14	7/6/2016 17:46	10353912011	Lead	1	15	ppb
094-07A Gymnasium Sink Faucet (Restroom)	6/26/2016 10:19	7/7/2016 09:43	10353912013	Copper	1.0	1.3	ppm
094-07A Gymnasium Sink Faucet (Restroom)	6/26/2016 10:19	7/6/2016 17:47	10353912013	Lead	1	15	ppb
094-08A Room 6 Water Spigot	6/26/2016 10:10	7/6/2016 14:03	10353912015	Copper	8.7	1.3	ppm
094-08A Room 6 Water Spigot	6/26/2016 10:10	7/6/2016 14:03	10353912015	Lead	1090	15	ppb
094-09A Gymnasium Water Spigot (Restroom)	6/26/2016 10:21	7/7/2016 09:45	10353912017	Copper	1.1	1.3	ppm
094-09A Gymnasium Water Spigot (Restroom)	6/26/2016 10:21	7/6/2016 17:49	10353912017	Lead	9	15	ppb
094-10A Room 8 Sink Faucet	6/26/2016 10:23	7/6/2016 17:50	10353912019	Copper	0.3	1.3	ppm
094-10A Room 8 Sink Faucet	6/26/2016 10:23	7/6/2016 17:50	10353912019	Lead	5	15	ppb
094-11A Room 8 Drinking Fountain	6/26/2016 10:25	7/6/2016 17:54	10353912021	Copper	0.3	1.3	ppm
094-11A Room 8 Drinking Fountain	6/26/2016 10:25	7/6/2016 17:54	10353912021	Lead	1	15	ppb
094-12A Room 9 Sink Faucet	6/26/2016 10:24	7/6/2016 17:57	10353912023	Copper	0.3	1.3	ppm
094-12A Room 9 Sink Faucet	6/26/2016 10:24	7/6/2016 17:57	10353912023	Lead	2	15	ppb
094-13A Room 9 Drinking Fountain	6/26/2016 10:25	7/6/2016 17:58	10353912025	Copper	0.3	1.3	ppm
094-13A Room 9 Drinking Fountain	6/26/2016 10:25	7/6/2016 17:58	10353912025	Lead	2	15	ppb
094-14A Staff Unisex Restroom Sink Faucet	6/26/2016 10:28	7/6/2016 18:00	10353912027	Copper	0.4	1.3	ppm
094-14A Staff Unisex Restroom Sink Faucet	6/26/2016 10:28	7/6/2016 18:00	10353912027	Lead	3	15	ppb
094-15A Room 10 Boys Restroom Sink Faucet (1)	6/26/2016 10:28	7/6/2016 18:01	10353912029	Copper	0.4	1.3	ppm
094-15A Room 10 Boys Restroom Sink Faucet (1)	6/26/2016 10:28	7/6/2016 18:01	10353912029	Lead	1	15	ppb
094-16A Room 10 Boys Restroom Sink Faucet (2)	6/26/2016 10:29	7/6/2016 18:02	10353912031	Copper	0.4	1.3	ppm
094-16A Room 10 Boys Restroom Sink Faucet (2)	6/26/2016 10:29	7/6/2016 18:02	10353912031	Lead	1	15	ppb
094-17A Room 10 Boys Restroom Water Spigot	6/26/2016 10:31	7/6/2016 14:05	10353912033	Copper	7.3	1.3	ppm
094-17A Room 10 Boys Restroom Water Spigot	6/26/2016 10:31	7/6/2016 13:24	10353912033	Lead	68	15	ppb
094-18A Room 11 Girls Restroom Sink Faucet (1)	6/26/2016 10:40	7/6/2016 18:04	10353912035	Copper	0.2	1.3	ppm
094-18A Room 11 Girls Restroom Sink Faucet (1)	6/26/2016 10:40	7/6/2016 18:04	10353912035	Lead	1	15	ppb
094-19A Room 11 Girls Restroom Sink Faucet (2)	6/26/2016 10:42	7/6/2016 18:05	10353912037	Copper	0.4	1.3	ppm
094-19A Room 11 Girls Restroom Sink Faucet (2)	6/26/2016 10:42	7/6/2016 18:05	10353912037	Lead	2	15	ppb
094-20A Room 11 Girls Restroom Water Spigot	6/26/2016 10:44	7/7/2016 09:46	10353912039	Copper	0.7	1.3	ppm
094-20A Room 11 Girls Restroom Water Spigot	6/26/2016 10:44	7/6/2016 18:07	10353912039	Lead	13	15	ppb
094-21A Room 12 Faculty Room Sink Faucet	6/26/2016 10:46	7/6/2016 16:49	10353912041	Copper	0.3	1.3	ppm
094-21A Room 12 Faculty Room Sink Faucet	6/26/2016 10:46	7/6/2016 16:49	10353912041	Lead	4	15	ppb
094-22A Room 31 Faculty Room Drinking Fountain	6/26/2016 10:48	7/6/2016 16:55	10353912043	Copper	0.0	1.3	ppm
094-22A Room 31 Faculty Room Drinking Fountain	6/26/2016 10:48	7/6/2016 16:55	10353912043	Lead	0	15	ppb
094-23A Kitchen Sink Faucet (1)	6/26/2016 10:45	7/6/2016 16:56	10353912045	Copper	0.1	1.3	ppm
094-23A Kitchen Sink Faucet (1)	6/26/2016 10:45	7/6/2016 16:56	10353912045	Lead	2	15	ppb
094-24A Kitchen Sink Faucet (2)	6/26/2016 10:49	7/6/2016 16:58	10353912047	Copper	0.3	1.3	ppm
094-24A Kitchen Sink Faucet (2)	6/26/2016 10:49	7/6/2016 16:58	10353912047	Lead	1	15	ppb
094-25A Kitchen Sink Faucet (3)	6/26/2016 10:49	7/6/2016 16:59	10353912049	Copper	0.2	1.3	ppm
094-25A Kitchen Sink Faucet (3)	6/26/2016 10:49	7/6/2016 16:59	10353912049	Lead	1	15	ppb
094-26A Kitchen Restroom Sink Faucet	6/26/2016 10:51	7/6/2016 17:04	10353912051	Copper	0.4	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Woodmere Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
094-26A Kitchen Restroom Sink Faucet	6/26/2016 10:51	7/6/2016 17:04	10353912051	Lead	1	15	ppb
094-27A Cafeteria Drinking Fountain	6/26/2016 10:53	7/6/2016 17:06	10353912053	Copper	0.0	1.3	ppm
094-27A Cafeteria Drinking Fountain	6/26/2016 10:53	7/6/2016 17:06	10353912053	Lead	22	15	ppb
094-28A Library Hallway Drinking Fountain	6/26/2016 11:00	7/6/2016 20:53	10353912055	Copper	0.6	1.3	ppm
094-28A Library Hallway Drinking Fountain	6/26/2016 11:00	7/6/2016 17:07	10353912055	Lead	3	15	ppb
094-29A Computer Lab Sink Faucet	6/26/2016 11:02	7/6/2016 20:55	10353912057	Copper	0.3	1.3	ppm
094-29A Computer Lab Sink Faucet	6/26/2016 11:02	7/6/2016 17:09	10353912057	Lead	6	15	ppb
094-30A Room 38 Sink Faucet	6/26/2016 11:05	7/6/2016 17:10	10353912059	Copper	0.3	1.3	ppm
094-30A Room 38 Sink Faucet	6/26/2016 11:05	7/6/2016 17:10	10353912059	Lead	2	15	ppb
094-31A Room 38 Drinking Fountain	6/26/2016 11:05	7/6/2016 20:56	10353912061	Copper	0.4	1.3	ppm
094-31A Room 38 Drinking Fountain	6/26/2016 11:05	7/6/2016 17:11	10353912061	Lead	2	15	ppb
094-32A Room 39 Sink Faucet	6/26/2016 11:10	7/6/2016 17:14	10353912063	Copper	0.4	1.3	ppm
094-32A Room 39 Sink Faucet	6/26/2016 11:10	7/6/2016 17:14	10353912063	Lead	2	15	ppb
094-33A Room 39 Drinking Fountain	6/26/2016 11:10	7/6/2016 17:16	10353912065	Copper	0.4	1.3	ppm
094-33A Room 39 Drinking Fountain	6/26/2016 11:10	7/6/2016 17:16	10353912065	Lead	1	15	ppb
094-34A Room 40 Sink Faucet	6/26/2016 11:13	7/6/2016 17:17	10353912067	Copper	0.4	1.3	ppm
094-34A Room 40 Sink Faucet	6/26/2016 11:13	7/6/2016 17:17	10353912067	Lead	6	15	ppb
094-35A Room 40 Drinking Fountain	6/26/2016 11:15	7/6/2016 17:24	10353912069	Copper	0.4	1.3	ppm
094-35A Room 40 Drinking Fountain	6/26/2016 11:15	7/6/2016 17:24	10353912069	Lead	1	15	ppb
094-36A Room 41 Boys Restroom Sink Faucet (1)	6/26/2016 11:17	7/7/2016 09:32	10353912071	Copper	0.5	1.3	ppm
094-36A Room 41 Boys Restroom Sink Faucet (1)	6/26/2016 11:17	7/6/2016 17:25	10353912071	Lead	4	15	ppb
094-37A Room 41 Boys Restroom Sink Faucet (2)	6/26/2016 11:19	7/7/2016 09:34	10353912073	Copper	0.5	1.3	ppm
094-37A Room 41 Boys Restroom Sink Faucet (2)	6/26/2016 11:19	7/6/2016 17:27	10353912073	Lead	4	15	ppb
094-38A Room 41 Boys Restroom Water Spigot	6/26/2016 11:21	7/7/2016 09:35	10353912075	Copper	1.4	1.3	ppm
094-38A Room 41 Boys Restroom Water Spigot	6/26/2016 11:21	7/6/2016 17:28	10353912075	Lead	55	15	ppb
094-39A Room 42 Custodian Sink Faucet	6/26/2016 11:32	7/6/2016 17:29	10353912077	Copper	0.4	1.3	ppm
094-39A Room 42 Custodian Sink Faucet	6/26/2016 11:32	7/6/2016 17:29	10353912077	Lead	72	15	ppb
094-40A Room 43 Girls Restroom Sink Faucet (1)	6/26/2016 11:34	7/6/2016 17:31	10353912079	Copper	0.4	1.3	ppm
094-40A Room 43 Girls Restroom Sink Faucet (1)	6/26/2016 11:34	7/6/2016 17:31	10353912079	Lead	3	15	ppb
094-41A Room 43 Girls Restroom Sink Faucet (2)	6/26/2016 11:36	7/7/2016 09:53	10353912081	Copper	0.6	1.3	ppm
094-41A Room 43 Girls Restroom Sink Faucet (2)	6/26/2016 11:36	7/6/2016 19:26	10353912081	Lead	4	15	ppb
094-42A Room 43 Girls Restroom Water Spigot	6/26/2016 11:38	7/6/2016 14:06	10353912083	Copper	1.6	1.3	ppm
094-42A Room 43 Girls Restroom Water Spigot	6/26/2016 11:38	7/6/2016 13:26	10353912083	Lead	302	15	ppb
094-43A Room 46 Sink Faucet	6/26/2016 11:23	7/6/2016 19:34	10353912085	Copper	0.3	1.3	ppm
094-43A Room 46 Sink Faucet	6/26/2016 11:23	7/6/2016 19:34	10353912085	Lead	3	15	ppb
094-44A Room 46 Drinking Fountain	6/26/2016 11:23	7/7/2016 09:56	10353912087	Copper	0.5	1.3	ppm
094-44A Room 46 Drinking Fountain	6/26/2016 11:23	7/6/2016 19:36	10353912087	Lead	2	15	ppb
094-45A Room 47 Sink Faucet	6/26/2016 11:25	7/6/2016 19:37	10353912089	Copper	0.3	1.3	ppm
094-45A Room 47 Sink Faucet	6/26/2016 11:25	7/6/2016 19:37	10353912089	Lead	2	15	ppb
094-46A Room 47 Drinking Fountain	6/26/2016 11:25	7/6/2016 19:39	10353912091	Copper	0.4	1.3	ppm
094-46A Room 47 Drinking Fountain	6/26/2016 11:25	7/6/2016 19:39	10353912091	Lead	1	15	ppb
094-47A Room 48 Sink Faucet	6/26/2016 11:27	7/6/2016 19:40	10353912093	Copper	0.2	1.3	ppm
094-47A Room 48 Sink Faucet	6/26/2016 11:27	7/6/2016 19:40	10353912093	Lead	2	15	ppb
094-48A Room 48 Drinking Fountain	6/26/2016 11:27	7/6/2016 19:41	10353912095	Copper	0.4	1.3	ppm
094-48A Room 48 Drinking Fountain	6/26/2016 11:27	7/6/2016 19:41	10353912095	Lead	2	15	ppb
094-49A Room 49 Girls Restroom Sink Faucet	6/26/2016 11:30	7/6/2016 19:43	10353912097	Copper	0.3	1.3	ppm
094-49A Room 49 Girls Restroom Sink Faucet	6/26/2016 11:30	7/6/2016 19:43	10353912097	Lead	1	15	ppb
094-50A Room 49 Girls Restroom Water Spigot	6/26/2016 11:30	7/6/2016 14:07	10353912099	Copper	4.6	1.3	ppm
094-50A Room 49 Girls Restroom Water Spigot	6/26/2016 11:30	7/6/2016 13:27	10353912099	Lead	57	15	ppb
094-51A Boys Restroom Sink Faucet (1)	6/26/2016 11:45	7/6/2016 19:44	10353912101	Copper	0.3	1.3	ppm
094-51A Boys Restroom Sink Faucet (1)	6/26/2016 11:45	7/6/2016 19:44	10353912101	Lead	2	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Woodmere Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
094-52A Boys Restroom Sink Faucet (2)	6/26/2016 11:47	7/6/2016 19:48	10353912103	Copper	0.3	1.3	ppm
094-52A Boys Restroom Sink Faucet (2)	6/26/2016 11:47	7/6/2016 19:48	10353912103	Lead	2	15	ppb
094-53A Boys Restroom Water Spigot	6/26/2016 11:49	7/6/2016 14:09	10353912105	Copper	1.30	1.3	ppm
094-53A Boys Restroom Water Spigot	6/26/2016 11:49	7/6/2016 13:28	10353912105	Lead	9	15	ppb
094-54A Room 52 Restroom Sink Faucet	6/26/2016 11:51	7/6/2016 19:50	10353912107	Copper	0.4	1.3	ppm
094-54A Room 52 Restroom Sink Faucet	6/26/2016 11:51	7/6/2016 19:50	10353912107	Lead	2	15	ppb
094-55A Room 53 Custodian Sink Faucet	6/26/2016 11:53	7/6/2016 19:52	10353912109	Copper	0.3	1.3	ppm
094-55A Room 53 Custodian Sink Faucet	6/26/2016 11:53	7/6/2016 19:52	10353912109	Lead	3	15	ppb
094-56A Kitchen Hallway Sink Faucet	6/26/2016 10:55	7/7/2016 10:04	10353912111	Copper	0.8	1.3	ppm
094-56A Kitchen Hallway Sink Faucet	6/26/2016 10:55	7/6/2016 19:54	10353912111	Lead	9	15	ppb
094-57A Room 13 Sink Faucet	6/26/2016 11:56	7/6/2016 19:55	10353912113	Copper	0.2	1.3	ppm
094-57A Room 13 Sink Faucet	6/26/2016 11:56	7/6/2016 19:55	10353912113	Lead	5	15	ppb
094-58A Room 13 Drinking Fountain	6/26/2016 11:56	7/6/2016 19:57	10353912115	Copper	0.3	1.3	ppm
094-58A Room 13 Drinking Fountain	6/26/2016 11:56	7/6/2016 19:57	10353912115	Lead	3	15	ppb
094-59A Room 14 Sink Faucet	6/26/2016 11:59	7/6/2016 19:58	10353912117	Copper	0.2	1.3	ppm
094-59A Room 14 Sink Faucet	6/26/2016 11:59	7/6/2016 19:58	10353912117	Lead	4	15	ppb
094-60A Room 14 Drinking Fountain	6/26/2016 11:59	7/6/2016 20:00	10353912119	Copper	0.4	1.3	ppm
094-60A Room 14 Drinking Fountain	6/26/2016 11:59	7/6/2016 20:00	10353912119	Lead	2	15	ppb
094-61A Room 28 Nurse Sink Faucet	6/26/2016 12:01	7/6/2016 18:45	10353912121	Copper	0.4	1.3	ppm
094-61A Room 28 Nurse Sink Faucet	6/26/2016 12:01	7/6/2016 18:45	10353912121	Lead	2	15	ppb
094-62A Copy Room Sink Faucet	6/26/2016 12:03	7/6/2016 18:50	10353912123	Copper	0.4	1.3	ppm
094-62A Copy Room Sink Faucet	6/26/2016 12:03	7/6/2016 18:50	10353912123	Lead	1	15	ppb
094-63A Room 26 Sink Faucet	6/26/2016 12:06	7/6/2016 18:52	10353912125	Copper	0.2	1.3	ppm
094-63A Room 26 Sink Faucet	6/26/2016 12:06	7/6/2016 18:52	10353912125	Lead	3	15	ppb
094-64A Room 26 Drinking Fountain	6/26/2016 12:06	7/6/2016 18:53	10353912127	Copper	0.3	1.3	ppm
094-64A Room 26 Drinking Fountain	6/26/2016 12:06	7/6/2016 18:53	10353912127	Lead	2	15	ppb
094-65A Room 15 Sink Faucet	6/26/2016 12:10	7/6/2016 18:54	10353912129	Copper	0.2	1.3	ppm
094-65A Room 15 Sink Faucet	6/26/2016 12:10	7/6/2016 18:54	10353912129	Lead	3	15	ppb
094-66A Room 15 Drinking Fountain	6/26/2016 12:12	7/6/2016 18:59	10353912131	Copper	0.3	1.3	ppm
094-66A Room 15 Drinking Fountain	6/26/2016 12:12	7/6/2016 18:59	10353912131	Lead	2	15	ppb
094-67A Room 25 Sink Faucet	6/26/2016 12:19	7/6/2016 19:00	10353912133	Copper	0.2	1.3	ppm
094-67A Room 25 Sink Faucet	6/26/2016 12:19	7/6/2016 19:00	10353912133	Lead	3	15	ppb
094-68A Room 25 Drinking Fountain	6/26/2016 12:19	7/6/2016 19:01	10353912135	Copper	0.4	1.3	ppm
094-68A Room 25 Drinking Fountain	6/26/2016 12:19	7/6/2016 19:01	10353912135	Lead	2	15	ppb
094-69A Room 16 Sink Faucet	6/26/2016 12:22	7/6/2016 19:03	10353912137	Copper	0.3	1.3	ppm
094-69A Room 16 Sink Faucet	6/26/2016 12:22	7/6/2016 19:03	10353912137	Lead	4	15	ppb
094-70A Room 16 Drinking Fountain	6/26/2016 12:22	7/6/2016 19:04	10353912139	Copper	0.4	1.3	ppm
094-70A Room 16 Drinking Fountain	6/26/2016 12:22	7/6/2016 19:04	10353912139	Lead	3	15	ppb
094-71A Room 17 Boys Restroom Sink Faucet (1)	6/26/2016 12:26	7/7/2016 09:48	10353912141	Copper	0.7	1.3	ppm
094-71A Room 17 Boys Restroom Sink Faucet (1)	6/26/2016 12:26	7/6/2016 19:05	10353912141	Lead	4	15	ppb
094-72A Room 17 Boys Restroom Sink Faucet (2)	6/26/2016 12:27	7/7/2016 09:49	10353912143	Copper	0.5	1.3	ppm
094-72A Room 17 Boys Restroom Sink Faucet (2)	6/26/2016 12:27	7/6/2016 19:08	10353912143	Lead	1	15	ppb
094-73A Room 17 Boys Restroom Water Spigot	6/26/2016 12:28	7/7/2016 09:50	10353912145	Copper	0.9	1.3	ppm
094-73A Room 17 Boys Restroom Water Spigot	6/26/2016 12:28	7/6/2016 19:10	10353912145	Lead	9	15	ppb
094-74A Room 18 Custodian Sink Faucet	6/26/2016 12:30	7/6/2016 19:11	10353912147	Copper	0.3	1.3	ppm
094-74A Room 18 Custodian Sink Faucet	6/26/2016 12:30	7/6/2016 19:11	10353912147	Lead	2	15	ppb
094-75A Room 20 Girls Restroom Sink Faucet (1)	6/26/2016 12:33	7/6/2016 19:18	10353912149	Copper	0.4	1.3	ppm
094-75A Room 20 Girls Restroom Sink Faucet (1)	6/26/2016 12:33	7/6/2016 19:18	10353912149	Lead	1	15	ppb
094-76A Room 20 Girls Restroom Sink Faucet (2)	6/26/2016 12:35	7/6/2016 19:19	10353912151	Copper	0.4	1.3	ppm
094-76A Room 20 Girls Restroom Sink Faucet (2)	6/26/2016 12:35	7/6/2016 19:19	10353912151	Lead	1	15	ppb
094-77A Room 20 Girls Restroom Water Spigot	6/26/2016 12:37	7/7/2016 09:52	10353912153	Copper	1.4	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Woodmere Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
094-77A Room 20 Girls Restroom Water Spigot	6/26/2016 12:37	7/6/2016 19:21	10353912153	Lead	168	15	ppb
094-78A Room 21 Sink Faucet	6/26/2016 12:40	7/6/2016 19:22	10353912155	Copper	0.2	1.3	ppm
094-78A Room 21 Sink Faucet	6/26/2016 12:40	7/6/2016 19:22	10353912155	Lead	2	15	ppb
094-79A Room 21 Water Spigot	6/26/2016 12:40	7/6/2016 19:23	10353912157	Copper	0.4	1.3	ppm
094-79A Room 21 Water Spigot	6/26/2016 12:40	7/6/2016 19:23	10353912157	Lead	1	15	ppb
094-80A Room 24 Sink Faucet (1)	6/26/2016 12:43	7/6/2016 19:25	10353912159	Copper	0.2	1.3	ppm
094-80A Room 24 Sink Faucet (1)	6/26/2016 12:43	7/6/2016 19:25	10353912159	Lead	2	15	ppb
094-81A Room 24 Sink Faucet (2)	6/26/2016 12:43	7/6/2016 20:11	10353912161	Copper	0.4	1.3	ppm
094-81A Room 24 Sink Faucet (2)	6/26/2016 12:43	7/6/2016 20:11	10353912161	Lead	3	15	ppb
094-82A Room 24 Drinking Fountain	6/26/2016 12:43	7/7/2016 10:08	10353912163	Copper	0.5	1.3	ppm
094-82A Room 24 Drinking Fountain	6/26/2016 12:43	7/6/2016 20:17	10353912163	Lead	1	15	ppb
094-83A Room 23 Sink Faucet (1)	6/26/2016 12:45	7/7/2016 10:49	10353912165	Copper	0.2	1.3	ppm
094-83A Room 23 Sink Faucet (1)	6/26/2016 12:45	7/7/2016 10:49	10353912165	Lead	2	15	ppb
094-84A Room 23 Sink Faucet (2)	6/26/2016 12:45	7/6/2016 20:18	10353912167	Copper	0.3	1.3	ppm
094-84A Room 23 Sink Faucet (2)	6/26/2016 12:45	7/6/2016 20:18	10353912167	Lead	3	15	ppb
094-85A Room 23 Drinking Fountain	6/26/2016 12:46	7/6/2016 20:22	10353912169	Copper	0.4	1.3	ppm
094-85A Room 23 Drinking Fountain	6/26/2016 12:46	7/6/2016 20:22	10353912169	Lead	1	15	ppb
094-86A Portable Restroom Sink Faucet (1)	6/26/2016 12:54	7/6/2016 20:23	10353912171	Copper	0.3	1.3	ppm
094-86A Portable Restroom Sink Faucet (1)	6/26/2016 12:54	7/6/2016 20:23	10353912171	Lead	1	15	ppb
094-87A Portable Restroom Sink Faucet (2)	6/26/2016 12:56	7/6/2016 20:25	10353912173	Copper	0.4	1.3	ppm
094-87A Portable Restroom Sink Faucet (2)	6/26/2016 12:56	7/6/2016 20:25	10353912173	Lead	1	15	ppb
094-88A Portable Restroom Sink Faucet (3)	6/26/2016 13:00	7/7/2016 10:09	10353912175	Copper	0.6	1.3	ppm
094-88A Portable Restroom Sink Faucet (3)	6/26/2016 13:00	7/6/2016 20:26	10353912175	Lead	1	15	ppb
094-89A Portable Restroom Sink Faucet (4)	6/26/2016 13:00	7/7/2016 10:11	10353912177	Copper	0.6	1.3	ppm
094-89A Portable Restroom Sink Faucet (4)	6/26/2016 13:00	7/6/2016 20:28	10353912177	Lead	4	15	ppb
094-90A Outside Portable Water Spigot	6/26/2016 13:04	7/7/2016 10:12	10353912179	Copper	0.5	1.3	ppm
094-90A Outside Portable Water Spigot	6/26/2016 13:04	7/6/2016 20:29	10353912179	Lead	7	15	ppb
094-91A Outside Water Spigot (1)	6/26/2016 13:08	7/7/2016 10:13	10353912181	Copper	0.6	1.3	ppm
094-91A Outside Water Spigot (1)	6/26/2016 13:08	7/6/2016 20:30	10353912181	Lead	4	15	ppb
094-92A Outside Cage Water Spigot	6/26/2016 13:12	7/6/2016 20:32	10353912183	Copper	0.0	1.3	ppm
094-92A Outside Cage Water Spigot	6/26/2016 13:12	7/6/2016 20:32	10353912183	Lead	5	15	ppb
094-93A Outside Water Spigot (2)	6/26/2016 13:15	7/7/2016 10:15	10353912185	Copper	0.7	1.3	ppm
094-93A Outside Water Spigot (2)	6/26/2016 13:15	7/6/2016 20:35	10353912185	Lead	26	15	ppb
094-94A Outside Water Spigot (3)	6/26/2016 13:17	7/7/2016 10:16	10353912187	Copper	1.1	1.3	ppm
094-94A Outside Water Spigot (3)	6/26/2016 13:17	7/6/2016 20:39	10353912187	Lead	5	15	ppb
094-95A Outside Water Spigot (4)	6/26/2016 13:19	7/7/2016 10:20	10353912189	Copper	0.7	1.3	ppm
094-95A Outside Water Spigot (4)	6/26/2016 13:19	7/6/2016 20:40	10353912189	Lead	12	15	ppb
094-96A Outside Water Spigot (5)	6/26/2016 13:21	7/7/2016 10:21	10353912191	Copper	0.5	1.3	ppm
094-96A Outside Water Spigot (5)	6/26/2016 13:21	7/6/2016 20:41	10353912191	Lead	3	15	ppb
094-97A Outside Water Spigot (6)	6/26/2016 13:23	7/6/2016 14:13	10353912193	Copper	1.2	1.3	ppm
094-97A Outside Water Spigot (6)	6/26/2016 13:23	7/6/2016 13:30	10353912193	Lead	35	15	ppb
094-98A Outside Water Spigot (7)	6/26/2016 13:24	7/6/2016 20:43	10353912195	Copper	0.1	1.3	ppm
094-98A Outside Water Spigot (7)	6/26/2016 13:24	7/6/2016 20:43	10353912195	Lead	2	15	ppb
094-99A Outside Water Spigot (8)	6/26/2016 13:28	7/7/2016 10:23	10353912197	Copper	0.6	1.3	ppm
094-99A Outside Water Spigot (8)	6/26/2016 13:28	7/6/2016 20:44	10353912197	Lead	10	15	ppb
094-100A Outside Water Spigot (9)	6/26/2016 13:30	7/6/2016 14:14	10353912199	Copper	0.8	1.3	ppm
094-100A Outside Water Spigot (9)	6/26/2016 13:30	7/6/2016 13:34	10353912199	Lead	16	15	ppb
094-101A Outside Water Spigot (10)	6/26/2016 13:32	7/7/2016 10:07	10353912201	Copper	0.6	1.3	ppm
094-101A Outside Water Spigot (10)	6/26/2016 13:32	7/6/2016 20:10	10353912201	Lead	6	15	ppb
094-102A Room 22 Drinking Fountain	6/26/2016 10:02	7/6/2016 20:45	10353912203	Copper	0.4	1.3	ppm
094-102A Room 22 Drinking Fountain	6/26/2016 10:02	7/6/2016 20:45	10353912203	Lead	0	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Woodmere Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
094-103A Hallway Drinking Fountain at Room 28	6/26/2016 12:03	7/7/2016 10:24	10353912205	Copper	0.7	1.3	ppm
094-103A Hallway Drinking Fountain at Room 28	6/26/2016 12:03	7/6/2016 20:47	10353912205	Lead	1	15	ppb
094-104A Hallway Drinking Fountain at Room 31	6/26/2016 10:56	7/7/2016 10:26	10353912207	Copper	0.6	1.3	ppm
094-104A Hallway Drinking Fountain at Room 31	6/26/2016 10:56	7/6/2016 20:48	10353912207	Lead	1	15	ppb

EPA Action Level for Lead of 15 ppb

ND = Non detect

EPA Action Level for Copper of 1.3 ppm

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.