April 2, 2021

Joe Crelier, Director–Risk Management
Portland Public Schools
501 N Dixon Street
Portland, Oregon

Via email: jcrelier@pps.net

Regarding: COVID Response Indoor Air Quality Testing Report
Sitton Elementary School
9930 N Smith Street
Portland, Oregon
PBS Project 25000.138

Dear Mr. Crelier:

On March 30, 2021, PBS Engineering and Environmental Inc. (PBS) performed indoor air quality testing in Sitton Elementary School located at the address above. These services were provided to Portland Public Schools (District) to measure air quality parameters before schools and district-owned buildings are opened again for reoccupancy.

As part of these indoor air quality testing services, PBS measured carbon monoxide (CO), carbon dioxide (CO_2), temperature in degrees Fahrenheit (°F), relative humidity (%RH), and airborne particulate (PM2.5 and PM10). Additionally, PBS reviewed and inventoried accessible components of the test rooms' heating, ventilation, and air conditioning (HVAC) systems

Based on PBS' findings, the portable building tested below the recommended range for indoor temperatures. The building was unoccupied at the time of the investigation. The results of the testing and assessment indicates that indoor air quality in the buildings is good and that the buildings are acceptable for occupancy.

While PBS observed no measurable indoor air quality concerns in any of the rooms that were tested, PBS did not test every occupiable room in each building. This investigation has been performed in concert with a concerted effort on the part of the District to perform regular inspections and repair of all HVAC mechanical systems throughout the District. Additionally, it is the District's policy that rooms without adequate ventilation will not be utilized moving forward.

VENTILATION PARAMETERS AND AIRBORNE PARTICULATE MONITORING

PBS took spot measurements of ventilation parameters in approximately 20% of the classrooms, offices, and common areas in the building (or each building). The readings were compared to recommendations in the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) Standard 62.1-2016, Ventilation for Acceptable Indoor Air Quality.

PBS used a TSI VelociCalc 9565 ventilation meter to measure temperature, %RH, CO, and CO_2. A TSI Aerotrak 9306-V2 optical particle counter was used to measure airborne particulate. The table below summarizes the results of the testing. Readings above or below the ASHRAE recommendations are shown in bold.

IAQ Testing Results

Room	CO	CO_2	Temp. (°F)	%RH	PM2.5	PM10	HVAC
Outdoor Air (Pre)	1.2	446	65.3	36.2	0.023	0.002	N/A
Main Office	0.0	449	68.8	39.4	0.002	0.001	Supply and Return Air, Operative Windows, Air Purifier
Office 4D	0.0	439	68.4	35.4	0.012	0.005	Supply and Return Air
Room 10A	0.0	447	68.7	34.0	0.011	0.006	Supply and Return Air, Operative Windows
Classroom 12	0.1	436	69.7	34.6	0.005	0.001	Operative Windows, Unit Ventilator
Room 22 – Music	0.0	451	70.0	32.7	0.013	0.008	Supply and Return Air
Classroom 15	0.1	439	70.0	33.4	0.005	0.002	Operative Windows, Unit Ventilator
Classroom 21	0.0	457	70.7	34.3	0.006	0.002	Supply and Return Air, Operative Windows, Unit Ventilator
Play Court (Semi-Outdoors)	0.6	459	67.6	34.1	0.005	0.001	Sliding Doors
Classroom 18	0.0	443	68.8	34.1	0.004	0.001	Operative Windows, Unit Ventilator
Gym	0.0	463	69.3	35.9	0.005	0.001	Supply and Return Air
Multipurpose	0.1	465	68.9	34.7	0.008	0.002	Supply and Return Air
Kitchen	0.0	460	68.8	35.0	0.002	0.001	Supply and Return Air
Room 28	0.1	449	**67.4**	33.8	0.003	0.001	Supply and Return Air, Operative Windows, Unit Ventilator
Library	0.0	439	**67.9**	34.3	0.005	0.002	Supply and Return Air, Operative Windows, Unit Ventilator
Classroom 9	0.1	441	68.3	31.7	0.005	0.001	Supply and Return Air, Operative Windows, Radiator, Air Purifier

Room	CO	CO_2	Temp. (°F)	%RH	PM2.5	PM10	HVAC
Classroom 3	0.0	439	69.3	31.7	0.004	0.001	Supply and Return Air, Operative Windows, Radiator
Outdoor Air (Post/Pre)	3.1	430	56.6	41.6	0.044	0.015	N/A
Portable R	0.0	440	**65.6**	40.4	0.013	0.008	Supply and Return Air, Operative Windows
Portable L	0.0	444	**66.9**	37.4	0.004	0.003	Supply and Return Air, Operative Windows
Outdoor Air (Post)	2.9	453	58.2	39.5	0.051	0.018	N/A

CO and CO_2 are presented in parts per million (ppm)
°F: degrees Fahrenheit
%RH: relative humidity
PM: particulate matter
HVAC: visible heating, ventilation, and air conditioning components

CARBON MONOXIDE

CO is produced from the incomplete combustion of carbon-containing fuels, including gasoline, heating oil, and natural gas. CO encountered in a classroom or office environment would likely be the result of proximity to motor vehicles or a malfunctioning heating system exhaust. While ASHRAE recommends that CO levels indoors should not exceed 9 parts per million (ppm), any sustained measurable amount of CO should be investigated.

CARBON DIOXIDE

CO_2 is a normal constituent of exhaled breath and indoor concentrations depend on the number of occupants, duration of occupancy, and air exchanges in a given space. ASHRAE recommends maintaining indoor CO_2 concentrations at less than approximately 1,200 ppm. Given that the building had only limited occupancy during the testing, the reported concentrations are not reflective of conditions during full occupancy.

TEMPERATURE

ASHRAE recommends maintaining indoor temperatures between 68 and 76°F.

RELATIVE HUMIDITY

ASHRAE recommends maintaining relative humidity indoors below 60%. Relative humidity indoors is difficult to regulate and is largely reflective of outdoor conditions.

AIRBORNE PARTICULATE

PM2.5

Airborne particulate matter was measured to assess the effectiveness of the buildings ventilation filtration system. ASHRAE recommends that ambient airborne particulate matter concentrations, measured as PM2.5, should meet National Ambient Air Quality Standards (NAAQS) which for PM2.5 which is 0.035 milligrams per cubic meter of air (mg/m^3) as measured and averaged over a period of 24 hours.

PM10
Airborne particulate matter was measured to assess the effectiveness of the buildings ventilation filtration system. ASHRAE recommends that airborne particulate matter concentrations, measured as PM10, should meet NAAQS which for PM10 which is 0.150 mg/m^3 as measured and averaged over a period of 24 hours.

HVAC
Outer classrooms are served by unit ventilators. Inner classrooms are served by fans. Cafeteria and auditorium share one fan unit. The gymnasium has its own fan unit.

RECOMMENDATIONS
PBS did not observe any rooms that had neither operable windows nor an obvious mechanical or gravity ventilation system. PBS has no recommendations concerning ambient air quality at this time.

LIMITATIONS OF SCOPE
This study was limited to the tests and locations as indicated above. The site as a whole may have other environmental concerns that will not be characterized by this study. The findings and conclusions of this work are not scientific certainties but probabilities based on professional judgment concerning the significance of the data gathered during the course of this investigation. PBS is not able to represent conditions on the site or adjoining sites beyond those detected or observed by PBS.

PBS respectfully submits these results of our indoor air quality investigation. Please feel free to contact me at 503.313.9061 or wayne.sehman@pbsusa.com with any questions or comments.

Sincerely,

Digitally signed by Wayne Sehman
Date: 2021.04.02 15:22:47 -07'00'

Wayne Sehman
Project Manager

WS:mo