

NOTICE OF TAP WATER RESULTS LEAD AND COPPER COMPLIANCE SAMPLING PROGRAM

PWS Name: Mt. Greylock Regional School
PWS ID: 1341010

Date: 6/30/2025

Dear Consumer:

As you may know, Mt. Greylock Regional School is also a public water system (PWS) responsible for providing drinking water that meets state and federal standards. This notice reports the lead and copper results from the samples collected at this facility on **6/17/2025**.

☒ A total of **[10]** samples were taken, and compliance is based on the 90th percentile for all of these samples.
See the attached analytical report for the lead and copper results for each location that was sampled.

The 90th percentile lead and copper levels in your water system are as follows:

LEAD: 0.00021 milligrams per liter (mg/l). This result is ☐ above/ ☒ below the Lead Action Level of 0.015 mg/l.
COPPER: 0.18 milligrams per liter (mg/l). This result is ☐ above/ ☒ below the Copper Action Level of 1.3 mg/l.

What Does This Mean?

The United States Environmental Protection Agency (EPA) and the Massachusetts Department of Environmental Protection (MassDEP) set the **Lead Action Level¹ for lead in drinking water at 0.015 mg/l (or parts per million) and the Copper Action Level at 1.3 mg/l**. Because lead may pose serious health risks, the EPA and MassDEP also set a **Maximum Contaminant Level Goal (MCLG)² for lead of zero. The MCLG for copper is 1.3 mg/l**.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our public water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. More information on lead in drinking water and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at: <http://www.epa.gov/safewater/lead>.

We recommend the following tips to keep any potential lead and copper out of the water you drink:

-) Most importantly – Flushing your water is the simplest way to reduce exposure to lead. When your water has been sitting for several hours, flush the tap until the water feels cold before use.
-) Never use hot water from the faucet for drinking or cooking especially when making baby formula.
-) Never boil water to remove lead or copper. Boiling water for an extended time may make the lead or copper more concentrated.

For more information on lead in drinking water visit:

-) <https://www.mass.gov/service-details/overview-of-lead-in-massachusetts-drinking-water>
-) <https://www.mass.gov/lists/lead-in-drinking-water>

For more information on copper in drinking water visit:

-) <https://www.mass.gov/service-details/copper-and-your-health>
-) <https://safewater.zendesk.com/hc/en-us/sections/202346427>

MDPH Lead and Copper in Drinking Water FAQ and Quick Facts:

-) <https://www.mass.gov/service-details/sources-of-lead-besides-lead-paint>
-) [Lead in Drinking Water FAQ \(https://www.mass.gov/media/1571266/\)](https://www.mass.gov/media/1571266/)
-) [Copper in Drinking Water FAQ \(https://www.mass.gov/media/1571251/\)](https://www.mass.gov/media/1571251/)

¹ The Action Level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

² The Maximum Contaminant Level Goal (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

CDC: <http://www.cdc.gov/nceh/lead/default.htm>.

USEPA: <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>

If you have any questions regarding lead or copper in drinking water or your lead or copper sampling results, please feel free to contact: **Housatonic Basin Sampling & Testing at 413-248-4622.**

Sincerely,

Housatonic Basin Sampling & Testing Staff



Lead and Copper Analysis Report

doc rev 12/2020

I. PWS INFORMATION: Please refer to your MassDEP Lead & Copper sampling plan for approved sampling locations.

PWS ID #:	MA1341010	City / Town:	Williamstown
PWS Name:	Mount Greylock Regional School	PWS Class:	COM ☐ NTNC ☒ TNC ☐

Routine or Special Sample ☒ RS ☐ SS	Original, Resubmitted or Confirmation Report ☒ Original ☐ Resubmitted ☐ Confirmation	If Resubmitted Report, list below:	
		(1) Reason for Resubmission ☐ Resample ☐ Reanalysis ☐ Report Correction	(2) Collection Date of Original Sample
SAMPLE COMMENTS			

II. ANALYTICAL LABORATORY INFORMATION: Attach copy of subcontracted lab analysis reports (as applicable)

Primary Lab MA Cert. #:	M-IN035	Primary Lab Name:	Eurofins Eaton Analytical South Bend	Subcontracted? (Y/N)	N
-------------------------	---------	-------------------	--------------------------------------	----------------------	---

Analyte	Action Level (mg/L)	Lab Method	MDL (mg/L)	MRL (mg/L)	Analysis Lab MA Cert #	Analysis Lab Name
Lead:	0.015	200.8	0.00012	0.00050	M-IN035	Eurofins Eaton Analytical South Bend
Copper:	1.3	200.8	0.00033	0.0020	M-IN035	Eurofins Eaton Analytical South Bend
LAB ANALYSIS COMMENTS			Result Qualifier and Description			
			J - Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.			

#	MassDEP Approved LCR Plan Sample Location	Collection Date	Dilution Factor	LEAD		Result Qualifier	COPPER		Result Qualifier	Primary Lab Sample ID# & Analysis Lab Sample ID#
				Date Analyzed	Result (mg/L)		Date Analyzed	Result (mg/L)		
1	Boys Locker Room Sink	06/17/2025	1	06/24/2025	0.00016	J	06/24/2025	0.034		810-153163-1
2	Girls Locker Room Sink	06/17/2025	1	06/24/2025	0.00017	J	06/24/2025	0.041		810-153163-2
3	Locker Hall Bathroom Sink	06/17/2025	1	06/24/2025	<0.00012		06/24/2025	0.062		810-153163-3
4	Nurses Office Sink	06/17/2025	1	06/24/2025	0.00021	J	06/24/2025	0.081		810-153163-4
5	Nurses Hall All Gender Restroom	06/17/2025	1	06/24/2025	<0.00012		06/24/2025	0.11		810-153163-5
6	Kitchen Prep Sink	06/17/2025	1	06/24/2025	0.00013	J	06/24/2025	0.15		810-153163-6
7	Academic Wing First Floor Boys Bathroom Sink	06/17/2025	1	06/24/2025	0.00021	J	06/24/2025	0.10		810-153163-7
8	Academic Wing Second Floor Boys Bathroom Sink	06/17/2025	1	06/24/2025	0.00012	J	06/24/2025	0.18		810-153163-8
9	Academic Wing Third Floor Boys Bathroom Sink	06/17/2025	1	06/24/2025	0.00016	J	06/24/2025	0.37		810-153163-9
10	Academic Wing Third Floor Teachers Lounge Sink	06/17/2025	1	06/24/2025	0.00019	J	06/24/2025	0.085		810-153163-10
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

Report SCHOOL RESULTS (250 ml) collected under (LCAA) in accordance with 310 CMR 22.06B (7)(a)9 below. Do not use these school results in 90th percentile calculations.

1										
2										
3										
4										

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Authorized Signature:

Nathan Trowbridge, designee for Amanda Scott, Project Manager

Date: 06/27/2025

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.

Page 1 of 1

COM & NTNC public water suppliers must submit forms LCR-D or LCR-E with this form to the appropriate MassDEP Regional Office.

DEP REVIEW STATUS (Initial and Date) ☐ Accepted ☐ Disapproved	Review Page 3 of 3	☐ WQTS Data Entered
--	-----------------------	--