

Vista Academy of Performing Arts – Switchgear Replacement

Vista Unified School District

ADDENDUM No. 1

July 7, 2025

The following is issued to supplement or revise the Contract Documents. The revisions to the documents are described below. Unless specifically changed by this addendum, the remainder of the drawings, documents, specifications, and bid date/time shall remain in effect as originally issued.

PRE-BID RFI's:

Question #1. Can you provide an as-built of existing single line and feeder schedule?

- a. As-builts have been sent to the District for distribution.

Question #2. Do you want junction boxes on the breezeway to be gutter type or stand up type?

- a. As long as the junction boxes are NEMA 3R and fit project needs, we do not have a preference.

