



TTI ENVIRONMENTAL, INC
Consulting & Contracting

1253 North Church Street, Moorestown, NJ 08057
www.ttienv.com o 856-840-8800 f 856-840-8815

July 3, 2025

Ed Kushpa C.E.F.M.
Supervisor of Buildings and Grounds
The Educational Services Commission of NJ
1660 Stelton Road
Piscataway, New Jersey 08854

Reference: Lead in Water Testing 2024-2025 School Year
Educational Services Commission of New Jersey
TTI Project No. 25-190

Dear Mr. Kushpa:

Thank you for selecting TTI Environmental, Inc. (TTI) for your environmental needs. This correspondence is being forwarded to report on the results of the Lead in Water Testing conducted for your district.

1.0 Introduction

TTI followed the recommended practices outlined in the Environmental Protection Agency (EPA) 3 T's for Reducing Lead in Drinking Water October 2006, New Jersey Department of Environmental Protection (NJDEP) Division of Water Supply & Geoscience – Lead in Drinking Water: Guidance for Schools & Child Care Facilities. The guidance documents along with the districts Sampling Plan outlines the procedures which were followed and consisted of; sample collection timing/methods, sample volume, laboratory methods and reporting.

The initial sampling was conducted on May 3, 2025, and samples were collected from bubblers, fountains, and other outlets used for consumption and were all first-draw samples (i.e., the stagnant water is sampled before any use occurs). All samples were collected within the recommended stagnation period between 8 and 48 hours.

2.0 Summary

The results of the initial sampling revealed that the below location(s) tested had elevated sources above the standard as set forth in (NJAC 6A:26-1.2 and 12.4) of 15.4 parts per billion (ppb). The following fixture(s) were immediately removed from service:

School	Fixture Location and Type
Piscataway Regional Day School	3 Behind Faculty Rm/Kitchen 4 Behind Faculty Rm/Kitchen 17 Main Hall/QT/PT
Bright Beginnings Learning Center	39 Classroom/ADL Room
Nuview Academy	2 nd Floor/Room 201 - Sink
Nuview Academy Annex	1-Sink/Kitchen 3-Sink/Kitchen 22-Sink/OT/PT Room
Academy Learning Center	34/Bathroom Sink-301 Cl/Rm – Initial – Sink 35/Cl/Rm Sink-301/Rm- Initial – Sink



The failed sources listed in the table above should be closed and/or labeled "HAND WASH ONLY".

Initial sampling at the Center for Lifelong Learning revealed that this school did not have any elevated sources above the standard as set forth in (NJAC 6A:26-1.2 and 12.4) of 15.4 parts per billion (ppb).

It should be noted that sampling for lead must be performed after the replacement of any drinking water outlet or any other alteration to plumbing or service lines that may impact lead levels.

The following attachments are provided for your review:

- Attachment 1 – Initial Sampling Data and Analytical Results (Initial Event)

If you should have any questions or require additional information, please feel free to contact me directly.

Sincerely,

TTI ENVIRONMENTAL, INC.

Timothy Popp
Vice President of Consulting



ATTACHMENT 1

Sampling Data and Analytical Results (Initial Event)

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520744
LIMS Reference ID: AD20744
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

25-190 Academy Learning Center

Customer PO:

041272

EMSL Sales Rep:

Sheryl Steinmetz

Received:

05/12/2025 09:00

Reported:

05/28/2025 19:23

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 1/Slop Sink - Kitchen - Initial - Sink Lims Reference ID: AD20744-01 Matrix: Drinking Water Sampled: 05/10/25 11:05:00									
Metals									
Lead	6.32		1	1.00	µg/L	05/23/25 09:09	05/27/25 17:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 2/Slop Sink - Kitchen - Initial - Sink Lims Reference ID: AD20744-02 Matrix: Drinking Water Sampled: 05/10/25 11:06:00									
Metals									
Lead	6.12		1	1.00	µg/L	05/23/25 09:09	05/27/25 17:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 3/Prep Sink - Kitchen - Initial - Sink Lims Reference ID: AD20744-03 Matrix: Drinking Water Sampled: 05/10/25 11:07:00									
Metals									
Lead	3.08		1	1.00	µg/L	05/23/25 09:09	05/27/25 17:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 4/Sink - Faculty Room - Initial - Sink Lims Reference ID: AD20744-04 Matrix: Drinking Water Sampled: 05/10/25 11:10:00									
Metals									
Lead	1.01		1	1.00	µg/L	05/23/25 09:09	05/27/25 17:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 5/Sink - Nurse - Initial - Sink Lims Reference ID: AD20744-05 Matrix: Drinking Water Sampled: 05/10/25 11:12:00									
Metals									
Lead	1.86		1	1.00	µg/L	05/23/25 09:09	05/27/25 17:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 6/Sink - Nurse's Bathroom - Initial - Sink Lims Reference ID: AD20744-06 Matrix: Drinking Water Sampled: 05/10/25 11:14:00									
Metals									
Lead	6.25		1	1.00	µg/L	05/23/25 09:09	05/28/25 07:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 7/Water Cooler - Front Rest Room - Initial - Water Cooler (Left Side) Lims Reference ID: AD20744-07 Matrix: Drinking Water Sampled: 05/10/25 11:16:00									
Metals									
Lead	ND		1	1.00	µg/L	05/23/25 09:09	05/28/25 07:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 8/Water Cooler - Front Rest Room - Initial - Water Cooler (Right Side) Lims Reference ID: AD20744-08 Matrix: Drinking Water Sampled: 05/10/25 11:17:00									
Metals									
Lead	ND		1	1.00	µg/L	05/23/25 09:09	05/28/25 07:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 10/Bathroom Sink - 200 Cl/Rm - Initial - Sink Lims Reference ID: AD20744-09 Matrix: Drinking Water Sampled: 05/10/25 11:20:00									
Metals									
Lead	ND		1	1.00	µg/L	05/23/25 09:09	05/28/25 07:35	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520744
LIMS Reference ID: AD20744
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

25-190 Academy Learning Center

Customer PO:

041272

EMSL Sales Rep:

Sheryl Steinmetz

Received:

05/12/2025 09:00

Reported:

05/28/2025 19:23

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: 10/Bathroom Sink - 200 Cl/Rm - Initial - Sink
(Continued)

Lims Reference ID: AD20744-09 Matrix: Drinking Water

Sampled: 05/10/25 11:20:00

Metals (Continued)

Sample: 11/Cl/Rm Sink - 200 Cl/Rm - Initial - Sink

Lims Reference ID: AD20744-10 Matrix: Drinking Water

Sampled: 05/10/25 11:21:00

Metals

Lead	ND	1	1.00	µg/L	05/23/25 09:09	05/28/25 07:37	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 12/Cl/Rm Sink - 201 Cl/Rm - Initial - Bubbler

Lims Reference ID: AD20744-11 Matrix: Drinking Water

Sampled: 05/10/25 11:23:00

Metals

Lead	1.38	1	1.00	µg/L	05/23/25 09:09	05/28/25 07:38	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 13/Bathroom Sink - 201 Cl/Rm - Initial - Sink

Lims Reference ID: AD20744-12 Matrix: Drinking Water

Sampled: 05/10/25 11:24:00

Metals

Lead	ND	1	1.00	µg/L	05/23/25 09:09	05/28/25 07:44	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 14/Cl/Rm Sink - 201 Cl/Rm - Initial - Sink

Lims Reference ID: AD20744-13 Matrix: Drinking Water

Sampled: 05/10/25 11:25:00

Metals

Lead	2.89	1	1.00	µg/L	05/23/25 09:09	05/28/25 07:46	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 15/Cl/Rm Sink - 204 Cl/Rm - Initial - Bubbler

Lims Reference ID: AD20744-14 Matrix: Drinking Water

Sampled: 05/10/25 11:27:00

Metals

Lead	1.21	1	1.00	µg/L	05/22/25 09:33	05/23/25 17:32	JW1	EPA 200.8 (Dig)/EPA 200.8
------	------	---	------	------	----------------	----------------	-----	---------------------------

Sample: 16/Bathroom Sink - 204 Cl/Rm - Initial - Sink

Lims Reference ID: AD20744-15 Matrix: Drinking Water

Sampled: 05/10/25 11:28:00

Metals

Lead	ND	1	1.00	µg/L	05/23/25 09:09	05/28/25 07:52	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 17/Cl/Rm Sink - 204 Cl/Rm - Initial - Sink

Lims Reference ID: AD20744-16 Matrix: Drinking Water

Sampled: 05/10/25 11:29:00

Metals

Lead	2.13	1	1.00	µg/L	05/23/25 09:09	05/28/25 07:54	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 19/Bathroom Sink - 205 Cl/Rm - Initial - Sink

Lims Reference ID: AD20744-17 Matrix: Drinking Water

Sampled: 05/10/25 11:32:00

Metals

Lead	ND	1	1.00	µg/L	05/23/25 09:09	05/28/25 07:56	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520744
LIMS Reference ID: AD20744
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Academy Learning Center

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 09:00
Reported: 05/28/2025 19:23

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 20/CI/Rm Sink - 205 CI/Rm - Initial - Water Cooler Lims Reference ID: AD20744-18 Matrix: Drinking Water Sampled: 05/10/25 11:33:00									
Metals									
Lead	3.19		1	1.00	µg/L	05/23/25 09:09	05/28/25 07:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 21/CI/Rm Sink - 206 CI/Rm - Initial - Bubbler (Low Flow) Lims Reference ID: AD20744-19 Matrix: Drinking Water Sampled: 05/10/25 11:36:00									
Metals									
Lead	1.44		1	1.00	µg/L	05/23/25 09:09	05/28/25 07:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 22/Bathroom Sink - 206 CI/Rm - Initial - Sink Lims Reference ID: AD20744-20 Matrix: Drinking Water Sampled: 05/10/25 11:37:00									
Metals									
Lead	ND		1	1.00	µg/L	05/23/25 09:09	05/28/25 08:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 23/CI/Rm Sink - 206 CI/Rm - Initial - Sink Lims Reference ID: AD20744-21 Matrix: Drinking Water Sampled: 05/10/25 11:38:00									
Metals									
Lead	3.75		1	1.00	µg/L	05/23/25 17:46	05/27/25 13:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 24/CI/Rm Sink - 209 CI/Rm - Initial - Bubbler Lims Reference ID: AD20744-22 Matrix: Drinking Water Sampled: 05/10/25 11:40:00									
Metals									
Lead	ND		1	1.00	µg/L	05/23/25 17:46	05/27/25 13:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 25/Bathroom Sink - 209 CI/Rm - Initial - Sink Lims Reference ID: AD20744-23 Matrix: Drinking Water Sampled: 05/10/25 11:41:00									
Metals									
Lead	ND		1	1.00	µg/L	05/23/25 17:46	05/27/25 13:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 26/CI/Rm Sink - 209 CI/Rm - Initial - Sink Lims Reference ID: AD20744-24 Matrix: Drinking Water Sampled: 05/10/25 11:42:00									
Metals									
Lead	1.97		1	1.00	µg/L	05/23/25 17:46	05/27/25 13:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 27/Sink - 118 Daily Living - Initial - Sink Lims Reference ID: AD20744-25 Matrix: Drinking Water Sampled: 05/10/25 11:45:00									
Metals									
Lead	ND		1	1.00	µg/L	05/23/25 17:46	05/27/25 13:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 28/Water Cooler - Atrium - Initial - Water Cooler Lims Reference ID: AD20744-26 Matrix: Drinking Water Sampled: 05/10/25 11:47:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520744
LIMS Reference ID: AD20744
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Academy Learning Center

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 09:00
Reported: 05/28/2025 19:23

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 28/Water Cooler - Atrium - Initial - Water Cooler (Continued) Lims Reference ID: AD20744-26 Matrix: Drinking Water Sampled: 05/10/25 11:47:00									
Metals (Continued)									
Lead	ND		1	1.00	µg/L	05/23/25 17:46	05/27/25 13:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 29/Water Cooler - Atrium - Initial - Water Cooler Lims Reference ID: AD20744-27 Matrix: Drinking Water Sampled: 05/10/25 11:47:00									
Metals									
Lead	ND		1	1.00	µg/L	05/23/25 17:46	05/27/25 13:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 31/Bathroom Sink - 300 Cl/Rm - Initial - Sink Lims Reference ID: AD20744-28 Matrix: Drinking Water Sampled: 05/10/25 11:49:00									
Metals									
Lead	1.06		1	1.00	µg/L	05/23/25 17:46	05/27/25 13:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 32/Cl/Rm Sink - 300 Cl/Rm - Initial - Sink Lims Reference ID: AD20744-29 Matrix: Drinking Water Sampled: 05/10/25 11:50:00									
Metals									
Lead	1.29		1	1.00	µg/L	05/23/25 17:46	05/27/25 13:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 33/Cl/Rm Sink - 301 Cl/Rm - Initial - Bubbler Lims Reference ID: AD20744-30 Matrix: Drinking Water Sampled: 05/10/25 11:52:00									
Metals									
Lead	ND		1	1.00	µg/L	05/23/25 17:46	05/27/25 13:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 34/Bathroom Sink - 301 Cl/Rm - Initial - Sink Lims Reference ID: AD20744-31 Matrix: Drinking Water Sampled: 05/10/25 11:53:00									
Metals									
Lead	20.2		1	1.00	µg/L	05/23/25 17:46	05/27/25 13:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 35/Cl/Rm Sink - 301 Cl/Rm - Initial - Sink Lims Reference ID: AD20744-32 Matrix: Drinking Water Sampled: 05/10/25 11:54:00									
Metals									
Lead	20.2		1	1.00	µg/L	05/23/25 17:46	05/27/25 13:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 36/Cl/Rm Sink - 304 Cl/Rm - Initial - Bubbler Lims Reference ID: AD20744-33 Matrix: Drinking Water Sampled: 05/10/25 11:56:00									
Metals									
Lead	ND		1	1.00	µg/L	05/23/25 17:46	05/27/25 13:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 37/Bathroom Sink - 304 Cl/Rm - Initial - Sink Lims Reference ID: AD20744-34 Matrix: Drinking Water Sampled: 05/10/25 11:57:00									
Metals									
Lead	1.62		1	1.00	µg/L	05/23/25 17:46	05/27/25 14:00	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520744
LIMS Reference ID: AD20744
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

25-190 Academy Learning Center

Customer PO:

041272

EMSL Sales Rep:

Sheryl Steinmetz

Received:

05/12/2025 09:00

Reported:

05/28/2025 19:23

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: 37/Bathroom Sink - 304 Cl/Rm - Initial - Sink
(Continued)

Lims Reference ID: AD20744-34 Matrix: Drinking Water

Sampled: 05/10/25 11:57:00

Metals (Continued)

Sample: 38/Cl/Rm Sink - 304 Cl/Rm - Initial - Sink

Lims Reference ID: AD20744-35 Matrix: Drinking Water

Sampled: 05/10/25 11:58:00

Metals

Lead	1.74	1	1.00	µg/L	05/23/25 17:46	05/27/25 14:01	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 40/Bathroom Sink - 305 Cl/Rm - Initial - Sink

Lims Reference ID: AD20744-36 Matrix: Drinking Water

Sampled: 05/10/25 12:02:00

Metals

Lead	ND	1	1.00	µg/L	05/23/25 17:46	05/27/25 14:04	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 41/Cl/Rm Sink - 305 Cl/Rm - Initial - Sink

Lims Reference ID: AD20744-37 Matrix: Drinking Water

Sampled: 05/10/25 12:03:00

Metals

Lead	1.93	1	1.00	µg/L	05/23/25 17:46	05/27/25 14:06	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 43/Bathroom Sink - 307 Cl/Rm - Initial - Sink

Lims Reference ID: AD20744-38 Matrix: Drinking Water

Sampled: 05/10/25 12:06:00

Metals

Lead	ND	1	1.00	µg/L	05/23/25 17:46	05/27/25 14:08	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 44/Cl/Rm Sink - 307 Cl/Rm - Initial - Sink

Lims Reference ID: AD20744-39 Matrix: Drinking Water

Sampled: 05/10/25 12:07:00

Metals

Lead	2.02	1	1.00	µg/L	05/23/25 17:46	05/27/25 14:10	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 46/Rm 308 - Bathroom Sink - Initial - Sink

Lims Reference ID: AD20744-40 Matrix: Drinking Water

Sampled: 05/10/25 12:10:00

Metals

Lead	ND	1	1.00	µg/L	05/23/25 17:46	05/27/25 14:11	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 47/Rm 308 - Sink Faucet - Initial - Sink

Lims Reference ID: AD20744-41 Matrix: Drinking Water

Sampled: 05/10/25 12:11:00

Metals

Lead	2.00	1	1.00	µg/L	05/23/25 17:51	05/27/25 15:31	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 48/Rm 400 - Sink - Initial - Bubbler

Lims Reference ID: AD20744-42 Matrix: Drinking Water

Sampled: 05/10/25 12:14:00

Metals

Lead	ND	1	1.00	µg/L	05/23/25 17:51	05/27/25 15:36	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520744
LIMS Reference ID: AD20744
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Academy Learning Center

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 09:00
Reported: 05/28/2025 19:23

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 49/Rm 400 - Sink Faucet - Initial - Sink Lims Reference ID: AD20744-43 Matrix: Drinking Water Sampled: 05/10/25 12:15:00									
Metals									
Lead	3.38		1	1.00	µg/L	05/23/25 17:51	05/27/25 15:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 50/Rm 400 - Bathroom Sink - Initial - Sink Lims Reference ID: AD20744-44 Matrix: Drinking Water Sampled: 05/10/25 12:16:00									
Metals									
Lead	ND		1	1.00	µg/L	05/23/25 17:51	05/27/25 15:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 51/Rm 401 - Sink Faucet - Initial - Sink Lims Reference ID: AD20744-45 Matrix: Drinking Water Sampled: 05/10/25 12:18:00									
Metals									
Lead	7.50		1	1.00	µg/L	05/23/25 17:51	05/27/25 15:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 52/Rm 401 - Bathroom Sink - Initial - Sink Lims Reference ID: AD20744-46 Matrix: Drinking Water Sampled: 05/10/25 12:20:00									
Metals									
Lead	1.25		1	1.00	µg/L	05/23/25 17:51	05/27/25 15:48	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520744
LIMS Reference ID: AD20744
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Academy Learning Center

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 09:00
Reported: 05/28/2025 19:23

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520744
LIMS Reference ID: AD20744
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

25-190 Academy Learning Center

Customer PO:

041272

EMSL Sales Rep:

Sheryl Steinmetz

Received:

05/12/2025 09:00

Reported:

05/28/2025 19:23

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: EnvChemistry2@EMSL.com

Page 9 of 12

4820744

Customer Information	Customer ID:			Billing ID:													
	Company Name: TTI Environmental, Inc			Company Name: Same													
	Contact Name: Tim Popp			Billing Contact: Jean Smith													
	Street Address: 1253 N Church St			Street Address:													
	City, State, Zip: Moorestown, NJ 08054		Country: US	City, State, Zip:		Country:											
	Phone: 856-840-8800			Phone:													
Email(s) for Report: timp@ttienv.com			Email(s) for Invoice: jeans@ttienv.com														
Project Name/No: 25-190 Academy Learning Center						Purchase Order: 041272											
EMSL LIMS Project ID: (If applicable, EMSL will provide)				US State where samples collected:		State of Connecticut (CT) must select project location: ☐ Commercial (Taxable) ☐ Residential (Non-Taxable)											
Samples for Compliance? ☒ Yes ☐ No If Yes, for NPDES? ☐ Yes ☒ No				Other (Specify)		PWS ID: State Reporting Required? ☐ Yes ☐ No											
Samples Collected by (Check One): ☐ EMSL ☒ CLIENT				Samples Received Chilled? ☐ Yes ☐ No		Sample(s) Temperature Upon Receipt (LAB ONLY)											
Sampled By Name: Miguel Popp				Sampled By Signature: Miguel Popp		No. of Samples in Shipment: 46											
Turn-Around-Time (TAT) Standard Turn-Around-Time: ☒ 2 Weeks				The following TAT's are subject to Lab approval. Call lab to confirm TAT before submittal: ☐ 1 Week ☐ 4 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day													
Client Sample ID	Comp	Grab	Date / Time Collected	Matrix DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	Preservative 1 HCL 2 HNO3 3 H2SO4 4 ICE 5 Other Describe below in Special Instructions	List Test(s) Needed (Write in test below, then check on sample line:)								Comments			
						Test 1: Lead	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:				
See attached		☒		W	None	☒											
Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)																	
Reporting Requirements: ☒ Results Only ☐ Results and QC ☐ Reduced Deliverables ☐ Hzresults EDD ☒ Excel ☐ Other (Describe Above)																	
Method of Shipment:						Sample Condition Upon Receipt:						Received on Ice? Check if Yes: ☐					
Relinquished by: Miguel Popp						Date/Time: 05/10/25						Received by: [Signature] WS			Date/Time: 5/10/25 1:50		
Relinquished by: [Signature]						Date/Time:						Received by: [Signature] (WT)			Date/Time: 5/12/25 0900		

Controlled Document - COC-07 Chemistry R13 05/31/2024

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by

Page 1 of 2

46mm



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD20744

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey			FACILITY: Academy Learning Center		
PO #: 041272		SAMPLER(S): <i>Miguel fern</i>		DATE: <i>05/10/25</i>		ADDRESS: 145 Pergola Ave., Monroe Township, NJ 08831	
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...	
1.	Slop Sink	Kitchen	<i>11:05</i>	Initial	Sink	250mL	
2.	Slop Sink	Kitchen	<i>11:06</i>	Initial	Sink	250mL	
3.	Prep Sink	Kitchen	<i>11:07</i>	Initial	Sink	250mL	
4.	Sink	Faculty Room	<i>11:10</i>	Initial	Sink	250mL	
5.	Sink	Nurse	<i>11:12</i>	Initial	Sink	250mL	
6.	Sink	Nurse's Bathroom	<i>11:14</i>	Initial	Sink	250mL	
7.	Water Cooler	Front Rest Room	<i>11:16</i>	Initial	Water Cooler	250mL	
8.	Water Cooler	Front Rest Room	<i>11:17</i>	Initial	Water Cooler	250mL	
9.	Bubbler	200 CI/Rm		Initial	Bubbler	250mL	
10.	Bathroom Sink	200 CI/Rm	<i>11:20</i>	Initial	Sink	250mL	
11.	CI/Rm Sink	200 CI/Rm	<i>11:21</i>	Initial	Sink	250mL	
12.	CI/Rm Sink	201 CI/Rm	<i>11:23</i>	Initial	Bubbler	250mL	
13.	Bathroom Sink	201 CI/Rm	<i>11:24</i>	Initial	Sink	250mL	
14.	CI/Rm Sink	201 CI/Rm	<i>11:25</i>	Initial	Sink	250mL	
15.	CI/Rm Sink	204 CI/Rm	<i>11:27</i>	Initial	Bubbler	250mL	
16.	Bathroom Sink	204 CI/Rm	<i>11:28</i>	Initial	Sink	250mL	
17.	CI/Rm Sink	204 CI/Rm	<i>11:29</i>	Initial	Sink	250mL	
18.	CI/Rm Sink	205 CI/Rm		Initial	Bubbler	250mL	
19.	Bathroom Sink	205 CI/Rm	<i>11:32</i>	Initial	Sink	250mL	



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD20744

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey			FACILITY: Academy Learning Center		
PO #: 041272		SAMPLER(S): Miguel Jimenez		DATE: 05/10/25		ADDRESS: 145 Pergola Ave., Monroe Township, NJ 08831	
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...	
20.	Cl/Rm Sink	205 Cl/Rm	11:33	Initial	Water Cooler	250mL	
21.	Cl/Rm Sink	206 Cl/Rm	11:36	Initial	Bubbler	250mL	
22.	Bathroom Sink	206 Cl/Rm	11:37	Initial	Sink	250mL	
23.	Cl/Rm Sink	206 Cl/Rm	11:38	Initial	Sink	250mL	
24.	Cl/Rm Sink	209 Cl/Rm	11:40	Initial	Bubbler	250mL	
25.	Bathroom Sink	209 Cl/Rm	11:41	Initial	Sink	250mL	
26.	Cl/Rm Sink	209 Cl/Rm	11:42	Initial	Sink	250mL	
27.	Sink	118 Daily Living	11:45	Initial	Sink	250mL	
28.	Water Cooler	Atrium	11:47	Initial	Water Cooler	250mL	
29.	Water Cooler	Atrium	11:47	Initial	Water Cooler	250mL	
30.	Cl/Rm Sink	300 Cl/Rm		Initial	Bubbler	250mL	
31.	Bathroom Sink	300 Cl/Rm	11:49	Initial	Sink	250mL	
32.	Cl/Rm Sink	300 Cl/Rm	11:50	Initial	Sink	250mL	
33.	Cl/Rm Sink	301 Cl/Rm	11:52	Initial	Bubbler	250mL	
34.	Bathroom Sink	301 Cl/Rm	11:53	Initial	Sink	250mL	
35.	Cl/Rm Sink	301 Cl/Rm	11:54	Initial	Sink	250mL	
36.	Cl/Rm Sink	304 Cl/Rm	11:56	Initial	Bubbler	250mL	
37.	Bathroom Sink	304 Cl/Rm	11:57	Initial	Sink	250mL	
38.	Cl/Rm Sink	304 Cl/Rm	11:58	Initial	Sink	250mL	



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD20744

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey			FACILITY: Academy Learning Center		
PO #: 041272		SAMPLER(S): <i>Miguel fern</i>		DATE: <i>05/10/25</i>	ADDRESS: 145 Pergola Ave., Monroe Township, NJ 08831		
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...	
39.	CI/Rm Sink	305 CI/Rm	Initial	Bubbler	250mL	Temp. Closed	
40.	Bathroom Sink	305 CI/Rm	12:02 Initial	Sink	250mL		
41.	CI/Rm Sink	305 CI/Rm	12:03 Initial	Sink	250mL		
42.	CI/Rm Sink	307 CI/Rm	Initial	Bubbler	250mL	Temp. Closed	
43.	Bathroom Sink	307 CI/Rm	12:06 Initial	Sink	250mL		
44.	CI/Rm Sink	307 CI/Rm	12:07 Initial	Sink	250mL		
45.	CI/Rm Sink	308 CI/Rm	Initial	Bubbler	250mL	Temp. Closed	
46	Rm 308	Bathroom Sink	12:10 Initial	Sink	250mL		
47	Rm 308	Sink Faucet	12:11 Initial	Sink	250mL		
48	Rm 400	Sink	12:14 Initial	Bubbler	250mL		
49	Rm 400	Sink Faucet	12:15 Initial	Sink	250mL		
50	Rm 400	Bathroom Sink	12:16 Initial	Sink	250mL		
51	Rm 401	Sink Faucet	12:18 Initial	Sink	250mL		
52	Rm 401	Bathroom Sink	12:20 Initial	Sink	250mL		
					250mL		
					250mL		
					250mL		

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519627
LIMS Reference ID: AD19627
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Bright Beginnings Learning Center

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/05/2025 09:00
Reported: 05/21/2025 16:28

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 1 Classroom/B4 Lims Reference ID: AD19627-01 Matrix: Drinking Water Sampled: 05/03/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:10	05/20/25 14:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 2 Bathroom/B4 Lims Reference ID: AD19627-02 Matrix: Drinking Water Sampled: 05/03/25 07:31:00									
Metals									
Lead	1.06		1	1.00	µg/L	05/19/25 14:10	05/20/25 14:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 3 Classroom/B3 Lims Reference ID: AD19627-03 Matrix: Drinking Water Sampled: 05/03/25 07:32:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:10	05/20/25 14:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 4 Bathroom/B3 Lims Reference ID: AD19627-04 Matrix: Drinking Water Sampled: 05/03/25 07:32:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:10	05/20/25 14:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 5 Classroom/B2 Lims Reference ID: AD19627-05 Matrix: Drinking Water Sampled: 05/03/25 07:33:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:10	05/20/25 14:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 6 Bathroom/B2 Lims Reference ID: AD19627-06 Matrix: Drinking Water Sampled: 05/03/25 07:33:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:10	05/20/25 14:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 7 Classroom/B1 Lims Reference ID: AD19627-07 Matrix: Drinking Water Sampled: 05/03/25 07:34:00									
Metals									
Lead	1.02		1	1.00	µg/L	05/19/25 14:10	05/20/25 14:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 8 Bathroom/B1 Lims Reference ID: AD19627-08 Matrix: Drinking Water Sampled: 05/03/25 07:34:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:10	05/20/25 14:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 9 Water Cooler/West Wing Hall Lims Reference ID: AD19627-09 Matrix: Drinking Water Sampled: 05/03/25 07:36:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:10	05/20/25 14:51	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519627
LIMS Reference ID: AD19627
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Bright Beginnings Learning Center

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/05/2025 09:00
Reported: 05/21/2025 16:28

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 10 Water Cooler/West Wing Hall Lims Reference ID: AD19627-10 Matrix: Drinking Water Sampled: 05/03/25 07:36:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:10	05/20/25 14:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 11 Classroom/A4 Lims Reference ID: AD19627-11 Matrix: Drinking Water Sampled: 05/03/25 07:38:00									
Metals									
Lead	1.30		1	1.00	µg/L	05/19/25 14:10	05/20/25 14:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12 Bathroom/A4 Lims Reference ID: AD19627-12 Matrix: Drinking Water Sampled: 05/03/25 07:38:00									
Metals									
Lead	1.05		1	1.00	µg/L	05/19/25 14:10	05/20/25 15:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 13 Classroom/A3 Lims Reference ID: AD19627-13 Matrix: Drinking Water Sampled: 05/03/25 07:40:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:10	05/20/25 15:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 14 Bathroom/A3 Lims Reference ID: AD19627-14 Matrix: Drinking Water Sampled: 05/03/25 07:40:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:10	05/20/25 15:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 15 Classroom/A2 Lims Reference ID: AD19627-15 Matrix: Drinking Water Sampled: 05/03/25 07:41:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:10	05/20/25 15:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 16 Bathroom/A2 Lims Reference ID: AD19627-16 Matrix: Drinking Water Sampled: 05/03/25 07:41:00									
Metals									
Lead	1.13		1	1.00	µg/L	05/19/25 14:10	05/20/25 15:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 17 Classroom/A1 Lims Reference ID: AD19627-17 Matrix: Drinking Water Sampled: 05/03/25 07:42:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:10	05/20/25 15:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 18 Bathroom/A1 Lims Reference ID: AD19627-18 Matrix: Drinking Water Sampled: 05/03/25 07:42:00									
Metals									
Lead	2.65		1	1.00	µg/L	05/19/25 14:10	05/20/25 15:16	PL	EPA 200.8 (DA)/EPA 200.8

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Bright Beginnings Learning Center

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/05/2025 09:00
Reported: 05/21/2025 16:28

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 19 Bathroom/Nurse's Office									
Lims Reference ID:		AD19627-19		Matrix: Drinking Water				Sampled: 05/03/25 07:45:00	
Metals									
Lead	1.21		1	1.00	µg/L	05/19/25 14:10	05/20/25 15:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 20 Office/Nurse's Office									
Lims Reference ID:		AD19627-20		Matrix: Drinking Water				Sampled: 05/03/25 07:45:00	
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:10	05/20/25 15:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 21 Water Cooler/Main Hall									
Lims Reference ID:		AD19627-21		Matrix: Drinking Water				Sampled: 05/03/25 07:47:00	
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:12	05/20/25 15:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 22 Water Cooler/Main Hall									
Lims Reference ID:		AD19627-22		Matrix: Drinking Water				Sampled: 05/03/25 07:47:00	
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:12	05/20/25 15:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 23 Classroom/C4									
Lims Reference ID:		AD19627-23		Matrix: Drinking Water				Sampled: 05/03/25 07:50:00	
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:12	05/20/25 15:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 24 Bathroom/C4									
Lims Reference ID:		AD19627-24		Matrix: Drinking Water				Sampled: 05/03/25 07:50:00	
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:12	05/20/25 15:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 25 Classroom/C3									
Lims Reference ID:		AD19627-25		Matrix: Drinking Water				Sampled: 05/03/25 07:51:00	
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:12	05/20/25 15:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 26 Bathroom/C3									
Lims Reference ID:		AD19627-26		Matrix: Drinking Water				Sampled: 05/03/25 07:51:00	
Metals									
Lead	1.08		1	1.00	µg/L	05/19/25 14:12	05/20/25 15:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 27 Classroom/C2									
Lims Reference ID:		AD19627-27		Matrix: Drinking Water				Sampled: 05/03/25 07:52:00	
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:12	05/20/25 15:54	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519627
LIMS Reference ID: AD19627
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Bright Beginnings Learning Center

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/05/2025 09:00
Reported: 05/21/2025 16:28

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 28 Bathroom/C2 Lims Reference ID: AD19627-28 Matrix: Drinking Water Sampled: 05/03/25 07:52:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:12	05/20/25 15:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 29 Classroom/C1 Lims Reference ID: AD19627-29 Matrix: Drinking Water Sampled: 05/03/25 07:53:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:12	05/20/25 15:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 30 Bathroom/C1 Lims Reference ID: AD19627-30 Matrix: Drinking Water Sampled: 05/03/25 07:53:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:12	05/20/25 15:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 31 Classroom/D4 Lims Reference ID: AD19627-31 Matrix: Drinking Water Sampled: 05/03/25 07:56:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:12	05/20/25 16:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 32 Bathroom/D4 Lims Reference ID: AD19627-32 Matrix: Drinking Water Sampled: 05/03/25 07:56:00									
Metals									
Lead	1.19		1	1.00	µg/L	05/19/25 14:12	05/20/25 16:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 33 Classroom/D3 Lims Reference ID: AD19627-33 Matrix: Drinking Water Sampled: 05/03/25 07:58:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:12	05/20/25 16:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 34 Bathroom/D3 Lims Reference ID: AD19627-34 Matrix: Drinking Water Sampled: 05/03/25 07:58:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:12	05/20/25 16:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 35 Classroom/D2 Lims Reference ID: AD19627-35 Matrix: Drinking Water Sampled: 05/03/25 08:00:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:12	05/20/25 16:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 36 Bathroom/D2 Lims Reference ID: AD19627-36 Matrix: Drinking Water Sampled: 05/03/25 08:01:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:12	05/20/25 16:18	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519627
LIMS Reference ID: AD19627
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

25-190 Bright Beginnings Learning Center

Customer PO:

041272

EMSL Sales Rep:

Sheryl Steinmetz

Received:

05/05/2025 09:00

Reported:

05/21/2025 16:28

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 37 Classroom/D1 Lims Reference ID: AD19627-37 Matrix: Drinking Water Sampled: 05/03/25 08:02:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:12	05/20/25 16:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 38 Bathroom/D1 Lims Reference ID: AD19627-38 Matrix: Drinking Water Sampled: 05/03/25 08:03:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:12	05/20/25 16:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 39 Classroom/ADL Room Lims Reference ID: AD19627-39 Matrix: Drinking Water Sampled: 05/03/25 08:07:00									
Metals									
Lead	59.6		1	1.00	µg/L	05/19/25 14:12	05/20/25 16:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 40 Bathroom/Principals Office Lims Reference ID: AD19627-40 Matrix: Drinking Water Sampled: 05/03/25 08:10:00									
Metals									
Lead	1.08		1	1.00	µg/L	05/19/25 14:12	05/20/25 16:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 41 Water Cooler/2nd Floor Main Hall Lims Reference ID: AD19627-41 Matrix: Drinking Water Sampled: 05/03/25 08:12:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:01	05/20/25 11:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 42 Water Cooler/2nd Floor Main Hall Lims Reference ID: AD19627-42 Matrix: Drinking Water Sampled: 05/03/25 08:13:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:01	05/20/25 11:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 43 Lunch Room/2nd Floor Staff Lounge Lims Reference ID: AD19627-43 Matrix: Drinking Water Sampled: 05/03/25 08:15:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:01	05/20/25 11:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 44 Lunch Room/2nd Floor Staff Lounge Lims Reference ID: AD19627-44 Matrix: Drinking Water Sampled: 05/03/25 08:15:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:01	05/20/25 11:50	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519627
LIMS Reference ID: AD19627
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Bright Beginnings Learning Center

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/05/2025 09:00
Reported: 05/21/2025 16:28

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519627
LIMS Reference ID: AD19627
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Bright Beginnings Learning Center

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/05/2025 09:00
Reported: 05/21/2025 16:28

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: EnvChemistry2@EMSL.com

AD19627

Customer Information	Customer ID:				Billing Information				Billing ID:						
	Company Name: TTI Environmental, Inc								Company Name: Same						
	Contact Name: Tim Popp								Billing Contact: Jean Smith						
	Street Address: 1253 N Church St								Street Address:						
	City, State, Zip: Moorestown, NJ 08054 Country: US								City, State, Zip: Country:						
Phone: 856-840-8800				Phone:				Email(s) for Invoice: jeans@ttienv.com							
Email(s) for Report: timp@ttienv.com															
Project Name/No: 25-190 Bright Beginnings Learning Center												Purchase Order: 041272			
EMSL LIMS Project ID: (If applicable, EMSL will provide)						US State where samples collected:		State of Connecticut (CT) must select project location: ☐ Commercial (Taxable) ☐ Residential (Non-Taxable)							
Samples for Compliance? ☒ Yes ☐ No If Yes, for NPDES? ☐ Yes ☒ No Other (Specify)						PWS ID:		State Reporting Required? ☐ Yes ☐ No							
Samples Collected by (Check One): ☐ EMSL ☒ CLIENT						Samples Received Chilled? ☐ Yes ☐ No		Sample(s) Temperature Upon Receipt (LAB ONLY)							
Sampled By Name: Miguel Perra						Sampled By Signature: Miguel Perra				No. of Samples in Shipment: 344					
Turn-Around-Time (TAT) Standard Turn-Around-Time: ☒ 2 Weeks						The following TAT's are subject to Lab approval. Call lab to confirm TAT before submittal: ☐ 1 Week ☐ 4 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day									
Client Sample ID	Comp	Grab	Date / Time Collected	Matrix	Preservative	List Test(s) Needed (Write in test below, then check on sample line:)								Comments	
				DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	1 HCL 2 HNO3 3 H2SO4 4 ICE 5 Other Describe below in Special Instructions	Test 1: Lead	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
See attached		☒		W	None	☒									
Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.) HNO3 added at 2:30pm on 5/5/25 PG															
Reporting Requirements: ☒ Results Only ☐ Results and QC ☐ Reduced Deliverables ☐ Hzresults EDD ☒ Excel ☐ Other (Describe Above)															
Method of Shipment:						Sample Condition Upon Receipt:				Received on Ice? ☐ Check if Yes:					
Relinquished by:						Date/Time:				Received by: Monnelly (WI)				Date/Time: 5/05/25 0900	
Relinquished by: Miguel Perra						Date/Time: 05/03/25				Received by:				Date/Time:	

Controlled Document - COC-07 Chemistry R13 05/31/2024

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD19627

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey			FACILITY: Bright Beginnings Learning Center			
PO #: 041272		SAMPLER(S): <i>Miguel Jena</i>		DATE: <i>05/03/25</i>		ADDRESS: 1660 Stelton Rd., Piscataway, NJ 08854		
Sample ID		Location/Description		Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...
1.	Classroom	B4		<i>7:30</i>	Initial	Sink	250mL	
2.	Bathroom	B4		<i>7:31</i>	Initial	Sink	250mL	
3.	Classroom	B3		<i>7:32</i>	Initial	Sink	250mL	
4.	Bathroom	B3		<i>7:32</i>	Initial	Sink	250mL	
5.	Classroom	B2		<i>7:33</i>	Initial	Sink	250mL	
6.	Bathroom	B2		<i>7:33</i>	Initial	Sink	250mL	
7.	Classroom	B1		<i>7:34</i>	Initial	Sink	250mL	
8.	Bathroom	B1		<i>7:34</i>	Initial	Sink	250mL	
9.	Water Cooler	West Wing Hall		<i>7:36</i>	Initial	Water Cooler	250mL	
10.	Water Cooler	West Wing Hall		<i>7:36</i>	Initial	Water Cooler	250mL	
11.	Classroom	A4		<i>7:38</i>	Initial	Sink	250mL	
12.	Bathroom	A4		<i>7:38</i>	Initial	Sink	250mL	
13.	Classroom	A3		<i>7:40</i>	Initial	Sink	250mL	
14.	Bathroom	A3		<i>7:40</i>	Initial	Sink	250mL	
15.	Classroom	A2		<i>7:41</i>	Initial	Sink	250mL	
16.	Bathroom	A2		<i>7:41</i>	Initial	Sink	250mL	
17.	Classroom	A1		<i>7:42</i>	Initial	Sink	250mL	
18.	Bathroom	A1		<i>7:42</i>	Initial	Sink	250mL	
19.	Bathroom	Nurse's Office		<i>7:45</i>	Initial	Sink	250mL	



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD19627

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey			FACILITY: Bright Beginnings Learning Center		
PO #: 041272		SAMPLER(S): <i>Miguel ferna</i>		DATE: <i>05/03/25</i>		ADDRESS: 1660 Stelton Rd., Piscataway, NJ 08854	
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...	
20.	Office	Nurse's Office	<i>7:45</i>	Initial	Sink	250mL	
21.	Water Cooler	Main Hall	<i>7:47</i>	Initial	Water Cooler	250mL	
22.	Water Cooler	Main Hall	<i>7:47</i>	Initial	Water Cooler	250mL	
23.	Classroom	C4	<i>7:50</i>	Initial	Sink	250mL	
24.	Bathroom	C4	<i>7:50</i>	Initial	Sink	250mL	
25.	Classroom	C3	<i>7:51</i>	Initial	Sink	250mL	
26.	Bathroom	C3	<i>7:51</i>	Initial	Sink	250mL	
27.	Classroom	C2	<i>7:52</i>	Initial	Sink	250mL	
28.	Bathroom	C2	<i>7:52</i>	Initial	Sink	250mL	
29.	Classroom	C1	<i>7:53</i>	Initial	Sink	250mL	
30.	Bathroom	C1	<i>7:53</i>	Initial	Sink	250mL	
31.	Classroom	D4	<i>7:56</i>	Initial	Sink	250mL	
32.	Bathroom	D4	<i>7:56</i>	Initial	Sink	250mL	
33.	Classroom	D3	<i>7:58</i>	Initial	Sink	250mL	
34.	Bathroom	D3	<i>7:58</i>	Initial	Sink	250mL	
35.	Classroom	D2	<i>8:00</i>	Initial	Sink	250mL	
36.	Bathroom	D2	<i>8:01</i>	Initial	Sink	250mL	
37.	Classroom	D1	<i>8:02</i>	Initial	Sink	250mL	
38.	Bathroom	D1	<i>8:03</i>	Initial	Sink	250mL	



AD19627

[illegible]

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 5-Sink/Cafeteria - Sink									
Lims Reference ID:				AD21117-01	Matrix: Drinking Water				Sampled: 05/10/25 09:30:00
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 19:51	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 6-Sink/Kitchen - Sink									
Lims Reference ID:				AD21117-02	Matrix: Drinking Water				Sampled: 05/10/25 09:31:00
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 19:57	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 7-Sink/Kitchen - Sink									
Lims Reference ID:				AD21117-03	Matrix: Drinking Water				Sampled: 05/10/25 09:32:00
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:00	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 8-Sink/OT/PT 114 - Sink									
Lims Reference ID:				AD21117-04	Matrix: Drinking Water				Sampled: 05/10/25 09:35:00
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:02	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 11-Sink/C10 Cl/Rm - Sink									
Lims Reference ID:				AD21117-05	Matrix: Drinking Water				Sampled: 05/10/25 09:37:00
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:04	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 12-Sink/C10 Bath Rm - Sink									
Lims Reference ID:				AD21117-06	Matrix: Drinking Water				Sampled: 05/10/25 09:38:00
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:11	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 13-Sink/C20 Cl/Rm - Sink									
Lims Reference ID:				AD21117-07	Matrix: Drinking Water				Sampled: 05/10/25 09:41:00
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:14	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 14-Sink/C20 Bath Rm - Sink									
Lims Reference ID:				AD21117-08	Matrix: Drinking Water				Sampled: 05/10/25 09:42:00
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:16	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 15-Sink/C30 Cl/Rm - Sink									
Lims Reference ID:				AD21117-09	Matrix: Drinking Water				Sampled: 05/10/25 09:44:00
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:18	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 16-Sink/C30 Bath Rm - Sink Lims Reference ID: AD21117-10 Matrix: Drinking Water Sampled: 05/10/25 09:45:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:20	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 17-Sink/C40 Cl/Rm - Sink Lims Reference ID: AD21117-11 Matrix: Drinking Water Sampled: 05/10/25 09:47:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:34	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 18-Sink/C40 Bath Rm - Sink Lims Reference ID: AD21117-12 Matrix: Drinking Water Sampled: 05/10/25 09:48:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:41	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 19-Sink/C50 Cl/Rm - Sink Lims Reference ID: AD21117-13 Matrix: Drinking Water Sampled: 05/10/25 09:50:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:43	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 20-Sink/C50 Bath Rm - Sink Lims Reference ID: AD21117-14 Matrix: Drinking Water Sampled: 05/10/25 09:50:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:50	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 21-Sink/C60 Cl/Rm - Sink Lims Reference ID: AD21117-15 Matrix: Drinking Water Sampled: 05/10/25 09:52:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:52	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 22-Sink/C60 Bath Rm - Sink Lims Reference ID: AD21117-16 Matrix: Drinking Water Sampled: 05/10/25 09:52:00									
Metals									
Lead	2.55		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:55	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 25-Sink/D10 Cl/Rm - Sink Lims Reference ID: AD21117-17 Matrix: Drinking Water Sampled: 05/10/25 09:54:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:57	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 26-Sink/D10 Bath Rm - Sink Lims Reference ID: AD21117-18 Matrix: Drinking Water Sampled: 05/10/25 09:54:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:59	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 27-Sink/D20 CI/Rm - Sink Lims Reference ID: AD21117-19 Matrix: Drinking Water Sampled: 05/10/25 09:56:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 21:01	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 28-Sink/D20 Bath Rm - Sink Lims Reference ID: AD21117-20 Matrix: Drinking Water Sampled: 05/10/25 09:56:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 21:04	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 29-Sink/D30 CI/Rm - Sink Lims Reference ID: AD21117-21 Matrix: Drinking Water Sampled: 05/10/25 09:58:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:24	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 30-Sink/D30 Bath Rm - Sink Lims Reference ID: AD21117-22 Matrix: Drinking Water Sampled: 05/10/25 09:58:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:31	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 31-Sink/D40 CI/Rm - Sink Lims Reference ID: AD21117-23 Matrix: Drinking Water Sampled: 05/10/25 10:00:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:34	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 32-Sink/D40 Bath Rm - Sink Lims Reference ID: AD21117-24 Matrix: Drinking Water Sampled: 05/10/25 10:01:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:36	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 33-Sink/D50 CI/Rm - Sink Lims Reference ID: AD21117-25 Matrix: Drinking Water Sampled: 05/10/25 10:03:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:38	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 34-Sink/D50 Bath Rm - Sink Lims Reference ID: AD21117-26 Matrix: Drinking Water Sampled: 05/10/25 10:04:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:45	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 35-Sink/D60 CI/Rm - Sink Lims Reference ID: AD21117-27 Matrix: Drinking Water Sampled: 05/10/25 10:06:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:47	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 36-Sink/D60 Bath Rm - Sink Lims Reference ID: AD21117-28 Matrix: Drinking Water Sampled: 05/10/25 10:07:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:50	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 37-Sink/Nurse - Sink Lims Reference ID: AD21117-29 Matrix: Drinking Water Sampled: 05/10/25 10:10:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:52	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 38-Sink/A10 Cl/Rm - Sink Lims Reference ID: AD21117-30 Matrix: Drinking Water Sampled: 05/10/25 10:12:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:54	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 39-Sink/A10 Bath Rm - Sink Lims Reference ID: AD21117-31 Matrix: Drinking Water Sampled: 05/10/25 10:14:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:56	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 40-Sink/A20 Cl/Rm - Sink Lims Reference ID: AD21117-32 Matrix: Drinking Water Sampled: 05/10/25 10:16:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:03	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 41-Sink/A20 Bath Rm - Sink Lims Reference ID: AD21117-33 Matrix: Drinking Water Sampled: 05/10/25 10:17:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:06	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 42-Sink/A30 Cl/Rm - Sink Lims Reference ID: AD21117-34 Matrix: Drinking Water Sampled: 05/10/25 10:19:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:12	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 43-Sink/A30 Bath Rm - Sink Lims Reference ID: AD21117-35 Matrix: Drinking Water Sampled: 05/10/25 10:20:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:15	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 44-Sink/A40 Cl/Rm - Sink Lims Reference ID: AD21117-36 Matrix: Drinking Water Sampled: 05/10/25 10:22:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:17	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 45-Sink/A40 Bath Rm - Sink Lims Reference ID: AD21117-37 Matrix: Drinking Water Sampled: 05/10/25 10:23:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:19	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 46-Sink/A50 Cl/Rm - Sink Lims Reference ID: AD21117-38 Matrix: Drinking Water Sampled: 05/10/25 10:25:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:22	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 47-Sink/A50 Bath Rm - Sink Lims Reference ID: AD21117-39 Matrix: Drinking Water Sampled: 05/10/25 10:26:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:24	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 48-Sink/A60 Cl/Rm - Sink Lims Reference ID: AD21117-40 Matrix: Drinking Water Sampled: 05/10/25 10:28:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:26	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 49-Sink/A60 Bath Rm - Sink Lims Reference ID: AD21117-41 Matrix: Drinking Water Sampled: 05/10/25 10:29:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:19	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 52-Sink/OT/PTE116 - Sink Lims Reference ID: AD21117-42 Matrix: Drinking Water Sampled: 05/10/25 10:34:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:24	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 55-Sink/Daily Living E122 - Sink Lims Reference ID: AD21117-43 Matrix: Drinking Water Sampled: 05/10/25 10:38:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:26	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 56-Sink/Daily Living E122 - Sink Lims Reference ID: AD21117-44 Matrix: Drinking Water Sampled: 05/10/25 10:39:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:28	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 57-Sink/B10 Cl/Rm - Sink Lims Reference ID: AD21117-45 Matrix: Drinking Water Sampled: 05/10/25 10:42:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:30	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 58-Sink/B10 Bath Rm - Sink Lims Reference ID: AD21117-46 Matrix: Drinking Water Sampled: 05/10/25 10:43:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:36	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 59-Sink/B20 Cl/Rm - Sink Lims Reference ID: AD21117-47 Matrix: Drinking Water Sampled: 05/10/25 10:46:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:13	05/22/25 16:46	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: 60-Sink/B20 Bath Rm - Sink Lims Reference ID: AD21117-48 Matrix: Drinking Water Sampled: 05/10/25 10:47:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:38	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 61-Sink/B30 Cl/Rm - Sink Lims Reference ID: AD21117-49 Matrix: Drinking Water Sampled: 05/10/25 10:50:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:40	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 62-Sink/B30 Bath Rm - Sink Lims Reference ID: AD21117-50 Matrix: Drinking Water Sampled: 05/10/25 10:52:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:42	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 63-Sink/B40 Cl/Rm - Sink Lims Reference ID: AD21117-51 Matrix: Drinking Water Sampled: 05/10/25 10:54:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:44	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 64-Sink/B40 Bath Rm - Sink Lims Reference ID: AD21117-52 Matrix: Drinking Water Sampled: 05/10/25 10:54:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:46	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 65-Sink/B50 Cl/Rm - Sink Lims Reference ID: AD21117-53 Matrix: Drinking Water Sampled: 05/10/25 10:56:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:51	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 66-Sink/B50 Bath Rm - Sink Lims Reference ID: AD21117-54 Matrix: Drinking Water Sampled: 05/10/25 10:56:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:53	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 67-Sink/B60 Cl/Rm - Sink Lims Reference ID: AD21117-55 Matrix: Drinking Water Sampled: 05/10/25 10:58:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:59	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 68-Sink/B60 Bath Rm - Sink Lims Reference ID: AD21117-56 Matrix: Drinking Water Sampled: 05/10/25 10:58:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 15:01	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: EnvChemistry2@EMSL.com

AD2117

Customer Information	Customer ID:			Billing Information	Billing ID:		
	Company Name:	TTI Environmental, Inc			Company Name:	Same	
	Contact Name:	Tim Popp			Billing Contact:	Jean Smith	
	Street Address:	1253 N Church St			Street Address:		
	City, State, Zip:	Moorestown, NJ 08054	Country:		US	City, State, Zip:	
Phone:	856-840-8800		Phone:				
Email(s) for Report:	timp@ttienv.com		Email(s) for Invoice:	jeans@ttienv.com			

Project Name/No: **25-190 Center For Lifelong Learning** Purchase Order: **041272**

EMSL LIMS Project ID: (If applicable, EMSL will provide) US State where samples collected: State of Connecticut (CT) must select project location:

Samples for Compliance? ☒ Yes ☐ No If Yes, for NPDES? ☐ Yes ☒ No Other (Specify) PWS ID: State Reporting Required? ☐ Yes ☐ No

Samples Collected by (Check One): ☐ EMSL ☒ CLIENT Samples Received Chilled? ☐ Yes ☐ No Sample(s) Temperature Upon Receipt (LAB ONLY)

Sampled By Name: *Miguel Lopez* Sampled By Signature: *Miguel Lopez* No. of Samples in Shipment: **56**

Turn-Around-Time (TAT) Standard Turn-Around-Time: ☒ 2 Weeks The following TAT's are subject to Lab approval. Call lab to confirm TAT before submit: ☐ 1 Week ☐ 4 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	Preservative 1 HCL 2 HNO3 3 H2SO4 4 ICE 5 Other Describe below in Special Instructions	List Test(s) Needed (Write in test below, then check on sample line:)								Comments	
						Test 1: Lead	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
See attached		☒		W	None	☒									

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Reporting Requirements: ☒ Results Only ☐ Results and QC ☐ Reduced Deliverables ☐ Hzresults EDD ☒ Excel ☐ Other (Describe Above)

Method of Shipment: Sample Condition Upon Receipt: Received on Ice? Check if Yes: ☐

Relinquished by: *Miguel Lopez* Date/Time: *05/10/25* Received by: *WJ* Date/Time: *5/10/25 150*

Relinquished by: *Miguel Lopez* Date/Time: *05/10/25* Received by: *WJ* Date/Time: *5/12/25 0900*

Controlled Document - CDC-07 Chemistry R13 05/31/2024

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by *WJ* *5/12/25* *SGM*

Page 1 of 2



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD21117

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey		FACILITY: Center For Lifelong Learning		
PO #: 041272		SAMPLER(S): <i>Miguel fern</i>		DATE: <i>05/10/25</i>		ADDRESS: 333 Cheesequake Road, Parlin, NJ 08859
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...
-1.	Water Cooler	Aquatic Center Pool	Initial	Water Cooler	250mL	Temp closed
2.	Water Cooler	Aquatic Center Pool	Initial	Water Cooler	250mL	↓
3.	Water Cooler	Locker Room Hall	Initial	Water Cooler	250mL	Temp closed
4.	Water Cooler	Locker Room Hall	Initial	Water Cooler	250mL	↓
5.	Sink	Cafeteria	9:30	Sink	250mL	
6.	Sink	Kitchen	9:31	Sink	250mL	
7.	Sink	Kitchen	9:32	Sink	250mL	
8.	Sink	OT/PT 114	9:35	Sink	250mL	
9.	Water Cooler	Red Hall	Initial	Water Cooler	250mL	↑
10.	Water Cooler	Red Hall	Initial	Water Cooler	250mL	Temp closed
11.	Sink	C10 CI/Rm	9:37	Sink	250mL	
12.	Sink	C10 Bath Rm	9:38	Sink	250mL	
13.	Sink	C20 CI/Rm	9:41	Sink	250mL	
14.	Sink	C20 Bath Rm	9:42	Sink	250mL	
15.	Sink	C30 CI/Rm	9:44	Sink	250mL	
16.	Sink	C30 Bath Rm	9:45	Sink	250mL	
17.	Sink	C40 CI/Rm	9:47	Sink	250mL	
18.	Sink	C40 Bath Rm	9:48	Sink	250mL	
19.	Sink	C50 CI/Rm	9:50	Sink	250mL	



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD2117

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey		FACILITY: Center For Lifelong Learning			
PO #: 041272		SAMPLER(S): <i>Miguel Jarama</i>		DATE: <i>05/10/25</i>		ADDRESS: 333 Cheesequake Road, Parlin, NJ 08859	
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...	
14 20.	Sink	C50 Bath Rm	<i>9:50</i>	Initial	Sink	250mL	
15 21.	Sink	C60 CI/Rm	<i>9:52</i>	Initial	Sink	250mL	
16 22.	Sink	C60 Bath Rm	<i>9:52</i>	Initial	Sink	250mL	
23.	Water Cooler	Orange Hall		Initial	Water Cooler	250mL	<i>Temp closed</i>
24.	Water Cooler	Orange Hall		Initial	Water Cooler	250mL	<i>↓</i>
17 25.	Sink	D10 CI/Rm	<i>9:54</i>	Initial	Sink	250mL	
18 26.	Sink	D10 Bath Rm	<i>9:54</i>	Initial	Sink	250mL	
19 27.	Sink	D20 CI/Rm	<i>9:56</i>	Initial	Sink	250mL	
20 28.	Sink	D20 Bath Rm	<i>9:56</i>	Initial	Sink	250mL	
21 29.	Sink	D30 CI/Rm	<i>9:58</i>	Initial	Sink	250mL	
22 30.	Sink	D30 Bath Rm	<i>9:58</i>	Initial	Sink	250mL	
23 31.	Sink	D40 CI/Rm	<i>10:00</i>	Initial	Sink	250mL	
24 32.	Sink	D40 Bath Rm	<i>10:01</i>	Initial	Sink	250mL	
25 33.	Sink	D50 CI/Rm	<i>10:03</i>	Initial	Sink	250mL	
26 34.	Sink	D50 Bath Rm	<i>10:04</i>	Initial	Sink	250mL	
27 35.	Sink	D60 CI/Rm	<i>10:06</i>	Initial	Sink	250mL	
28 36.	Sink	D60 Bath Rm	<i>10:07</i>	Initial	Sink	250mL	
29 37.	Sink	Nurse	<i>10:10</i>	Initial	Sink	250mL	
30 38.	Sink	A10 CI/Rm	<i>10:12</i>	Initial	Sink	250mL	



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD21117

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey		FACILITY: Center For Lifelong Learning			
PO #: 041272		SAMPLER(S): <i>Miguel Jara</i>		DATE: <i>05/10/25</i>		ADDRESS: 333 Cheesequake Road, Parlin, NJ 08859	
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...	
31 39.	Sink	A10 Bath Rm	<i>10:14</i>	Initial	Sink	250mL	
32 40.	Sink	A20 Cl/Rm	<i>10:16</i>	Initial	Sink	250mL	
33 41.	Sink	A20 Bath Rm	<i>10:17</i>	Initial	Sink	250mL	
34 42.	Sink	A30 Cl/Rm	<i>10:19</i>	Initial	Sink	250mL	
35 43.	Sink	A30 Bath Rm	<i>10:20</i>	Initial	Sink	250mL	
36 44.	Sink	A40 Cl/Rm	<i>10:22</i>	Initial	Sink	250mL	
37 45.	Sink	A40 Bath Rm	<i>10:23</i>	Initial	Sink	250mL	
38 46.	Sink	A50 Cl/Rm	<i>10:25</i>	Initial	Sink	250mL	
39 47.	Sink	A50 Bath Rm	<i>10:26</i>	Initial	Sink	250mL	
40 48.	Sink	A60 Cl/Rm	<i>10:28</i>	Initial	Sink	250mL	
41 49.	Sink	A60 Bath Rm	<i>10:29</i>	Initial	Sink	250mL	
50.	Water Cooler	Green Main Hall		Initial	Water Cooler	250mL	<i>Temp Closed</i>
51.	Water Cooler	Green Main Hall		Initial	Water Cooler	250mL	<i>↓</i>
42 52.	Sink	OT/PTE116	<i>10:34</i>	Initial	Sink	250mL	
53.	Water Cooler	Blue Main Hall		Initial	Water Cooler	250mL	<i>Temp Closed</i>
54.	Water Cooler	Blue Main Hall		Initial	Water Cooler	250mL	<i>↓</i>
43 55.	Sink	Daily Living E122	<i>10:38</i>	Initial	Sink	250mL	
44 56.	Sink	Daily Living E122	<i>10:39</i>	Initial	Sink	250mL	
45 57.	Sink	B10 Cl/Rm	<i>10:42</i>	Initial	Sink	250mL	



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD21117

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey		FACILITY: Center For Lifelong Learning		
PO #: 041272		SAMPLER(S): <i>Miguel Lopez</i>		DATE: <i>05/10/25</i> ADDRESS: 333 Cheesequake Road, Parlin, NJ 08859		
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...
46 58.	Sink	B10 Bath Rm	10:43 Initial	Sink	250mL	
47 59.	Sink	B20 Cl/Rm	10:46 Initial	Sink	250mL	
48 60.	Sink	B20 Bath Rm	10:47 Initial	Sink	250mL	
49 61.	Sink	B30 Cl/Rm	10:50 Initial	Sink	250mL	
50 62.	Sink	B30 Bath Rm	10:52 Initial	Sink	250mL	
51 63.	Sink	B40 Cl/Rm	10:54 Initial	Sink	250mL	
52 64.	Sink	B40 Bath Rm	10:54 Initial	Sink	250mL	
53 65.	Sink	B50 Cl/Rm	10:56 Initial	Sink	250mL	
54 66.	Sink	B50 Bath Rm	10:56 Initial	Sink	250mL	
55 67.	Sink	B60 Cl/Rm	10:58 Initial	Sink	250mL	
56 68.	Sink	B60 Bath Rm	10:58 Initial	Sink	250mL	
69.					250mL	
70.					250mL	
71.					250mL	
72.					250mL	
73.					250mL	
74.					250mL	
75.					250mL	

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520579
LIMS Reference ID: AD20579
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Nuview Academy

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 09:00
Reported: 05/27/2025 17:38

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: Lower Kitchen/Kitchen-Coffee Maker Lims Reference ID: AD20579-01 Matrix: Drinking Water Sampled: 05/10/25 08:30:00									
Metals									
Lead	2.59		1	1.00	µg/L	05/22/25 09:44	05/23/25 13:23	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: Lower Kitchen/Kitchen-Sink Lims Reference ID: AD20579-02 Matrix: Drinking Water Sampled: 05/10/25 08:31:00									
Metals									
Lead	4.86		1	1.00	µg/L	05/22/25 09:44	05/23/25 13:25	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: Lower Kitchen/Kitchen-Sink Lims Reference ID: AD20579-03 Matrix: Drinking Water Sampled: 05/10/25 08:32:00									
Metals									
Lead	9.57		1	1.00	µg/L	05/22/25 09:44	05/23/25 13:27	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: Lower Kitchen/Kitchen-Sink Lims Reference ID: AD20579-04 Matrix: Drinking Water Sampled: 05/10/25 08:33:00									
Metals									
Lead	7.28		1	1.00	µg/L	05/22/25 09:44	05/23/25 13:33	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: Outside Gym/1st Floor-Water Cooler-Left Side Lims Reference ID: AD20579-05 Matrix: Drinking Water Sampled: 05/10/25 08:36:00									
Metals									
Lead	ND		1	1.00	µg/L	05/22/25 09:44	05/23/25 13:35	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: Outside Gym/1st Floor-Water Cooler-Right Side Lims Reference ID: AD20579-06 Matrix: Drinking Water Sampled: 05/10/25 08:37:00									
Metals									
Lead	ND		1	1.00	µg/L	05/22/25 09:44	05/23/25 13:37	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 1st Floor/Nurse's Office-Sink Lims Reference ID: AD20579-07 Matrix: Drinking Water Sampled: 05/10/25 08:39:00									
Metals									
Lead	1.12		1	1.00	µg/L	05/22/25 09:44	05/23/25 13:38	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 2nd Floor/Faculty Room-Sink Lims Reference ID: AD20579-08 Matrix: Drinking Water Sampled: 05/10/25 08:42:00									
Metals									
Lead	ND		1	1.00	µg/L	05/22/25 09:44	05/23/25 13:40	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 2nd Floor/Outside Counselor-Water Cooler-Low Flow Lims Reference ID: AD20579-09 Matrix: Drinking Water Sampled: 05/10/25 08:45:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520579
LIMS Reference ID: AD20579
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Nuview Academy

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 09:00
Reported: 05/27/2025 17:38

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 2nd Floor/Outside Counselor-Water Cooler-Low Flow (Continued) Lims Reference ID: AD20579-09 Matrix: Drinking Water Sampled: 05/10/25 08:45:00									
Metals (Continued)									
Lead	ND		1	1.00	µg/L	05/22/25 09:44	05/23/25 13:42	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 2nd Floor/Outside Counselor-Water Cooler-Low Flow Lims Reference ID: AD20579-10 Matrix: Drinking Water Sampled: 05/10/25 08:44:00									
Metals									
Lead	ND		1	1.00	µg/L	05/22/25 09:44	05/23/25 13:48	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 2nd Floor/Room 201-Sink Lims Reference ID: AD20579-11 Matrix: Drinking Water Sampled: 05/10/25 08:50:00									
Metals									
Lead	15.4	D	5	5.00	µg/L	05/22/25 09:33	05/23/25 17:45	JW1	EPA 200.8 (Dig)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520579
LIMS Reference ID: AD20579
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Nuview Academy

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 09:00
Reported: 05/27/2025 17:38

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520579
LIMS Reference ID: AD20579
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Nuview Academy

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 09:00
Reported: 05/27/2025 17:38

Notes and Definitions

Item	Definition
D	Analyte was reported from a dilution run.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: EnvChemistry2@EMSL.com

AD 20579

Customer Information	Customer ID:				Billing Information	Billing ID:											
	Company Name: TTI Environmental, Inc					Company Name: Same											
	Contact Name: Tim Popp					Billing Contact: Jean Smith											
	Street Address: 1253 N Church St					Street Address:											
	City, State, Zip: Moorestown, NJ 08054		Country: US			City, State, Zip:		Country:									
	Phone: 856-840-8800					Phone:											
Email(s) for Report: timp@ttienv.com				Email(s) for Invoice: jeans@ttienv.com													
Project Name/No: 25-190 Nuview Academy Purchase Order: 041272																	
EMSL LIMS Project ID: (If applicable, EMSL will provide)					US State where samples collected:		State of Connecticut (CT) must select project location: ☐ Commercial (Taxable) ☐ Residential (Non-Taxable)										
Samples for Compliance? ☒ Yes ☐ No If Yes, for NPDES? ☐ Yes ☒ No Other (Specify)					PWS ID:		State Reporting Required? ☐ Yes ☐ No										
Samples Collected by (Check One): ☐ EMSL ☒ CLIENT Samples Received Chilled? ☐ Yes ☐ No					Sample(s) Temperature Upon Receipt (LAB ONLY)												
Sampled By Name: <i>Michael Popp</i>				Sampled By Signature: <i>Michael Popp</i>				No. of Samples in Shipment: 11									
Turn-Around-Time (TAT) Standard Turn-Around-Time: ☒ 2 Weeks The following TAT's are subject to Lab approval. Call lab to confirm TAT before submittal: <table style="display: inline-table; border: none;"> <tr> <td>☐ 1 Week</td> <td>☐ 4 Days</td> <td>☐ 3 Days</td> <td>☐ 2 Days</td> <td>☐ 1 Day</td> </tr> </table>										☐ 1 Week	☐ 4 Days	☐ 3 Days	☐ 2 Days	☐ 1 Day			
☐ 1 Week	☐ 4 Days	☐ 3 Days	☐ 2 Days	☐ 1 Day													
Client Sample ID	Comp	Grab	Date / Time Collected	Matrix	Preservative	List Test(s) Needed (Write in test below, then check on sample line:)								Comments			
				DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	1 HCL 2 HNO3 3 H2SO4 4 ICE 5 Other <i>Describe below in Special Instructions</i>	Test 1:	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:				
See attached		☒		W	None	☒											
Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)																	
HNO3 added @ 1:39pm on 5/12/25 PG																	
Reporting Requirements:				☒ Results Only	☐ Results and QC	☐ Reduced Deliverables	☐ Hzresults EDD	☒ Excel	☐ Other (Describe Above)								
Method of Shipment:						Sample Condition Upon Receipt:						Received on Ice? ☐ Check if Yes:					
Relinquished by: <i>Michael Popp</i>				Date/Time: 05/10/25		Received by: <i>WJ</i>				Date/Time: 5/10/25 1:50							
Relinquished by:				Date/Time:		Received by: <i>Annunzio (WJ)</i>				Date/Time: 6/12/25 0900							

Controlled Document - COC-07 Chemistry R13 05/31/2024

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

Page 5 of 6



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD 20579

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey			FACILITY: Nuview Academy		
PO #: 041272		SAMPLER(S): Miguel Lema		DATE: 05/10/25		ADDRESS: 1 Park Avenue, Piscataway, NJ 08854	
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...	
1	Lower Kitchen	Kitchen	8:30	Initial	Coffee Maker	250mL	
2	Lower Kitchen	Kitchen	8:31	Initial	Sink	250mL	
3	Lower Kitchen	Kitchen	8:32	Initial	Sink	250mL	
4	Lower Kitchen	Kitchen	8:33	Initial	Sink	250mL	
5	Outside Gym	1st Floor	8:36	Initial	Water Cooler	250mL	Left side
6	Outside Gym	1st Floor	8:37	Initial	Water Cooler	250mL	Right side
7	1st Floor	Nurse's Office	8:39	Initial	Sink	250mL	
8	2nd Floor	Faculty Room	8:42	Initial	Sink	250mL	
9	2nd Floor	Outside Counselor	8:45	Initial	Water Cooler	250mL	Low flow
10	2nd Floor	Outside Counselor	8:44	Initial	Water Cooler	250mL	Low flow
11	2nd Floor	Room 201	8:50	Initial	Sink	250mL	
						250mL	
						250mL	
						250mL	
						250mL	
						250mL	
						250mL	
						250mL	

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519753
LIMS Reference ID: AD19753
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Nuview Academy Annex

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/05/2025 09:00
Reported: 06/02/2025 14:56

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 1-Sink/Kitchen Lims Reference ID: AD19753-01 Matrix: Drinking Water Sampled: 05/03/25 06:42:00									
Metals									
Lead	89.9	D	2	2.00	µg/L	05/16/25 17:25	05/21/25 07:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 2-Sink/Kitchen Lims Reference ID: AD19753-02 Matrix: Drinking Water Sampled: 05/03/25 06:43:00									
Metals									
Lead	ND		1	1.00	µg/L	05/16/25 17:25	05/20/25 19:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 3-Sink/Kitchen Lims Reference ID: AD19753-03 Matrix: Drinking Water Sampled: 05/03/25 06:43:00									
Metals									
Lead	34.3		1	1.00	µg/L	05/16/25 17:25	05/20/25 19:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 4-Sink/Kitchen Lims Reference ID: AD19753-04 Matrix: Drinking Water Sampled: 05/03/25 06:44:00									
Metals									
Lead	1.41		1	1.00	µg/L	05/16/25 17:25	05/20/25 19:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 5-Sink/Kitchen Lims Reference ID: AD19753-05 Matrix: Drinking Water Sampled: 05/03/25 06:44:00									
Metals									
Lead	3.19		1	1.00	µg/L	05/16/25 17:25	05/20/25 19:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 6-Sink/Faculty Lounge Lims Reference ID: AD19753-06 Matrix: Drinking Water Sampled: 05/03/25 06:46:00									
Metals									
Lead	7.81		1	1.00	µg/L	05/16/25 17:25	05/20/25 19:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 7- Water Fountain/Main Hall Cafe Lims Reference ID: AD19753-07 Matrix: Drinking Water Sampled: 05/03/25 06:47:00									
Metals									
Lead	ND		1	1.00	µg/L	05/16/25 17:25	05/20/25 19:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 10- Water Fountain/Gym Lims Reference ID: AD19753-08 Matrix: Drinking Water Sampled: 05/03/25 06:50:00									
Metals									
Lead	ND		1	1.00	µg/L	05/16/25 17:25	05/20/25 19:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 11- Water Fountain/A-Wing Lims Reference ID: AD19753-09 Matrix: Drinking Water Sampled: 05/03/25 06:52:00									
Metals									
Lead	ND		1	1.00	µg/L	05/16/25 17:25	05/20/25 19:22	PL	EPA 200.8 (DA)/EPA 200.8

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Nuview Academy Annex

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/05/2025 09:00
Reported: 06/02/2025 14:56

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 12- Water Fountain/A-Wing	Lims Reference ID:			AD19753-10	Matrix: Drinking Water			Sampled: 05/03/25 06:53:00	
Metals									
Lead	ND	1	1.00	µg/L	05/16/25 17:25	05/20/25 19:24	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: 15-Sink/Principal Bathroom	Lims Reference ID:			AD19753-11	Matrix: Drinking Water			Sampled: 05/03/25 06:56:00	
Metals									
Lead	7.11	1	1.00	µg/L	05/16/25 17:25	05/20/25 19:26	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: 16-Sink/Nurse's Office	Lims Reference ID:			AD19753-12	Matrix: Drinking Water			Sampled: 05/03/25 06:58:00	
Metals									
Lead	2.66	1	1.00	µg/L	05/16/25 17:25	05/20/25 19:31	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: 17-Sink/Nurse's Office	Lims Reference ID:			AD19753-13	Matrix: Drinking Water			Sampled: 05/03/25 06:58:00	
Metals									
Lead	3.29	1	1.00	µg/L	05/16/25 17:25	05/20/25 19:33	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: 18-Water Fountain/B Wing	Lims Reference ID:			AD19753-14	Matrix: Drinking Water			Sampled: 05/03/25 07:00:00	
Metals									
Lead	ND	1	1.00	µg/L	05/16/25 17:25	05/20/25 19:39	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: 19-Water Fountain/B Wing	Lims Reference ID:			AD19753-15	Matrix: Drinking Water			Sampled: 05/03/25 07:01:00	
Metals									
Lead	ND	1	1.00	µg/L	05/16/25 17:25	05/20/25 19:41	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: 22-Sink/OT/PT Room	Lims Reference ID:			AD19753-16	Matrix: Drinking Water			Sampled: 05/03/25 07:04:00	
Metals									
Lead	25.8	1	1.00	µg/L	05/21/25 10:51	05/22/25 12:43	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: 23-Sink/NonPublic Lounge	Lims Reference ID:			AD19753-17	Matrix: Drinking Water			Sampled: 05/03/25 07:06:00	
Metals									
Lead	ND	1	1.00	µg/L	05/16/25 17:25	05/20/25 19:45	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: 24-Quench Cooler/NonPublic Hall	Lims Reference ID:			AD19753-18	Matrix: Drinking Water			Sampled: 05/03/25 07:07:00	
Metals									
Lead	ND	1	1.00	µg/L	05/16/25 17:25	05/20/25 19:47	PL	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519753
LIMS Reference ID: AD19753
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Nuview Academy Annex

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/05/2025 09:00
Reported: 06/02/2025 14:56

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 25-Sink/C1 Classroom Lims Reference ID: AD19753-19 Matrix: Drinking Water Sampled: 05/03/25 07:09:00									
Metals									
Lead	ND		1	1.00	µg/L	05/16/25 17:25	05/20/25 19:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 26-Sink/C2 Classroom Lims Reference ID: AD19753-20 Matrix: Drinking Water Sampled: 05/03/25 07:10:00									
Metals									
Lead	1.65		1	1.00	µg/L	05/16/25 17:25	05/20/25 19:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 27-Water Fountain/C-Wing Lims Reference ID: AD19753-21 Matrix: Drinking Water Sampled: 05/03/25 07:12:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 13:52	05/20/25 20:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 28-Water Fountain/C-Wing Lims Reference ID: AD19753-22 Matrix: Drinking Water Sampled: 05/03/25 07:13:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 13:52	05/20/25 20:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 29-Sink/C3 Classroom Lims Reference ID: AD19753-23 Matrix: Drinking Water Sampled: 05/03/25 07:15:00									
Metals									
Lead	1.38		1	1.00	µg/L	05/19/25 13:52	05/20/25 20:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 30-Sink/C4 Classroom Lims Reference ID: AD19753-24 Matrix: Drinking Water Sampled: 05/03/25 07:16:00									
Metals									
Lead	1.65		1	1.00	µg/L	05/19/25 13:52	05/20/25 20:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 31-Sink/C5 Classroom Lims Reference ID: AD19753-25 Matrix: Drinking Water Sampled: 05/03/25 07:17:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 13:52	05/20/25 20:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 32-Sink/C6 Classroom Lims Reference ID: AD19753-26 Matrix: Drinking Water Sampled: 05/03/25 07:18:00									
Metals									
Lead	1.04		1	1.00	µg/L	05/19/25 13:52	05/20/25 20:19	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519753
LIMS Reference ID: AD19753
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Nuview Academy Annex

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/05/2025 09:00
Reported: 06/02/2025 14:56

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519753
LIMS Reference ID: AD19753
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Nuview Academy Annex

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/05/2025 09:00
Reported: 06/02/2025 14:56

Notes and Definitions

Item	Definition
D	Analyte was reported from a dilution run.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: EnvChemistry2@EMSL.com

ADP573

Customer Information	Customer ID:	Billing ID:
	Company Name: TTI Environmental, Inc	Company Name: Same
	Contact Name: Tim Popp	Billing Contact: Jean Smith
	Street Address: 1253 N Church St	Street Address:
	City, State, Zip: Moorestown, NJ 08054 Country: US	City, State, Zip: Country:
	Phone: 856-840-8800	Phone:
Email(s) for Report: timp@ttienv.com	Email(s) for Invoice: jeans@ttienv.com	

Project Name/No: 25-190 Nuview Academy Annex	Purchase Order: 041272
EMSL LIMS Project ID: (If applicable, EMSL will provide)	US State where samples collected: State of Connecticut (CT) must select project location: ☐ Commercial (Taxable) ☐ Residential (Non-Taxable)
Samples for Compliance? ☒ Yes ☐ No If Yes, for NPDES? ☐ Yes ☒ No Other (Specify)	PWS ID: State Reporting Required? ☐ Yes ☐ No
Samples Collected by (Check One): ☐ EMSL ☒ CLIENT Samples Received Chilled? ☐ Yes ☐ No	Sample(s) Temperature Upon Receipt (LAB ONLY)
Sampled By Name: Miguel Lopez	Sampled By Signature: Miguel Lopez
Turn-Around-Time (TAT) Standard Turn-Around-Time: ☒ 2 Weeks	No. of Samples in Shipment: 26

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	Preservative 1 HCL 2 HNO3 3 H2SO4 4 ICE 5 Other Describe below in Special Instructions	List Test(s) Needed (Write in test below, then check on sample line:)								Comments	
						Test 1: Lead	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
See attached		☒		W	None	☒									

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.) HNO3 added @ 3:00pm on 5/5/25 PG						
Reporting Requirements:	☒ Results Only	☐ Results and QC	☐ Reduced Deliverables	☐ H2results EDD	☒ Excel	☐ Other (Describe Above)
Method of Shipment:	Sample Condition Upon Receipt:		Received on Ice? ☐			
Relinquished by:	Date/Time:	Received by:	Date/Time:			
Relinquished by: Miguel Lopez	Date/Time: 05/03/25	Received by: [Signature]	Date/Time: 5/05/25 0900			

Controlled Document - CDC-07 Chemistry R13 05/31/2024

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

Page 1 of 2

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD14575

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey		FACILITY: Nuview Academy Annex		
PO #: 041272		SAMPLER(S): <i>Miguel Flores</i>		DATE: <i>05/03/25</i>		
ADDRESS: 1690 Stelton Rd, Piscataway, NJ 08854						
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...
1. Sink	Kitchen	6:42	Initial	Sink	250mL	
2. Sink	Kitchen	6:43	Initial	Sink	250mL	
3. Sink	Kitchen	6:43	Initial	Sink	250mL	
4. Sink	Kitchen	6:44	Initial	Sink	250mL	NVA4
5. Sink	Kitchen	6:44	Initial	Bathroom Sink	250mL	NVA5 / Bathroom
6. Sink	Faculty Lounge	6:46	Initial	Sink	250mL	NVA6 label
7. Water Fountain	Main Hall Café	6:47	Initial	Water Fountain	250mL	Next to D-3
8. Water Fountain	Main Hall Café		Initial	Water Fountain	250mL	Remove
9. Water Fountain	Main Hall Café		Initial	Water Fountain	250mL	Remove
10. Water Fountain	Gym	6:50	Initial	Water Fountain	250mL	
11. Water Fountain	A-Wing	6:52	Initial	Water Fountain	250mL	Next to A-1
12. Water Fountain	A-Wing	6:53	Initial	Water Fountain	250mL	Next to A-2
13. Water Fountain	Main Hall Office		Initial	Water Fountain	250mL	Temp out of spec
14. Water Fountain	Main Hall Office		Initial	Water Fountain	250mL	↓
15. Sink	Principal Bathroom	6:56	Initial	Sink	250mL	
16. Sink	Nurse's Office	6:58	Initial	Sink	250mL	NVA16
17. Sink	Nurse's Office	6:58	Initial	Bathroom Sink	250mL	NVA17
18. Water Fountain	B Wing	7:00	Initial	Water Fountain	250mL	Next to B-1
19. Water Fountain	B Wing	7:01	Initial	Water Fountain	250mL	Next to B-2



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD 19573

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey		FACILITY: Nuvew Academy Annex		
PO #: 041272		SAMPLER(S): Miguel Jena		DATE: 05/03/25		
ADDRESS: 1690 Stelton Rd, Piscataway, NJ 08854						
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...
X 20	Water Fountain		Initial	Water Fountain	250mL	Temp out of sev.
X 21	Water Fountain		Initial	Water Fountain	250mL	↓
16 22	Sink	7:04	Initial	Sink	250mL	NVA 22 / Discolored
17 23	Sink	7:06	Initial	Sink	250mL	NVA 23 label
18 24	Quench Cooler	7:07	Initial	Quench Cooler	250mL	NVA 23 label
19 25	Sink	7:09	Initial	Bathroom Sink	250mL	Bathroom Sink only
20 26	Sink	7:10	Initial	Bathroom Sink	250mL	↓
21 27	Water Fountain	7:12	Initial	Water Fountain	250mL	Next to C-1
22 28	Water Fountain	7:13	Initial	Water Fountain	250mL	Next to C-2
23 29	Sink	7:15	Initial	Bathroom Sink	250mL	NVA 29 Bathroom
24 30	Sink	7:16	Initial	Sink	250mL	NVA 30 Bathroom
25 31	Sink	7:17	Initial	Bathroom Sink	250mL	Bathroom Sink only
26 32	Sink	7:18	Initial	Bathroom Sink	250mL	↓
27 33					250mL	
28 34					250mL	
29 35					250mL	
30 36					250mL	
31 37					250mL	



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: EnvChemistry2@EMSL.com

ADP573

Customer Information	Customer ID:	Billing ID:
	Company Name: TTI Environmental, Inc	Company Name: Same
	Contact Name: Tim Popp	Billing Contact: Jean Smith
	Street Address: 1253 N Church St	Street Address:
	City, State, Zip: Moorestown, NJ 08054 Country: US	City, State, Zip: Country:
	Phone: 856-840-8800	Phone:
Email(s) for Report: timp@ttienv.com	Email(s) for Invoice: jeans@ttienv.com	

Project Name/No: 25-190 Nuview Academy Annex	Purchase Order: 041272
EMSL LIMS Project ID: (If applicable, EMSL will provide)	US State where samples collected: State of Connecticut (CT) must select project location: ☐ Commercial (Taxable) ☐ Residential (Non-Taxable)
Samples for Compliance? ☒ Yes ☐ No If Yes, for NPDES? ☐ Yes ☒ No Other (Specify)	PWS ID: State Reporting Required? ☐ Yes ☐ No
Samples Collected by (Check One): ☐ EMSL ☒ CLIENT Samples Received Chilled? ☐ Yes ☐ No	Sample(s) Temperature Upon Receipt (LAB ONLY)
Sampled By Name: Miguel Lopez	Sampled By Signature: Miguel Lopez
Turn-Around-Time (TAT) Standard Turn-Around-Time: ☒ 2 Weeks	No. of Samples in Shipment: 26

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	Preservative 1 HCL 2 HNO3 3 H2SO4 4 ICE 5 Other Describe below in Special Instructions	List Test(s) Needed (Write in test below, then check on sample line:)								Comments	
						Test 1: Lead	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
See attached		☒		W	None	☒									

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.) HNO3 added @ 3:00pm on 5/5/25 PG						
Reporting Requirements:	☒ Results Only	☐ Results and QC	☐ Reduced Deliverables	☐ Hresults EDD	☒ Excel	☐ Other (Describe Above)
Method of Shipment:	Sample Condition Upon Receipt:		Received on Ice? ☐			
Relinquished by:	Date/Time:	Received by:	Date/Time:			
Relinquished by: Miguel Lopez	Date/Time: 05/03/25	Received by: [Signature]	Date/Time: 5/05/25 0900			

Controlled Document - CDC-07 Chemistry R13 05/31/2024

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

Page 1 of 2

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD14575

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey		FACILITY: Nuview Academy Annex		
PO #: 041272		SAMPLER(S): <i>Miguel Flores</i>		DATE: <i>05/03/25</i>		
ADDRESS: 1690 Stelton Rd, Piscataway, NJ 08854						
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...
1. Sink	Kitchen	6:42	Initial	Sink	250mL	
2. Sink	Kitchen	6:43	Initial	Sink	250mL	
3. Sink	Kitchen	6:43	Initial	Sink	250mL	
4. Sink	Kitchen	6:44	Initial	Sink	250mL	NVA4
5. Sink	Kitchen	6:44	Initial	Bathroom Sink	250mL	NVA5 / Bathroom
6. Sink	Faculty Lounge	6:46	Initial	Sink	250mL	NVA6 label
7. Water Fountain	Main Hall Café	6:47	Initial	Water Fountain	250mL	Next to D-3
8. Water Fountain	Main Hall Café		Initial	Water Fountain	250mL	Remove
9. Water Fountain	Main Hall Café		Initial	Water Fountain	250mL	Remove
10. Water Fountain	Gym	6:50	Initial	Water Fountain	250mL	
11. Water Fountain	A-Wing	6:52	Initial	Water Fountain	250mL	Next to A-1
12. Water Fountain	A-Wing	6:53	Initial	Water Fountain	250mL	Next to A-2
13. Water Fountain	Main Hall Office		Initial	Water Fountain	250mL	Temp out of spec
14. Water Fountain	Main Hall Office		Initial	Water Fountain	250mL	↓
15. Sink	Principal Bathroom	6:56	Initial	Sink	250mL	
16. Sink	Nurse's Office	6:58	Initial	Sink	250mL	NVA16
17. Sink	Nurse's Office	6:58	Initial	Bathroom Sink	250mL	NVA17
18. Water Fountain	B Wing	7:00	Initial	Water Fountain	250mL	Next to B-1
19. Water Fountain	B Wing	7:01	Initial	Water Fountain	250mL	Next to B-2



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD 19573

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey		FACILITY: Nuvew Academy Annex		
PO #: 041272		SAMPLER(S): Miguel Jena		DATE: 05/03/25		ADDRESS: 1690 Stelton Rd, Piscataway, NJ 08854
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...
20	Water Fountain		Initial	Water Fountain	250mL	Temp out of sev.
21	Water Fountain		Initial	Water Fountain	250mL	↓
22	Sink	7:04	Initial	Sink	250mL	NVA 22 / Discolored
23	Sink	7:06	Initial	Sink	250mL	NVA 23 label
24	Quench Cooler	7:07	Initial	Quench Cooler	250mL	NVA 23 label
25	Sink	7:09	Initial	Bathroom Sink	250mL	Bathroom Sink only
26	Sink	7:10	Initial	Bathroom Sink	250mL	↓
27	Water Fountain	7:12	Initial	Water Fountain	250mL	Next to C-1
28	Water Fountain	7:13	Initial	Water Fountain	250mL	Next to C-2
29	Sink	7:15	Initial	Bathroom Sink	250mL	NVA 29 Bathroom
30	Sink	7:16	Initial	Sink	250mL	NVA 30 Bathroom
31	Sink	7:17	Initial	Bathroom Sink	250mL	Bathroom Sink only
32	Sink	7:18	Initial	Bathroom Sink	250mL	↓
33					250mL	
34					250mL	
35					250mL	
36					250mL	
37					250mL	

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519610
LIMS Reference ID: AD19610
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Piscataway Regional Day School

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/05/2025 09:00
Reported: 05/21/2025 18:10

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 1 OT/PT/Main Hall Lims Reference ID: AD19610-01 Matrix: Drinking Water Sampled: 05/03/25 06:34:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 16:07	05/20/25 18:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 2 Main Hall/Staff Lounge Lims Reference ID: AD19610-02 Matrix: Drinking Water Sampled: 05/03/25 06:08:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 16:07	05/20/25 18:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 3 Behind Faculty Rm/Kitchen Lims Reference ID: AD19610-03 Matrix: Drinking Water Sampled: 05/03/25 06:05:00									
Metals									
Lead	97.4	D	2	2.00	µg/L	05/19/25 16:58	05/20/25 16:51	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: 4 Behind Faculty Rm/Kitchen Lims Reference ID: AD19610-04 Matrix: Drinking Water Sampled: 05/03/25 06:04:00									
Metals									
Lead	16.2		1	1.00	µg/L	05/19/25 16:07	05/20/25 18:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 5 Main Hall/Nurse's Office Lims Reference ID: AD19610-05 Matrix: Drinking Water Sampled: 05/03/25 06:06:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 16:07	05/20/25 18:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 6 Center/A Pod Lims Reference ID: AD19610-06 Matrix: Drinking Water Sampled: 05/03/25 06:10:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 16:07	05/20/25 18:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 7 A1/C1/Rm Lims Reference ID: AD19610-07 Matrix: Drinking Water Sampled: 05/03/25 06:12:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 16:07	05/20/25 18:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 8 A2/C1/Rm Lims Reference ID: AD19610-08 Matrix: Drinking Water Sampled: 05/03/25 06:13:00									
Metals									
Lead	1.36		1	1.00	µg/L	05/19/25 16:07	05/20/25 18:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 9 A3/C1/Rm Lims Reference ID: AD19610-09 Matrix: Drinking Water Sampled: 05/03/25 06:14:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 16:07	05/20/25 18:40	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519610
LIMS Reference ID: AD19610
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Piscataway Regional Day School

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/05/2025 09:00
Reported: 05/21/2025 18:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 10 A4/C1/Rm Lims Reference ID: AD19610-10 Matrix: Drinking Water Sampled: 05/03/25 06:15:00									
Metals									
Lead	1.36		1	1.00	µg/L	05/19/25 16:07	05/20/25 18:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 11 Sink/Frank's Cafe Lims Reference ID: AD19610-11 Matrix: Drinking Water Sampled: 05/03/25 06:17:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 16:09	05/19/25 23:58	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 12 Center/B Pod Lims Reference ID: AD19610-12 Matrix: Drinking Water Sampled: 05/03/25 06:19:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 16:09	05/20/25 00:05	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 13 Bathrm/B1 Class Rm Lims Reference ID: AD19610-13 Matrix: Drinking Water Sampled: 05/03/25 06:20:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 16:09	05/20/25 00:07	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 14 Bathrm/B2 Class Rm Lims Reference ID: AD19610-14 Matrix: Drinking Water Sampled: 05/03/25 06:21:00									
Metals									
Lead	1.08		1	1.00	µg/L	05/19/25 16:09	05/20/25 00:09	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 15 Bathrm/B3 Class Rm Lims Reference ID: AD19610-15 Matrix: Drinking Water Sampled: 05/03/25 06:22:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 16:09	05/20/25 00:12	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 16 Bathrm/B4 Class Rm Lims Reference ID: AD19610-16 Matrix: Drinking Water Sampled: 05/03/25 06:23:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 16:09	05/20/25 00:18	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 17 Main Hall/Qt/PT Lims Reference ID: AD19610-17 Matrix: Drinking Water Sampled: 05/03/25 06:24:00									
Metals									
Lead	141	D	5	5.00	µg/L	05/19/25 16:09	05/20/25 12:50	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 18 Center/D Pod Lims Reference ID: AD19610-18 Matrix: Drinking Water Sampled: 05/03/25 06:26:00									
Metals									
Lead	1.45		1	1.00	µg/L	05/19/25 16:09	05/20/25 00:23	JW1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519610

LIMS Reference ID: AD19610

EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]

1253 North Church Street

Moorestown, NJ 08057

(856) 840-8800

timp@ttienv.com

Project Name:

25-190 Piscataway Regional Day School

Customer PO:

041272

EMSL Sales Rep:

Sheryl Steinmetz

Received:

05/05/2025 09:00

Reported:

05/21/2025 18:10

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 19 Center/D Pod Bathrm									
Lims Reference ID:			AD19610-19			Matrix: Drinking Water			Sampled: 05/03/25 06:27:00
Metals									
Lead	ND	1	1.00	µg/L	05/19/25 16:09	05/20/25 00:25	JW1	EPA 200.8 (DA)/EPA 200.8	
Sample: 20 Center/C Pod									
Lims Reference ID:			AD19610-20			Matrix: Drinking Water			Sampled: 05/03/25 06:30:00
Metals									
Lead	ND	1	1.00	µg/L	05/19/25 16:09	05/20/25 00:28	JW1	EPA 200.8 (DA)/EPA 200.8	
Sample: 21 Bathrm/C1									
Lims Reference ID:			AD19610-21			Matrix: Drinking Water			Sampled: 05/03/25 06:31:00
Metals									
Lead	1.08	1	1.00	µg/L	05/19/25 16:09	05/20/25 00:30	JW1	EPA 200.8 (DA)/EPA 200.8	
Sample: 22 Bathrm/C2									
Lims Reference ID:			AD19610-22			Matrix: Drinking Water			Sampled: 05/03/25 06:32:00
Metals									
Lead	ND	1	1.00	µg/L	05/19/25 16:09	05/20/25 00:37	JW1	EPA 200.8 (DA)/EPA 200.8	
Sample: 23 Blank/Blank									
Lims Reference ID:			AD19610-23			Matrix: Drinking Water			Sampled: 05/03/25 06:40:00
Metals									
Lead	ND	1	1.00	µg/L	05/19/25 16:09	05/20/25 00:39	JW1	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519610
LIMS Reference ID: AD19610
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Piscataway Regional Day School

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/05/2025 09:00
Reported: 05/21/2025 18:10

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519610
LIMS Reference ID: AD19610
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Piscataway Regional Day School

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/05/2025 09:00
Reported: 05/21/2025 18:10

Notes and Definitions

Item	Definition
D	Analyte was reported from a dilution run.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: EnvChemistry2@EMSL.com

Customer Information		Billing Information	
Customer ID:		Billing ID:	
Company Name: TTI Environmental, Inc		Company Name: Same	
Contact Name: Tim Popp		Billing Contact: Jean Smith	
Street Address: 1253 N Church St		Street Address:	
City, State, Zip: Moorestown, NJ 08054		City, State, Zip:	
Country: US		Country:	
Phone: 856-840-8800		Phone:	
Email(s) for Report: timp@ttienv.com		Email(s) for Invoice: jeans@ttienv.com	

Project Name/No: 25-190 Piscataway Regional Day School		Purchase Order: 041272	
EMSL LIMS Project ID: (If applicable, EMSL will provide)		US State where samples collected:	
State of Connecticut (CT) must select project location:			
Commercial (Taxable)		Residential (Non-Taxable)	
Samples for Compliance? ☒ Yes ☐ No		If Yes, for NPDES? ☐ Yes ☒ No	
Other (Specify)		PWS ID:	
State Reporting Required? ☐ Yes ☐ No			
Samples Collected by (Check One): ☐ EMSL ☒ CLIENT		Samples Received Chilled? ☐ Yes ☐ No	
Sample(s) Temperature Upon Receipt (LAB ONLY)			
Sampled By Name: Miguel Popp		Sampled By Signature: Miguel Popp	
No. of Samples in Shipment: 23			
Turn-Around-Time (TAT)		Standard Turn-Around-Time: ☒ 2 Weeks	
The following TAT's are subject to Lab approval. Call lab to confirm TAT before submittal:		☐ 1 Week ☐ 4 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day	

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	Preservative 1 HCL 2 HNO3 3 H2SO4 4 ICE 5 Other Describe below in Special Instructions	List Test(s) Needed (Write in test below, then check on sample line:)								Comments	
						Test 1:	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
See attached		☒		W	None	☒									

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

HNO3 added @ 1:55pm on 5/5/25 PG

Reporting Requirements:		☒ Results Only		☐ Results and QC		☐ Reduced Deliverables		☐ Hzresults EDD		☒ Excel		☐ Other (Describe Above)	
Method of Shipment:		Sample Condition Upon Receipt:		Received on Ice? Check if Yes:									
Relinquished by:		Date/Time:		Received by:		M. Popp (WT)		Date/Time:		5/05/25 0900			
Relinquished by: Miguel Popp		Date/Time: 05/03/25		Received by:				Date/Time:					

Page 6 of 8

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

Page 1 of 2



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD19610

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey			FACILITY: Piscataway Regional Day School		
PO #: 041272		SAMPLER(S): <i>Miguel J. Ferrer</i>		DATE: <i>05/03/25</i>	ADDRESS: 1670 Stelton Road, Piscataway, NJ 08854		
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...	
1	OT/PT	Main Hall	<i>6:34</i>	Initial	Water Bubbler	250mL	
2	Main Hall	Staff Lounge	<i>6:08</i>	Initial	Sink	250mL	<i>PRDS9 label</i>
3	Behind Faculty Rm	Kitchen	<i>6:05</i>	Initial	Sink	250mL	<i>PRDS3 label</i>
4	Behind Faculty Rm	Kitchen	<i>6:04</i>	Initial	Sink	250mL	<i>PRDS6 label</i>
5	Main Hall	Nurse's Office	<i>6:06</i>	Initial	Sink	250mL	<i>PRDS10 label</i>
6	Center	A Pod	<i>6:10</i>	Initial	Sink	250mL	
7	A1	Cl/Rm	<i>6:12</i>	Initial	Sink Bathrm	250mL	<i>PRDS14 label</i>
8	A2	Cl/Rm	<i>6:13</i>	Initial	Sink Bathrm	250mL	<i>PRDS15 label</i>
9	A3	Cl/Rm	<i>6:14</i>	Initial	Sink Bathrm	250mL	<i>PRDS16 label</i>
10	A4	Cl/Rm	<i>6:15</i>	Initial	Sink Bathrm	250mL	<i>PRDS17 label</i>
11	Sink	Frank's Café	<i>6:17</i>	Initial	Sink	250mL	<i>PRDS19 label</i>
12	Center	B Pod	<i>6:19</i>	Initial	Sink	250mL	<i>PRDS21 label</i>
13	Bathrm	B1 Class Rm	<i>6:20</i>	Initial	Sink	250mL	<i>PRDS22 label</i>
14	Bathrm	B2 Class Rm	<i>6:21</i>	Initial	Sink	250mL	<i>PRDS23 label</i>
15	Bathrm	B3 Class Rm	<i>6:22</i>	Initial	Sink	250mL	<i>PRDS24 label</i>
16	Bathrm	B4 Class Rm	<i>6:23</i>	Initial	Sink	250mL	<i>PRDS25 label</i>
17	Main Hall	Qt/PT	<i>6:24</i>	Initial	Sink	250mL	<i>PRDS20 label</i>
18	Center	D Pod	<i>6:26</i>	Initial	Sink	250mL	<i>PRDS26 label</i>
19	Center	D Pod Bathrm	<i>6:27</i>	Initial	Sink	250mL	



AD1961D

[illegible]