

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 5-Sink/Cafeteria - Sink Lims Reference ID: AD21117-01 Matrix: Drinking Water Sampled: 05/10/25 09:30:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 19:51	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 6-Sink/Kitchen - Sink Lims Reference ID: AD21117-02 Matrix: Drinking Water Sampled: 05/10/25 09:31:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 19:57	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 7-Sink/Kitchen - Sink Lims Reference ID: AD21117-03 Matrix: Drinking Water Sampled: 05/10/25 09:32:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:00	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 8-Sink/OT/PT 114 - Sink Lims Reference ID: AD21117-04 Matrix: Drinking Water Sampled: 05/10/25 09:35:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:02	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 11-Sink/C10 Cl/Rm - Sink Lims Reference ID: AD21117-05 Matrix: Drinking Water Sampled: 05/10/25 09:37:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:04	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 12-Sink/C10 Bath Rm - Sink Lims Reference ID: AD21117-06 Matrix: Drinking Water Sampled: 05/10/25 09:38:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:11	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 13-Sink/C20 Cl/Rm - Sink Lims Reference ID: AD21117-07 Matrix: Drinking Water Sampled: 05/10/25 09:41:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:14	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 14-Sink/C20 Bath Rm - Sink Lims Reference ID: AD21117-08 Matrix: Drinking Water Sampled: 05/10/25 09:42:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:16	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 15-Sink/C30 Cl/Rm - Sink Lims Reference ID: AD21117-09 Matrix: Drinking Water Sampled: 05/10/25 09:44:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:18	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 16-Sink/C30 Bath Rm - Sink Lims Reference ID: AD21117-10 Matrix: Drinking Water Sampled: 05/10/25 09:45:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:20	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 17-Sink/C40 Cl/Rm - Sink Lims Reference ID: AD21117-11 Matrix: Drinking Water Sampled: 05/10/25 09:47:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:34	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 18-Sink/C40 Bath Rm - Sink Lims Reference ID: AD21117-12 Matrix: Drinking Water Sampled: 05/10/25 09:48:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:41	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 19-Sink/C50 Cl/Rm - Sink Lims Reference ID: AD21117-13 Matrix: Drinking Water Sampled: 05/10/25 09:50:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:43	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 20-Sink/C50 Bath Rm - Sink Lims Reference ID: AD21117-14 Matrix: Drinking Water Sampled: 05/10/25 09:50:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:50	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 21-Sink/C60 Cl/Rm - Sink Lims Reference ID: AD21117-15 Matrix: Drinking Water Sampled: 05/10/25 09:52:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:52	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 22-Sink/C60 Bath Rm - Sink Lims Reference ID: AD21117-16 Matrix: Drinking Water Sampled: 05/10/25 09:52:00									
Metals									
Lead	2.55		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:55	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 25-Sink/D10 Cl/Rm - Sink Lims Reference ID: AD21117-17 Matrix: Drinking Water Sampled: 05/10/25 09:54:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:57	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 26-Sink/D10 Bath Rm - Sink Lims Reference ID: AD21117-18 Matrix: Drinking Water Sampled: 05/10/25 09:54:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 20:59	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 27-Sink/D20 CI/Rm - Sink Lims Reference ID: AD21117-19 Matrix: Drinking Water Sampled: 05/10/25 09:56:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 21:01	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 28-Sink/D20 Bath Rm - Sink Lims Reference ID: AD21117-20 Matrix: Drinking Water Sampled: 05/10/25 09:56:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:37	05/21/25 21:04	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 29-Sink/D30 CI/Rm - Sink Lims Reference ID: AD21117-21 Matrix: Drinking Water Sampled: 05/10/25 09:58:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:24	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 30-Sink/D30 Bath Rm - Sink Lims Reference ID: AD21117-22 Matrix: Drinking Water Sampled: 05/10/25 09:58:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:31	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 31-Sink/D40 CI/Rm - Sink Lims Reference ID: AD21117-23 Matrix: Drinking Water Sampled: 05/10/25 10:00:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:34	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 32-Sink/D40 Bath Rm - Sink Lims Reference ID: AD21117-24 Matrix: Drinking Water Sampled: 05/10/25 10:01:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:36	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 33-Sink/D50 CI/Rm - Sink Lims Reference ID: AD21117-25 Matrix: Drinking Water Sampled: 05/10/25 10:03:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:38	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 34-Sink/D50 Bath Rm - Sink Lims Reference ID: AD21117-26 Matrix: Drinking Water Sampled: 05/10/25 10:04:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:45	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 35-Sink/D60 CI/Rm - Sink Lims Reference ID: AD21117-27 Matrix: Drinking Water Sampled: 05/10/25 10:06:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:47	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 36-Sink/D60 Bath Rm - Sink Lims Reference ID: AD21117-28 Matrix: Drinking Water Sampled: 05/10/25 10:07:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:50	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 37-Sink/Nurse - Sink Lims Reference ID: AD21117-29 Matrix: Drinking Water Sampled: 05/10/25 10:10:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:52	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 38-Sink/A10 Cl/Rm - Sink Lims Reference ID: AD21117-30 Matrix: Drinking Water Sampled: 05/10/25 10:12:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:54	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 39-Sink/A10 Bath Rm - Sink Lims Reference ID: AD21117-31 Matrix: Drinking Water Sampled: 05/10/25 10:14:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 21:56	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 40-Sink/A20 Cl/Rm - Sink Lims Reference ID: AD21117-32 Matrix: Drinking Water Sampled: 05/10/25 10:16:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:03	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 41-Sink/A20 Bath Rm - Sink Lims Reference ID: AD21117-33 Matrix: Drinking Water Sampled: 05/10/25 10:17:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:06	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 42-Sink/A30 Cl/Rm - Sink Lims Reference ID: AD21117-34 Matrix: Drinking Water Sampled: 05/10/25 10:19:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:12	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 43-Sink/A30 Bath Rm - Sink Lims Reference ID: AD21117-35 Matrix: Drinking Water Sampled: 05/10/25 10:20:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:15	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 44-Sink/A40 Cl/Rm - Sink Lims Reference ID: AD21117-36 Matrix: Drinking Water Sampled: 05/10/25 10:22:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:17	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 45-Sink/A40 Bath Rm - Sink Lims Reference ID: AD21117-37 Matrix: Drinking Water Sampled: 05/10/25 10:23:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:19	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 46-Sink/A50 Cl/Rm - Sink Lims Reference ID: AD21117-38 Matrix: Drinking Water Sampled: 05/10/25 10:25:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:22	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 47-Sink/A50 Bath Rm - Sink Lims Reference ID: AD21117-39 Matrix: Drinking Water Sampled: 05/10/25 10:26:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:24	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 48-Sink/A60 Cl/Rm - Sink Lims Reference ID: AD21117-40 Matrix: Drinking Water Sampled: 05/10/25 10:28:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:38	05/21/25 22:26	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 49-Sink/A60 Bath Rm - Sink Lims Reference ID: AD21117-41 Matrix: Drinking Water Sampled: 05/10/25 10:29:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:19	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 52-Sink/OT/PTE116 - Sink Lims Reference ID: AD21117-42 Matrix: Drinking Water Sampled: 05/10/25 10:34:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:24	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 55-Sink/Daily Living E122 - Sink Lims Reference ID: AD21117-43 Matrix: Drinking Water Sampled: 05/10/25 10:38:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:26	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 56-Sink/Daily Living E122 - Sink Lims Reference ID: AD21117-44 Matrix: Drinking Water Sampled: 05/10/25 10:39:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:28	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 57-Sink/B10 Cl/Rm - Sink Lims Reference ID: AD21117-45 Matrix: Drinking Water Sampled: 05/10/25 10:42:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:30	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 58-Sink/B10 Bath Rm - Sink Lims Reference ID: AD21117-46 Matrix: Drinking Water Sampled: 05/10/25 10:43:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:36	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 59-Sink/B20 Cl/Rm - Sink Lims Reference ID: AD21117-47 Matrix: Drinking Water Sampled: 05/10/25 10:46:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:13	05/22/25 16:46	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: 60-Sink/B20 Bath Rm - Sink Lims Reference ID: AD21117-48 Matrix: Drinking Water Sampled: 05/10/25 10:47:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:38	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 61-Sink/B30 Cl/Rm - Sink Lims Reference ID: AD21117-49 Matrix: Drinking Water Sampled: 05/10/25 10:50:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:40	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 62-Sink/B30 Bath Rm - Sink Lims Reference ID: AD21117-50 Matrix: Drinking Water Sampled: 05/10/25 10:52:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:42	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 63-Sink/B40 Cl/Rm - Sink Lims Reference ID: AD21117-51 Matrix: Drinking Water Sampled: 05/10/25 10:54:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:44	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 64-Sink/B40 Bath Rm - Sink Lims Reference ID: AD21117-52 Matrix: Drinking Water Sampled: 05/10/25 10:54:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:46	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 65-Sink/B50 Cl/Rm - Sink Lims Reference ID: AD21117-53 Matrix: Drinking Water Sampled: 05/10/25 10:56:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:51	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 66-Sink/B50 Bath Rm - Sink Lims Reference ID: AD21117-54 Matrix: Drinking Water Sampled: 05/10/25 10:56:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:53	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 67-Sink/B60 Cl/Rm - Sink Lims Reference ID: AD21117-55 Matrix: Drinking Water Sampled: 05/10/25 10:58:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 14:59	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 68-Sink/B60 Bath Rm - Sink Lims Reference ID: AD21117-56 Matrix: Drinking Water Sampled: 05/10/25 10:58:00									
Metals									
Lead	ND		1	1.00	µg/L	05/21/25 11:58	05/23/25 15:01	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521117
LIMS Reference ID: AD21117
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-190 Center For Lifelong Learning

Customer PO: 041272
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/12/2025 12:45
Reported: 05/27/2025 17:39

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

A02117

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey		FACILITY: Center For Lifelong Learning		
PO #: 041272		SAMPLER(S): <i>Michael, Lisa</i>		ADDRESS: 333 Cheesequake Road, Parlin, NJ 08859		
DATE: 05/10/25						
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...
1. Water Cooler	Aquatic Center Pool		Initial	Water Cooler	250mL	Temp closed
2. Water Cooler	Aquatic Center Pool		Initial	Water Cooler	250mL	Temp closed
3. Water Cooler	Locker Room Hall		Initial	Water Cooler	250mL	Temp closed
4. Water Cooler	Locker Room Hall		Initial	Water Cooler	250mL	Temp closed
5. Sink	Cafeteria	9:30	Initial	Sink	250mL	
6. Sink	Kitchen	9:31	Initial	Sink	250mL	
7. Sink	Kitchen	9:32	Initial	Sink	250mL	
8. Sink	OT/PT 114	9:35	Initial	Sink	250mL	
9. Water Cooler	Red Hall		Initial	Water Cooler	250mL	Temp closed
10. Water Cooler	Red Hall		Initial	Water Cooler	250mL	Temp closed
11. Sink	C10 C1/Rm	9:37	Initial	Sink	250mL	
12. Sink	C10 Bath Rm	9:38	Initial	Sink	250mL	
13. Sink	C20 C1/Rm	9:41	Initial	Sink	250mL	
14. Sink	C20 Bath Rm	9:42	Initial	Sink	250mL	
15. Sink	C30 C1/Rm	9:44	Initial	Sink	250mL	
16. Sink	C30 Bath Rm	9:45	Initial	Sink	250mL	
17. Sink	C40 C1/Rm	9:47	Initial	Sink	250mL	
18. Sink	C40 Bath Rm	9:49	Initial	Sink	250mL	
19. Sink	C50 C1/Rm	9:50	Initial	Sink	250mL	



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD2117

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey		FACILITY: Center For Lifelong Learning		
PO #: 041272		SAMPLER(S): <i>Michael Perma</i>		ADDRESS: 333 Cheesequake Road, Parlin, NJ 08859		
DATE: 05/10/25						
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...
14 20.	Sink		Initial	Sink	250mL	
15 21.	Sink	9:50	Initial	Sink	250mL	
16 22.	Sink	9:52	Initial	Sink	250mL	
16 23.	Water Cooler	9:52	Initial	Sink	250mL	
17 24.	Water Cooler		Initial	Water Cooler	250mL	Temp closed
17 25.	Sink		Initial	Sink	250mL	
18 26.	Sink	9:54	Initial	Sink	250mL	
19 27.	Sink	9:54	Initial	Sink	250mL	
20 28.	Sink	9:56	Initial	Sink	250mL	
21 29.	Sink	9:56	Initial	Sink	250mL	
22 30.	Sink	9:58	Initial	Sink	250mL	
23 31.	Sink	9:58	Initial	Sink	250mL	
24 32.	Sink	10:00	Initial	Sink	250mL	
24 33.	Sink	10:01	Initial	Sink	250mL	
25 34.	Sink	10:03	Initial	Sink	250mL	
26 35.	Sink	10:04	Initial	Sink	250mL	
27 36.	Sink	10:06	Initial	Sink	250mL	
28 37.	Sink	10:07	Initial	Sink	250mL	
29 38.	Sink	10:10	Initial	Sink	250mL	
30	Sink	10:12	Initial	Sink	250mL	



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD21117

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey		FACILITY: Center For Lifelong Learning			
PO #: 041272		SAMPLER(S): <i>Niguel Pera</i>		ADDRESS: 333 Cheesapeake Road, Parlin, NJ 08859			
DATE: 05/10/25		Sample Type: Initial Flush (30sec / 15min)		Notes: Discolored, Odor, Low Flow, Etc...			
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...	
31 39.	Sink	A10 Bath Rm	10:14	Initial	Sink	250mL	
32 40.	Sink	A20 Cl/Rm	10:16	Initial	Sink	250mL	
33 41.	Sink	A20 Bath Rm	10:17	Initial	Sink	250mL	
34 42.	Sink	A30 Cl/Rm	10:19	Initial	Sink	250mL	
35 43.	Sink	A30 Bath Rm	10:20	Initial	Sink	250mL	
36 44.	Sink	A40 Cl/Rm	10:22	Initial	Sink	250mL	
37 45.	Sink	A40 Bath Rm	10:23	Initial	Sink	250mL	
38 46.	Sink	A50 Cl/Rm	10:25	Initial	Sink	250mL	
39 47.	Sink	A50 Bath Rm	10:26	Initial	Sink	250mL	
40 48.	Sink	A60 Cl/Rm	10:28	Initial	Sink	250mL	
41 49.	Sink	A60 Bath Rm	10:29	Initial	Sink	250mL	
50.	Water Cooler	Green Main Hall		Initial	Water Cooler	250mL	Temp closed
51.	Water Cooler	Green Main Hall		Initial	Water Cooler	250mL	↓
52.	Sink	OT/PTE116	10:34	Initial	Sink	250mL	
53.	Water Cooler	Blue Main Hall		Initial	Water Cooler	250mL	Temp closed
54.	Water Cooler	Blue Main Hall		Initial	Water Cooler	250mL	↓
55.	Sink	Daily Living E122	10:38	Initial	Sink	250mL	
56.	Sink	Daily Living E122	10:39	Initial	Sink	250mL	
57.	Sink	B10 Cl/Rm	10:42	Initial	Sink	250mL	



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD2117

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-190		CLIENT: Educational Services Commission of New Jersey		FACILITY: Center For Lifelong Learning		
PO #: 041272		SAMPLER(S): <i>Wiggle Floor</i>		ADDRESS: 333 Cheesapeake Road, Parlin, NJ 08859		
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...
46. 58.	Sink		Initial	Sink	250mL	
47. 59.	Sink		Initial	Sink	250mL	
48. 60.	Sink		Initial	Sink	250mL	
49. 61.	Sink		Initial	Sink	250mL	
50. 62.	Sink		Initial	Sink	250mL	
51. 63.	Sink		Initial	Sink	250mL	
52. 64.	Sink		Initial	Sink	250mL	
53. 65.	Sink		Initial	Sink	250mL	
54. 66.	Sink		Initial	Sink	250mL	
55. 67.	Sink		Initial	Sink	250mL	
56. 68.	Sink		Initial	Sink	250mL	
69.					250mL	
70.					250mL	
71.					250mL	
72.					250mL	
73.					250mL	
74.					250mL	
75.					250mL	