Technical Report

prepared for:

Parkway School
c/o Greenwich Public Schools, 290 Greenwich Ave
Greenwich, CT 06830
Attention: Elisa Gonzalez

Report Date: 07/08/2025
Client Project ID: PWS ID CT0570212
York Project (SDG) No.: N5F0790

CT Cert. No. PH-0800

New York Cert. No. 11706

56 Church Hill Road #2 ■ Newtown, CT 06470

www.YORKLAB.com (203) 270-9973 FAX (203) 270-3348 ClientServices@yorklab.com

Report Date: 07/08/2025
Client Project ID: PWS ID CT0570212
York Project (SDG) No.: N5F0790

Parkway School
c/o Greenwich Public Schools, 290 Greenwich Ave
Greenwich, CT 06830
Attention: Elisa Gonzalez

Purpose and Results

This report contains the analytical data for the sample(s) identified on the attached chain-of-custody received in our laboratory on June 26, 2025 and listed below. The project was identified as your project: **PWS ID CT0570212**.

The analyses were conducted utilizing appropriate EPA, Standard Methods, and ASTM methods as detailed in the data summary tables.

All samples were received in proper condition meeting the customary acceptance requirements for environmental samples except those indicated under the Sample and Analysis Qualifiers section of this report.

All analyses met the method and laboratory standard operating procedure requirements except as indicated by any data flags, the meaning of which are explained in the Sample and Data Qualifiers Relating to This Work Order section of this report and case narrative if applicable.

Please contact Client Services at 203-270-9973 with any questions regarding this report.

York Sample ID	Client Sample ID	Matrix	Date Collected	Date Received
N5F0790-01	PS004	Drinking Water	06/26/2025	06/26/2025
N5F0790-02	PS023	Drinking Water	06/26/2025	06/26/2025
N5F0790-03	PS005	Drinking Water	06/26/2025	06/26/2025
N5F0790-04	PS008	Drinking Water	06/26/2025	06/26/2025
N5F0790-05	PS017	Drinking Water	06/26/2025	06/26/2025
N5F0790-06	PS029	Drinking Water	06/26/2025	06/26/2025
N5F0790-07	PS010	Drinking Water	06/26/2025	06/26/2025
N5F0790-08	PS003	Drinking Water	06/26/2025	06/26/2025
N5F0790-09	PS019	Drinking Water	06/26/2025	06/26/2025
N5F0790-10	PS011	Drinking Water	06/26/2025	06/26/2025

YORK
ANALYTICAL LABORATORIES INC

Sample Information

Client Sample ID: **PS004** **York Sample ID:** **N5F0790-01**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
N5F0790	PWS ID CT0570212	Drinking Water	June 26, 2025 6:05 am	06/26/2025

Field Analyses: Log-in/Sample Notes:

Results

Parameter	Result	Units	Qualifier	RL	MCL	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
Copper	**0.0326**	mg/L		0.02	1.3	EPA 200.7	06/27/2025 17:44	07/01/2025 18:26	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706	
Lead	**1.41**	ug/L		1.00	15	EPA 200.8	06/27/2025 17:34	06/30/2025 18:07	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706	

Sample Information

Client Sample ID: **PS023** **York Sample ID:** **N5F0790-02**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
N5F0790	PWS ID CT0570212	Drinking Water	June 26, 2025 6:12 am	06/26/2025

Field Analyses: Log-in/Sample Notes:

Results

Parameter	Result	Units	Qualifier	RL	MCL	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
Copper	**0.143**	mg/L		0.02	1.3	EPA 200.7	06/27/2025 17:44	07/01/2025 18:30	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706	
Lead	**2.45**	ug/L		1.00	15	EPA 200.8	06/27/2025 17:34	06/30/2025 18:11	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706	

Sample Information

Client Sample ID: **PS005** **York Sample ID:** **N5F0790-03**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
N5F0790	PWS ID CT0570212	Drinking Water	June 26, 2025 6:21 am	06/26/2025

Field Analyses: Log-in/Sample Notes:

Results

Parameter	Result	Units	Qualifier	RL	MCL	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
Copper	**0.199**	mg/L		0.02	1.3	EPA 200.7	06/27/2025 17:44	07/01/2025 18:35	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706	
Lead	**< 1.00**	ug/L		1.00	15	EPA 200.8	06/27/2025 17:34	06/30/2025 18:15	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706	

Sample Information

Client Sample ID: PS008 **York Sample ID:** N5F0790-04

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
N5F0790	PWS ID CT0570212	Drinking Water	June 26, 2025 6:02 am	06/26/2025

Field Analyses: Log-in/Sample Notes:

Results

Parameter	Result	Units	Qualifier	RL	MCL	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
Copper	**0.0379**	mg/L		0.02	1.3	EPA 200.7	06/27/2025 17:44	07/01/2025 18:39	DLW
							Certifications: CTDOH-PH-0800,NELAC-NY11706		
Lead	**1.75**	ug/L		1.00	15	EPA 200.8	06/27/2025 17:34	06/30/2025 18:18	DLW
							Certifications: CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: PS017 **York Sample ID:** N5F0790-05

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
N5F0790	PWS ID CT0570212	Drinking Water	June 26, 2025 6:07 am	06/26/2025

Field Analyses: Log-in/Sample Notes:

Results

Parameter	Result	Units	Qualifier	RL	MCL	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
Copper	**0.0517**	mg/L		0.02	1.3	EPA 200.7	07/02/2025 13:35	07/02/2025 22:45	DLW
							Certifications: CTDOH-PH-0800,NELAC-NY11706		
Lead	**1.04**	ug/L		1.00	15	EPA 200.8	06/27/2025 17:34	06/30/2025 18:22	DLW
							Certifications: CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: PS029 **York Sample ID:** N5F0790-06

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
N5F0790	PWS ID CT0570212	Drinking Water	June 26, 2025 6:17 am	06/26/2025

Field Analyses: Log-in/Sample Notes:

Results

Parameter	Result	Units	Qualifier	RL	MCL	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
Copper	**0.154**	mg/L		0.02	1.3	EPA 200.7	07/02/2025 13:35	07/02/2025 22:49	DLW
							Certifications: CTDOH-PH-0800,NELAC-NY11706		
Lead	**2.75**	ug/L		1.00	15	EPA 200.8	06/27/2025 17:34	06/30/2025 18:26	DLW
							Certifications: CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: PS010 **York Sample ID:** N5F0790-07

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
N5F0790	PWS ID CT0570212	Drinking Water	June 26, 2025 6:23 am	06/26/2025

Field Analyses: Log-in/Sample Notes:

Results

Parameter	Result	Units	Qualifier	RL	MCL	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
Copper	**0.169**	mg/L		0.02	1.3	EPA 200.7	07/02/2025 13:35	07/02/2025 22:53	DLW
							Certifications: CTDOH-PH-0800,NELAC-NY11706		
Lead	**2.14**	ug/L		1.00	15	EPA 200.8	06/27/2025 17:34	06/30/2025 18:29	DLW
							Certifications: CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: PS003 **York Sample ID:** N5F0790-08

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
N5F0790	PWS ID CT0570212	Drinking Water	June 26, 2025 6:08 am	06/26/2025

Field Analyses: Log-in/Sample Notes:

Results

Parameter	Result	Units	Qualifier	RL	MCL	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
Copper	**0.138**	mg/L		0.02	1.3	EPA 200.7	07/02/2025 13:35	07/02/2025 22:57	DLW
							Certifications: CTDOH-PH-0800,NELAC-NY11706		
Lead	**1.32**	ug/L		1.00	15	EPA 200.8	06/27/2025 17:34	06/30/2025 18:33	DLW
							Certifications: CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: PS019 **York Sample ID:** N5F0790-09

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
N5F0790	PWS ID CT0570212	Drinking Water	June 26, 2025 6:18 am	06/26/2025

Field Analyses: Log-in/Sample Notes:

Results

Parameter	Result	Units	Qualifier	RL	MCL	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
Copper	**0.150**	mg/L		0.02	1.3	EPA 200.7	07/02/2025 13:35	07/02/2025 23:01	DLW
							Certifications: CTDOH-PH-0800,NELAC-NY11706		
Lead	**2.84**	ug/L		1.00	15	EPA 200.8	07/03/2025 13:42	07/03/2025 15:12	DLW
							Certifications: CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **PS011**

York Sample ID: **N5F0790-10**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
N5F0790	PWS ID CT0570212	Drinking Water	June 26, 2025 6:24 am	06/26/2025

Field Analyses:

Log-in/Sample Notes:

Results

Parameter	Result	Units	Qualifier	RL	MCL	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
Copper	**0.231**	mg/L		0.02	1.3	EPA 200.7	07/02/2025 13:35 Certifications: CTDOH-PH-0800,NELAC-NY11706	07/02/2025 23:13	DLW
Lead	**5.19**	ug/L		1.00	15	EPA 200.8	07/03/2025 13:42 Certifications: CTDOH-PH-0800,NELAC-NY11706	07/03/2025 15:16	DLW

Definitions and Other Information

* Analyte is not certified or the state of the samples origination does not offer certification for the Analyte.

MCL The Maximum Contaminant Level (MCL) is the maximum concentration of a chemical that is allowed in public drinking water systems. The MCL is established by the U.S. Environmental Protection Agency (EPA). Some states have MCLs that are equal to or less than the Federally established MCL. The listed MCL value reflects the MCL established by the State where the sample was taken.

General Notes for

1. The RLs and MDLs (Reporting Limit and Method Detection Limit respectively) reported are adjusted for any dilution necessary due to the levels of target and/or non-target analytes and matrix interference. The RL(REPORTING LIMIT) is based upon the lowest standard utilized for the calibration where applicable.
2. Samples are retained for a period of thirty days after submittal of report, unless other arrangements are made.
3. York's liability for the above data is limited to the dollar value paid to York for the referenced project.
4. This report shall not be reproduced without the written approval of York Analytical Laboratories, Inc.
5. All analyses conducted met method or Laboratory SOP requirements. See the Sample and Data Qualifiers Section for further information.
6. It is noted that no analyses reported herein were subcontracted to another laboratory, unless noted in the report.
7. This report reflects results that relate only to the samples submitted on the attached chain-of-custody form(s) received by York.

Approved By:

Cassie Mosher
Chemistry Director



Phil Murphy
Interim Microbiology Director



Date: July 08, 2025

system learns of the tap monitoring results)

TO BE COMPLETED BY THE RESIDENT OR SAMPLER

Name: Parkway School Sample Date: 6/26/2025

Address: _____ Sample Time: 6:05AM

Sample Location: PS 004 / 3west. (Kitchen sink/ Bathroom Sink ETC.)

I have read the above directions and have taken a tap sample in accordance with these directions.

Signed: _____ Date: _____

Comments/ Notes:

_____

_____

PLEASE FILL OUT FORM COMPLETELY- THIS INFORMATION IS IMPORTANT TO THE LAB!!

Lab Use Only:

Water samples received – Date: 6/26/25 Time: 4:50 AM / PM

Temperature: 2°C / On Ice? Y/N

Signature of Lab Representative: _____ Sample ID: NSF0790-01

system learns of the tap monitoring ...)

TO BE COMPLETED BY THE RESIDENT OR SAMPLER

Name: Parkway School Sample Date: 6/26/2025

Address: _____ Sample Time: 6:12AM

Sample Location: PS073 / Kitchen M (Kitchen sink/ Bathroom Sink ETC.)

I have read the above directions and have taken a tap sample in accordance with these directions.

Signed: _____ Date: _____

Comments/ Notes:

_____

_____

PLEASE FILL OUT FORM COMPLETELY- THIS INFORMATION IS IMPORTANT TO THE LAB!!

Lab Use Only:

Water samples received – Date: 6/26/25 Time: 9:50 AM / PM

Temperature: 2°C / On Ice? Y/N

Signature of Lab Representative: _____ Sample ID: NSF0790-02

File Storage (Q:) \09 – Aqua Enviromental\Admin\Sheets to Print\New COC for Pb + Cu

TO BE COMPLETED BY THE RESIDENT OR SAMPLER

Name: Parkway School Sample Date: 6/26/2025

Address: _____ Sample Time: 6:21 AM.

Sample Location: P5005 / 4 East. (Kitchen sink/ Bathroom Sink ETC.)

I have read the above directions and have taken a tap sample in accordance with these directions.

Signed: _____ Date: _____

Comments/ Notes:

_____

_____

PLEASE FILL OUT FORM COMPLETELY- THIS INFORMATION IS IMPORTANT TO THE LAB!!

Lab Use Only:

Water samples received – Date: 6/26/25 Time: 4:50 AM / ~~PM~~

Temperature: 22 / On Ice? Y/N

Signature of Lab Representative: _____ Sample ID: N5F0790-03

File Storage (Q:) \09 – Aqua Enviromental\Admin\Sheets to Print\New COC for Pb + Cu

system learns of the tap monitoring results)

TO BE COMPLETED BY THE RESIDENT OR SAMPLER

Name: Parkway School Sample Date: 6/26/2025

Address: _____ Sample Time: 6:05AM

Sample Location: PS008 / 4WEST. (Kitchen sink/ Bathroom Sink ETC.)

I have read the above directions and have taken a tap sample in accordance with these directions.

Signed: _____ Date: _____

Comments/ Notes:

_____

_____

PLEASE FILL OUT FORM COMPLETELY- THIS INFORMATION IS IMPORTANT TO THE LAB!!

Lab Use Only:

Water samples received – Date: 6/26/25 Time: 4:50 AM / PM

Temperature: 2C / On Ice? Y/N

Signature of Lab Representative: _____ Sample ID: NSF0790-04

File Storage (Q:) \09 – Aqua Enviromental\Admin\Sheets to Print\New COC for Pb + Cu

TO BE COMPLETED BY THE RESIDENT OR SAMPLER

Name: Parkway School Sample Date: 6/26/2025

Address: _____ Sample Time: 6:07 AM

Sample Location: PS017 / Teachers RM (Kitchen sink/ Bathroom Sink ETC.)

I have read the above directions and have taken a tap sample in accordance with these directions.

Signed: _____ Date: _____

Comments/ Notes:

_____

_____

PLEASE FILL OUT FORM COMPLETELY- THIS INFORMATION IS IMPORTANT TO THE LAB!!

Lab Use Only:

Water samples received – Date: 6/26/25 Time: 4:50 AM / PM

Temperature: 2° / On Ice? Y/N

Signature of Lab Representative: _____ Sample ID: N5F0790-05

File Storage (Q:) \09 – Aqua Enviromental\Admin\Sheets to Print\New COC for Pb + Cu

TO BE COMPLETED BY THE RESIDENT OR SAMPLER

Name: Parkway School Sample Date: 6/26/2025

Address: _____ Sample Time: 6:17AM

Sample Location: P5029 / Nurse RM. (Kitchen sink/ Bathroom Sink ETC.)

I have read the above directions and have taken a tap sample in accordance with these directions.

Signed: _____ Date: _____

Comments/ Notes:

_____

_____

PLEASE FILL OUT FORM COMPLETELY- THIS INFORMATION IS IMPORTANT TO THE LAB!!

Lab Use Only:

Water samples received – Date: 6/26/25 Time: 4:50 AM / PM

Temperature: 2° / On Ice? Y/N

Signature of Lab Representative: _____ Sample ID: N5F0790-D6

File Storage (Q:) \09 – Aqua Enviromental\Admin\Sheets to Print\New COC for Pb + Cu

TO BE COMPLETED BY THE RESIDENT OR SAMPLER

Name: Parkway School Sample Date: 6/26/2025

Address: _____ Sample Time: 6:23Am

Sample Location: RS010 / 7 EAST (Kitchen sink/ Bathroom Sink ETC.)

I have read the above directions and have taken a tap sample in accordance with these directions.

Signed: _____ Date: _____

Comments/ Notes:

_____

_____

PLEASE FILL OUT FORM COMPLETELY- THIS INFORMATION IS IMPORTANT TO THE LAB!!

Lab Use Only:

Water samples received – Date: 6/26/25 Time: 4:50 AM / PM

Temperature: 2c / On Ice? Y/N

Signature of Lab Representative: _____ Sample ID: N5F0790-07

File Storage (Q:) \09 – Aqua Enviromental\Admin\Sheets to Print\New COC for Pb + Cu

TO BE COMPLETED BY THE RESIDENT OR SAMPLER

Name: Parkway School Sample Date: 6/26/2025

Address: _____ Sample Time: 6:08AM

Sample Location: PS003 / 3 South (Kitchen sink/ Bathroom Sink ETC.)

I have read the above directions and have taken a tap sample in accordance with these directions.

Signed: _____ Date: _____

Comments/ Notes:

_____

_____

PLEASE FILL OUT FORM COMPLETELY- THIS INFORMATION IS IMPORTANT TO THE LAB!!

Lab Use Only:

Water samples received – Date: 6/26/25 Time: 4:50 AM / ~~PM~~

Temperature: 2 / On Ice? Y/N

Signature of Lab Representative: _____ Sample ID: N5F0790-08

File Storage (Q:) \09 – Aqua Enviromental\Admin\Sheets to Print\New COC for Pb + Cu

system learns of the tap monitoring results)

TO BE COMPLETED BY THE RESIDENT OR SAMPLER

Name: Parkway School Sample Date: 6/26/2025

Address: _____ Sample Time: 6/8AM

Sample Location: PS 019 / Art #2 (Kitchen sink/ Bathroom Sink ETC.)

I have read the above directions and have taken a tap sample in accordance with these directions.

Signed: _____ Date: _____

Comments/ Notes:

_____

_____

PLEASE FILL OUT FORM COMPLETELY- THIS INFORMATION IS IMPORTANT TO THE LAB!!

Lab Use Only:

Water samples received – Date: 6/26/25 Time: 4:50 AM / ~~PM~~

Temperature: 2c / On Ice? Y/N

Signature of Lab Representative: _____ Sample ID: N5F0790 - 09

File Storage (Q:) \09 – Aqua Enviromental\Admin\Sheets to Print\New COC for Pb + Cu

TO BE COMPLETED BY THE RESIDENT OR SAMPLER

Name: Parkway School Sample Date: 6/26/2025

Address: _____ Sample Time: 6:24AM

Sample Location: RS011 / 8EAST. (Kitchen sink/ Bathroom Sink ETC.)

I have read the above directions and have taken a tap sample in accordance with these directions.

Signed: _____ Date: _____

Comments/ Notes:

_____

_____

PLEASE FILL OUT FORM COMPLETELY- THIS INFORMATION IS IMPORTANT TO THE LAB!!

Lab Use Only:

Water samples received – Date: 6/26/25 Time: 4:50 AM / PM

Temperature: 2 / On Ice? Y/N

Signature of Lab Representative: _____ Sample ID: N5F0790-10

File Storage (Q:) \09 – Aqua Enviromental\Admin\Sheets to Print\New COC for Pb + Cu