December 17, 2024

Providing Trusted
Health and Safety Solutions

Jason Bichler
Director of Buildings and Grounds
St. Michael-Albertville ISD #885
11343 50th Street NE
Albertville, MN 55301

RE: St. Michael-Albertville ISD #885
Lead-in-Water First Draw – Initial Testing
IEA Project #202410983

Dear Mr. Bichler:

At the request of St. Michael-Albertville ISD #885, the Institute for Environmental Assessment, Inc. (IEA) collected 560 water samples from identified water sources on November 12, 2024, November 13, 2024, and December 6, 2024, for lead analyses from the following buildings:

- Community Education (51 samples)
- Fieldstone Elementary (144 samples)
- St. Michael Elementary (111 samples)
- STMA High School (237 samples)
- STMA Ice Arena (17 samples)

The purpose of the sampling is to document lead content in the sampled locations to assist the District in complying with Minnesota Statute 121A.225.

INTRODUCTION

Lead is a metal that usually enters drinking water through the distribution system, including pipes, solders, faucets, and valves. Lead content in water may increase when the water is allowed to sit undisturbed in the system. Exposure to lead is a health concern.

Minnesota Statute 121A.335 requires public school buildings serving prekindergarten through grade 12 to test for lead in potable water fixtures every five years. The *3Ts for Reducing Lead in Drinking Water Toolkit (2018)* and the Lead Contamination Control Act (LCCA) of 1988 were created by the Environmental Protection Agency (EPA) to identify and reduce lead in drinking water. Statute 121A.335 requires remediation of water fixtures with levels of 5 parts per billion (ppb) or higher.

BROOKLYN PARK
9201 West Broadway, #600
Brooklyn Park, MN 55445
763-315-7900 / FAX 763-315-7920
800-233-9513

MANKATO
610 North Riverfront Drive
Mankato, MN 56001
507-345-8818 / FAX 507-345-5301
800-233-9513

ROCHESTER
210 Woodlake Drive SE
Rochester, MN 55904
507-281-6664 / FAX 507-281-6695
800-233-9513

BRAINERD
601 NW 5th Street, Ste. #4
Brainerd, MN 56401
218-454-0703 / FAX 218-454-0703
800-233-9513

MARSHALL
1420 East College Drive
Marshall, MN 56258
507-476-3599 / FAX 507-537-6985
800-233-9513

VIRGINIA
5525 Emerald Avenue
Mountain Iron, MN 55768
218-410-9521
800-233-9513

© 2024 Institute for Environmental Assessment, Inc. All Rights Reserved.

METHODOLOGY

IEA collected 560 first draw (unless otherwise noted) samples of approximately 250 milliliters (ml) of water. "First draw" means the samples are collected before the fixture is used or flushed during the day. The first-draw sample results reflect a worst-case scenario, i.e., the highest lead level that would be consumed by building occupants. MDH recommends that fixtures are not used, eight to 18 hours prior to sampling fixtures.

Water samples were analyzed by Minnesota Valley Testing Laboratories (MVTL) in New Ulm, Minnesota, which uses EPA-approved analytical methods and quality control/assurance procedures. Samples were analyzed using the MVTL Method: ICP/MS EPA Method 200.8.

RESULTS & DISCUSSION

The water analyses results are listed below in Table 1. Ninety (90) sampled locations had lead content above the Minnesota Statute 121A.335 action level of five ppb. The laboratory reports and maps are provided in Appendix A. Laboratory results are reported in micrograms per liter (µg/L) which is equivalent to parts per billion (ppb).

Note: Samples collected from Fieldstone Elementary on November 13, 2024, were resampled on December 6, 2024, due to improper labeling. The corrected samples from December 6, 2024, will be used to determine compliance. The November 13, 2024, results are struck through in Appendix A to denote this.

Table 1: Water Testing Results Exceeding 5 ppb – November 12, 2024, November 13, 2024, and December 6, 2024

Sample Number	Building	Sampling Location	Fixture Type	Lead Results (ppb)
111224STMAHS-20	STMA HS	Dish Room West Middle SNK	Sink	7.96
111224STMAHS-27	STMA HS	Kitchen 2713-East SNK	Sink	5.98
111224STMAHS-36	STMA HS	Room 2804-Middle SNK	Sink	5.37
111224STMAHS-102	STMA HS	Room 3335-SNK	Sink	8.58
111224STMAHS-112	STMA HS	Room 1458-SNK #3	Sink	15.5
111224STMAHS-116	STMA HS	Room 1458-SNK #7	Sink	6.96
111224STMAHS-119	STMA HS	Room 1456-SNK #1	Sink	10.2
111224STMAHS-125	STMA HS	Room 1456-SNK #7	Sink	5.51
111224STMAHS-126	STMA HS	Room 1456-SNK #8	Sink	5.66
111224STMAHS-153	STMA HS	Room 1436-SNK #3	Sink	5.49
111224STMAHS-158	STMA HS	Room 1435-West SNK	Sink	13.7
111224STMAHS-170	STMA HS	Room 1434-SNK #6	Sink	15.3
111224STMAHS-172	STMA HS	Room 1432-SNK #1	Sink	6.36
111224STMAHS-188	STMA HS	Room 1418-SNK #7	Sink	15.8
111224STMAHS-189	STMA HS	Room 1417-SNK	Sink	8.73
111224STMAHS-190	STMA HS	Room 1416-SNK #1	Sink	14.1
111224STMAHS-193	STMA HS	Room 1416-SNK #4	Sink	38.6
111224STMAHS-194	STMA HS	Room 1416-SNK #5	Sink	33.7

© 2024 Institute for Environmental Assessment, Inc. All Rights Reserved.
www.ieasafety.com

Sample Number	Building	Sampling Location	Fixture Type	Lead Results (ppb)
120624FE-1	Fieldstone Elementary	Kitchen-SW SNK	Sink	5.86
120624FE-3	Fieldstone Elementary	Kitchen-West SNK	Sink	12.8
120624FE-4	Fieldstone Elementary	Kitchen-North SNK	Sink	8.65
120624FE-8	Fieldstone Elementary	Kitchen-SE STK	Steam Kettle	5.28
120624FE-10	Fieldstone Elementary	Kitchen-West SPR	Sprayer	17.8
120624FE-11	Fieldstone Elementary	Kitchen-East SPR	Sprayer	25.1
111324FE-23	Fieldstone Elementary	Office Next to Gymnasium-SNK	Sink	99.8
111324FE-49	Fieldstone Elementary	Room 209-SNK	Sink	5.16
111324FE-50	Fieldstone Elementary	Room 209-DF	Drinking Fountain	7.5
111324FE-55	Fieldstone Elementary	Room 218-SNK	Sink	5.05
111324FE-66	Fieldstone Elementary	Room 226-DF	Drinking Fountain	16.8
111324FE-67	Fieldstone Elementary	Room 225-SNK	Sink	9.87
111324FE-74	Fieldstone Elementary	Room 326-DF	Drinking Fountain	6.78
111324FE-75	Fieldstone Elementary	Room 325-SNK	Sink	8.48
111324FE-83	Fieldstone Elementary	Room 331-DF	Drinking Fountain	5.93
111324FE-84	Fieldstone Elementary	Room 322-SNK	Sink	9.47
111324FE-88	Fieldstone Elementary	Room 333-SNK #1	Sink	6.14
111324FE-93	Fieldstone Elementary	Room 333-SNK #6	Sink	8.07
111324FE-97	Fieldstone Elementary	Room 333-SNK #10	Sink	6.05
111324FE-100	Fieldstone Elementary	Room 333-SNK #13	Sink	5.23
111324FE-102	Fieldstone Elementary	Room 333-SNK #15	Sink	6.18
111324FE-119	Fieldstone Elementary	Room 334-SNK #16	Sink	5.42
111324FE-122	Fieldstone Elementary	Room 125-SNK	Sink	8.81
111324-FE-152	Fieldstone Elementary	Room 116-SNK	Sink	5.78
111324-FE-161	Fieldstone Elementary	Room 217-SNK	Sink	7.96
111324STME-5	St. Michael Elementary	Kitchen-STK	Steam Kettle	6.95
111324STME-9	St. Michael Elementary	Kitchen-Middle SPR	Sprayer	447
111324STME-23	St. Michael Elementary	Music Room Office-SNK	Sink	10.5
111324STME-24	St. Michael Elementary	Room 129 Office-SNK	Sink	32.1
111324STME-31	St. Michael Elementary	Room 133-SNK	Sink	67.7
111324STME-37	St. Michael Elementary	Art Room-North SNK	Sink	6.84
111324STME-42	St. Michael Elementary	Room 140 Bathroom-SNK	Sink	14.7
111324STME-48	St. Michael Elementary	Room 101-SNK	Sink	6.45
111324STME-49	St. Michael Elementary	Room 101-DF	Drinking Fountain	8.41
111324STME-50	St. Michael Elementary	Room 102-SNK	Sink	7.19
111324STME-51	St. Michael Elementary	Room 102-DF	Drinking Fountain	7.75
111324STME-54	St. Michael Elementary	Room 103-DF	Drinking Fountain	8.25
111324STME-55	St. Michael Elementary	Room 104-SNK	Sink	5.94

© 2024 Institute for Environmental Assessment, Inc. All Rights Reserved.
www.ieasafety.com

Sample Number	Building	Sampling Location	Fixture Type	Lead Results (ppb)
111324STME-56	St. Michael Elementary	Room 104-DF	Drinking Fountain	5.28
111324STME-59	St. Michael Elementary	Room 106-SNK	Sink	29.8
111324STME-61	St. Michael Elementary	Room 107-SNK	Sink	67.2
111324STME-65	St. Michael Elementary	Room 112-SNK	Sink	14.8
111324STME-67	St. Michael Elementary	Room 113-SNK	Sink	5.28
111324STME-69	St. Michael Elementary	Room 114-SNK	Sink	5.38
111324STME-70	St. Michael Elementary	Room 114-DF	Drinking Fountain	6.98
111324STME-73	St. Michael Elementary	Room 117-SNK	Sink	16
111324STME-79	St. Michael Elementary	Room 120-SNK	Sink	6.53
111324STME-89	St. Michael Elementary	Room 124-DF	Drinking Fountain	9.98
111324STME-90	St. Michael Elementary	Room 142-SNK	Sink	6.61
111324STME-92	St. Michael Elementary	Room 143-SNK	Sink	12.3
111324STME-93	St. Michael Elementary	Room 143-DF	Drinking Fountain	7.33
111324STME-94	St. Michael Elementary	Room 144-SNK	Sink	14
111324STME-95	St. Michael Elementary	Room 144-DF	Drinking Fountain	8.55
111324STME-96	St. Michael Elementary	Room 145-SNK	Sink	5.7
111324STME-97	St. Michael Elementary	Room 145-DF	Drinking Fountain	6.19
111324STME-101	St. Michael Elementary	Room 149-DF	Drinking Fountain	7.86
111324STME-102	St. Michael Elementary	Room 150-SNK	Sink	13.4
111324STME-103	St. Michael Elementary	Room 150-DF	Drinking Fountain	5.29
111324STME-107	St. Michael Elementary	Room 146-SNK	Sink	5.74
111324STME-108	St. Michael Elementary	Room 146-DF	Drinking Fountain	8.75
111324STME-109	St. Michael Elementary	Room 147-SNK	Sink	5.42
111324STME-110	St. Michael Elementary	Room 147-DF	Drinking Fountain	6.49
111224CEC-1	Community Education	Kitchen-NW KSN	Sink	7.81
111224CEC-2	Community Education	Kitchen-SW KSN	Sink	13.3
111224CEC-6	Community Education	Room 108-SNK	Sink	5.24
111224CEC-7	Community Education	Room 107-SNK	Sink	12.4
111224CEC-15	Community Education	Room 105 Office-SNK	Sink	13
111224CEC-24	Community Education	Room 206-SNK	Sink	62.3
111224CEC-28	Community Education	Room 204-DF	Drinking Fountain	5.17
111224CEC-44	Community Education	Room 305/306 Office-SNK	Sink	23.9
111224CEC-47	Community Education	Custodial Office Bathroom-SNK	Sink	8.82
111224CEC-49	Community Education	Room 301-SNK	Sink	7.34

ppb – parts per billion

© 2024 Institute for Environmental Assessment, Inc. All Rights Reserved.

CONCLUSIONS

Of the 560 fixtures sampled, 90 fixtures had lead levels above the Minnesota Statute 121A.335 action level of five ppb.

RECOMMENDATIONS

IEA recommends removing the fixtures with elevated lead content from service immediately. This can be completed by disconnecting the fixture from the water supply and/or posting signage noting the water is not potable. If additional water in the area is needed, bottled water meeting Food and Drug Administration (FDA) and State standards or another water source can be provided.

IEA recommends determining a remediation plan for the fixtures exceeding the indicated action level. IEA recommends selecting one of the following remediation options:

1) Determine if the fixture can be permanently changed to a non-potable fixture and label it accordingly. *(In this case, notification to parents, guardians, and staff within 30 days is required.)*
2) Disconnect the fixture from use permanently.
3) Remove, inspect, clean and/or replace aerators and retest to confirm a lower lead content.
4) Complete follow-up flush sampling and retesting to help determine the location of the lead content. *(These sample results will help determine if the lead source is in the fixture or interior plumbing to determine if replacing the fixture is an effective remediation option.)*

If remediation of the fixtures is not completed within 30 days, with lead levels documented below the MDH action level, parents, guardians, and staff must be notified.

The District is required to ensure the lead-in-water management plan is available on the district's website. In addition, annual notification of the lead-in-water management plan is included in the student handbook or another method used to communicate policy information. Lead-in-water testing records must be available upon request.

Test results and remediation documentation is required to be reported annually to the MDH by July 1st. Lead results and remediation documentation is required to be maintained by the District for 15 years.

Lead-in-water testing is required every five years in Minnesota schools.

GENERAL CONDITIONS

The analysis and opinions expressed in this report are based upon data obtained from St. Michael-Albertville ISD #885 at the indicated locations. This report does not reflect variations in conditions that may occur across the site, property, or facility. Actual conditions may vary and may not become evident without further assessment.

The report is prepared for the exclusive use of our client for specific application to the project discussed and has been prepared in accordance with generally accepted environmental, health, and safety practices. Other than as provided in the preceding sentence and in our Proposal #12370 dated August 26, 2024, regarding lead-in-water sampling at St. Michael-Albertville ISD #885, including the General Conditions attached thereto, no warranties are extended or made.

© 2024 Institute for Environmental Assessment, Inc. All Rights Reserved.

Please contact IEA if you would like assistance with any of the above recommendations or have questions regarding this report.

Sincerely,

IEA, Inc.



Daniel Holcomb, CSP, CHMM
Senior Account Manager

Reviewed by:



Mary Ferrian, CSP
EHS Division Manager

DH/khb 12172024

Enc.

© 2024 Institute for Environmental Assessment, Inc. All Rights Reserved.

Appendix A

Laboratory Testing Reports and Maps

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Community Education (70886)
Account #: 2190
Project #: 202410983

Client: Institute for Environmental Assessment (IEA)
PO: 202410983

Emma Squires-Sperling
IEA / Brooklyn Park
9201 W Broadway Suite #600
Brooklyn Park, MN 55445

Certificate of Analysis

Approval

All data reported has been reviewed and approved by:



Dave Smahel, Inorganic Chemistry/Feed Lab Manager New Ulm, MN

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:
MN LAB # 027-015-125ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:
MN LAB # 038-999-267ND W/DW # ND-016

Workorder Comments

All samples were preserved with nitric acid upon receipt at the laboratory.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Community Education (70886) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70886001 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-1 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen-NW KSN

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**7.81**	ug/L	15	EPA 200.8	11/26/2024 08:54	

Lab ID: 70886002 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-2 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen-SW KSN

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**13.3**	ug/L	15	EPA 200.8	11/26/2024 08:55	

Lab ID: 70886003 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-3 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen-East KSN

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.47**	ug/L	15	EPA 200.8	11/26/2024 08:56	

Lab ID: 70886004 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-4 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen-West SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 08:57	

Lab ID: 70886005 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-5 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen-East SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.97**	ug/L	15	EPA 200.8	11/26/2024 08:59	

Lab ID: 70886006 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-6 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 108-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.24**	ug/L	15	EPA 200.8	11/26/2024 09:00	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Community Education (70886) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70886007 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-7 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 107-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**12.4**	ug/L	15	EPA 200.8	11/26/2024 09:01	

Lab ID: 70886008 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-8 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 106-North SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.15**	ug/L	15	EPA 200.8	11/26/2024 09:02	

Lab ID: 70886009 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-9 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 106-South SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.25**	ug/L	15	EPA 200.8	11/26/2024 09:03	

Lab ID: 70886010 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-10 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Cafeteria-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 09:04	

Lab ID: 70886011 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-11 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Cafeteria-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 09:13	

Lab ID: 70886012 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-12 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 106-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 09:14	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Community Education (70886) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70886013 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-13 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 106-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 09:15	

Lab ID: 70886014 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-14 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 105-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 09:16	

Lab ID: 70886015 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-15 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 105 Office-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**13.0**	ug/L	15	EPA 200.8	11/26/2024 09:17	

Lab ID: 70886016 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-16 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Main Office Prep Room-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.49**	ug/L	15	EPA 200.8	11/26/2024 09:19	

Lab ID: 70886017 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-17 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 209-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.67**	ug/L	15	EPA 200.8	11/26/2024 09:20	

Lab ID: 70886018 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-18 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 209-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.21**	ug/L	15	EPA 200.8	11/26/2024 09:21	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Community Education (70886) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70886019 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-19 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 208-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 09:22	

Lab ID: 70886020 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-20 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 208-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 09:23	

Lab ID: 70886021 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-21 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 207-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 09:36	

Lab ID: 70886022 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-22 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 207-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.12**	ug/L	15	EPA 200.8	11/26/2024 09:37	

Lab ID: 70886023 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-23 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 207-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.17**	ug/L	15	EPA 200.8	11/26/2024 09:38	

Lab ID: 70886024 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-24 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 206-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**62.3**	ug/L	15	EPA 200.8	11/26/2024 09:40	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Community Education (70886) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70886025 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-25 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 205-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.97**	ug/L	15	EPA 200.8	11/26/2024 09:41	

Lab ID: 70886026 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-26 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 205-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.72**	ug/L	15	EPA 200.8	11/26/2024 09:42	

Lab ID: 70886027 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-27 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 204-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.20**	ug/L	15	EPA 200.8	11/26/2024 09:43	

Lab ID: 70886028 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-28 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 204-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.17**	ug/L	15	EPA 200.8	11/26/2024 09:44	

Lab ID: 70886029 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-29 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 201-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 09:45	

Lab ID: 70886030 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-30 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 201-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 09:46	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Community Education (70886) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70886031 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-31 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 201-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.39**	ug/L	15	EPA 200.8	11/26/2024 09:55	

Lab ID: 70886032 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-32 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 201-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.51**	ug/L	15	EPA 200.8	11/26/2024 09:56	

Lab ID: 70886033 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-33 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 203-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.85**	ug/L	15	EPA 200.8	11/26/2024 09:57	

Lab ID: 70886034 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-35 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 202-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.07**	ug/L	15	EPA 200.8	11/26/2024 09:58	

Lab ID: 70886035 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-36 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 202-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.63**	ug/L	15	EPA 200.8	11/26/2024 09:59	

Lab ID: 70886036 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-37 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 309-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 10:01	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Community Education (70886) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70886037 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-38 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 307-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 10:02	

Lab ID: 70886038 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-39 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 307-NE SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.30**	ug/L	15	EPA 200.8	11/26/2024 10:03	

Lab ID: 70886039 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-40 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 307-East SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.82**	ug/L	15	EPA 200.8	11/26/2024 10:04	

Lab ID: 70886040 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-41 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 307-SE SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.60**	ug/L	15	EPA 200.8	11/26/2024 10:05	

Lab ID: 70886041 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-42 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 307-South Middle SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.43**	ug/L	15	EPA 200.8	11/26/2024 10:14	

Lab ID: 70886042 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-43 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 307-SW SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.09**	ug/L	15	EPA 200.8	11/26/2024 10:15	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Community Education (70886) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70886043 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-44 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 305/306 Office-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**23.9**	ug/L	15	EPA 200.8	11/27/2024 10:49	

Lab ID: 70886044 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-45 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 304/305 Office-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 10:16	

Lab ID: 70886045 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-46 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 310-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.62**	ug/L	15	EPA 200.8	11/26/2024 10:17	

Lab ID: 70886046 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-47 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Custodial Office Bathroom-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**8.82**	ug/L	15	EPA 200.8	11/26/2024 10:18	

Lab ID: 70886047 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-48 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 304-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 10:19	

Lab ID: 70886048 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-49 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 301-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**7.34**	ug/L	15	EPA 200.8	11/26/2024 10:21	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Community Education (70886) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70886049 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-50 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 207-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 10:22	

Lab ID: 70886050 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-51 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 304-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 10:23	

Lab ID: 70886051 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224CEC-52 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 307-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 10:24	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Community Education (70886) **Client:** Institute for Environmental Assessment (IEA)



MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Community Education (70886) **Client:** Institute for Environmental Assessment (IEA)

70886

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

Client Name	St. Michael-Albertville ISD #885	Building Name	Community Education	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Jake Schisler	Date	Time 6:00AM	Analyzed By (Company)	Analyst / Date & Time
Reviewed By		Date	Time		
Shipped By	Sashya Wandmaker	Date	Time 10:00AM	Turnaround Time	Notes
Received By		Date	Time	Sample Condition	Temperature

Lab Number	Sample Number	Sample Location	Sample Type: Water	Soil	Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
		Lower Level							
01	111224CEC-1	Kitchen - NW KSN	X				250mL unpreserved	Lead	
02	111224CEC-2	Kitchen - SW KSN	X				250mL unpreserved	Lead	
03	111224CEC-3	Kitchen - East KSN	X				250mL unpreserved	Lead	
04	111224CEC-4	Kitchen - West SPR	X				250mL unpreserved	Lead	
05	111224CEC-5	Kitchen - East SPR	X				250mL unpreserved	Lead	
06	111224CEC-6	Room 108 - SNK	X				250mL unpreserved	Lead	
07	111224CEC-7	Room 107 - SNK	X				250mL unpreserved	Lead	
08	111224CEC-8	Room 106 - North SNK	X				250mL unpreserved	Lead	
09	111224CEC-9	Room 106 - South SNK	X				250mL unpreserved	Lead	
10	111224CEC-10	Cafeteria - WC	X				250mL unpreserved	Lead	
11	111224CEC-11	Cafeteria - WBF	X				250mL unpreserved	Lead	
12	111224CEC-12	Outside Room 106 - WC	X				250mL unpreserved	Lead	
13	111224CEC-13	Outside Room 106 - WBF	X				250mL unpreserved	Lead	
14	111224CEC-14	Room 105 - SNK	X				250mL unpreserved	Lead	
15	111224CEC-15	Room 105 Office - SNK	X				250mL unpreserved	Lead	
		Main Level							
16	111224CEC-16	Main Office Prep Room - SNK	X				250mL unpreserved	Lead	
17	111224CEC-17	Room 209 - SNK	X				250mL unpreserved	Lead	
18	111224CEC-18	Room 209 - DF	X				250mL unpreserved	Lead	
19	111224CEC-19	Outside Room 208 - WC	X				250mL unpreserved	Lead	
20	111224CEC-20	Outside Room 208 - WBF	X				250mL unpreserved	Lead	
21	111224CEC-21	Outside Room 207 - WC	X				250mL unpreserved	Lead	
22	111224CEC-22	Room 207 - SNK	X				250mL unpreserved	Lead	
23	111224CEC-23	Room 207 - DF	X				250mL unpreserved	Lead	
24	111224CEC-24	Room 206 - SNK	X				250mL unpreserved	Lead	
25	111224CEC-25	Room 205 - SNK	X				250mL unpreserved	Lead	
26	111224CEC-26	Room 205 - DF	X				250mL unpreserved	Lead	

AMB
SP 13Nov24 14:14 19.0 TT74

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

SP 13 Nov 24 1414 AMB 19.0 774

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Community Education (70886) **Client:** Institute for Environmental Assessment (IEA)

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

Client Name	St. Michael-Albertville ISD #885	Building Name	Community Education	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Jake Schisler	Date		Time 6:00AM	Analyzed By (Company) / Analyst / Date & Time
Reviewed By		Date		Time	
Shipped By	Sashya Wandmaker	Date		Time 10:00AM	Turnaround Time / Notes
Received By		Date		Time	Sample Condition / Temperature

Lab Number	Sample Number	Sample Location	Sample Type: Water	Soil	Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
27	111224CEC-27	Room 204 - SNK	X				250mL unpreserved	Lead	
28	111224CEC-28	Room 204 - DF	X				250mL unpreserved	Lead	
29	111224CEC-29	Outside Room 201 - WC	X				250mL unpreserved	Lead	
30	111224CEC-30	Outside Room 201 - WBF	X				250mL unpreserved	Lead	
31	111224CEC-31	Room 201 - SNK	X				250mL unpreserved	Lead	
32	111224CEC-32	Room 201 - DF	X				250mL unpreserved	Lead	
33	111224CEC-33	Room 203 - SNK	X				250mL unpreserved	Lead	
34	111224CEC-35	Room 202 - SNK	X				250mL unpreserved	Lead	
35	111224CEC-36	Room 202 - DF	X				250mL unpreserved	Lead	
		Upper Level							
	111224CEC-37	Room 309 - SNK	X				250mL unpreserved	Lead	
	111224CEC-38	Outside Room 307 - WC	X				250mL unpreserved	Lead	
	111224CEC-39	Room 307 - NE SNK	X				250mL unpreserved	Lead	
	111224CEC-40	Room 307 - East SNK	X				250mL unpreserved	Lead	
	111224CEC-41	Room 307 - SE SNK	X				250mL unpreserved	Lead	
	111224CEC-42	Room 307 - South Middle SNK	X				250mL unpreserved	Lead	
	111224CEC-43	Room 307 - SW SNK	X				250mL unpreserved	Lead	
	111224CEC-44	Room 305/306 Office - SNK	X				250mL unpreserved	Lead	
	111224CEC-45	Room 304/305 Office - SNK	X				250mL unpreserved	Lead	
	111224CEC-46	Room 310 - SNK	X				250mL unpreserved	Lead	
	111224CEC-47	Custodial Office Bathroom - SNK	X				250mL unpreserved	Lead	
	111224CEC-48	Outside Room 304 - WC	X				250mL unpreserved	Lead	
	111224CEC-49	Room 301 - SNK	X				250mL unpreserved	Lead	
	111224CEC-50	Outside Room 207-WBF	X				250mL unpreserved	Lead	
	111224CEC-51	Outside Room 304 - WBF	X				250mL unpreserved	Lead	
	111224CEC-52	Outside Room 307 - WBF	X				250mL unpreserved	Lead	
	~~111224CEC-34~~	~~Room 203 - DF~~	X				~~250mL unpreserved~~	~~Lead~~	
			X				250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Community Education (70886) **Client:** Institute for Environmental Assessment (IEA)

Sample Condition Checklist

Date: 13 Nov 24 Time: 1414 ☐ AM ☒ PM By: SP

Account Name: IEA - CEC Account # ~

Bill of Lading #: ~ Cooler #: ~

Temp: 19.0 °C ROI ☐ Ambient ☒ Tracking #: ~

TM#: 774 Ice Crystals Present in Sample ☐ ~

MVTL Courier: Dan Other:

MVTL Route: Metro Walk-In ☐ UPS Air ☐ FedEx Air ☐ SpeeDee ☐

Mail ☐ UPS Ground ☐ Fed Ex Ground ☐

Containers Supplied by MVTL: Yes ☒ No ☐ Designate customer supplied containers as "Other" in container size column


Comments:

Number	Containers Size (mL)	Container Type	Preservation	pH
51	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	Low Level Mercury Kit	***!!DO NOT OPEN THE PLASTIC BAGS HOLDING THE SAMPLE BOTTLES!!***		
	4 oz Jar	Clear Amber	MeOH None	n/a
	2 oz Jar	Clear Amber	MeOH None	n/a
	Vials Individual Set of 2 Set of 3	Clear Amber	HCl H_3PO_4 H_2SO_4 None	n/a
	Vials Individual Set of 2 Set of 3	Clear Amber	HCl H_3PO_4 H_2SO_4 None	n/a
	Trip Blank Individual Set of 2 Set of 3	n/a		
	Moisture Vial	n/a		
	Manure Bottle	n/a		

*ANY CONTAINER SENT TO A SUBCONTRACT LABORATORY WILL NOT BE CHECKED FOR PRESERVATION!

Form # 30-911001-0 Page 1 of 1 Effective Date: 29 September 2021


MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



INSTITUTE FOR ENVIRONMENTAL ASSESSMENT
9201 West Broadway Brooklyn Park, MN 55445
Tel: 763.315.7900 Toll Free: 800.233.9513
Fax: 763.315.7920

COMMUNITY EDUCATION CENTER

FIRST LEVEL FLOOR PLAN | DEC. 2024




INSTITUTE FOR
ENVIRONMENTAL ASSESSMENT
9201 West Broadway Brooklyn Park, MN 55445
Tel: 763.315.7900 Toll Free: 800.233.9513
Fax: 763.315.7920

COMMUNITY EDUCATION CENTER

SECOND LEVEL FLOOR PLAN | DEC. 2024

N



INSTITUTE FOR
ENVIRONMENTAL ASSESSMENT
9201 West Broadway Brooklyn Park, MN 55445
Tel: 763.315.7900 Toll Free: 800.233.9513
Fax: 763.315.7920

COMMUNITY EDUCATION CENTER

THIRD LEVEL FLOOR PLAN | DEC. 2024

N

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086)
Account #: 2190
Project #: 202410983

Client: Institute for Environmental Assessment (IEA)
PO: 202410983

Emma Squires-Sperling
IEA / Brooklyn Park
9201 W Broadway Suite #600
Brooklyn Park, MN 55445

Certificate of Analysis

Approval

All data reported has been reviewed and approved by:



Dave Smahel, Inorganic Chemistry/Feed Lab Manager New Ulm, MN

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:
MN LAB # 027-015-125ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:
MN LAB # 038-999-267ND W/DW # ND-016

Workorder Comments

All samples were preserved with nitric acid upon receipt at the laboratory.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086001 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-1 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Kitchen-SW Sink

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.92**	ug/L	15	EPA 200.8	11/25/2024 09:44	

Lab ID: 71086002 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-2 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Kitchen-SE Sink

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.30**	ug/L	15	EPA 200.8	11/25/2024 09:45	

Lab ID: 71086003 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-3 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Kitchen-West Sink

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.50**	ug/L	15	EPA 200.8	11/25/2024 09:46	

Lab ID: 71086004 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-5 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Kitchen-East Sink

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.56**	ug/L	15	EPA 200.8	11/25/2024 09:47	

Lab ID: 71086005 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-6 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Kitchen-HWD

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 09:48	

Lab ID: 71086006 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-7 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Kitchen-NW STK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.89**	ug/L	15	EPA 200.8	11/25/2024 09:49	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086007 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-8 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Kitchen-SE STK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.22**	ug/L	15	EPA 200.8	11/25/2024 09:50	

Lab ID: 71086008 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-9 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Kitchen-South SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**21.1**	ug/L	15	EPA 200.8	11/25/2024 09:51	

Lab ID: 71086009 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-10 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Kitchen-West SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.84**	ug/L	15	EPA 200.8	11/26/2024 11:30	

Lab ID: 71086010 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-11 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Kitchen-East SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**7.66**	ug/L	15	EPA 200.8	11/26/2024 11:31	

Lab ID: 71086011 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-12 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Dishroom-NW SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.82**	ug/L	15	EPA 200.8	11/25/2024 09:53	

Lab ID: 71086012 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-13 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Dishroom-Middle SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.31**	ug/L	15	EPA 200.8	11/25/2024 10:01	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086013 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-14 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Dishroom-SE SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.16**	ug/L	15	EPA 200.8	11/25/2024 10:02	

Lab ID: 71086014 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-15 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Dishroom-West SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.54**	ug/L	15	EPA 200.8	11/25/2024 10:04	

Lab ID: 71086015 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-16 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Dishroom-East SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.77**	ug/L	15	EPA 200.8	11/25/2024 10:05	

Lab ID: 71086016 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-17 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Cafeteria-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 10:06	

Lab ID: 71086017 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-18 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Cafeteria-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 10:07	

Lab ID: 71086018 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-19 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Hallway Outside Cafeteria-West WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 10:08	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086019 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-20 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Hallway Outside Cafeteria-East WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.58**	ug/L	15	EPA 200.8	11/25/2024 10:09	

Lab ID: 71086020 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-21 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Gymnasium-West DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 10:10	

Lab ID: 71086021 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-22 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Gymnasium-East DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 10:11	

Lab ID: 71086022 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-23 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Office Next to Gymnasium-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**99.8**	ug/L	15	EPA 200.8	11/26/2024 11:42	

Lab ID: 71086023 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-24 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Hallway Outside Gymnasium-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 10:20	

Lab ID: 71086024 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-25 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Hallway Outside Gymnasium-West WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 10:21	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086025 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-26 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Hallway Outside Gymnasium-East WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 10:22	

Lab ID: 71086026 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-27 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Hallway by Main Office-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 10:24	

Lab ID: 71086027 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-28 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Staff Dining-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.11**	ug/L	15	EPA 200.8	11/25/2024 10:25	

Lab ID: 71086028 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-29 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Nurse-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.72**	ug/L	15	EPA 200.8	11/25/2024 10:26	

Lab ID: 71086029 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-30 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Main Office Mail Room-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.29**	ug/L	15	EPA 200.8	11/25/2024 10:27	

Lab ID: 71086030 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-31 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 416-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 10:28	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086031 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-32 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 417-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 10:29	

Lab ID: 71086032 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-33 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Media Center-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 10:30	

Lab ID: 71086033 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-34 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Media Center Workroom-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.70**	ug/L	15	EPA 200.8	11/25/2024 10:44	

Lab ID: 71086034 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-35 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 215-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.31**	ug/L	15	EPA 200.8	11/25/2024 10:45	

Lab ID: 71086035 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-36 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 215-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.53**	ug/L	15	EPA 200.8	11/25/2024 10:46	

Lab ID: 71086036 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-37 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 216-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.57**	ug/L	15	EPA 200.8	11/25/2024 10:47	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086037 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-38 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 216-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.87**	ug/L	15	EPA 200.8	11/25/2024 10:48	

Lab ID: 71086038 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-39 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 217-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.84**	ug/L	15	EPA 200.8	11/25/2024 10:49	

Lab ID: 71086039 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-40 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 217-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.51**	ug/L	15	EPA 200.8	11/25/2024 10:50	

Lab ID: 71086040 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-41 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 214-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.14**	ug/L	15	EPA 200.8	11/25/2024 10:51	

Lab ID: 71086041 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-42 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 214-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.78**	ug/L	15	EPA 200.8	11/25/2024 10:52	

Lab ID: 71086042 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-43 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 212-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.70**	ug/L	15	EPA 200.8	11/25/2024 10:54	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086043 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-44 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 212-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.75**	ug/L	15	EPA 200.8	11/25/2024 11:02	

Lab ID: 71086044 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-45 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 211-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.86**	ug/L	15	EPA 200.8	11/25/2024 11:04	

Lab ID: 71086045 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-46 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 211-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 11:05	

Lab ID: 71086046 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-47 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 210-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.30**	ug/L	15	EPA 200.8	11/25/2024 11:06	

Lab ID: 71086047 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-48 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 210-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 11:07	

Lab ID: 71086048 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-49 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 209-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.16**	ug/L	15	EPA 200.8	11/22/2024 18:56	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086049 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-50 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 209-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**7.50**	ug/L	15	EPA 200.8	11/22/2024 18:57	

Lab ID: 71086050 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-51 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: East Courtyard-South WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 18:58	

Lab ID: 71086051 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-52 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: East Courtyard-South SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.08**	ug/L	15	EPA 200.8	11/22/2024 18:59	

Lab ID: 71086052 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-53 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: East Courtyard-North WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 19:01	

Lab ID: 71086053 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-54 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: East Courtyard-North SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.21**	ug/L	15	EPA 200.8	11/22/2024 19:02	

Lab ID: 71086054 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-55 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 218-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.05**	ug/L	15	EPA 200.8	11/22/2024 19:03	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086055 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-56 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 218-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.28**	ug/L	15	EPA 200.8	11/22/2024 19:04	

Lab ID: 71086056 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-57 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 219-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 19:13	

Lab ID: 71086057 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-58 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 219-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.45**	ug/L	15	EPA 200.8	11/22/2024 19:14	

Lab ID: 71086058 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-59 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 220-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.64**	ug/L	15	EPA 200.8	11/22/2024 19:15	

Lab ID: 71086059 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-60 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 220-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.55**	ug/L	15	EPA 200.8	11/22/2024 19:16	

Lab ID: 71086060 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-61 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 221-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 19:17	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086061 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-62 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 221-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.65**	ug/L	15	EPA 200.8	11/22/2024 19:18	

Lab ID: 71086062 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-63 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 223-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.80**	ug/L	15	EPA 200.8	11/22/2024 19:19	

Lab ID: 71086063 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-64 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 223-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 19:21	

Lab ID: 71086064 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-65 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 226-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.69**	ug/L	15	EPA 200.8	11/22/2024 19:22	

Lab ID: 71086065 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-66 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 226-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**16.8**	ug/L	15	EPA 200.8	11/22/2024 19:23	

Lab ID: 71086066 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-67 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 225-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**9.87**	ug/L	15	EPA 200.8	11/22/2024 19:36	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086067 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-68 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 225-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.99**	ug/L	15	EPA 200.8	11/22/2024 19:37	

Lab ID: 71086068 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-69 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 224-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.25**	ug/L	15	EPA 200.8	11/22/2024 19:38	

Lab ID: 71086069 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-70 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 224-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 19:40	

Lab ID: 71086070 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-71 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 328-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.13**	ug/L	15	EPA 200.8	11/22/2024 19:41	

Lab ID: 71086071 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-72 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 328-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.34**	ug/L	15	EPA 200.8	11/22/2024 19:42	

Lab ID: 71086072 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-73 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 326-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 19:43	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086073 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-74 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 326-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.78**	ug/L	15	EPA 200.8	11/22/2024 19:44	

Lab ID: 71086074 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-75 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 325-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**8.48**	ug/L	15	EPA 200.8	11/22/2024 19:45	

Lab ID: 71086075 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-76 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 325-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.09**	ug/L	15	EPA 200.8	11/22/2024 19:46	

Lab ID: 71086076 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-77 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 324-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.22**	ug/L	15	EPA 200.8	11/22/2024 19:55	

Lab ID: 71086077 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-78 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 324-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.75**	ug/L	15	EPA 200.8	11/22/2024 19:56	

Lab ID: 71086078 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-81 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 323-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 19:57	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086079 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-82 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 331-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.11**	ug/L	15	EPA 200.8	11/22/2024 19:59	

Lab ID: 71086080 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-83 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 331-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.93**	ug/L	15	EPA 200.8	11/22/2024 20:00	

Lab ID: 71086081 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-84 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 322-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**9.47**	ug/L	15	EPA 200.8	11/22/2024 20:01	

Lab ID: 71086082 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-85 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 322-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.34**	ug/L	15	EPA 200.8	11/22/2024 20:02	

Lab ID: 71086083 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-86 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 320-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.23**	ug/L	15	EPA 200.8	11/22/2024 20:03	

Lab ID: 71086084 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-87 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 320-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.91**	ug/L	15	EPA 200.8	11/22/2024 20:04	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086085 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-88 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 333-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.14**	ug/L	15	EPA 200.8	11/22/2024 20:05	

Lab ID: 71086086 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-89 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 333-SNK #2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.26**	ug/L	15	EPA 200.8	11/22/2024 20:14	

Lab ID: 71086087 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-90 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 333-SNK #3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.61**	ug/L	15	EPA 200.8	11/22/2024 20:15	

Lab ID: 71086088 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-92 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 333-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.36**	ug/L	15	EPA 200.8	11/22/2024 20:16	

Lab ID: 71086089 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-93 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 333-SNK #6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**8.07**	ug/L	15	EPA 200.8	11/22/2024 20:17	

Lab ID: 71086090 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-94 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 333-SNK #7

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.19**	ug/L	15	EPA 200.8	11/22/2024 20:19	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086091 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-95 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 333-SNK #8

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.06**	ug/L	15	EPA 200.8	11/22/2024 20:20	

Lab ID: 71086092 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-96 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 333-SNK #9

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.03**	ug/L	15	EPA 200.8	11/22/2024 20:21	

Lab ID: 71086093 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-97 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 333-SNK #10

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.05**	ug/L	15	EPA 200.8	11/22/2024 20:22	

Lab ID: 71086094 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-98 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 333-SNK #11

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 20:23	

Lab ID: 71086095 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-99 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 333-SNK #12

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.64**	ug/L	15	EPA 200.8	11/22/2024 20:24	

Lab ID: 71086096 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-100 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 333-SNK #13

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.23**	ug/L	15	EPA 200.8	11/25/2024 11:08	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086097 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-101 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 333-SNK #14

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.35**	ug/L	15	EPA 200.8	11/25/2024 11:09	

Lab ID: 71086098 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-102 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 333-SNK #15

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.18**	ug/L	15	EPA 200.8	11/26/2024 11:37	

Lab ID: 71086099 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-103 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 333-SNK #16

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.30**	ug/L	15	EPA 200.8	11/25/2024 11:10	

Lab ID: 71086100 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-119 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 334-SNK #16

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.42**	ug/L	15	EPA 200.8	11/25/2024 11:11	

Lab ID: 71086101 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-120 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 124-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.12**	ug/L	15	EPA 200.8	11/26/2024 11:38	

Lab ID: 71086102 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-121 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 124-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.80**	ug/L	15	EPA 200.8	11/25/2024 11:12	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086103 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-122 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 125-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**8.81**	ug/L	15	EPA 200.8	11/26/2024 11:39	

Lab ID: 71086104 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-123 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 125-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 11:21	

Lab ID: 71086105 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-124 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 126-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.45**	ug/L	15	EPA 200.8	11/25/2024 11:22	

Lab ID: 71086106 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-125 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 126-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.68**	ug/L	15	EPA 200.8	11/25/2024 11:23	

Lab ID: 71086107 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-126 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 123-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.77**	ug/L	15	EPA 200.8	11/25/2024 11:25	

Lab ID: 71086108 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-127 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 123-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.61**	ug/L	15	EPA 200.8	11/25/2024 11:26	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086109 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-128 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 121-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.22**	ug/L	15	EPA 200.8	11/25/2024 11:27	

Lab ID: 71086110 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-129 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 121-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.72**	ug/L	15	EPA 200.8	11/25/2024 11:28	

Lab ID: 71086111 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-130 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 120-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.79**	ug/L	15	EPA 200.8	11/26/2024 11:40	

Lab ID: 71086112 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324FE-131 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 120-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 11:29	

Lab ID: 71086113 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-132 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 119-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.63**	ug/L	15	EPA 200.8	11/25/2024 11:30	

Lab ID: 71086114 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-133 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 119-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.51**	ug/L	15	EPA 200.8	11/25/2024 11:31	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086115 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-134 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 118-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.64**	ug/L	15	EPA 200.8	11/25/2024 11:45	

Lab ID: 71086116 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-135 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 118-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 11:46	

Lab ID: 71086117 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-136 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: West Courtyard-North WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 11:47	

Lab ID: 71086118 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-137 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: West Courtyard-North SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.50**	ug/L	15	EPA 200.8	11/25/2024 11:48	

Lab ID: 71086119 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-138 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: West Courtyard-South WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 11:49	

Lab ID: 71086120 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-139 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: West Courtyard-South SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.91**	ug/L	15	EPA 200.8	11/25/2024 11:50	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086121 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-140 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 109-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.78**	ug/L	15	EPA 200.8	11/25/2024 11:51	

Lab ID: 71086122 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-141 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 109-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 11:52	

Lab ID: 71086123 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-142 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 110-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.53**	ug/L	15	EPA 200.8	11/25/2024 11:53	

Lab ID: 71086124 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-143 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 110-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.55**	ug/L	15	EPA 200.8	11/25/2024 11:55	

Lab ID: 71086125 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-144 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 111-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.24**	ug/L	15	EPA 200.8	11/25/2024 12:03	

Lab ID: 71086126 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-145 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 111-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 12:05	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086127 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-146 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 112-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.07**	ug/L	15	EPA 200.8	11/25/2024 12:06	

Lab ID: 71086128 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-147 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 112-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 12:07	

Lab ID: 71086129 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-148 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 114-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.83**	ug/L	15	EPA 200.8	11/25/2024 12:08	

Lab ID: 71086130 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-149 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 114-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.64**	ug/L	15	EPA 200.8	11/25/2024 12:09	

Lab ID: 71086131 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-150 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 117-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.35**	ug/L	15	EPA 200.8	11/25/2024 12:10	

Lab ID: 71086132 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-151 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 117-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.55**	ug/L	15	EPA 200.8	11/25/2024 12:11	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086133 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-152 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 116-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.78**	ug/L	15	EPA 200.8	11/25/2024 12:12	

Lab ID: 71086134 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-153 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 116-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.17**	ug/L	15	EPA 200.8	11/25/2024 12:13	

Lab ID: 71086135 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-154 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 115-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.00**	ug/L	15	EPA 200.8	11/26/2024 15:33	

Lab ID: 71086136 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-155 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 115-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.89**	ug/L	15	EPA 200.8	11/26/2024 15:35	

Lab ID: 71086137 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-156 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 321-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.80**	ug/L	15	EPA 200.8	11/25/2024 12:27	

Lab ID: 71086138 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-157 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: West Courtyard-North WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 12:28	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71086139 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-158 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: West Courtyard-South WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 12:29	

Lab ID: 71086140 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-159 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: East Courtyard-South WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 12:30	

Lab ID: 71086141 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-160 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: East Courtyard-North WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 15:36	

Lab ID: 71086142 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-161 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Room 217-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**7.96**	ug/L	15	EPA 200.8	11/25/2024 12:31	


Lab ID: 71086143 **Date Collected:** 11/13/2024 06:00 **Matrix:** Potable Water
Sample ID: 111324-FE-162 **Date Received:** 11/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Hallway Outside Cafe-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 12:32	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)



MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

71086

Client Name	St. Michael-Albertville ISD #885	Building Name	Fieldstone Elementary	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Jake Schisler & Rebecca Escamilla	Date 11/13/2024	Time 6:00AM	Analyzed By (Company)	Analyst / Date & Time
Reviewed By		Date	Time		
Shipped By	Sashya Wandmaker	Date	Time 10:00AM	Turnaround Time	Notes
Received By		Date	Time	Sample Condition	Temperature

Lab Number	Sample Number	Sample Location	Sample Type: Water	Soil	Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
01	111324FE-1	Kitchen - SW SNK	X				250mL unpreserved	Lead	
02	111324FE-2	Kitchen - SE SNK	X				250mL unpreserved	Lead	NFD
03	111324FE-3	Kitchen - West SNK	X				250mL unpreserved	Lead	
04	111324FE-5	Kitchen - East SNK	X				250mL unpreserved	Lead	
05	111324FE-6	Kitchen - HWD	X				250mL unpreserved	Lead	
06	111324FE-7	Kitchen - NW STK	X				250mL unpreserved	Lead	
07	111324FE-8	Kitchen - SE STK	X				250mL unpreserved	Lead	
08	111324FE-9	Kitchen - South SPR	X				250mL unpreserved	Lead	
09	111324FE-10	Kitchen - West SPR	X				250mL unpreserved	Lead	
10	111324FE-11	Kitchen - East SPR	X				250mL unpreserved	Lead	
11	111324FE-12	Dishroom - NW SNK	X				250mL unpreserved	Lead	
12	111324FE-13	Dishroom - Middle SNK	X				250mL unpreserved	Lead	
13	111324FE-14	Dishroom - SE SNK	X				250mL unpreserved	Lead	
14	111324FE-15	Dishroom - West SPR	X				250mL unpreserved	Lead	
15	111324FE-16	Dishroom - East SPR	X				250mL unpreserved	Lead	
16	111324FE-17	Cafeteria - WC	X				250mL unpreserved	Lead	
17	111324FE-18	Cafeteria - WBF	X				250mL unpreserved	Lead	
18	111324FE-19	Hallway Outside Cafeteria - West WC	X				250mL unpreserved	Lead	
19	111324FE-20	Hallway Outside Cafeteria - East WC	X				250mL unpreserved	Lead	
20	111324FE-21	Gymnasium - West DF	X				250mL unpreserved	Lead	
21	111324FE-22	Gymnasium - East DF	X				250mL unpreserved	Lead	
22	111324FE-23	Office Next to Gymnasium - SNK	X				250mL unpreserved	Lead	
23	111324FE-24	Hallway Outside Gymnasium - WBF	X				250mL unpreserved	Lead	
24	111324FE-25	Hallway Outside Gymnasium - West WC	X				250mL unpreserved	Lead	
25	111324FE-26	Hallway Outside Gymnasium - East WC	X				250mL unpreserved	Lead	
26	111324FE-27	Hallway By Main Office - WC	X				250mL unpreserved	Lead	
27	111324FE-28	Staff Dining - SNK	X				250mL unpreserved	Lead	
28	111324FE-29	Nurse - SNK	X				250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

14 Nov 24 1400 AMB 19.0 774

SP 14 Nov 24 1400 AMB 19.0 774

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

71086

Client Name	St. Michael-Albertville ISD #885	Building Name	Fieldstone Elementary	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Jake Schisler & Rebecca Escamilla	Date 11/13/2024	Time 6:00AM	Analyzed By (Company)	Analyst / Date & Time
Reviewed By		Date	Time		
Shipped By	Sashya Wandmaker	Date	Time 10:00AM	Turnaround Time	Notes
Received By		Date	Time	Sample Condition	Temperature

Lab Number	Sample Number	Sample Location	Sample Type: Water	Soil	Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
29	111324FE-30	Main Office Mail Room - SNK	X				250mL unpreserved	Lead	
30	111324FE-31	Room 416 - WC	X				250mL unpreserved	Lead	
31	111324FE-32	Room 417 - WC	X				250mL unpreserved	Lead	
32	111324FE-33	Media Center - WC	X				250mL unpreserved	Lead	
33	111324FE-34	Media Center Workroom - SNK	X				250mL unpreserved	Lead	
34	111324FE-35	Room 215 - SNK	X				250mL unpreserved	Lead	
35	111324FE-36	Room 215 - DF	X				250mL unpreserved	Lead	
36	111324FE-37	Room 216 - SNK	X				250mL unpreserved	Lead	
37	111324FE-38	Room 216 - DF	X				250mL unpreserved	Lead	
38	111324FE-39	Room 217 - SNK	X				250mL unpreserved	Lead	
39	111324FE-40	Room 217 - DF	X				250mL unpreserved	Lead	
40	111324FE-41	Room 214 - SNK	X				250mL unpreserved	Lead	
41	111324FE-42	Room 214 - DF	X				250mL unpreserved	Lead	
42	111324FE-43	Room 212 - SNK	X				250mL unpreserved	Lead	
43	111324FE-44	Room 212 - DF	X				250mL unpreserved	Lead	
44	111324FE-45	Room 211 - SNK	X				250mL unpreserved	Lead	NFD
45	111324FE-46	Room 211 - DF	X				250mL unpreserved	Lead	
46	111324FE-47	Room 210 - SNK	X				250mL unpreserved	Lead	
47	111324FE-48	Room 210 - DF	X				250mL unpreserved	Lead	
48	111324FE-49	Room 209 - SNK	X				250mL unpreserved	Lead	
49	111324FE-50	Room 209 - DF	X				250mL unpreserved	Lead	
50	111324FE-51	East Courtyard - South WC	X				250mL unpreserved	Lead	
51	111324FE-52	East Courtyard - South SNK	X				250mL unpreserved	Lead	
52	111324FE-53	East Courtyard - North WC	X				250mL unpreserved	Lead	
53	111324FE-54	East Courtyard - North SNK	X				250mL unpreserved	Lead	
54	111324FE-55	Room 218 - SNK	X				250mL unpreserved	Lead	NFD
55	111324FE-56	Room 218 - DF	X				250mL unpreserved	Lead	
56	111324FE-57	Room 219 - SNK	X				250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

71086

Client Name	St. Michael-Albertville ISD #885	Building Name	Fieldstone Elementary	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Jake Schisler & Rebecca Escamilla	Date 11/13/2024	Time 6:00AM	Analyzed By (Company)	Analyst / Date & Time
Reviewed By		Date	Time		
Shipped By	Sashya Wandmaker	Date	Time 10:00AM	Turnaround Time	Notes
Received By		Date	Time	Sample Condition	Temperature

Lab Number	Sample Number	Sample Location	Sample Type: Water	Soil	Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
57	111324FE-58	Room 219 - DF	X				250mL unpreserved	Lead	
58	111324FE-59	Room 220 - SNK	X				250mL unpreserved	Lead	
59	111324FE-60	Room 220 - DF	X				250mL unpreserved	Lead	
60	111324FE-61	Room 221 - SNK	X				250mL unpreserved	Lead	
61	111324FE-62	Room 221 - DF	X				250mL unpreserved	Lead	
62	111324FE-63	Room 223 - SNK	X				250mL unpreserved	Lead	
63	111324FE-64	Room 223 - DF	X				250mL unpreserved	Lead	
64	111324FE-65	Room 226 - SNK	X				250mL unpreserved	Lead	
65	111324FE-66	Room 226 - DF	X				250mL unpreserved	Lead	
66	111324FE-67	Room 225 - SNK	X				250mL unpreserved	Lead	
67	111324FE-68	Room 225 - DF	X				250mL unpreserved	Lead	
68	111324FE-69	Room 224 - SNK	X				250mL unpreserved	Lead	
69	111324FE-70	Room 224 - DF	X				250mL unpreserved	Lead	
70	111324FE-71	Room 328 - SNK	X				250mL unpreserved	Lead	
71	111324FE-72	Room 328 - DF	X				250mL unpreserved	Lead	
72	111324FE-73	Room 326 - SNK	X				250mL unpreserved	Lead	
73	111324FE-74	Room 326 - DF	X				250mL unpreserved	Lead	
74	111324FE-75	Room 325 - SNK	X				250mL unpreserved	Lead	
75	111324FE-76	Room 325 - DF	X				250mL unpreserved	Lead	
76	111324FE-77	Room 324 - SNK	X				250mL unpreserved	Lead	
77	111324FE-78	Room 324 - DF	X				250mL unpreserved	Lead	
78	111324FE-81	Hallway Outside Room 323 - WC	X				250mL unpreserved	Lead	
79	111324FE-82	Room 331 - SNK	X				250mL unpreserved	Lead	
80	111324FE-83	Room 331 - DF	X				250mL unpreserved	Lead	
81	111324FE-84	Room 322 - SNK	X				250mL unpreserved	Lead	
82	111324FE-85	Room 322 - DF	X				250mL unpreserved	Lead	
83	111324FE-86	Room 320 - SNK	X				250mL unpreserved	Lead	
84	111324FE-87	Room 320 - DF	X				250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

71086

Client Name	St. Michael-Albertville ISD #885	Building Name	Fieldstone Elementary	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Jake Schisler & Rebecca Escamilla	Date 11/13/2024	Time 6:00AM	Analyzed By (Company)	Analyst / Date & Time
Reviewed By		Date	Time		
Shipped By	Sashya Wandmaker	Date	Time 10:00AM	Turnaround Time	Notes
Received By		Date	Time	Sample Condition	Temperature

Lab Number	Sample Number	Sample Location	Sample Type: Water	Soil	Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
85	111324FE-88	Room 333 - SNK #1	X				250mL unpreserved	Lead	
86	111324FE-89	Room 333 - SNK #2	X				250mL unpreserved	Lead	
87	111324FE-90	Room 333 - SNK #3	X				250mL unpreserved	Lead	
88	111324FE-92	Room 333 - SNK #5	X				250mL unpreserved	Lead	
89	111324FE-93	Room 333 - SNK #6	X				250mL unpreserved	Lead	
90	111324FE-94	Room 333 - SNK #7	X				250mL unpreserved	Lead	
91	111324FE-95	Room 333 - SNK #8	X				250mL unpreserved	Lead	
92	111324FE-96	Room 333 - SNK #9	X				250mL unpreserved	Lead	
93	111324FE-97	Room 333 - SNK #10	X				250mL unpreserved	Lead	
94	111324FE-98	Room 333 - SNK #11	X				250mL unpreserved	Lead	
95	111324FE-99	Room 333 - SNK #12	X				250mL unpreserved	Lead	
96	111324FE-100	Room 333 - SNK #13	X				250mL unpreserved	Lead	
97	111324FE-101	Room 333 - SNK #14	X				250mL unpreserved	Lead	
98	111324FE-102	Room 333 - SNK #15	X				250mL unpreserved	Lead	
99	111324FE-103	Room 333 - SNK #16	X				250mL unpreserved	Lead	
100	111324FE-119	Room 334 - SNK #16	X				250mL unpreserved	Lead	
01	111324FE-120	Room 124 - SNK	X				250mL unpreserved	Lead	
02	111324FE-121	Room 124 - DF	X				250mL unpreserved	Lead	
03	111324FE-122	Room 125 - SNK	X				250mL unpreserved	Lead	
04	111324FE-123	Room 125 - DF	X				250mL unpreserved	Lead	
05	111324FE-124	Room 126 - SNK	X				250mL unpreserved	Lead	
06	111324FE-125	Room 126 - DF	X				250mL unpreserved	Lead	
07	111324FE-126	Room 123 - SNK	X				250mL unpreserved	Lead	
08	111324FE-127	Room 123 - DF	X				250mL unpreserved	Lead	
09	111324FE-128	Room 121 - SNK	X				250mL unpreserved	Lead	
10	111324FE-129	Room 121 - DF	X				250mL unpreserved	Lead	
11	111324FE-130	Room 120 - SNK	X				250mL unpreserved	Lead	
12	111324FE-131	Room 120 - DF	X				250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

71086

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

Client Name	St. Michael-Albertville ISD #885	Building Name	Fieldstone Elementary	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Jake Schisler & Rebecca Escamilla	Date 11/13/2024	Time 6:00AM	Analyzed By (Company)	Analyst / Date & Time
Reviewed By		Date	Time		
Shipped By	Sashya Wandmaker	Date	Time 10:00AM	Turnaround Time	Notes
Received By		Date	Time	Sample Condition	Temperature

Lab Number	Sample Number	Sample Location	Sample Type: Water	Soil	Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
13	111324FE-132	Room 119 - SNK	X				250mL unpreserved	Lead	
14	111324FE-133	Room 119 - DF	X				250mL unpreserved	Lead	
15	111324FE-134	Room 118 - SNK	X				250mL unpreserved	Lead	
16	111324FE-135	Room 118 - DF	X				250mL unpreserved	Lead	
17	111324FE-136	West Courtyard - North WC	X				250mL unpreserved	Lead	
18	111324FE-137	West Courtyard - North SNK	X				250mL unpreserved	Lead	
19	111324FE-138	West Courtyard - South WC	X				250mL unpreserved	Lead	
20	111324FE-139	West Courtyard - South SNK	X				250mL unpreserved	Lead	
21	111324FE-140	Room 109 - SNK	X				250mL unpreserved	Lead	
22	111324FE-141	Room 109 - DF	X				250mL unpreserved	Lead	
23	111324FE-142	Room 110 - SNK	X				250mL unpreserved	Lead	
24	111324FE-143	Room 110 - DF	X				250mL unpreserved	Lead	
25	111324FE-144	Room 111 - SNK	X				250mL unpreserved	Lead	
26	111324FE-145	Room 111 - DF	X				250mL unpreserved	Lead	
27	111324FE-146	Room 112 - SNK	X				250mL unpreserved	Lead	
28	111324FE-147	Room 112 - DF	X				250mL unpreserved	Lead	
29	111324FE-148	Room 114 - SNK	X				250mL unpreserved	Lead	
30	111324FE-149	Room 114 - DF	X				250mL unpreserved	Lead	
31	111324FE-150	Room 117 - SNK	X				250mL unpreserved	Lead	
32	111324FE-151	Room 117 - DF	X				250mL unpreserved	Lead	
33	111324FE-152	Room 116 - SNK	X				250mL unpreserved	Lead	
34	111324FE-153	Room 116 - DF	X				250mL unpreserved	Lead	
35	111324FE-154	Room 115 - SNK	X				250mL unpreserved	Lead	
36	111324FE-155	Room 115 - DF	X				250mL unpreserved	Lead	
37	111324FE-156	Room 321 - SNK	X				250mL unpreserved	Lead	
38	111324FE-157	West Courtyard - North WBF	X				250mL unpreserved	Lead	
39	111324FE-158	West Courtyard - South WBF	X				250mL unpreserved	Lead	
40	111324FE-159	East Courtyard - South WBF	X				250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

71086

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

Client Name	St. Michael-Albertville ISD #885	Building Name	Fieldstone Elementary	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Jake Schisler & Rebecca Escamilla	Date 11/13/2024	Time 6:00AM	Analyzed By (Company)	Analyst / Date & Time
Reviewed By		Date	Time		
Shipped By	Sashya Wandmaker	Date	Time 10:00AM	Turnaround Time	Notes
Received By		Date	Time	Sample Condition	Temperature

Lab Number	Sample Number	Sample Location	Sample Type: Water	Soil	Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
	111324FE-160	East Courtyard - North WBF	X				250mL unpreserved	Lead	
	111324FE-161	Room 217 - SNK	X				250mL unpreserved	Lead	NFD
	111324FE-162	Hallway Outside Café - WBF	X				250mL unpreserved	Lead	
	~~111324FE-79~~	~~Room 323 - SNK~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-80~~	~~Room 323 - DF~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-91~~	~~Room 333 - SNK #4~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-104~~	~~Room 334 - SNK #1~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-105~~	~~Room 334 - SNK #2~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-106~~	~~Room 334 - SNK #3~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-107~~	~~Room 334 - SNK #4~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-108~~	~~Room 334 - SNK #5~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-109~~	~~Room 334 - SNK #6~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-110~~	~~Room 334 - SNK #7~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-111~~	~~Room 334 - SNK #8~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-112~~	~~Room 334 - SNK #9~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-113~~	~~Room 334 - SNK #10~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-114~~	~~Room 334 - SNK #11~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-115~~	~~Room 334 - SNK #12~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-116~~	~~Room 334 - SNK #13~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-117~~	~~Room 334 - SNK #14~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-118~~	~~Room 334 - SNK #15~~	X				~~250mL unpreserved~~	~~Lead~~	
	~~111324FE-4~~	~~Kitchen - N SNK~~	X				~~250mL unpreserved~~	~~Lead~~	
			X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (71086) **Client:** Institute for Environmental Assessment (IEA)

Sample Condition Checklist

Date: 14 Nov 24 Time: 1400 ☐ AM ☒ PM By: SP

Account Name: IEA - FE Account # –

Bill of Lading #: – Cooler #: –

Temp: 19.0 °C ROI ☐ Ambient ☒ Tracking #: –

TM#: 774 Ice Crystals Present in Sample ☐

MVTL Courier: Dan Other:

MVTL Route: Metro Walk-In ☐ UPS Air ☐ FedEx Air ☐ SpeeDee ☐

Mail ☐ UPS Ground ☐ Fed Ex Ground ☐

Containers Supplied by MVTL: Yes ☒ No ☐ Designate customer supplied containers as "Other" in container size column

Comments:

Number	Containers Size (mL)	Container Type	Preservation	pH
143	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	~~(100) (120)~~ (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	~~(100) (120) (125) (250) (290) (500) (1000)~~ Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	Low Level Mercury Kit	***DO NOT OPEN THE PLASTIC BAGS HOLDING THE SAMPLE BOTTLES!!***		
	4 oz Jar	Clear Amber	MeOH None	n/a
	2 oz Jar	Clear Amber	MeOH None	n/a
	Vials Individual Set of 2 Set of 3	Clear Amber	HCl H_3PO_4 H_2SO_4 None	n/a
	Vials Individual Set of 2 Set of 3	Clear Amber	HCl H_3PO_4 H_2SO_4 None	n/a
	Trip Blank Individual Set of 2 Set of 3	n/a		
	Moisture Vial	n/a		
	Manure Bottle	n/a		

*ANY CONTAINER SENT TO A SUBCONTRACT LABORATORY WILL NOT BE CHECKED FOR PRESERVATION!

Form # 30-911001-0 Page 1 of 1 Effective Date: 29 September 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (73120)
Account #: 2190
Project #: 202410983

Client: Institute for Environmental Assessment (IEA)
PO: 202410983

Emma Squires-Sperling
IEA / Brooklyn Park
9201 W Broadway Suite #600
Brooklyn Park, MN 55445

Certificate of Analysis

Approval

All data reported has been reviewed and approved by:



Dave Smahel, Inorganic Chemistry/Feed Lab Manager New Ulm, MN

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:
MN LAB # 027-015-125ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:
MN LAB # 038-999-267ND W/DW # ND-016

Workorder Comments

All samples were preserved with nitric acid upon receipt at the laboratory.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (73120) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 73120001 **Date Collected:** 12/06/2024 06:00 **Matrix:** Potable Water
Sample ID: 120624FE-1 **Date Received:** 12/06/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen- SW SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.86**	ug/L	15	EPA 200.8	12/12/2024 09:12	

Lab ID: 73120002 **Date Collected:** 12/06/2024 06:00 **Matrix:** Potable Water
Sample ID: 120624FE-2 **Date Received:** 12/06/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen SE SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.79**	ug/L	15	EPA 200.8	12/12/2024 09:13	

Lab ID: 73120003 **Date Collected:** 12/06/2024 06:00 **Matrix:** Potable Water
Sample ID: 120624FE-3 **Date Received:** 12/06/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen West SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**12.8**	ug/L	15	EPA 200.8	12/12/2024 09:15	

Lab ID: 73120004 **Date Collected:** 12/06/2024 06:00 **Matrix:** Potable Water
Sample ID: 120624FE-4 **Date Received:** 12/06/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen N SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**8.65**	ug/L	15	EPA 200.8	12/12/2024 09:16	

Lab ID: 73120005 **Date Collected:** 12/06/2024 06:00 **Matrix:** Potable Water
Sample ID: 120624FE-5 **Date Received:** 12/06/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen East SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.51**	ug/L	15	EPA 200.8	12/12/2024 09:17	

Lab ID: 73120006 **Date Collected:** 12/06/2024 06:00 **Matrix:** Potable Water
Sample ID: 120624FE-6 **Date Received:** 12/06/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen HWD

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	12/12/2024 09:18	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, December 13, 2024 9:08:03 AM

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (73120) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 73120007 **Date Collected:** 12/06/2024 06:00 **Matrix:** Potable Water
Sample ID: 120624FE-7 **Date Received:** 12/06/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen NW STK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.66**	ug/L	15	EPA 200.8	12/12/2024 09:19	

Lab ID: 73120008 **Date Collected:** 12/06/2024 06:00 **Matrix:** Potable Water
Sample ID: 120624FE-8 **Date Received:** 12/06/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen SE STK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.28**	ug/L	15	EPA 200.8	12/12/2024 09:20	

Lab ID: 73120009 **Date Collected:** 12/06/2024 06:00 **Matrix:** Potable Water
Sample ID: 120624FE-9 **Date Received:** 12/06/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen South SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.67**	ug/L	15	EPA 200.8	12/12/2024 09:21	

Lab ID: 73120010 **Date Collected:** 12/06/2024 06:00 **Matrix:** Potable Water
Sample ID: 120624FE-10 **Date Received:** 12/06/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen West SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**17.8**	ug/L	15	EPA 200.8	12/12/2024 09:22	

Lab ID: 73120011 **Date Collected:** 12/06/2024 06:00 **Matrix:** Potable Water
Sample ID: 120624FE-11 **Date Received:** 12/06/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen East SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**25.1**	ug/L	15	EPA 200.8	12/12/2024 09:31	

Lab ID: 73120012 **Date Collected:** 12/06/2024 06:00 **Matrix:** Potable Water
Sample ID: 120624FE-12 **Date Received:** 12/06/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom NW SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.23**	ug/L	15	EPA 200.8	12/12/2024 09:32	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (73120) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 73120013 **Date Collected:** 12/06/2024 06:00 **Matrix:** Potable Water
Sample ID: 120624FE-13 **Date Received:** 12/06/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom Middle SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.89**	ug/L	15	EPA 200.8	12/12/2024 09:33	

Lab ID: 73120014 **Date Collected:** 12/06/2024 06:00 **Matrix:** Potable Water
Sample ID: 120624FE-14 **Date Received:** 12/06/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom SE SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.89**	ug/L	15	EPA 200.8	12/12/2024 09:34	

Lab ID: 73120015 **Date Collected:** 12/06/2024 06:00 **Matrix:** Potable Water
Sample ID: 120624FE-15 **Date Received:** 12/06/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom West SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.78**	ug/L	15	EPA 200.8	12/12/2024 09:35	


Lab ID: 73120016 **Date Collected:** 12/06/2024 06:00 **Matrix:** Potable Water
Sample ID: 120624FE-16 **Date Received:** 12/06/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom East SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.75**	ug/L	15	EPA 200.8	12/12/2024 09:36	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (73120) **Client:** Institute for Environmental Assessment (IEA)



MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (73120) **Client:** Institute for Environmental Assessment (IEA)

1 of 1

73120

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.5513

Client Name	St. Michael-Albertville ISD #885	Building Name	Fieldstone Elementary	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Daniel Holcomb	Date 12/5/2024	Time 6:00AM	Analyzed By (Company)	Analyst / Date & Time
Reviewed By		Date	Time		
Shipped By	Daniel Holcomb	Date 12/6/24	Time 8:00AM	Turnaround Time	Notes
Received By		Date	Time	Sample Condition	Temperature

Normal 500mL unpreserved Lead
Rush 40mL unpreserved GRO
Other DRO
BTEX

Lab Number	Sample Number	Sample Location	Sample Type: Water	Soil	Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
	120624FE-1	Kitchen - SW SNK	X				250mL unpreserved	Lead	
	120624FE-2	Kitchen - SE SNK	X				250mL unpreserved	Lead	
	120624FE-3	Kitchen - West SNK	X				250mL unpreserved	Lead	
	120624FE-4	Kitchen - N SNK	X				250mL unpreserved	Lead	
	120624FE-5	Kitchen - East SNK	X				250mL unpreserved	Lead	
	120624FE-6	Kitchen - HWD	X				250mL unpreserved	Lead	
	120624FE-7	Kitchen - NW STK	X				250mL unpreserved	Lead	
	120624FE-8	Kitchen - SE STK	X				250mL unpreserved	Lead	
	120624FE-9	Kitchen - South SPR	X				250mL unpreserved	Lead	
	120624FE-10	Kitchen - West SPR	X				250mL unpreserved	Lead	
	120624FE-11	Kitchen - East SPR	X				250mL unpreserved	Lead	
	120624FE-12	Dishroom - NW SNK	X				250mL unpreserved	Lead	
	120624FE-13	Dishroom - Middle SNK	X				250mL unpreserved	Lead	
	120624FE-14	Dishroom - SE SNK	X				250mL unpreserved	Lead	
	120624FE-15	Dishroom - West SPR	X				250mL unpreserved	Lead	
	120624FE-16	Dishroom - East SPR	X				250mL unpreserved	Lead	

001-016

06 Dec 24 0930 AMB 15.5
06 Dec 24 1414 771

SP 6 Dec 24 1414
AMB 15.5 771

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Fieldstone Elementary (73120) **Client:** Institute for Environmental Assessment (IEA)

Sample Condition Checklist

Date: 6 Dec 24 Time: 1414 ☐ AM ☒ PM By: SP

Account Name: IEA - FE Account #: -

Bill of Lading #: - Cooler #: -

Temp: 15.5 °C ROI ☐ Ambient ☒ Tracking #: -

TM#: 771 Ice Crystals Present in Sample ☐ -

MVTL Courier: Dan Other:

MVTL Route: Metro Walk-In ☐ UPS Air ☐ FedEx Air ☐ SpeeDee ☐

Mail ☐ UPS Ground ☐ Fed Ex Ground ☐

Containers Supplied by MVTL: Yes ☒ No ☐ Designate customer supplied containers as "Other" in container size column

Comments:

Number	Containers Size (mL)	Container Type	Preservation	pH
16	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	Low Level Mercury Kit	***!!DO NOT OPEN THE PLASTIC BAGS HOLDING THE SAMPLE BOTTLES!!***		
	4 oz Jar	Clear Amber	MeOH None	n/a
	2 oz Jar	Clear Amber	MeOH None	n/a
	Vials Individual Set of 2 Set of 3	Clear Amber	HCl H_3PO_4 H_2SO_4 None	n/a
	Vials Individual Set of 2 Set of 3	Clear Amber	HCl H_3PO_4 H_2SO_4 None	n/a
	Trip Blank Individual Set of 2 Set of 3	n/a		
	Moisture Vial	n/a		
	Manure Bottle	n/a		


*ANY CONTAINER SENT TO A SUBCONTRACT LABORATORY WILL NOT BE CHECKED FOR PRESERVATION!

Form # 30-911001-0 Page 1 of 1 Effective Date: 29 September 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

LEGEND

- DRINKING FOUNTAIN
- WATER COOLER
- SINK
- KITCHEN SINK
- STEAM KETTLE
- SPRAYER
- BOTTLE FILLER
- HOT WATER DISPENSER
- X NON-OPERABLE



INSTITUTE FOR ENVIRONMENTAL ASSESSMENT
9201 West Broadway Brooklyn Park, MN 55445
Tel: 763.315.7900 Toll Free: 800.233.9513
Fax: 763.315.7920

FIELDSTONE ELEMENTARY

FIRST LEVEL FLOOR PLAN | ST. MICHAEL-ALBERTVILLE ISD #885
DEC. 2024

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894)
Account #: 2190
Project #: 202410983

Client: Institute for Environmental Assessment (IEA)
PO: 202410983

Emma Squires-Sperling
IEA / Brooklyn Park
9201 W Broadway Suite #600
Brooklyn Park, MN 55445

Certificate of Analysis

Approval

All data reported has been reviewed and approved by:



Dave Smahel, Inorganic Chemistry/Feed Lab Manager New Ulm, MN

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:
MN LAB # 027-015-125ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:
MN LAB # 038-999-267ND W/DW # ND-016

Workorder Comments

All samples were preserved with nitric acid upon receipt at the laboratory.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894001 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-1 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen 2780-North SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.14**	ug/L	15	EPA 200.8	11/21/2024 12:00	

Lab ID: 70894002 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-2 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen 2780-South SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.63**	ug/L	15	EPA 200.8	11/21/2024 12:01	

Lab ID: 70894003 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-3 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Main Kitchen-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.02**	ug/L	15	EPA 200.8	11/21/2024 12:02	

Lab ID: 70894004 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-4 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Main Kitchen-SNK #2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.07**	ug/L	15	EPA 200.8	11/21/2024 12:16	

Lab ID: 70894005 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-5 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Main Kitchen-SNK #3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.03**	ug/L	15	EPA 200.8	11/21/2024 12:17	

Lab ID: 70894006 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-6 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Main Kitchen-SNK #4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.29**	ug/L	15	EPA 200.8	11/21/2024 12:18	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894007 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-7 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Main Kitchen-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.66**	ug/L	15	EPA 200.8	11/21/2024 12:19	

Lab ID: 70894008 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-8 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Main Kitchen-SNK #6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.08**	ug/L	15	EPA 200.8	11/21/2024 12:20	

Lab ID: 70894009 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-9 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Main Kitchen-SNK #7

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.52**	ug/L	15	EPA 200.8	11/21/2024 12:21	

Lab ID: 70894010 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-10 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Main Kitchen-SNK #8

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.51**	ug/L	15	EPA 200.8	11/21/2024 12:22	

Lab ID: 70894011 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-11 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Main Kitchen-SNK #9

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.45**	ug/L	15	EPA 200.8	11/21/2024 12:23	

Lab ID: 70894012 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-12 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Main Kitchen-SNK #10

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.35**	ug/L	15	EPA 200.8	11/21/2024 12:25	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894013 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-13 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Main Kitchen-SNK #11

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.55**	ug/L	15	EPA 200.8	11/21/2024 12:26	

Lab ID: 70894014 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-14 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Main Kitchen-North STK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.08**	ug/L	15	EPA 200.8	11/21/2024 12:35	

Lab ID: 70894015 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-15 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Main Kitchen-Middle STK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.11**	ug/L	15	EPA 200.8	11/21/2024 12:36	

Lab ID: 70894016 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-16 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Main Kitchen-South STK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.10**	ug/L	15	EPA 200.8	11/21/2024 12:37	

Lab ID: 70894017 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-17 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Main Kitchen-SE SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.51**	ug/L	15	EPA 200.8	11/21/2024 12:38	

Lab ID: 70894018 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-19 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom-West SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.68**	ug/L	15	EPA 200.8	11/21/2024 12:39	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894019 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-20 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom-West Middle SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**7.96**	ug/L	15	EPA 200.8	11/21/2024 12:40	

Lab ID: 70894020 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-21 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom-East Middle SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.56**	ug/L	15	EPA 200.8	11/21/2024 12:41	

Lab ID: 70894021 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-22 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom-East SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.59**	ug/L	15	EPA 200.8	11/21/2024 12:42	

Lab ID: 70894022 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-23 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom-North SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.88**	ug/L	15	EPA 200.8	11/21/2024 12:43	

Lab ID: 70894023 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-24 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom-South SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.77**	ug/L	15	EPA 200.8	11/21/2024 12:45	

Lab ID: 70894024 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-25 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen 2713-West SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.45**	ug/L	15	EPA 200.8	11/21/2024 16:20	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894025 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-26 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen 2713-Middle SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.20**	ug/L	15	EPA 200.8	11/21/2024 16:22	

Lab ID: 70894026 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-27 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen 2713-East SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.98**	ug/L	15	EPA 200.8	11/21/2024 16:23	

Lab ID: 70894027 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-28 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Cafeteria-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/21/2024 16:24	

Lab ID: 70894028 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-29 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Cafeteria-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/21/2024 16:25	

Lab ID: 70894029 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-30 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 2787-West WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.73**	ug/L	15	EPA 200.8	11/21/2024 16:26	

Lab ID: 70894030 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-31 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 2787-East WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/21/2024 16:27	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894031 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-32 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2762-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.10**	ug/L	15	EPA 200.8	11/21/2024 16:28	

Lab ID: 70894032 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-33 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2765-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.93**	ug/L	15	EPA 200.8	11/21/2024 16:29	

Lab ID: 70894033 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-34 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2766-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/21/2024 16:30	

Lab ID: 70894034 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-35 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2804-West SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.00**	ug/L	15	EPA 200.8	11/21/2024 16:39	

Lab ID: 70894035 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-36 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2804-Middle SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.37**	ug/L	15	EPA 200.8	11/21/2024 16:40	

Lab ID: 70894036 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-37 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2804-East SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.13**	ug/L	15	EPA 200.8	11/21/2024 16:42	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894037 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-38 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 2803-West WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/21/2024 16:43	

Lab ID: 70894038 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-39 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 2803-East WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/21/2024 16:44	

Lab ID: 70894039 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-40 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 2802-West WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/21/2024 16:45	

Lab ID: 70894040 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-41 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 2802-East WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/21/2024 16:46	

Lab ID: 70894041 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-42 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 2813-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/21/2024 16:47	

Lab ID: 70894042 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-43 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 2813-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/21/2024 16:48	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894043 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-44 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2813-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/21/2024 16:49	

Lab ID: 70894044 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-45 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2813-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/21/2024 16:58	

Lab ID: 70894045 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-46 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2704-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.09**	ug/L	15	EPA 200.8	11/21/2024 16:59	

Lab ID: 70894046 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-47 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2020-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.91**	ug/L	15	EPA 200.8	11/22/2024 12:04	

Lab ID: 70894047 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-48 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2030-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.54**	ug/L	15	EPA 200.8	11/22/2024 12:05	

Lab ID: 70894048 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-49 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 2258-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 12:06	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894049 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-50 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 2258-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 12:07	

Lab ID: 70894050 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-51 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2210-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 12:08	

Lab ID: 70894051 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-52 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2204-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.17**	ug/L	15	EPA 200.8	11/22/2024 12:09	

Lab ID: 70894052 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-53 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2266-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.33**	ug/L	15	EPA 200.8	11/22/2024 12:10	

Lab ID: 70894053 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-54 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2264-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.93**	ug/L	15	EPA 200.8	11/22/2024 12:11	

Lab ID: 70894054 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-55 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 2298-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 12:13	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894055 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-56 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 2298-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 12:14	

Lab ID: 70894056 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-57 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2222-West SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.97**	ug/L	15	EPA 200.8	11/22/2024 12:23	

Lab ID: 70894057 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-58 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2222-East SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.85**	ug/L	15	EPA 200.8	11/22/2024 12:24	

Lab ID: 70894058 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-59 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2224-West SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.12**	ug/L	15	EPA 200.8	11/22/2024 12:25	

Lab ID: 70894059 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-60 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2224-East SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.10**	ug/L	15	EPA 200.8	11/22/2024 12:26	

Lab ID: 70894060 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-61 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2226-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.06**	ug/L	15	EPA 200.8	11/22/2024 12:27	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894061 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-62 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2228-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.37**	ug/L	15	EPA 200.8	11/22/2024 12:28	

Lab ID: 70894062 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-63 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2228-SNK #2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.31**	ug/L	15	EPA 200.8	11/22/2024 12:29	

Lab ID: 70894063 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-64 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2228-SNK #3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.70**	ug/L	15	EPA 200.8	11/22/2024 12:30	

Lab ID: 70894064 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-65 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2228-SNK #4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.48**	ug/L	15	EPA 200.8	11/22/2024 12:31	

Lab ID: 70894065 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-66 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2228-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.50**	ug/L	15	EPA 200.8	11/22/2024 12:33	

Lab ID: 70894066 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-67 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2228-SNK #6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.32**	ug/L	15	EPA 200.8	11/22/2024 12:46	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894067 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-68 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2228-SNK #7

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.91**	ug/L	15	EPA 200.8	11/22/2024 12:47	

Lab ID: 70894068 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-69 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2228-SNK #8

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.36**	ug/L	15	EPA 200.8	11/22/2024 12:48	

Lab ID: 70894069 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-70 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2400-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.76**	ug/L	15	EPA 200.8	11/22/2024 12:49	

Lab ID: 70894070 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-71 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2400-SNK #2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.83**	ug/L	15	EPA 200.8	11/22/2024 12:50	

Lab ID: 70894071 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-72 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2400-SNK #3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.26**	ug/L	15	EPA 200.8	11/22/2024 12:51	

Lab ID: 70894072 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-73 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2400-SNK #4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.16**	ug/L	15	EPA 200.8	11/22/2024 12:52	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894073 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-74 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2400-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.01**	ug/L	15	EPA 200.8	11/22/2024 12:54	

Lab ID: 70894074 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-75 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2400-SNK #6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.30**	ug/L	15	EPA 200.8	11/22/2024 12:55	

Lab ID: 70894075 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-76 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2400-SNK #7

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.25**	ug/L	15	EPA 200.8	11/22/2024 12:56	

Lab ID: 70894076 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-77 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2400-SNK #8

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.28**	ug/L	15	EPA 200.8	11/22/2024 13:05	

Lab ID: 70894077 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-78 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2400-SNK #9

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.73**	ug/L	15	EPA 200.8	11/22/2024 13:06	

Lab ID: 70894078 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-79 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 2400-SNK #10

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.76**	ug/L	15	EPA 200.8	11/22/2024 13:07	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894079 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-80 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 3400-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.80**	ug/L	15	EPA 200.8	11/22/2024 13:08	

Lab ID: 70894080 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-81 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 3400-SNK #2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.56**	ug/L	15	EPA 200.8	11/22/2024 13:09	

Lab ID: 70894081 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-82 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 3400-SNK #3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 13:10	

Lab ID: 70894082 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-83 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 3400-SNK #4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 13:11	

Lab ID: 70894083 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-84 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 3400-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.54**	ug/L	15	EPA 200.8	11/22/2024 13:12	

Lab ID: 70894084 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-85 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 3400-SNK #6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.66**	ug/L	15	EPA 200.8	11/22/2024 13:14	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894085 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-86 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 3400-SNK #7

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.01**	ug/L	15	EPA 200.8	11/22/2024 13:15	

Lab ID: 70894086 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-87 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 3400-SNK #8

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.62**	ug/L	15	EPA 200.8	11/22/2024 13:28	

Lab ID: 70894087 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-88 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 3400-SNK #9

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.74**	ug/L	15	EPA 200.8	11/22/2024 13:29	

Lab ID: 70894088 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-89 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 3400-SNK #10

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.18**	ug/L	15	EPA 200.8	11/22/2024 13:30	

Lab ID: 70894089 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-90 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 3398-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 13:31	

Lab ID: 70894090 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-91 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 3398-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 13:32	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894091 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-92 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 3366-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.84**	ug/L	15	EPA 200.8	11/22/2024 13:33	

Lab ID: 70894092 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-93 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 3358-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 13:35	

Lab ID: 70894093 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-94 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 3358-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 13:36	

Lab ID: 70894094 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-102 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 3335-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**8.58**	ug/L	15	EPA 200.8	11/21/2024 17:00	

Lab ID: 70894095 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-104 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 3328-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.47**	ug/L	15	EPA 200.8	11/21/2024 17:02	

Lab ID: 70894096 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-105 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 3328-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.89**	ug/L	15	EPA 200.8	11/21/2024 17:03	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894097 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-106 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 3311-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.81**	ug/L	15	EPA 200.8	11/21/2024 17:04	

Lab ID: 70894098 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-107 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 3311-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.48**	ug/L	15	EPA 200.8	11/21/2024 17:05	

Lab ID: 70894099 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-108 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 1198-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/21/2024 17:06	

Lab ID: 70894100 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-109 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 1198-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/21/2024 17:07	

Lab ID: 70894101 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-110 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1458-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.22**	ug/L	15	EPA 200.8	11/21/2024 17:08	

Lab ID: 70894102 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-111 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1458-SNK #2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.85**	ug/L	15	EPA 200.8	11/21/2024 17:21	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894103 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-112 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1458-SNK #3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**15.5**	ug/L	15	EPA 200.8	11/21/2024 17:23	

Lab ID: 70894104 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-113 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1458-SNK #4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.86**	ug/L	15	EPA 200.8	11/21/2024 17:24	

Lab ID: 70894105 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-114 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1458-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.60**	ug/L	15	EPA 200.8	11/21/2024 17:25	

Lab ID: 70894106 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-115 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1458-SNK #6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.96**	ug/L	15	EPA 200.8	11/21/2024 17:26	

Lab ID: 70894107 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-116 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1458-SNK #7

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.96**	ug/L	15	EPA 200.8	11/21/2024 17:27	

Lab ID: 70894108 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-117 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1458-SNK #8

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.01**	ug/L	15	EPA 200.8	11/21/2024 17:28	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894109 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-118 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1460-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.56**	ug/L	15	EPA 200.8	11/21/2024 17:29	

Lab ID: 70894110 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-119 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1456-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**10.2**	ug/L	15	EPA 200.8	11/21/2024 17:30	

Lab ID: 70894111 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-120 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1456-SNK #2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.41**	ug/L	15	EPA 200.8	11/21/2024 17:31	

Lab ID: 70894112 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-121 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1456-SNK #3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.88**	ug/L	15	EPA 200.8	11/21/2024 17:40	

Lab ID: 70894113 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-122 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1456-SNK #4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.39**	ug/L	15	EPA 200.8	11/21/2024 17:41	

Lab ID: 70894114 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-123 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1456-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.29**	ug/L	15	EPA 200.8	11/21/2024 17:43	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894115 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-124 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1456-SNK #6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.22**	ug/L	15	EPA 200.8	11/21/2024 17:44	

Lab ID: 70894116 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-125 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1456-SNK #7

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.51**	ug/L	15	EPA 200.8	11/21/2024 17:45	

Lab ID: 70894117 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-126 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1456-SNK #8

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.66**	ug/L	15	EPA 200.8	11/21/2024 17:46	

Lab ID: 70894118 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-127 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1454-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.78**	ug/L	15	EPA 200.8	11/21/2024 17:47	

Lab ID: 70894119 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-128 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1454-SNK #2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.67**	ug/L	15	EPA 200.8	11/21/2024 17:48	

Lab ID: 70894120 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-129 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1454-SNK #3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.02**	ug/L	15	EPA 200.8	11/21/2024 17:49	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894121 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-130 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1454-SNK #4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.07**	ug/L	15	EPA 200.8	11/21/2024 17:50	

Lab ID: 70894122 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-131 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1454-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.11**	ug/L	15	EPA 200.8	11/21/2024 18:04	

Lab ID: 70894123 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-132 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1454-SNK #6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.10**	ug/L	15	EPA 200.8	11/21/2024 18:05	

Lab ID: 70894124 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-133 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1454-SNK #7

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.68**	ug/L	15	EPA 200.8	11/21/2024 18:06	

Lab ID: 70894125 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-134 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1452-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.85**	ug/L	15	EPA 200.8	11/21/2024 18:07	

Lab ID: 70894126 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-135 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1452-SNK #2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.27**	ug/L	15	EPA 200.8	11/21/2024 18:08	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894127 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-136 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1452-SNK #3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.68**	ug/L	15	EPA 200.8	11/21/2024 18:09	

Lab ID: 70894128 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-137 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1452-SNK #4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.51**	ug/L	15	EPA 200.8	11/21/2024 18:10	

Lab ID: 70894129 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-138 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1452-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.54**	ug/L	15	EPA 200.8	11/21/2024 18:11	

Lab ID: 70894130 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-139 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1452-SNK #6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.99**	ug/L	15	EPA 200.8	11/21/2024 18:13	

Lab ID: 70894131 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-140 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1452-SNK #7

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.53**	ug/L	15	EPA 200.8	11/21/2024 18:14	

Lab ID: 70894132 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-141 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1176-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.16**	ug/L	15	EPA 200.8	11/21/2024 18:23	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894133 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-142 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1168-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.97**	ug/L	15	EPA 200.8	11/21/2024 18:24	

Lab ID: 70894134 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-143 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1438-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.56**	ug/L	15	EPA 200.8	11/21/2024 18:25	

Lab ID: 70894135 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-144 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1438-SNK #2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.92**	ug/L	15	EPA 200.8	11/21/2024 18:26	

Lab ID: 70894136 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-145 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1438-SNK #3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.16**	ug/L	15	EPA 200.8	11/21/2024 18:27	

Lab ID: 70894137 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-146 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1438-SNK #4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.12**	ug/L	15	EPA 200.8	11/21/2024 18:28	

Lab ID: 70894138 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-147 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1438-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.42**	ug/L	15	EPA 200.8	11/21/2024 18:29	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894139 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-148 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1438-SNK #6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.68**	ug/L	15	EPA 200.8	11/21/2024 18:30	

Lab ID: 70894140 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-149 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1438-SNK #7

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.46**	ug/L	15	EPA 200.8	11/21/2024 18:31	

Lab ID: 70894141 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-150 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1439-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.77**	ug/L	15	EPA 200.8	11/21/2024 18:33	

Lab ID: 70894142 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-151 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1436-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.30**	ug/L	15	EPA 200.8	11/22/2024 13:37	

Lab ID: 70894143 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-152 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1436-SNK #2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.08**	ug/L	15	EPA 200.8	11/22/2024 13:38	

Lab ID: 70894144 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-153 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1436-SNK #3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.49**	ug/L	15	EPA 200.8	11/22/2024 13:47	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894145 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-154 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1436-SNK #4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.08**	ug/L	15	EPA 200.8	11/22/2024 13:48	

Lab ID: 70894146 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-155 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1436-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.64**	ug/L	15	EPA 200.8	11/22/2024 13:49	

Lab ID: 70894147 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-156 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1436-SNK #6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.51**	ug/L	15	EPA 200.8	11/22/2024 13:50	

Lab ID: 70894148 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-157 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1436-SNK #7

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.71**	ug/L	15	EPA 200.8	11/22/2024 13:51	

Lab ID: 70894149 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-158 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1435-West SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**13.7**	ug/L	15	EPA 200.8	11/22/2024 13:52	

Lab ID: 70894150 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-159 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1435-Middle SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.01**	ug/L	15	EPA 200.8	11/26/2024 11:08	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894151 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-160 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1435-East SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.39**	ug/L	15	EPA 200.8	11/22/2024 13:53	

Lab ID: 70894152 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-161 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1437-West SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 13:55	

Lab ID: 70894153 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-162 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1437-West SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.70**	ug/L	15	EPA 200.8	11/22/2024 13:56	

Lab ID: 70894154 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-163 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1437-East SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.99**	ug/L	15	EPA 200.8	11/26/2024 11:09	

Lab ID: 70894155 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-164 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1437-East SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.69**	ug/L	15	EPA 200.8	11/22/2024 13:57	

Lab ID: 70894156 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-165 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1434-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.08**	ug/L	15	EPA 200.8	11/22/2024 14:10	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894157 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-166 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1434-SNK #2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.44**	ug/L	15	EPA 200.8	11/22/2024 14:11	

Lab ID: 70894158 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-167 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1434-SNK #3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.68**	ug/L	15	EPA 200.8	11/22/2024 14:12	

Lab ID: 70894159 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-168 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1434-SNK #4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.01**	ug/L	15	EPA 200.8	11/22/2024 14:13	

Lab ID: 70894160 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-169 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1434-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.68**	ug/L	15	EPA 200.8	11/22/2024 14:15	

Lab ID: 70894161 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-170 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1434-SNK #6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**15.3**	ug/L	15	EPA 200.8	11/22/2024 14:16	

Lab ID: 70894162 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-171 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1434-SNK #7

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.21**	ug/L	15	EPA 200.8	11/22/2024 14:17	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894163 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-172 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1432-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.36**	ug/L	15	EPA 200.8	11/26/2024 11:10	

Lab ID: 70894164 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-173 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1432-SNK #2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.44**	ug/L	15	EPA 200.8	11/22/2024 14:18	

Lab ID: 70894165 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-174 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1432-SNK #3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.30**	ug/L	15	EPA 200.8	11/22/2024 14:19	

Lab ID: 70894166 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-175 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1432-SNK #4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.27**	ug/L	15	EPA 200.8	11/22/2024 14:20	

Lab ID: 70894167 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-176 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1432-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.01**	ug/L	15	EPA 200.8	11/22/2024 14:29	

Lab ID: 70894168 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-177 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1432-SNK #6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.40**	ug/L	15	EPA 200.8	11/22/2024 14:30	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894169 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-178 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1432-SNK #7

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.29**	ug/L	15	EPA 200.8	11/22/2024 14:31	

Lab ID: 70894170 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-179 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1433-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.37**	ug/L	15	EPA 200.8	11/22/2024 14:32	

Lab ID: 70894171 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-180 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 1158-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 14:33	

Lab ID: 70894172 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-181 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 1158-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 14:35	

Lab ID: 70894173 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-182 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1418-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.73**	ug/L	15	EPA 200.8	11/22/2024 14:36	

Lab ID: 70894174 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-183 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1418-SNK #2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.01**	ug/L	15	EPA 200.8	11/22/2024 14:37	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894175 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-184 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1418-SNK #3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.21**	ug/L	15	EPA 200.8	11/22/2024 14:38	

Lab ID: 70894176 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-185 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1418-SNK #4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.99**	ug/L	15	EPA 200.8	11/22/2024 14:39	

Lab ID: 70894177 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-186 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1418-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.39**	ug/L	15	EPA 200.8	11/22/2024 14:52	

Lab ID: 70894178 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-187 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1418-SNK #6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.01**	ug/L	15	EPA 200.8	11/22/2024 14:53	

Lab ID: 70894179 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-188 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1418-SNK #7

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**15.8**	ug/L	15	EPA 200.8	11/22/2024 14:55	

Lab ID: 70894180 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-189 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1417-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**8.73**	ug/L	15	EPA 200.8	11/22/2024 14:56	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894181 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-190 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1416-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**14.1**	ug/L	15	EPA 200.8	11/26/2024 11:11	

Lab ID: 70894182 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-193 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1416-SNK #4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**38.6**	ug/L	15	EPA 200.8	11/26/2024 11:13	

Lab ID: 70894183 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-194 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1416-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**33.7**	ug/L	15	EPA 200.8	11/26/2024 11:14	

Lab ID: 70894184 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-197 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1414-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.51**	ug/L	15	EPA 200.8	11/22/2024 14:57	

Lab ID: 70894185 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-198 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1414-SNK #2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.10**	ug/L	15	EPA 200.8	11/22/2024 14:58	

Lab ID: 70894186 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-199 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1414-SNK #3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.00**	ug/L	15	EPA 200.8	11/22/2024 14:59	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894187 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-200 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1414-SNK #4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.56**	ug/L	15	EPA 200.8	11/22/2024 15:00	

Lab ID: 70894188 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-201 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1414-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.19**	ug/L	15	EPA 200.8	11/22/2024 15:01	

Lab ID: 70894189 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-202 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1414-SNK #6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.09**	ug/L	15	EPA 200.8	11/22/2024 15:02	

Lab ID: 70894190 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-203 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1414-SNK #7

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.51**	ug/L	15	EPA 200.8	11/22/2024 15:11	

Lab ID: 70894191 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-204 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1412-SNK #1

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.70**	ug/L	15	EPA 200.8	11/22/2024 15:12	

Lab ID: 70894192 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-205 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1412-SNK #2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.25**	ug/L	15	EPA 200.8	11/22/2024 15:13	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894193 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-206 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1412-SNK #3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.25**	ug/L	15	EPA 200.8	11/22/2024 15:15	

Lab ID: 70894194 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-207 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1412-SNK #4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.41**	ug/L	15	EPA 200.8	11/22/2024 15:16	

Lab ID: 70894195 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-208 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1412-SNK #5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.20**	ug/L	15	EPA 200.8	11/22/2024 15:17	

Lab ID: 70894196 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-209 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1412-SNK #6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.62**	ug/L	15	EPA 200.8	11/22/2024 15:18	

Lab ID: 70894197 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-210 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1610-NW WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 15:19	

Lab ID: 70894198 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-211 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1610-SE WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 15:20	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894199 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-212 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1610-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 15:21	

Lab ID: 70894200 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-213 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1651-North WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 15:34	

Lab ID: 70894201 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-214 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1651-South WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 15:36	

Lab ID: 70894202 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-215 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1653-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.96**	ug/L	15	EPA 200.8	11/22/2024 15:37	

Lab ID: 70894203 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-217 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1659-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 15:38	

Lab ID: 70894204 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-218 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1745-North SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.02**	ug/L	15	EPA 200.8	11/22/2024 15:39	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894205 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-219 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1745-South SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.28**	ug/L	15	EPA 200.8	11/22/2024 15:40	

Lab ID: 70894206 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-220 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1745-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.05**	ug/L	15	EPA 200.8	11/22/2024 15:41	

Lab ID: 70894207 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-221 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1616-West WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 15:42	

Lab ID: 70894208 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-222 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1616-East WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 15:43	

Lab ID: 70894209 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-223 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1628-West WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 15:44	

Lab ID: 70894210 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-224 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1628-East WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 15:53	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894211 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-225 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1634-North WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 15:54	

Lab ID: 70894212 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-226 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1634-South WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 15:56	

Lab ID: 70894213 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-227 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1634-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 15:57	

Lab ID: 70894214 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-228 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 1661-West Wc

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 15:58	

Lab ID: 70894215 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-229 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 1661-East WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 15:59	

Lab ID: 70894216 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-230 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 1663-West Wc

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 16:01	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894217 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-231 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 1663-East WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 16:02	

Lab ID: 70894218 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-232 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Hallway Outside Room 1668-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 16:03	

Lab ID: 70894219 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-233 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1682-North SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.67**	ug/L	15	EPA 200.8	11/22/2024 16:04	

Lab ID: 70894220 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-234 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1682-Middle SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.56**	ug/L	15	EPA 200.8	11/22/2024 16:13	

Lab ID: 70894221 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-235 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1682-South SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.05**	ug/L	15	EPA 200.8	11/22/2024 16:14	

Lab ID: 70894222 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-236 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1684-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.64**	ug/L	15	EPA 200.8	11/22/2024 16:16	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894223 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-237 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1683-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.31**	ug/L	15	EPA 200.8	11/22/2024 16:17	

Lab ID: 70894224 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-238 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1683-Spigot

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.70**	ug/L	15	EPA 200.8	11/22/2024 16:18	

Lab ID: 70894225 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-239 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1685-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.65**	ug/L	15	EPA 200.8	11/22/2024 16:19	

Lab ID: 70894226 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-240 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1688-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 16:20	

Lab ID: 70894227 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-241 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Fieldhouse NW-North DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 16:21	

Lab ID: 70894228 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-242 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Fieldhouse NW-South DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 16:22	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894229 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-243 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Fieldhouse NW-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 16:23	

Lab ID: 70894230 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-244 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Fieldhouse NE-North DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 17:06	

Lab ID: 70894231 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-245 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Fieldhouse NE-South DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 17:07	

Lab ID: 70894232 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-246 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Nurses Office SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.25**	ug/L	15	EPA 200.8	11/22/2024 17:09	

Lab ID: 70894233 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-247 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1651-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 17:10	

Lab ID: 70894234 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-248 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1653-SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.41**	ug/L	15	EPA 200.8	11/22/2024 17:11	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 70894235 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-249 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1659-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 17:12	

Lab ID: 70894236 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-250 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1686-Ice Machine

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 17:13	

Lab ID: 70894237 **Date Collected:** 11/12/2024 05:30 **Matrix:** Potable Water
Sample ID: 111224STMAHS-251 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 1621-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.27**	ug/L	15	EPA 200.8	11/22/2024 17:14	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)



MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

70894

Client Name	St. Michael-Albertville ISD #885	Building Name	STMA High School	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Blair Cecil, Rebecca Escamilla, Sashya Wandmaker	Date 11/12/2024	Time 5:30am	Analyzed By (Company)	Analyst / Date & Time
Reviewed By		Date	Time		
Shipped By	Sashya Wandmaker	Date	Time 10:00 AM	Turnaround Time	Notes
Received By		Date	Time	Sample Condition	Temperature

Lab Number	Sample Number	Sample Location	Sample Type: Water	Soil	Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
		Main Level							
001	111224STMAHS-1	Kitchen 2780 - North SNK	X			11/12/2024	250mL unpreserved	Lead	
002	111224STMAHS-2	Kitchen 2780 - South SNK	X			11/12/2024	250mL unpreserved	Lead	
003	111224STMAHS-3	Main Kitchen - SNK #1	X			11/12/2024	250mL unpreserved	Lead	
004	111224STMAHS-4	Main Kitchen - SNK #2	X			11/12/2024	250mL unpreserved	Lead	
005	111224STMAHS-5	Main Kitchen - SNK #3	X			11/12/2024	250mL unpreserved	Lead	
006	111224STMAHS-6	Main Kitchen - SNK #4	X			11/12/2024	250mL unpreserved	Lead	
007	111224STMAHS-7	Main Kitchen - SNK #5	X			11/12/2024	250mL unpreserved	Lead	
008	111224STMAHS-8	Main Kitchen - SNK #6	X			11/12/2024	250mL unpreserved	Lead	
009	111224STMAHS-9	Main Kitchen - SNK #7	X			11/12/2024	250mL unpreserved	Lead	
010	111224STMAHS-10	Main Kitchen - SNK #8	X			11/12/2024	250mL unpreserved	Lead	
011	111224STMAHS-11	Main Kitchen - SNK #9	X			11/12/2024	250mL unpreserved	Lead	
012	111224STMAHS-12	Main Kitchen - SNK #10	X			11/12/2024	250mL unpreserved	Lead	
013	111224STMAHS-13	Main Kitchen - SNK #11	X			11/12/2024	250mL unpreserved	Lead	
014	111224STMAHS-14	Main Kitchen - North STK	X			11/12/2024	250mL unpreserved	Lead	
015	111224STMAHS-15	Main Kitchen - Middle STK	X			11/12/2024	250mL unpreserved	Lead	
016	111224STMAHS-16	Main Kitchen - South STK	X			11/12/2024	250mL unpreserved	Lead	
017	111224STMAHS-17	Main Kitchen - SE SPR	X			11/12/2024	250mL unpreserved	Lead	
018	111224STMAHS-19	Dishroom - West SNK	X			11/12/2024	250mL unpreserved	Lead	
019	111224STMAHS-20	Dishroom - West Middle SNK	X			11/12/2024	250mL unpreserved	Lead	
020	111224STMAHS-21	Dishroom - East Middle SNK	X			11/12/2024	250mL unpreserved	Lead	NFD
021	111224STMAHS-22	Dishroom - East SNK	X			11/12/2024	250mL unpreserved	Lead	
022	111224STMAHS-23	Dishroom - North SPR	X			11/12/2024	250mL unpreserved	Lead	
023	111224STMAHS-24	Dishroom - South SPR	X			11/12/2024	250mL unpreserved	Lead	
024	111224STMAHS-25	Kitchen 2713 - West SNK	X			11/12/2024	250mL unpreserved	Lead	
025	111224STMAHS-26	Kitchen 2713 - Middle SNK	X			11/12/2024	250mL unpreserved	Lead	
026	111224STMAHS-27	Kitchen 2713 - East SNK	X			11/12/2024	250mL unpreserved	Lead	
027	111224STMAHS-28	Cafeteria - WC	X			11/12/2024	250mL unpreserved	Lead	
028	111224STMAHS-29	Cafeteria - WBF	X			11/12/2024	250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

SP 13 Nov 24 1414
AMB 19.0 77Y

4 C-R 13 Nov 24 1414 AMB 19.0 77Y

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

9201 West Broadway North, Suite 650
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

Chain of Custody

Client Name	St. Michael-Albertville ISD #885	Building Name	STMA High School	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com

Other Information

Sampled By	Blair Cecil, Rebecca Escamilla, Sashya Wandmaker	Date	11/12/2024	Time	5:30am	Analyzed By (Company)		Analyst	Date & Time	
Reviewed By		Date		Time					Notes	
Shipped By	Sashya Wandmaker	Date		Time	10:00 AM	Turnaround Time				
Received By		Date		Time		Sample Condition			Temperature	

Lab Number	Sample Number	Sample Location	Sample Type: Water	Sample Type: Soil	Sample Type: Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
029	111224STMAHS-30	Hallway Outside Room 2787 - West WC	X			11/12/2024	250mL unpreserved	Lead	
030	111224STMAHS-31	Hallway Outside Room 2787 - East WC	X			11/12/2024	250mL unpreserved	Lead	
031	111224STMAHS-32	Room 2762 - SNK	X			11/12/2024	250mL unpreserved	Lead	
032	111224STMAHS-33	Room 2765 - SNK	X			11/12/2024	250mL unpreserved	Lead	
033	111224STMAHS-34	Room 2766 - WC	X			11/12/2024	250mL unpreserved	Lead	
034	111224STMAHS-35	Room 2804 - West SNK	X			11/12/2024	250mL unpreserved	Lead	
035	111224STMAHS-36	Room 2804 - Middle SNK	X			11/12/2024	250mL unpreserved	Lead	
036	111224STMAHS-37	Room 2804 - East SNK	X			11/12/2024	250mL unpreserved	Lead	
037	111224STMAHS-38	Hallway Outside Room 2803 - West WC	X			11/12/2024	250mL unpreserved	Lead	
038	111224STMAHS-39	Hallway Outside Room 2803 - East WC	X			11/12/2024	250mL unpreserved	Lead	
039	111224STMAHS-40	Hallway Outside Room 2802 - West WC	X			11/12/2024	250mL unpreserved	Lead	
040	111224STMAHS-41	Hallway Outside Room 2802 - East WC	X			11/12/2024	250mL unpreserved	Lead	
041	111224STMAHS-42	Hallway Outside Room 2813 - WC	X			11/12/2024	250mL unpreserved	Lead	NFD
042	111224STMAHS-43	Hallway Outside Room 2813 - WBF	X			11/12/2024	250mL unpreserved	Lead	NFD
043	111224STMAHS-44	Room 2813 - DF	X			11/12/2024	250mL unpreserved	Lead	
044	111224STMAHS-45	Room 2813 - WBF	X			11/12/2024	250mL unpreserved	Lead	
045	111224STMAHS-46	Room 2704 - SNK	X			11/12/2024	250mL unpreserved	Lead	
046	111224STMAHS-47	Room 2020 - SNK	X			11/12/2024	250mL unpreserved	Lead	NFD
047	111224STMAHS-48	Room 2030 - SNK	X			11/12/2024	250mL unpreserved	Lead	
048	111224STMAHS-49	Hallway Outside Room 2258 - WC	X			11/12/2024	250mL unpreserved	Lead	
049	111224STMAHS-50	Hallway Outside Room 2258 - WBF	X			11/12/2024	250mL unpreserved	Lead	
050	111224STMAHS-51	Room 2210 - WC	X			11/12/2024	250mL unpreserved	Lead	
051	111224STMAHS-52	Room 2204 - SNK	X			11/12/2024	250mL unpreserved	Lead	
052	111224STMAHS-53	Room 2266 - SNK	X			11/12/2024	250mL unpreserved	Lead	
053	111224STMAHS-54	Room 2264 - SNK	X			11/12/2024	250mL unpreserved	Lead	
054	111224STMAHS-55	Hallway Outside Room 2298 - WC	X			11/12/2024	250mL unpreserved	Lead	
055	111224STMAHS-56	Hallway Outside Room 2298 - WBF	X			11/12/2024	250mL unpreserved	Lead	
056	111224STMAHS-57	Room 2222 - West SNK	X			11/12/2024	250mL unpreserved	Lead	
057	111224STMAHS-58	Room 2222 - East SNK	X			11/12/2024	250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

2 of 9

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

Client Name	St. Michael-Albertville ISD #885	Building Name	STMA High School	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Blair Cecil, Rebecca Escamilla, Sashya Wandmaker	Date 11/12/2024	Time 5:30am	Analyzed By (Company)	Analyst / Date & Time
Reviewed By		Date	Time		
Shipped By	Sashya Wandmaker	Date	Time 10:00 AM	Turnaround Time	Notes
Received By		Date	Time	Sample Condition	Temperature

Lab Number	Sample Number	Sample Location	Sample Type: Water	Sample Type: Soil	Sample Type: Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
058	111224STMAHS-59	Room 2224 - West SNK	X			11/12/2024	250mL unpreserved	Lead	
059	111224STMAHS-60	Room 2224 - East SNK	X			11/12/2024	250mL unpreserved	Lead	
060	111224STMAHS-61	Room 2226 - SNK	X			11/12/2024	250mL unpreserved	Lead	
061	111224STMAHS-62	Room 2228 - SNK #1	X			11/12/2024	250mL unpreserved	Lead	
062	111224STMAHS-63	Room 2228 - SNK #2	X			11/12/2024	250mL unpreserved	Lead	
063	111224STMAHS-64	Room 2228 - SNK #3	X			11/12/2024	250mL unpreserved	Lead	
064	111224STMAHS-65	Room 2228 - SNK #4	X			11/12/2024	250mL unpreserved	Lead	
065	111224STMAHS-66	Room 2228 - SNK #5	X			11/12/2024	250mL unpreserved	Lead	
066	111224STMAHS-67	Room 2228 - SNK #6	X			11/12/2024	250mL unpreserved	Lead	
067	111224STMAHS-68	Room 2228 - SNK #7	X			11/12/2024	250mL unpreserved	Lead	
068	111224STMAHS-69	Room 2228 - SNK #8	X			11/12/2024	250mL unpreserved	Lead	
069	111224STMAHS-70	Room 2400 - SNK #1	X			11/12/2024	250mL unpreserved	Lead	
070	111224STMAHS-71	Room 2400 - SNK #2	X			11/12/2024	250mL unpreserved	Lead	
071	111224STMAHS-72	Room 2400 - SNK #3	X			11/12/2024	250mL unpreserved	Lead	
072	111224STMAHS-73	Room 2400 - SNK #4	X			11/12/2024	250mL unpreserved	Lead	
073	111224STMAHS-74	Room 2400 - SNK #5	X			11/12/2024	250mL unpreserved	Lead	
074	111224STMAHS-75	Room 2400 - SNK #6	X			11/12/2024	250mL unpreserved	Lead	
075	111224STMAHS-76	Room 2400 - SNK #7	X			11/12/2024	250mL unpreserved	Lead	
076	111224STMAHS-77	Room 2400 - SNK #8	X			11/12/2024	250mL unpreserved	Lead	
077	111224STMAHS-78	Room 2400 - SNK #9	X			11/12/2024	250mL unpreserved	Lead	
078	111224STMAHS-79	Room 2400 - SNK #10	X			11/12/2024	250mL unpreserved	Lead	
		Upper Level							
079	111224STMAHS-80	Room 3400 - SNK #1	X			11/12/2024	250mL unpreserved	Lead	
080	111224STMAHS-81	Room 3400 - SNK #2	X			11/12/2024	250mL unpreserved	Lead	
081	111224STMAHS-82	Room 3400 - SNK #3	X			11/12/2024	250mL unpreserved	Lead	
082	111224STMAHS-83	Room 3400 - SNK #4	X			11/12/2024	250mL unpreserved	Lead	
083	111224STMAHS-84	Room 3400 - SNK #5	X			11/12/2024	250mL unpreserved	Lead	
084	111224STMAHS-85	Room 3400 - SNK #6	X			11/12/2024	250mL unpreserved	Lead	
085	111224STMAHS-86	Room 3400 - SNK #7	X			11/12/2024	250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

Client Name	St. Michael-Albertville ISD #885	Building Name	STMA High School	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Blair Cecil, Rebecca Escamilla, Sashya Wandmaker	Date	11/12/2024	Time	5:30am
Reviewed By		Date		Time	
Shipped By	Sashya Wandmaker	Date		Time	10:00 AM
Received By		Date		Time	

Analyzed By (Company)	Analyst	Date & Time
Turnaround Time		Notes
Sample Condition		Temperature

Lab Number	Sample Number	Sample Location	Sample Type			Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
			Water	Soil	Other				
086	111224STMAHS-87	Room 3400 - SNK #8	X			11/12/2024	250mL unpreserved	Lead	
087	111224STMAHS-88	Room 3400 - SNK #9	X			11/12/2024	250mL unpreserved	Lead	
088	111224STMAHS-89	Room 3400 - SNK #10	X			11/12/2024	250mL unpreserved	Lead	
089	111224STMAHS-90	Hallway Outside Room 3398 - WC	X			11/12/2024	250mL unpreserved	Lead	
090	111224STMAHS-91	Hallway Outside Room 3398 - WBF	X			11/12/2024	250mL unpreserved	Lead	NFD
091	111224STMAHS-92	Hallway Outside Room 3366 - SNK	X			11/12/2024	250mL unpreserved	Lead	NFD
092	111224STMAHS-93	Hallway Outside Room 3358 - WC	X			11/12/2024	250mL unpreserved	Lead	NFD
093	111224STMAHS-94	Hallway Outside Room 3358 - WBF	X			11/12/2024	250mL unpreserved	Lead	NFD
094	111224STMAHS-102	Room 3335 - SNK	X			11/12/2024	250mL unpreserved	Lead	
095	111224STMAHS-104	Room 3328 - SNK	X			11/12/2024	250mL unpreserved	Lead	
096	111224STMAHS-105	Room 3328 - DF	X			11/12/2024	250mL unpreserved	Lead	
097	111224STMAHS-106	Room 3311 - SNK	X			11/12/2024	250mL unpreserved	Lead	NFD
098	111224STMAHS-107	Room 3311 - DF	X			11/12/2024	250mL unpreserved	Lead	
		Lower Level							
099	111224STMAHS-108	Hallway Outside Room 1198 - WC	X			11/12/2024	250mL unpreserved	Lead	NFD
100	111224STMAHS-109	Hallway Outside Room 1198 - WBF	X			11/12/2024	250mL unpreserved	Lead	NFD
101	111224STMAHS-110	Room 1458 - SNK #1	X			11/12/2024	250mL unpreserved	Lead	
102	111224STMAHS-111	Room 1458 - SNK #2	X			11/12/2024	250mL unpreserved	Lead	
103	111224STMAHS-112	Room 1458 - SNK #3	X			11/12/2024	250mL unpreserved	Lead	
104	111224STMAHS-113	Room 1458 - SNK #4	X			11/12/2024	250mL unpreserved	Lead	
105	111224STMAHS-114	Room 1458 - SNK #5	X			11/12/2024	250mL unpreserved	Lead	
106	111224STMAHS-115	Room 1458 - SNK #6	X			11/12/2024	250mL unpreserved	Lead	
107	111224STMAHS-116	Room 1458 - SNK #7	X			11/12/2024	250mL unpreserved	Lead	
108	111224STMAHS-117	Room 1458 - SNK #8	X			11/12/2024	250mL unpreserved	Lead	
109	111224STMAHS-118	Room 1460 - SNK	X			11/12/2024	250mL unpreserved	Lead	
110	111224STMAHS-119	Room 1456 - SNK #1	X			11/12/2024	250mL unpreserved	Lead	
111	111224STMAHS-120	Room 1456 - SNK #2	X			11/12/2024	250mL unpreserved	Lead	
112	111224STMAHS-121	Room 1456 - SNK #3	X			11/12/2024	250mL unpreserved	Lead	
113	111224STMAHS-122	Room 1456 - SNK #4	X			11/12/2024	250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

Client Name	St. Michael-Albertville ISD #885	Building Name	STMA High School	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Blair Cecil, Rebecca Escamilla, Sashya Wandmaker	Date	11/12/2024	Time	5:30am
Reviewed By		Date		Time	
Shipped By	Sashya Wandmaker	Date		Time	10:00 AM
Received By		Date		Time	

Analyzed By (Company)	Analyst	Date & Time
Turnaround Time		Notes
Sample Condition		Temperature

Lab Number	Sample Number	Sample Location	Sample Type			Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
			Water	Soil	Other				
114	111224STMAHS-123	Room 1456 - SNK #5	X			11/12/2024	250mL unpreserved	Lead	
115	111224STMAHS-124	Room 1456 - SNK #6	X			11/12/2024	250mL unpreserved	Lead	
116	111224STMAHS-125	Room 1456 - SNK #7	X			11/12/2024	250mL unpreserved	Lead	
117	111224STMAHS-126	Room 1456 - SNK #8	X			11/12/2024	250mL unpreserved	Lead	
118	111224STMAHS-127	Room 1454 - SNK #1	X			11/12/2024	250mL unpreserved	Lead	
119	111224STMAHS-128	Room 1454 - SNK #2	X			11/12/2024	250mL unpreserved	Lead	
120	111224STMAHS-129	Room 1454 - SNK #3	X			11/12/2024	250mL unpreserved	Lead	
121	111224STMAHS-130	Room 1454 - SNK #4	X			11/12/2024	250mL unpreserved	Lead	
122	111224STMAHS-131	Room 1454 - SNK #5	X			11/12/2024	250mL unpreserved	Lead	
123	111224STMAHS-132	Room 1454 - SNK #6	X			11/12/2024	250mL unpreserved	Lead	
124	111224STMAHS-133	Room 1454 - SNK #7	X			11/12/2024	250mL unpreserved	Lead	
125	111224STMAHS-134	Room 1452 - SNK #1	X			11/12/2024	250mL unpreserved	Lead	
126	111224STMAHS-135	Room 1452 - SNK #2	X			11/12/2024	250mL unpreserved	Lead	
127	111224STMAHS-136	Room 1452 - SNK #3	X			11/12/2024	250mL unpreserved	Lead	
128	111224STMAHS-137	Room 1452 - SNK #4	X			11/12/2024	250mL unpreserved	Lead	
129	111224STMAHS-138	Room 1452 - SNK #5	X			11/12/2024	250mL unpreserved	Lead	
130	111224STMAHS-139	Room 1452 - SNK #6	X			11/12/2024	250mL unpreserved	Lead	
131	111224STMAHS-140	Room 1452 - SNK #7	X			11/12/2024	250mL unpreserved	Lead	
132	111224STMAHS-141	Room 1176 - SNK	X			11/12/2024	250mL unpreserved	Lead	
133	111224STMAHS-142	Room 1168 - SNK	X			11/12/2024	250mL unpreserved	Lead	
134	111224STMAHS-143	Room 1438 - SNK #1	X			11/12/2024	250mL unpreserved	Lead	
135	111224STMAHS-144	Room 1438 - SNK #2	X			11/12/2024	250mL unpreserved	Lead	
136	111224STMAHS-145	Room 1438 - SNK #3	X			11/12/2024	250mL unpreserved	Lead	
137	111224STMAHS-146	Room 1438 - SNK #4	X			11/12/2024	250mL unpreserved	Lead	
138	111224STMAHS-147	Room 1438 - SNK #5	X			11/12/2024	250mL unpreserved	Lead	
139	111224STMAHS-148	Room 1438 - SNK #6	X			11/12/2024	250mL unpreserved	Lead	
140	111224STMAHS-149	Room 1438 - SNK #7	X			11/12/2024	250mL unpreserved	Lead	
141	111224STMAHS-150	Room 1439 - SNK	X			11/12/2024	250mL unpreserved	Lead	
142	111224STMAHS-151	Room 1436 - SNK #1	X			11/12/2024	250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

Client Name	St. Michael-Albertville ISD #885	Building Name	STMA High School	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Blair Cecil, Rebecca Escamilla, Sashya Wandmaker	Date	11/12/2024	Time	5:30am
Reviewed By		Date		Time	
Shipped By	Sashya Wandmaker	Date		Time	10:00 AM
Received By		Date		Time	

Analyzed By (Company)	Analyst	Date & Time
Turnaround Time		Notes
Sample Condition		Temperature


Lab Number	Sample Number	Sample Location	Sample Type			Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
			Water	Soil	Other				
143	111224STMAHS-152	Room 1436 - SNK #2	X			11/12/2024	250mL unpreserved	Lead	
144	111224STMAHS-153	Room 1436 - SNK #3	X			11/12/2024	250mL unpreserved	Lead	
145	111224STMAHS-154	Room 1436 - SNK #4	X			11/12/2024	250mL unpreserved	Lead	
146	111224STMAHS-155	Room 1436 - SNK #5	X			11/12/2024	250mL unpreserved	Lead	
147	111224STMAHS-156	Room 1436 - SNK #6	X			11/12/2024	250mL unpreserved	Lead	
148	111224STMAHS-157	Room 1436 - SNK #7	X			11/12/2024	250mL unpreserved	Lead	
149	111224STMAHS-158	Room 1435 - West SNK	X			11/12/2024	250mL unpreserved	Lead	
150	111224STMAHS-159	Room 1435 - Middle SNK	X			11/12/2024	250mL unpreserved	Lead	
151	111224STMAHS-160	Room 1435 - East SNK	X			11/12/2024	250mL unpreserved	Lead	
152	111224STMAHS-161	Room 1437 - West SPR	X			11/12/2024	250mL unpreserved	Lead	
153	111224STMAHS-162	Room 1437 - West SNK	X			11/12/2024	250mL unpreserved	Lead	
154	111224STMAHS-163	Room 1437 - East SPR	X			11/12/2024	250mL unpreserved	Lead	
155	111224STMAHS-164	Room 1437 - East SNK	X			11/12/2024	250mL unpreserved	Lead	
156	111224STMAHS-165	Room 1434 - SNK #1	X			11/12/2024	250mL unpreserved	Lead	
157	111224STMAHS-166	Room 1434 - SNK #2	X			11/12/2024	250mL unpreserved	Lead	
158	111224STMAHS-167	Room 1434 - SNK #3	X			11/12/2024	250mL unpreserved	Lead	
159	111224STMAHS-168	Room 1434 - SNK #4	X			11/12/2024	250mL unpreserved	Lead	
160	111224STMAHS-169	Room 1434 - SNK #5	X			11/12/2024	250mL unpreserved	Lead	
161	111224STMAHS-170	Room 1434 - SNK #6	X			11/12/2024	250mL unpreserved	Lead	
162	111224STMAHS-171	Room 1434 - SNK #7	X			11/12/2024	250mL unpreserved	Lead	
163	111224STMAHS-172	Room 1432 - SNK #1	X			11/12/2024	250mL unpreserved	Lead	
164	111224STMAHS-173	Room 1432 - SNK #2	X			11/12/2024	250mL unpreserved	Lead	
165	111224STMAHS-174	Room 1432 - SNK #3	X			11/12/2024	250mL unpreserved	Lead	
166	111224STMAHS-175	Room 1432 - SNK #4	X			11/12/2024	250mL unpreserved	Lead	
167	111224STMAHS-176	Room 1432 - SNK #5	X			11/12/2024	250mL unpreserved	Lead	
168	111224STMAHS-177	Room 1432 - SNK #6	X			11/12/2024	250mL unpreserved	Lead	
169	111224STMAHS-178	Room 1432 - SNK #7	X			11/12/2024	250mL unpreserved	Lead	
170	111224STMAHS-179	Room 1433 - SNK	X			11/12/2024	250mL unpreserved	Lead	
171	111224STMAHS-180	Hallway Outside Room 1158 - WC	X			11/12/2024	250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)



Chain of Custody

Client Name	St. Michael-Albertville ISD #885	Building Name	STMA High School	Analytical Lab	MVTL
Contact Name	Emma Squires-Spelling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@stayfetch.com

Other Information

Sampled By	Blair Cecil, Rebecca Escamilla, Sashya Wandmaker	Date	11/12/2024	Time	5:30am	Analyzed By (Company)	Analyst	Date & Time
Relinquished By		Date		Time				
Shipped By	Sashya Wandmaker	Date		Time	10:00 AM	Turnaround Time	Notes	
Received By		Date		Time		Sample Condition	Temperature	

Lab Number	Sample Number	Sample Location	Sample Type: Water	Sample Type: Soil	Sample Type: Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
178	111224STMAHS-181	Hallway Outside Room 1158 - WBF	X			11/12/2024	250mL unpreserved	Lead	
179	111224STMAHS-182	Room 1418 - SNK #1	X			11/12/2024	250mL unpreserved	Lead	
174	111224STMAHS-183	Room 1418 - SNK #2	X			11/12/2024	250mL unpreserved	Lead	
175	111224STMAHS-184	Room 1418 - SNK #3	X			11/12/2024	250mL unpreserved	Lead	
176	111224STMAHS-185	Room 1418 - SNK #4	X			11/12/2024	250mL unpreserved	Lead	
177	111224STMAHS-186	Room 1418 - SNK #5	X			11/12/2024	250mL unpreserved	Lead	
178	111224STMAHS-187	Room 1418 - SNK #6	X			11/12/2024	250mL unpreserved	Lead	
179	111224STMAHS-188	Room 1418 - SNK #7	X			11/12/2024	250mL unpreserved	Lead	
180	111224STMAHS-189	Room 1417 - SNK	X			11/12/2024	250mL unpreserved	Lead	
181	111224STMAHS-190	Room 1416 - SNK #1	X			11/12/2024	250mL unpreserved	Lead	Sink stopped working after ~ 30 seconds
182	111224STMAHS-193	Room 1416 - SNK #4	X			11/12/2024	250mL unpreserved	Lead	
183	111224STMAHS-194	Room 1416 - SNK #5	X			11/12/2024	250mL unpreserved	Lead	Sink stopped working after ~ 30 seconds
184	111224STMAHS-197	Room 1414 - SNK #1	X			11/12/2024	250mL unpreserved	Lead	
185	111224STMAHS-198	Room 1414 - SNK #2	X			11/12/2024	250mL unpreserved	Lead	
186	111224STMAHS-199	Room 1414 - SNK #3	X			11/12/2024	250mL unpreserved	Lead	
187	111224STMAHS-200	Room 1414 - SNK #4	X			11/12/2024	250mL unpreserved	Lead	
188	111224STMAHS-201	Room 1414 - SNK #5	X			11/12/2024	250mL unpreserved	Lead	
189	111224STMAHS-202	Room 1414 - SNK #6	X			11/12/2024	250mL unpreserved	Lead	
190	111224STMAHS-203	Room 1414 - SNK #7	X			11/12/2024	250mL unpreserved	Lead	
191	111224STMAHS-204	Room 1412 - SNK #1	X			11/12/2024	250mL unpreserved	Lead	
192	111224STMAHS-205	Room 1412 - SNK #2	X			11/12/2024	250mL unpreserved	Lead	
193	111224STMAHS-206	Room 1412 - SNK #3	X			11/12/2024	250mL unpreserved	Lead	
194	111224STMAHS-207	Room 1412 - SNK #4	X			11/12/2024	250mL unpreserved	Lead	
195	111224STMAHS-208	Room 1412 - SNK #5	X			11/12/2024	250mL unpreserved	Lead	
196	111224STMAHS-209	Room 1412 - SNK #6	X			11/12/2024	250mL unpreserved	Lead	
197	111224STMAHS-210	Room 1610 - NW WC	X			11/12/2024	250mL unpreserved	Lead	
198	111224STMAHS-211	Room 1610 - SE WC	X			11/12/2024	250mL unpreserved	Lead	
199	111224STMAHS-212	Room 1610 - WBF	X			11/12/2024	250mL unpreserved	Lead	
200	111224STMAHS-213	Room 1651 - North WC	X			11/12/2024	250mL unpreserved	Lead	
201	111224STMAHS-214	Room 1651 - South WC	X			11/12/2024	250mL unpreserved	Lead	
202	111224STMAHS-215	Room 1653 - SNK	X			11/12/2024	250mL unpreserved	Lead	
203	111224STMAHS-217	Room 1659 - WC	X			11/12/2024	250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

Client Name	St. Michael-Albertville ISD #885	Building Name	STMA High School	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Blair Cecil, Rebecca Escamilla, Sashya Wandmaker	Date 11/12/2024	Time 5:30am	Analyzed By (Company)	Analyst / Date & Time
Reviewed By		Date	Time		
Shipped By	Sashya Wandmaker	Date	Time 10:00 AM	Turnaround Time	Notes
Received By		Date	Time	Sample Condition	Temperature

Lab Number	Sample Number	Sample Location	Sample Type: Water	Soil	Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
204	111224STMAHS-218	Room 1745 - North SNK	X			11/12/2024	250mL unpreserved	Lead	
205	111224STMAHS-219	Room 1745 - South SNK	X			11/12/2024	250mL unpreserved	Lead	
206	111224STMAHS-220	Room 1745 - WC	X			11/12/2024	250mL unpreserved	Lead	
207	111224STMAHS-221	Room 1616 - West WC	X			11/12/2024	250mL unpreserved	Lead	
208	111224STMAHS-222	Room 1616 - East WC	X			11/12/2024	250mL unpreserved	Lead	
209	111224STMAHS-223	Room 1628 - West WC	X			11/12/2024	250mL unpreserved	Lead	
210	111224STMAHS-224	Room 1628 - East WC	X			11/12/2024	250mL unpreserved	Lead	
211	111224STMAHS-225	Room 1634 - North WC	X			11/12/2024	250mL unpreserved	Lead	NFD
212	111224STMAHS-226	Room 1634 - South WC	X			11/12/2024	250mL unpreserved	Lead	
213	111224STMAHS-227	Room 1634 - WBF	X			11/12/2024	250mL unpreserved	Lead	
214	111224STMAHS-228	Hallway Outside Room 1661 - West WC	X			11/12/2024	250mL unpreserved	Lead	
215	111224STMAHS-229	Hallway Outside Room 1661 - East WC	X			11/12/2024	250mL unpreserved	Lead	
216	111224STMAHS-230	Hallway Outside Room 1663 - West WC	X			11/12/2024	250mL unpreserved	Lead	
217	111224STMAHS-231	Hallway Outside Room 1663 - East WC	X			11/12/2024	250mL unpreserved	Lead	
218	111224STMAHS-232	Hallway Outside Room 1668 - DF	X			11/12/2024	250mL unpreserved	Lead	
219	111224STMAHS-233	Room 1682 - North SNK	X			11/12/2024	250mL unpreserved	Lead	
220	111224STMAHS-234	Room 1682 - Middle SNK	X			11/12/2024	250mL unpreserved	Lead	
221	111224STMAHS-235	Room 1682 - South SNK	X			11/12/2024	250mL unpreserved	Lead	
222	111224STMAHS-236	Room 1684 - SNK	X			11/12/2024	250mL unpreserved	Lead	
223	111224STMAHS-237	Room 1683 - SNK	X			11/12/2024	250mL unpreserved	Lead	
224	111224STMAHS-238	Room 1683 - Spigot	X			11/12/2024	250mL unpreserved	Lead	
225	111224STMAHS-239	Room 1685 - SNK	X			11/12/2024	250mL unpreserved	Lead	
226	111224STMAHS-240	Room 1688 - DF	X			11/12/2024	250mL unpreserved	Lead	
227	111224STMAHS-241	Fieldhouse NW - North DF	X			11/12/2024	250mL unpreserved	Lead	
228	111224STMAHS-242	Fieldhouse NW - South DF	X			11/12/2024	250mL unpreserved	Lead	
229	111224STMAHS-243	Fieldhouse NW - WBF	X			11/12/2024	250mL unpreserved	Lead	
230	111224STMAHS-244	Fieldhouse NE - North DF	X			11/12/2024	250mL unpreserved	Lead	
231	111224STMAHS-245	Fieldhouse NE - South DF	X			11/12/2024	250mL unpreserved	Lead	
232	111224STMAHS-246	Nurses Office SNK	X			11/12/2024	250mL unpreserved	Lead	Room 2050
233	111224STMAHS-247	Room 1651 - WBF	X			11/12/2024	250mL unpreserved	Lead	
234	111224STMAHS-248	Room 1653 -SPR	X			11/12/2024	250mL unpreserved	Lead	
235	111224STMAHS-249	Room 1659 - WBF	X			11/12/2024	250mL unpreserved	Lead	
236	111224STMAHS-250	Room 1686 - Ice Machine	X			11/12/2024	250mL unpreserved	Lead	
237	111224STMAHS-251	Room 1621 - SNK	X			11/12/2024	250mL unpreserved	Lead	
	111224STMAHS-18	~~Main Kitchen--NW SPR~~	X			11/12/2024	~~250mL unpreserved~~	Lead	In-operable; Staff does not use. Cap screwed on.

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

Client Name	St. Michael-Albertville ISD #885	Building Name	STMA High School	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@iaasafety.com
Other Information					
Sampled By	Blair Cecil, Rebecca Escamilla, Sashya Wandmaker	Date 11/12/2024	Time 5:30am	Analyzed By (Company)	Analyst / Date & Time
Reviewed By		Date	Time		
Shipped By	Sashya Wandmaker	Date	Time 10:00 AM	Turnaround Time	Notes
Received By		Date	Time	Sample Condition	Temperature

Lab Number	Sample Number	Sample Location	Sample Type: Water	Sample Type: Soil	Sample Type: Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
	111224STMAHS-95	~~Room 3336 - SNK #1~~	X			11/12/2024	~~250mL unpreserved~~	~~Lead~~	In-operable; Computer Lab
	111224STMAHS-96	~~Room 3336 - SNK #2~~	X			11/12/2024	~~250mL unpreserved~~	~~Lead~~	In-operable; Computer Lab
	111224STMAHS-97	~~Room 3336 - SNK #3~~	X			11/12/2024	~~250mL unpreserved~~	~~Lead~~	In-operable; Computer Lab
	111224STMAHS-98	~~Room 3336 - SNK #4~~	X			11/12/2024	~~250mL unpreserved~~	~~Lead~~	In-operable; Computer Lab
	111224STMAHS-99	~~Room 3336 - SNK #5~~	X			11/12/2024	~~250mL unpreserved~~	~~Lead~~	In-operable; Computer Lab
	111224STMAHS-100	~~Room 3336 - SNK #6~~	X			11/12/2024	~~250mL unpreserved~~	~~Lead~~	In-operable; Computer Lab
	111224STMAHS-101	~~Room 3336 - SNK #7~~	X			11/12/2024	~~250mL unpreserved~~	~~Lead~~	In-operable; Computer Lab
	111224STMAHS-103	~~Room 3335 - DF~~	X			11/12/2024	~~250mL unpreserved~~	~~Lead~~	In-operable; spray pattern obstructed, sample could not be tested
	111224STMAHS-191	~~Room 1416 - SNK #2~~	X			11/12/2024	~~250mL unpreserved~~	~~Lead~~	Inoperable
	111224STMAHS-192	~~Room 1416 - SNK #3~~	X			11/12/2024	~~250mL unpreserved~~	~~Lead~~	Inoperable
	111224STMAHS-195	~~Room 1416 - SNK #6~~	X			11/12/2024	~~250mL unpreserved~~	~~Lead~~	Inoperable
	111224STMAHS-196	~~Room 1416 - SNK #7~~	X			11/12/2024	~~250mL unpreserved~~	~~Lead~~	Inoperable
	111224STMAHS-216	~~Room 1655 - WC~~	X			11/12/2024	~~250mL unpreserved~~	~~Lead~~	Non-Operational

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA High School (70894) **Client:** Institute for Environmental Assessment (IEA)

Sample Condition Checklist

Date: 13 Nov 24 Time: 1414 ☐ AM ☒ PM By: JP

Account Name: IEA - STMAHS Account # –

Bill of Lading #: – Cooler #: –

Temp: 19.0 °C ROI ☐ Ambient ☒ Tracking #: –

TM#: 774 Ice Crystals Present in Sample ☐ –

MVTL Courier: Dan Other:

MVTL Route: Metro Walk-In ☐ UPS Air ☐ FedEx Air ☐ SpeeDee ☐
Mail ☐ UPS Ground ☐ Fed Ex Ground ☐

Containers Supplied by MVTL: Yes ☒ No ☐ Designate customer supplied containers as "Other" in container size column

Comments:

Number	Containers Size (mL)	Container Type	Preservation	pH
237	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	Low Level Mercury Kit	***!!DO NOT OPEN THE PLASTIC BAGS HOLDING THE SAMPLE BOTTLES!!***		
	4 oz Jar	Clear Amber	MeOH None	n/a
	2 oz Jar	Clear Amber	MeOH None	n/a
	Vials Individual Set of 2 Set of 3	Clear Amber	HCl H_3PO_4 H_2SO_4 None	n/a
	Vials Individual Set of 2 Set of 3	Clear Amber	HCl H_3PO_4 H_2SO_4 None	n/a
	Trip Blank Individual Set of 2 Set of 3	n/a		
	Moisture Vial	n/a		
	Manure Bottle	n/a		


*ANY CONTAINER SENT TO A SUBCONTRACT LABORATORY WILL NOT BE CHECKED FOR PRESERVATION!


Form # 30-911001-0 Page 1 of 1 Effective Date: 29 September 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

LEGEND

- WATER COOLER
- SINK
- SPRAYER
- BOTTLE FILLER
- X NON-OPERABLE






INSTITUTE FOR ENVIRONMENTAL ASSESSMENT
9201 West Broadway Brooklyn Park, MN 55445
Tel: 763.315.7900 Toll Free: 800.233.9513
Fax: 763.315.7920

ST. MICHAEL-ALBERTVILLE HIGH SCHOOL
LOWER LEVEL FLOOR PLAN | DEC. 2024

LEGEND

- DRINKING FOUNTAIN
- WATER COOLER
- SINK
- SPRAYER
- BOTTLE FILLER
- ICE MAKER
- X NON-OPERABLE




INSTITUTE FOR ENVIRONMENTAL ASSESSMENT
9201 West Broadway Brooklyn Park, MN 55445
Tel: 763.315.7900 Toll Free: 800.233.9513
Fax: 763.315.7920

ST. MICHAEL-ALBERTVILLE HIGH SCHOOL
LOWER LEVEL FLOOR PLAN

DEC. 2024

LEGEND


- WATER COOLER
- SINK
- BOTTLE FILLER



INSTITUTE FOR ENVIRONMENTAL ASSESSMENT
9201 West Broadway Brooklyn Park, MN 55445
Tel: 763.315.7900 Toll Free: 800.233.9513
Fax: 763.315.7920

ST. MICHAEL-ALBERTVILLE HIGH SCHOOL
MAIN LEVEL FLOOR PLAN

DEC. 2024



INSTITUTE FOR ENVIRONMENTAL ASSESSMENT
9201 West Broadway Brooklyn Park, MN 55445
Tel: 763.315.7900 Toll Free: 800.233.9513
Fax: 763.315.7920


ST. MICHAEL-ALBERTVILLE HIGH SCHOOL
MAIN LEVEL FLOOR PLAN

DEC. 2024

LEGEND

- DRINKING FOUNTAIN
- WATER COOLER
- SINK
- BOTTLE FILLER
- X NON-OPERABLE





INSTITUTE FOR ENVIRONMENTAL ASSESSMENT
9201 West Broadway Brooklyn Park, MN 55445
Tel: 763.315.7900 Toll Free: 800.233.9513
Fax: 763.315.7920

ST. MICHAEL-ALBERTVILLE HIGH SCHOOL

UPPER LEVEL FLOOR PLAN | DEC. 2024

N

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085)
Account #: 2190
Project #: 202410983

Client: Institute for Environmental Assessment (IEA)
PO: 202410983

Emma Squires-Sperling
IEA / Brooklyn Park
9201 W Broadway Suite #600
Brooklyn Park, MN 55445

Certificate of Analysis

Approval

All data reported has been reviewed and approved by:



Dan O'Connell, Organic Chemistry Lab Manager New Ulm, MN

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:
MN LAB # 027-015-125ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:
MN LAB # 038-999-267ND W/DW # ND-016

Workorder Comments

All samples were preserved with nitric acid upon receipt at the laboratory.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085001 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-1 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen-North SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.97**	ug/L	15	EPA 200.8	11/25/2024 09:08	

Lab ID: 71085002 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-2 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen-West SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.65**	ug/L	15	EPA 200.8	11/25/2024 09:09	

Lab ID: 71085003 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-3 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen-Middle SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.68**	ug/L	15	EPA 200.8	11/25/2024 09:10	

Lab ID: 71085004 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-4 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen-SE SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.88**	ug/L	15	EPA 200.8	11/25/2024 09:19	

Lab ID: 71085005 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-5 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen-STK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.95**	ug/L	15	EPA 200.8	11/25/2024 09:20	

Lab ID: 71085006 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-6 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen-West Steamer

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.72**	ug/L	15	EPA 200.8	11/25/2024 09:21	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085007 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-7 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen-East Steamer

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.82**	ug/L	15	EPA 200.8	11/25/2024 09:23	

Lab ID: 71085008 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-8 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen-North SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.57**	ug/L	15	EPA 200.8	11/25/2024 09:24	

Lab ID: 71085009 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-9 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen-Middle SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**447**	ug/L	15	EPA 200.8	11/26/2024 11:21	

Lab ID: 71085010 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-10 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen-South SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.39**	ug/L	15	EPA 200.8	11/25/2024 09:25	

Lab ID: 71085011 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-11 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom-NW SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.45**	ug/L	15	EPA 200.8	11/25/2024 09:26	

Lab ID: 71085012 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-12 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom-West Middle SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.03**	ug/L	15	EPA 200.8	11/25/2024 09:27	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085013 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-13 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom-SW SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.93**	ug/L	15	EPA 200.8	11/25/2024 09:28	

Lab ID: 71085014 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-14 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom-SE SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.69**	ug/L	15	EPA 200.8	11/25/2024 09:29	

Lab ID: 71085015 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-15 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom-West SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.51**	ug/L	15	EPA 200.8	11/25/2024 09:43	

Lab ID: 71085016 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-16 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Dishroom-East SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.78**	ug/L	15	EPA 200.8	11/22/2024 17:15	

Lab ID: 71085017 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-17 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Cafeteria-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 17:16	

Lab ID: 71085018 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-18 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Staff Lounge SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.98**	ug/L	15	EPA 200.8	11/22/2024 17:25	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085019 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-19 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Staff Lounge-West SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.56**	ug/L	15	EPA 200.8	11/22/2024 17:26	

Lab ID: 71085020 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-20 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Staff Lounge-West Middle SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.11**	ug/L	15	EPA 200.8	11/22/2024 17:27	

Lab ID: 71085021 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-21 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Staff Lounge-East Middle SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.16**	ug/L	15	EPA 200.8	11/22/2024 17:29	

Lab ID: 71085022 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-23 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Music Room Office-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**10.5**	ug/L	15	EPA 200.8	11/22/2024 17:30	

Lab ID: 71085023 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-24 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 129 Office-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**32.1**	ug/L	15	EPA 200.8	11/22/2024 17:31	

Lab ID: 71085024 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-26 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 131-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 17:32	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085025 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-27 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 131-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.72**	ug/L	15	EPA 200.8	11/22/2024 17:33	

Lab ID: 71085026 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-28 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 132-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.86**	ug/L	15	EPA 200.8	11/22/2024 17:34	

Lab ID: 71085027 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-29 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 132-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.32**	ug/L	15	EPA 200.8	11/22/2024 17:35	

Lab ID: 71085028 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-30 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 132-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.98**	ug/L	15	EPA 200.8	11/22/2024 17:49	

Lab ID: 71085029 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-31 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 133-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**67.7**	ug/L	15	EPA 200.8	11/22/2024 17:50	

Lab ID: 71085030 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-32 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 133-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.01**	ug/L	15	EPA 200.8	11/22/2024 17:51	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085031 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-33 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 134-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.93**	ug/L	15	EPA 200.8	11/22/2024 17:52	

Lab ID: 71085032 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-34 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 134-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.81**	ug/L	15	EPA 200.8	11/22/2024 17:53	

Lab ID: 71085033 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-35 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 135-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.04**	ug/L	15	EPA 200.8	11/22/2024 17:54	

Lab ID: 71085034 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-36 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 135-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.28**	ug/L	15	EPA 200.8	11/26/2024 11:16	

Lab ID: 71085035 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-37 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Art Room-North SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.84**	ug/L	15	EPA 200.8	11/22/2024 17:55	

Lab ID: 71085036 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-38 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Art Room-Middle SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.07**	ug/L	15	EPA 200.8	11/22/2024 17:56	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085037 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-39 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Art Room-South SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.46**	ug/L	15	EPA 200.8	11/22/2024 17:57	

Lab ID: 71085038 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-40 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Gymnasium-West WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.06**	ug/L	15	EPA 200.8	11/22/2024 17:58	

Lab ID: 71085039 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-41 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Gymnasium-East WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.87**	ug/L	15	EPA 200.8	11/22/2024 18:07	

Lab ID: 71085040 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-42 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 140 Bathroom-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**14.7**	ug/L	15	EPA 200.8	11/22/2024 18:08	

Lab ID: 71085041 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-43 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 200-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 18:10	

Lab ID: 71085042 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-44 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 200-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 18:11	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085043 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-45 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Work Room-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.23**	ug/L	15	EPA 200.8	11/22/2024 18:12	

Lab ID: 71085044 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-47 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Nurse-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.22**	ug/L	15	EPA 200.8	11/22/2024 18:13	

Lab ID: 71085045 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-48 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 101-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.45**	ug/L	15	EPA 200.8	11/22/2024 18:14	

Lab ID: 71085046 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-49 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 101-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**8.41**	ug/L	15	EPA 200.8	11/22/2024 18:15	

Lab ID: 71085047 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-50 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 102-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**7.19**	ug/L	15	EPA 200.8	11/26/2024 11:17	

Lab ID: 71085048 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-51 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 102-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**7.75**	ug/L	15	EPA 200.8	11/22/2024 18:16	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085049 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-52 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 103-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 18:17	

Lab ID: 71085050 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-53 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 103-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.13**	ug/L	15	EPA 200.8	11/22/2024 18:31	

Lab ID: 71085051 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-54 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 103-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**8.25**	ug/L	15	EPA 200.8	11/22/2024 18:32	

Lab ID: 71085052 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-55 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 104-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.94**	ug/L	15	EPA 200.8	11/22/2024 18:33	

Lab ID: 71085053 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-56 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 104-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.28**	ug/L	15	EPA 200.8	11/22/2024 18:34	

Lab ID: 71085054 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-57 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 105-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.55**	ug/L	15	EPA 200.8	11/22/2024 18:35	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085055 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-58 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 105-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.44**	ug/L	15	EPA 200.8	11/22/2024 18:36	

Lab ID: 71085056 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-59 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 106-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**29.8**	ug/L	15	EPA 200.8	11/22/2024 18:37	

Lab ID: 71085057 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-60 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 106-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 18:38	

Lab ID: 71085058 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-61 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 107-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**67.2**	ug/L	15	EPA 200.8	11/22/2024 18:40	

Lab ID: 71085059 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-62 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 107-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.94**	ug/L	15	EPA 200.8	11/26/2024 11:18	

Lab ID: 71085060 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-63 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 108-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 18:41	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085061 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-64 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 108-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/22/2024 18:54	

Lab ID: 71085062 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-65 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 112-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**14.8**	ug/L	15	EPA 200.8	11/26/2024 11:29	

Lab ID: 71085063 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-66 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 112-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.56**	ug/L	15	EPA 200.8	11/22/2024 18:55	

Lab ID: 71085064 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-67 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 113-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.28**	ug/L	15	EPA 200.8	11/26/2024 13:08	

Lab ID: 71085065 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-68 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 113-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.71**	ug/L	15	EPA 200.8	11/26/2024 13:09	

Lab ID: 71085066 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-69 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 114-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.38**	ug/L	15	EPA 200.8	11/26/2024 13:10	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085067 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-70 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 114-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.98**	ug/L	15	EPA 200.8	11/26/2024 13:12	

Lab ID: 71085068 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-71 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 114-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 13:13	

Lab ID: 71085069 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-72 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 212-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.54**	ug/L	15	EPA 200.8	11/26/2024 13:14	

Lab ID: 71085070 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-73 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 117-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**16.0**	ug/L	15	EPA 200.8	11/26/2024 13:15	

Lab ID: 71085071 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-74 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 117-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.06**	ug/L	15	EPA 200.8	11/26/2024 13:16	

Lab ID: 71085072 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-75 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 118-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 13:17	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085073 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-76 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 118-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.65**	ug/L	15	EPA 200.8	11/26/2024 13:18	

Lab ID: 71085074 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-77 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 119-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.15**	ug/L	15	EPA 200.8	11/26/2024 13:27	

Lab ID: 71085075 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-78 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 119-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.71**	ug/L	15	EPA 200.8	11/26/2024 13:28	

Lab ID: 71085076 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-79 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 120-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.53**	ug/L	15	EPA 200.8	11/26/2024 13:29	

Lab ID: 71085077 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-80 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 120-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.45**	ug/L	15	EPA 200.8	11/26/2024 13:30	

Lab ID: 71085078 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-81 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 121-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.23**	ug/L	15	EPA 200.8	11/26/2024 13:31	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085079 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-82 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 121-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.84**	ug/L	15	EPA 200.8	11/26/2024 13:33	

Lab ID: 71085080 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-83 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 122-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 13:34	

Lab ID: 71085081 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-84 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 122-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.46**	ug/L	15	EPA 200.8	11/26/2024 13:35	

Lab ID: 71085082 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-85 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 123-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.12**	ug/L	15	EPA 200.8	11/26/2024 13:36	

Lab ID: 71085083 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-86 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 123-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.43**	ug/L	15	EPA 200.8	11/26/2024 13:37	

Lab ID: 71085084 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-87 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 124-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 13:46	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085085 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-88 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 124-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 13:47	

Lab ID: 71085086 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-89 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 124-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**9.98**	ug/L	15	EPA 200.8	11/26/2024 13:48	

Lab ID: 71085087 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-90 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 142-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.61**	ug/L	15	EPA 200.8	11/26/2024 13:49	

Lab ID: 71085088 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-92 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 143-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**12.3**	ug/L	15	EPA 200.8	11/26/2024 13:50	

Lab ID: 71085089 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-93 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 143-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**7.33**	ug/L	15	EPA 200.8	11/26/2024 13:51	

Lab ID: 71085090 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-94 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 144-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**14.0**	ug/L	15	EPA 200.8	11/27/2024 10:50	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085091 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-95 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 144-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**8.55**	ug/L	15	EPA 200.8	11/26/2024 13:53	

Lab ID: 71085092 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-96 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 145-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.70**	ug/L	15	EPA 200.8	11/26/2024 13:54	

Lab ID: 71085093 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-97 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 145-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.19**	ug/L	15	EPA 200.8	11/26/2024 13:55	

Lab ID: 71085094 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-98 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 148-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.42**	ug/L	15	EPA 200.8	11/26/2024 13:56	

Lab ID: 71085095 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-100 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 149-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.00**	ug/L	15	EPA 200.8	11/26/2024 14:09	

Lab ID: 71085096 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-101 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 149-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**7.86**	ug/L	15	EPA 200.8	11/26/2024 14:10	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085097 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-102 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 150-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**13.4**	ug/L	15	EPA 200.8	11/26/2024 14:11	

Lab ID: 71085098 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-103 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 150-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.29**	ug/L	15	EPA 200.8	11/26/2024 14:12	

Lab ID: 71085099 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-104 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 208-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.04**	ug/L	15	EPA 200.8	11/26/2024 14:14	

Lab ID: 71085100 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-105 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 207-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.50**	ug/L	15	EPA 200.8	11/26/2024 14:15	

Lab ID: 71085101 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-107 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 146-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.74**	ug/L	15	EPA 200.8	11/26/2024 14:16	

Lab ID: 71085102 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-108 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 146-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**8.75**	ug/L	15	EPA 200.8	11/26/2024 14:17	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085103 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-109 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 147-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.42**	ug/L	15	EPA 200.8	11/26/2024 14:18	

Lab ID: 71085104 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-110 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 147-DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.49**	ug/L	15	EPA 200.8	11/26/2024 14:19	

Lab ID: 71085105 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-111 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 203-WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 14:28	

Lab ID: 71085106 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-112 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Room 203-SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.06**	ug/L	15	EPA 200.8	11/26/2024 14:29	

Lab ID: 71085107 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-114 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Cafeteria-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 14:30	

Lab ID: 71085108 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-115 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 103-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 14:31	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71085109 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-116 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 114-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 14:32	

Lab ID: 71085110 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-117 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 124-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 14:33	


Lab ID: 71085111 **Date Collected:** 11/13/2024 05:30 **Matrix:** Potable Water
Sample ID: 111324STME-118 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 203-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/26/2024 14:35	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)



MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

71085

Client Name	St. Michael-Albertville ISD #885	Building Name	St. Michael Elementary	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Blair Cecil	Date	11/13/2024	Time	5:30am
Reviewed By		Date		Time	
Shipped By	Blair Cecil	Date	11/13/2024	Time	10:00am
Received By		Date		Time	

Analyzed By (Company)	Analyst	Date & Time
Turnaround Time		Notes
Sample Condition		Temperature

Lab Number	Sample Number	Sample Location	Sample Type: Water	Sample Type: Soil	Sample Type: Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
01	111324STME-1	Kitchen - North SNK	X			11/13/2024	250mL unpreserved	Lead	
02	111324STME-2	Kitchen - West SNK	X			11/13/2024	250mL unpreserved	Lead	
03	111324STME-3	Kitchen - Middle SNK	X			11/13/2024	250mL unpreserved	Lead	
04	111324STME-4	Kitchen - SE SNK	X			11/13/2024	250mL unpreserved	Lead	
05	111324STME-5	Kitchen - STK	X			11/13/2024	250mL unpreserved	Lead	
06	111324STME-6	Kitchen - West Steamer	X			11/13/2024	250mL unpreserved	Lead	
07	111324STME-7	Kitchen - East Steamer	X			11/13/2024	250mL unpreserved	Lead	
08	111324STME-8	Kitchen - North SPR	X			11/13/2024	250mL unpreserved	Lead	
09	111324STME-9	Kitchen - Middle SPR	X			11/13/2024	250mL unpreserved	Lead	
10	111324STME-10	Kitchen - South SPR	X			11/13/2024	250mL unpreserved	Lead	
11	111324STME-11	Dishroom - NW SNK	X			11/13/2024	250mL unpreserved	Lead	
12	111324STME-12	Dishroom - West Middle SNK	X			11/13/2024	250mL unpreserved	Lead	
13	111324STME-13	Dishroom - SW SNK	X			11/13/2024	250mL unpreserved	Lead	
14	111324STME-14	Dishroom - SE SNK	X			11/13/2024	250mL unpreserved	Lead	
15	111324STME-15	Dishroom - West SPR	X			11/13/2024	250mL unpreserved	Lead	
16	111324STME-16	Dishroom - East SPR	X			11/13/2024	250mL unpreserved	Lead	
17	111324STME-17	Cafeteria - DF	X			11/13/2024	250mL unpreserved	Lead	
18	111324STME-18	Staff Lounge - SNK	X			11/13/2024	250mL unpreserved	Lead	
19	111324STME-19	Outside Staff Lounge - West SNK	X			11/13/2024	250mL unpreserved	Lead	
20	111324STME-20	Outside Staff Lounge - West Middle SNK	X			11/13/2024	250mL unpreserved	Lead	
21	111324STME-21	Outside Staff Lounge - East Middle SNK	X			11/13/2024	250mL unpreserved	Lead	
22	111324STME-23	Music Room Office - SNK	X			11/13/2024	250mL unpreserved	Lead	
23	111324STME-24	Room 129 Office - SNK	X			11/13/2024	250mL unpreserved	Lead	
24	111324STME-26	Room 131 - SNK	X			11/13/2024	250mL unpreserved	Lead	
25	111324STME-27	Room 131 - DF	X			11/13/2024	250mL unpreserved	Lead	
26	111324STME-28	Room 132 - SNK	X			11/13/2024	250mL unpreserved	Lead	
27	111324STME-29	Room 132 - DF	X			11/13/2024	250mL unpreserved	Lead	
28	111324STME-30	Outside Room 132 - DF	X			11/13/2024	250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

AMB DR 13Nov24 14:14 AMB 19.0 TM 24

AMB DR 13Nov24 14:14 19.0 TM

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

Client Name	St. Michael-Albertville ISD #885	Building Name	St. Michael Elementary	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Blair Cecil	Date	11/13/2024	Time	5:30am
Reviewed By		Date		Time	
Shipped By	Blair Cecil	Date	11/13/2024	Time	10:00am
Received By		Date		Time	

Analyzed By (Company)	Analyst	Date & Time
Turnaround Time		Notes
Sample Condition		Temperature

Lab Number	Sample Number	Sample Location	Sample Type: Water	Sample Type: Soil	Sample Type: Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
29	111324STME-31	Room 133 - SNK	X			11/13/2024	250mL unpreserved	Lead	
30	111324STME-32	Room 133 - DF	X			11/13/2024	250mL unpreserved	Lead	
31	111324STME-33	Room 134 - SNK	X			11/13/2024	250mL unpreserved	Lead	
32	111324STME-34	Room 134 - DF	X			11/13/2024	250mL unpreserved	Lead	
33	111324STME-35	Room 135 - SNK	X			11/13/2024	250mL unpreserved	Lead	
34	111324STME-36	Room 135 - DF	X			11/13/2024	250mL unpreserved	Lead	
35	111324STME-37	Art Room - North SNK	X			11/13/2024	250mL unpreserved	Lead	
36	111324STME-38	Art Room - Middle SNK	X			11/13/2024	250mL unpreserved	Lead	
37	111324STME-39	Art Room - South SNK	X			11/13/2024	250mL unpreserved	Lead	
38	111324STME-40	Gymnasium - West WC	X			11/13/2024	250mL unpreserved	Lead	
39	111324STME-41	Gymnasium - East WC	X			11/13/2024	250mL unpreserved	Lead	
40	111324STME-42	Room 140 Bathroom - SNK	X			11/13/2024	250mL unpreserved	Lead	
41	111324STME-43	Outside Room 200 - WC	X			11/13/2024	250mL unpreserved	Lead	
42	111324STME-44	Outside Room 200 - WBF	X			11/13/2024	250mL unpreserved	Lead	
43	111324STME-45	Work Room - SNK	X			11/13/2024	250mL unpreserved	Lead	
44	111324STME-47	Nurse - SNK	X			11/13/2024	250mL unpreserved	Lead	
45	111324STME-48	Room 101 - SNK	X			11/13/2024	250mL unpreserved	Lead	
46	111324STME-49	Room 101 - DF	X			11/13/2024	250mL unpreserved	Lead	
47	111324STME-50	Room 102 - SNK	X			11/13/2024	250mL unpreserved	Lead	
48	111324STME-51	Room 102 - DF	X			11/13/2024	250mL unpreserved	Lead	
49	111324STME-52	Outside Room 103 - WC	X			11/13/2024	250mL unpreserved	Lead	
50	111324STME-53	Room 103 - SNK	X			11/13/2024	250mL unpreserved	Lead	
51	111324STME-54	Room 103 - DF	X			11/13/2024	250mL unpreserved	Lead	
52	111324STME-55	Room 104 - SNK	X			11/13/2024	250mL unpreserved	Lead	
53	111324STME-56	Room 104 - DF	X			11/13/2024	250mL unpreserved	Lead	
54	111324STME-57	Room 105 - SNK	X			11/13/2024	250mL unpreserved	Lead	
55	111324STME-58	Room 105 - DF	X			11/13/2024	250mL unpreserved	Lead	
56	111324STME-59	Room 106 - SNK	X			11/13/2024	250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

Client Name	St. Michael-Albertville ISD #885	Building Name	St. Michael Elementary	Analytical Lab	MVTL
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	202410983	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900	IEA Fax #	763-315-7927	Written Sample Results To	lab@ieasafety.com
Other Information					
Sampled By	Blair Cecil	Date	11/13/2024	Time	5:30am
Reviewed By		Date		Time	
Shipped By	Blair Cecil	Date	11/13/2024	Time	10:00am
Received By		Date		Time	

Analyzed By (Company)	Analyst	Date & Time
Turnaround Time		Notes
Sample Condition		Temperature


Lab Number	Sample Number	Sample Location	Sample Type			Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
			Water	Soil	Other				
57	111324STME-60	Room 106 - DF	X			11/13/2024	250mL unpreserved	Lead	
58	111324STME-61	Room 107 - SNK	X			11/13/2024	250mL unpreserved	Lead	
59	111324STME-62	Room 107 - DF	X			11/13/2024	250mL unpreserved	Lead	
60	111324STME-63	Room 108 - SNK	X			11/13/2024	250mL unpreserved	Lead	
61	111324STME-64	Room 108 - DF	X			11/13/2024	250mL unpreserved	Lead	
62	111324STME-65	Room 112 - SNK	X			11/13/2024	250mL unpreserved	Lead	
63	111324STME-66	Room 112 - DF	X			11/13/2024	250mL unpreserved	Lead	
64	111324STME-67	Room 113 - SNK	X			11/13/2024	250mL unpreserved	Lead	
65	111324STME-68	Room 113 - DF	X			11/13/2024	250mL unpreserved	Lead	
66	111324STME-69	Room 114 - SNK	X			11/13/2024	250mL unpreserved	Lead	
67	111324STME-70	Room 114 - DF	X			11/13/2024	250mL unpreserved	Lead	
68	111324STME-71	Outside Room 114 - WC	X			11/13/2024	250mL unpreserved	Lead	
69	111324STME-72	Room 212 - SNK	X			11/13/2024	250mL unpreserved	Lead	
70	111324STME-73	Room 117 - SNK	X			11/13/2024	250mL unpreserved	Lead	
71	111324STME-74	Room 117 - DF	X			11/13/2024	250mL unpreserved	Lead	
72	111324STME-75	Room 118 - SNK	X			11/13/2024	250mL unpreserved	Lead	
73	111324STME-76	Room 118 - DF	X			11/13/2024	250mL unpreserved	Lead	
74	111324STME-77	Room 119 - SNK	X			11/13/2024	250mL unpreserved	Lead	
75	111324STME-78	Room 119 - DF	X			11/13/2024	250mL unpreserved	Lead	
76	111324STME-79	Room 120 - SNK	X			11/13/2024	250mL unpreserved	Lead	
77	111324STME-80	Room 120 - DF	X			11/13/2024	250mL unpreserved	Lead	
78	111324STME-81	Room 121 - SNK	X			11/13/2024	250mL unpreserved	Lead	
79	111324STME-82	Room 121 - DF	X			11/13/2024	250mL unpreserved	Lead	
80	111324STME-83	Room 122 - SNK	X			11/13/2024	250mL unpreserved	Lead	
81	111324STME-84	Room 122 - DF	X			11/13/2024	250mL unpreserved	Lead	
82	111324STME-85	Room 123 - SNK	X			11/13/2024	250mL unpreserved	Lead	
83	111324STME-86	Room 123 - DF	X			11/13/2024	250mL unpreserved	Lead	
84	111324STME-87	Outside Room 124 - WC	X			11/13/2024	250mL unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)



Chain of Custody

Lab Number	Sample Number	Sample Location	Sample Type: Water	Sample Type: Soil	Sample Type: Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
1113245TME-88	84	Room 124 - SNK	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-89	85	Room 124 - DF	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-90	86	Room 142 - SNK	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-92	88	Room 143 - SNK	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-93	89	Room 143 - DF	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-94	90	Room 144 - SNK	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-95	91	Room 144 - DF	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-96	92	Room 145 - SNK	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-97	93	Room 145 - DF	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-98	94	Room 148 - SNK	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-100	95	Room 149 - SNK	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-101	96	Room 149 - DF	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-102	97	Room 150 - SNK	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-103	98	Room 150 - DF	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-104	99	Room 208 - SNK	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-105	100	Room 207 - SNK	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-107	101	Room 146 - SNK	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-108	102	Room 146 - DF	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-109	103	Room 147 - SNK	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-110	104	Room 147 - DF	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-111	105	Outside Room 203 - WC	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-112	106	Room 203 - SNK	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-114	107	Cafeteria - WBF	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-115	108	Outside Room 103 - WBF	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-116	109	Outside Room 114 - WBF	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-117	110	Outside Room 124 - WBF	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-118	111	Outside Room 203 - WBF	X			11/13/2024	250mL unpreserved	Lead	
1113245TME-22	84	~~Outside Staff Lounge - East SNK~~	X			11/13/2024	250mL unpreserved	Lead	In-operable

Client Name	St. Michael-Albertville ISD #885	Building Name	St. Michael Elementary
Contact Name	Emma Squires-Sperling Daniel Holcomb	Project #	20241098 3
Phone #	763-315-7900	IEA Fax #	763-315-7927
Other Information			
Sampled By	Blair Cecil	Date	11/13/2024 Time 5:30am
Received By	Blair Cecil	Date	11/13/2024 Time 10:00am
Notes		Temperature Time	Sample Condition

Analyst	Analyzed By (Company)	Date & Time	


Analytical Lab	MVTL
Project Name	2024-2025 STMA LLW
Written Sample Results To	lab@ieaccafety.com

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.333.3513

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)



Chain of Custody

9201 Vycst Broadway North, Suite 600
Brooklyn Park, MN 55445
763 315 7900 1 800 233 9513

| | | |

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Member ACIL

Workorder: St. Michael Elementary (71085) **Client:** Institute for Environmental Assessment (IEA)

Sample Condition Checklist

Date: 13 Nov 24 Time: 14:14 ☐ AM ☐ PM By: DwonR

Account Name: St Michaels Elem. Account # —

Bill of Lading #: — Cooler #: —

Temp: 19.0 °C ROI ☐ Ambient ☑ Tracking #: —

TM#: 774 Ice Crystals Present in Sample ☐

MVTL Courier: Dan Other: IEA

MVTL Route: Metro Walk-In ☐ UPS Air ☐ FedEx Air ☐ SpeeDee ☐

Mail ☐ UPS Ground ☐ Fed Ex Ground ☐

Containers Supplied by MVTL: Yes ☑ No ☐ Designate customer supplied containers as "Other" in container size column

Comments:

Number	Containers Size (mL)	Container Type	Preservation	pH
III	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	Low Level Mercury Kit	***!!DO NOT OPEN THE PLASTIC BAGS HOLDING THE SAMPLE BOTTLES!!***		
	4 oz Jar	Clear Amber	MeOH None	n/a
	2 oz Jar	Clear Amber	MeOH None	n/a
	Vials Individual Set of 2 Set of 3	Clear Amber	HCl H_3PO_4 H_2SO_4 None	n/a
	Vials Individual Set of 2 Set of 3	Clear Amber	HCl H_3PO_4 H_2SO_4 None	n/a
	Trip Blank Individual Set of 2 Set of 3	n/a		
	Moisture Vial	n/a		
	Manure Bottle	n/a		

*ANY CONTAINER SENT TO A SUBCONTRACT LABORATORY WILL NOT BE CHECKED FOR PRESERVATION!

Form # 30-911001-0 Page 1 of 1 Effective Date: 29 September 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



INSTITUTE FOR ENVIRONMENTAL ASSESSMENT
9201 West Broadway Brooklyn Park, MN 55445
Tel: 763.315.7900 Toll Free: 800.233.9513
Fax: 763.315.7920

ST. MICHAEL ELEMENTARY

FIRST LEVEL FLOOR PLAN

ST. MICHAEL-ALBERTVILLE ISD #885
DEC. 2024

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA Ice Arena (71030)
Account #: 2190
Project #: 202410983

Client: Institute for Environmental Assessment (IEA)
PO: 202410983

Emma Squires-Sperling
IEA / Brooklyn Park
9201 W Broadway Suite #600
Brooklyn Park, MN 55445

Certificate of Analysis

Approval

All data reported has been reviewed and approved by:



Dave Smahel, Inorganic Chemistry/Feed Lab Manager New Ulm, MN

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:
MN LAB # 027-015-125ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:
MN LAB # 038-999-267ND W/DW # ND-016

Workorder Comments

All samples were preserved with nitric acid upon receipt at the laboratory.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, November 26, 2024 6:51:06 AM

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA Ice Arena (71030) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71030001 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-01 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Entrance - North WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 08:42	

Lab ID: 71030002 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-02 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Entrance - South WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 08:43	

Lab ID: 71030003 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-03 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Entrance - WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 08:44	

Lab ID: 71030004 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-04 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Concessions - HWD

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.65**	ug/L	15	EPA 200.8	11/25/2024 08:45	

Lab ID: 71030005 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-05 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Concessions - West SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 08:46	

Lab ID: 71030006 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-06 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Concessions - Middle SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 08:47	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA Ice Arena (71030) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71030007 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-07 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Concessions - East SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.56**	ug/L	15	EPA 200.8	11/25/2024 08:48	

Lab ID: 71030008 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-08 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Locker Room Hallway - West WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 08:49	

Lab ID: 71030009 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-09 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: Locker Room Hallway - East WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 08:50	

Lab ID: 71030010 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-10 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: West Locker Room - North SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.78**	ug/L	15	EPA 200.8	11/25/2024 08:52	

Lab ID: 71030011 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-11 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: West Locker Room - South SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.90**	ug/L	15	EPA 200.8	11/25/2024 09:00	

Lab ID: 71030012 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-12 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: East Locker Room - North SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.52**	ug/L	15	EPA 200.8	11/25/2024 09:02	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA Ice Arena (71030) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 71030013 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-13 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: East Locker Room - South SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.06**	ug/L	15	EPA 200.8	11/25/2024 09:03	

Lab ID: 71030014 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-14 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: 2nd Floor - West WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 09:04	

Lab ID: 71030015 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-15 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: 2nd Floor - East WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 09:05	

Lab ID: 71030016 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-16 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: 2nd Floor - WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/25/2024 09:06	

Lab ID: 71030017 **Date Collected:** No Date Sampled Supplied **Matrix:** Potable Water
Sample ID: 111224STMAIA-17 **Date Received:** 11/13/2024 14:14
Temp @ Receipt (C):
Sample Desc: 2nd Floor Community Room - SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.55**	ug/L	15	EPA 200.8	11/25/2024 09:07	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA Ice Arena (71030) **Client:** Institute for Environmental Assessment (IEA)



MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, November 26, 2024 6:51:06 AM

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA Ice Arena (71030) **Client:** Institute for Environmental Assessment (IEA)

Chain of Custody

Client Name	St. Michael-Albertville ISD #885		Building Name	STMA Ice Arena	Analytical Lab	MVTL
Contact Name	Emma Squires-Spelling	Daniel Holcomb	Project #	20241098 3	Project Name	2024-2025 STMA LIW
Phone #	763-315-7900		IEA Fax #	763-315-7927	Written Sample Results To	lab@leasafety.com
Other Information						
Sampled By	Jake Schisler	Date	Time	7:00AM	Analyzed By (Company)	Analyst	Date & Time
Received By		Date	Time				
Shipped By	Sashya Wandmaker	Date	Time	10:00AM	Turnaround Time	Notes
Received By		Date	Time		Sample Condition	Temperature

Lab Number	Sample Number	Sample Location	Sample Type: Water	Sample Type: Soil	Sample Type: Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
First Floor									
1	1112245TMAIA-01	Entrance - North WC	X				250ml unpreserved	Lead	
2	1112245TMAIA-02	Entrance - South WC	X				250ml unpreserved	Lead	
3	1112245TMAIA-03	Entrance - WBF	X				250ml unpreserved	Lead	
4	1112245TMAIA-04	Concessions - HWD	X				250ml unpreserved	Lead	
5	1112245TMAIA-05	Concessions - West SNK	X				250ml unpreserved	Lead	
6	1112245TMAIA-06	Concessions - Middle SNK	X				250ml unpreserved	Lead	
7	1112245TMAIA-07	Concessions - East SNK	X				250ml unpreserved	Lead	
8	1112245TMAIA-08	Locker Room Hallway - West WBF	X				250ml unpreserved	Lead	
9	1112245TMAIA-09	Locker Room Hallway - East WBF	X				250ml unpreserved	Lead	
10	1112245TMAIA-10	West Locker Room - North SNK	X				250ml unpreserved	Lead	
11	1112245TMAIA-11	West Locker Room - South SNK	X				250ml unpreserved	Lead	
12	1112245TMAIA-12	East Locker Room - North SNK	X				250ml unpreserved	Lead	
13	1112245TMAIA-13	East Locker Room - South SNK	X				250ml unpreserved	Lead	
Second Floor									
14	1112245TMAIA-14	2nd Floor - West WC	X				250ml unpreserved	Lead	
15	1112245TMAIA-15	2nd Floor - East WC	X				250ml unpreserved	Lead	
16	1112245TMAIA-16	2nd Floor - WBF	X				250ml unpreserved	Lead	
17	1112245TMAIA-17	2nd Floor Community Room - SNK	X				250ml unpreserved	Lead	
			X				250ml unpreserved	Lead	
			X				250ml unpreserved	Lead	
			X				250ml unpreserved	Lead	
			X				250ml unpreserved	Lead	
			X				250ml unpreserved	Lead	
			X				250ml unpreserved	Lead	
			X				250ml unpreserved	Lead	
			X				250ml unpreserved	Lead	
			X				250ml unpreserved	Lead	
			X				250ml unpreserved	Lead	
			X				250ml unpreserved	Lead	

Original - Analytical Lab
Copy - Client File
Copy - IEA Lab

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763 315 7900 1 800 233 9513

1 of 14

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: STMA Ice Arena (71030) **Client:** Institute for Environmental Assessment (IEA)

Sample Condition Checklist

Date: 13 Nov 24 Time: 1414 ☐ AM ☒ PM By: SP

Account Name: IEA - STMAIA Account # –

Bill of Lading #: – Cooler #: –

Temp: 19.0 °C ROI ☐ Ambient ☒ Tracking #: –

TM#: 774 Ice Crystals Present in Sample ☐

MVTL Courier: Dan Other:

MVTL Route: Metro Walk-In ☐ UPS Air ☐ FedEx Air ☐ SpeeDee ☐

Mail ☐ UPS Ground ☐ Fed Ex Ground ☐

Containers Supplied by MVTL: Yes ☒ No ☐ Designate customer supplied containers as "Other" in container size column


Comments:

Number	Containers Size (mL)	Container Type	Preservation	pH
17	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	Low Level Mercury Kit	***!!DO NOT OPEN THE PLASTIC BAGS HOLDING THE SAMPLE BOTTLES!!***		
	4 oz Jar	Clear Amber	MeOH None	n/a
	2 oz Jar	Clear Amber	MeOH None	n/a
	Vials Individual Set of 2 Set of 3	Clear Amber	HCl H_3PO_4 H_2SO_4 None	n/a
	Vials Individual Set of 2 Set of 3	Clear Amber	HCl H_3PO_4 H_2SO_4 None	n/a
	Trip Blank Individual Set of 2 Set of 3	n/a		
	Moisture Vial	n/a		
	Manure Bottle	n/a		

*ANY CONTAINER SENT TO A SUBCONTRACT LABORATORY WILL NOT BE CHECKED FOR PRESERVATION!

Form # 30-911001-0 Page 1 of 1 Effective Date: 29 September 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.




INSTITUTE FOR ENVIRONMENTAL ASSESSMENT
9201 West Broadway Brooklyn Park, MN 55445
Tel: 763.315.7900 Toll Free: 800.233.9513
Fax: 763.315.7920

STMA ICE ARENA

MAIN LEVEL FLOOR PLAN | DEC. 2024

LEGEND

- WATER COOLER
- SINK
- BOTTLE FILLER



INSTITUTE FOR ENVIRONMENTAL ASSESSMENT
9201 West Broadway Brooklyn Park, MN 55445
Tel: 763.315.7900 Toll Free: 800.233.9513
Fax: 763.315.7920

STMA ICE ARENA

UPPER LEVEL FLOOR PLAN | DEC. 2024

N