

ENVIRONMENTAL LABWORKS, INC.

May 12, 2025

New Paltz CSD
196 Main Street
New Paltz, NY 12561

Dear James,

The following are results of the analyses performed on water samples from **Duzine Elementary School - 31 Sunset Ridge, New Paltz, NY** received at the laboratory on 04/23/25.

Date/Time Collected: 04/23/25 7:58-8:17am First Draw
Collected By: UC BOCES
Project ID: 04232513
Secondary ID: DE251461-76

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Prep Sink 04232513-1	EPA 200.8 Lead	0.0014 mg/L		0.005 mg/L	04/30/25
Kitchen Back Prep Sink 04232513-2	EPA 200.8 Lead	0.0180 mg/L	X	0.005 mg/L	04/30/25
Cafeteria Fountain 04232513-3	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Cafeteria Bottle Fill 04232513-4	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Gym Hall Left Fountain 04232513-5	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Gym Hall Bottle Fill Left 04232513-6	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Gym Hall Right Fountain 04232513-7	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Gym Hall Right Bottle Fill 04232513-8	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Hall by Boiler Rm Right Fountain 04232513-9	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Hall by Boiler Rm Bottle Fill 04232513-10	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25

ENVIRONMENTAL LABWORKS, INC.

Duzine Elementary School - 04232513


LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Hall by Boiler Rm Left Fountain 04232513-11	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Hall by Boiler Rm Left Bottle Fill 04232513-12	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Library Hall Fountain Left 04232513-13	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Library Hall Left Bottle Fill 04232513-14	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Library Hall Right Fountain 04232513-15	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Library Hall Right Bottle Fill 04232513-16	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director