



part of
ALS Limited

Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

York Analytical Laboratory A Division of ALS Limited

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : PAC Academy / Marion P. Thomas Charter Sch., 28 Burnet Street, Newark, NJ 07103

PAS Project ID : P25-05362

Matrix : Drinking Water

Report Date : 6/23/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-05362-01	PAC-2-WC-03C	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/3/25 06:06	6/16/25 22:18
P25-05362-03	PAC-6-3-FBC	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/3/25 06:24	6/16/25 22:41

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

J = Estimated result

* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer