



TOWNSHIP OF OCEAN SCHOOLS

Business Office

163 Monmouth Road
Oakhurst, NJ 07755

gastings@oceanschools.org
(732) 531-5600 ext. 3100

Geoffrey J. Hastings

Business Administrator /
Board Secretary

March 24, 2025

Ocean Township School District
Ocean Township Intermediate School
1200 West Park Ave.
Ocean, NJ 07712

Dear Ocean Township Intermediate School Community:

Our school system is committed to protecting student, teacher, and staff health. To protect our community, in accordance with the Department of Education regulations at N.J.A.C. 6A:26-12.4, the Ocean Township School District tested our schools drinking water for lead.

In accordance with the Department of Education regulations, the Ocean Township School District will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within the Ocean Township Intermediate School. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 41 outlets sampled, 3 first draw samples tested above the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]). Of the 7 follow-up flush samples collected, 0 tested above the lead action level.

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead with the associated first draw and follow-up flush sample lead levels, as well as what temporary remedial action Ocean Township School District has taken or plans to take to reduce the levels of lead at these locations.

Sample Location	First Draw Result in µg/l (ppb)	Follow-up flush Result in µg/l (ppb)	Remedial Action
Nurse-NS-P Sink ID AC34717-02	15.8	7.11	Immediately ceased potable usage and bottled water provided. Posted signage "DO NOT DRINK - SAFE FOR HANDWASHING ONLY"

Home of the Spartans!
#SpartanLegacy





TOWNSHIP OF OCEAN SCHOOLS

Business Office

163 Monmouth Road
Oakhurst, NJ 07755

gastings@oceanschools.org
(732) 531-5600 ext. 3100

Geoffrey J. Hastings

Business Administrator /
Board Secretary

Room 656-DW-P Drinking Water Fountain ID# AC34717-03	21.1	1.80	Immediately shut down fountain. Water is provided by other fountain(s) not found in exceedance
Room 752-DW-P Drinking Water Fountain ID# AC34717-04	19.8	2.54	Immediately shut down fountain. Water is provided by other fountain(s) not found in exceedance

Summary of Actions Taken

The following actions were taken regarding the Ocean Township Intermediate School lead in school drinking water exceedances:

1. All drinking water outlets were immediately shut off [or disconnected] where any first draw test result revealed lead concentrations greater than 15µg/l (ppb);
2. Alternate drinking water was provided to students and staff of the school from other existing outlets tested below lead action levels in any test. Follow up flush results showed no exceedances above the action level were detected.

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body.

Health Effects of Lead (continued)

Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At very high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers, and lakes. Lead enters drinking water primarily because of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes, and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Home of the Spartans!
#SpartanLegacy





TOWNSHIP OF OCEAN SCHOOLS

Business Office

163 Monmouth Road

Oakhurst, NJ 07755

ghastings@oceanschools.org

(732) 531-5600 ext. 3100

Geoffrey J. Hastings

Business Administrator /

Board Secretary

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at www.oceanschools.org. For more information about water quality in our schools, contact Geoffrey Hastings, School Business Administrator, (732) 531-5600, extension 3100.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

Geoffrey J. Hastings

School Business Administrator/Board Secretary

Home of the Spartans!
#SpartanLegacy

