



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number **Sample Location** **Collected By**
0522-1084 550 West Park Avenue - Ocean Twp Ken, Waldele

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0522-1084	4/30/2022 11:30:00 AM Boiler Room Spigot	5/9/2022 9:18:00 AM	Lead (1st Draw)	226 ug/l*	15 ug/L	Std Method 3113B
0522-1084-10	4/30/2022 11:55:00 AM D Hall Center Boys/Girls Left Fountain	5/5/2022 8:42:00 AM	Lead (1st Draw)	9.61 ug/l	15 ug/L	Std Method 3113B
0522-1084-11	4/30/2022 12:00:00 PM By Library C Hall Faculty Left Fountain	5/5/2022 8:42:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1084-12	4/30/2022 12:02:00 PM By Library C Hall Faculty Center Fountain	5/5/2022 8:42:00 AM	Lead (1st Draw)	2.17 ug/l	15 ug/L	Std Method 3113B
0522-1084-13	4/30/2022 12:01:00 PM By Library C Hall Faculty Right Fountain	5/5/2022 8:42:00 AM	Lead (1st Draw)	3.04 ug/l	15 ug/L	Std Method 3113B
0522-1084-14	4/30/2022 12:09:00 PM C114 Home Ec Sink #1	5/9/2022 9:18:00 AM	Lead (1st Draw)	4.89 ug/l	15 ug/L	Std Method 3113B
0522-1084-15	4/30/2022 12:10:00 PM C114 Home Ec Sink #2	5/9/2022 9:18:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1084-16	4/30/2022 12:11:00 PM C114 Home Ec Sink #3	5/9/2022 9:18:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1084-17	4/30/2022 12:12:00 PM C114 Home Ec Sink #4	5/9/2022 9:18:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1084-18	4/30/2022 12:13:00 PM C114 Home Ec Sink #5	5/9/2022 9:18:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1084-19	4/30/2022 12:14:00 PM C114 Home Ec Sink #6	5/9/2022 9:18:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1084-2	4/30/2022 11:33:00 AM Kitchen Left of Kettle Spigot	5/5/2022 8:42:00 AM	Lead (1st Draw)	16.6 ug/l*	15 ug/L	Std Method 3113B
0522-1084-20	4/30/2022 12:20:00 PM C110 Sink	5/9/2022 9:18:00 AM	Lead (1st Draw)	2.84 ug/l	15 ug/L	Std Method 3113B
0522-1084-21	4/30/2022 12:23:00 PM C108 Sink	5/9/2022 9:18:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1084-22	4/30/2022 12:27:00 PM Girls Locker Room Bottle Filler	5/9/2022 9:18:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Thursday, May 12, 2022

NJDEP Laboratory Certification # 14006

Page 1 of 4



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0522-1084	550 West Park Avenue - Ocean Twp	Ken, Waldele

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0522-1084-23	4/30/2022 12:30:00 PM Boys Locker Room Bottle Filler	5/9/2022 9:18:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1084-24	4/30/2022 12:33:00 PM Near Gym B Hall Boys/Girls Fountain Left	5/9/2022 9:18:00 AM	Lead (1st Draw)	72.7 ug/l*	15 ug/L	Std Method 3113B
0522-1084-25	4/30/2022 12:34:00 PM Near Gym B Hall Boys/Girls Fountain Center	5/9/2022 9:18:00 AM	Lead (1st Draw)	79.7 ug/l*	15 ug/L	Std Method 3113B
0522-1084-26	4/30/2022 12:35:00 PM Near Gym B Hall Boys/Girls Fountain Right	5/11/2022 8:48:00 AM	Lead (1st Draw)	185 ug/l*	15 ug/L	Std Method 3113B
0522-1084-27	4/30/2022 12:40:00 PM Center B Hall Boys/Girls Fountain Left	5/9/2022 9:18:00 AM	Lead (1st Draw)	4.33 ug/l	15 ug/L	Std Method 3113B
0522-1084-28	4/30/2022 12:41:00 PM Center B Hall Boys/Girls Fountain Center	5/9/2022 9:18:00 AM	Lead (1st Draw)	4.47 ug/l	15 ug/L	Std Method 3113B
0522-1084-29	4/30/2022 12:42:00 PM Center B Hall Boys/Girls Fountain Right	5/9/2022 9:18:00 AM	Lead (1st Draw)	4.84 ug/l	15 ug/L	Std Method 3113B
0522-1084-3	4/30/2022 11:35:00 AM Kitchen Sink Across From Kettle	5/5/2022 8:42:00 AM	Lead (1st Draw)	37.9 ug/l*	15 ug/L	Std Method 3113B
0522-1084-30	4/30/2022 12:44:00 PM B Hall Faculty Left Fountain	5/9/2022 9:18:00 AM	Lead (1st Draw)	6.83 ug/l	15 ug/L	Std Method 3113B
0522-1084-31	4/30/2022 12:45:00 PM B Hall Faculty Center Fountain	5/9/2022 9:18:00 AM	Lead (1st Draw)	3.09 ug/l	15 ug/L	Std Method 3113B
0522-1084-32	4/30/2022 12:46:00 PM B Hall Faculty Right Fountain	5/9/2022 9:18:00 AM	Lead (1st Draw)	3.08 ug/l	15 ug/L	Std Method 3113B
0522-1084-33	4/30/2022 12:47:00 PM E Wing Between Boys/Girls Fountain	5/9/2022 9:18:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1084-34	4/30/2022 12:56:00 PM D Hall Second Floor Boys/Girls Left Fountain	5/9/2022 9:18:00 AM	Lead (1st Draw)	3.09 ug/l	15 ug/L	Std Method 3113B
0522-1084-35	4/30/2022 12:57:00 PM D Hall Second Floor Boys/Girls Center Fountain	5/9/2022 9:18:00 AM	Lead (1st Draw)	3.10 ug/l	15 ug/L	Std Method 3113B
0522-1084-36	4/30/2022 12:58:00 PM D Hall Second Floor Boys/Girls Right Fountain	5/9/2022 9:18:00 AM	Lead (1st Draw)	6.25 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Thursday, May 12, 2022

NJDEP Laboratory Certification # 14006

Page 2 of 4



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0522-1084	550 West Park Avenue - Ocean Twp	Ken, Waldele

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0522-1084-37	4/30/2022 1:05:00 PM	5/9/2022 9:18:00 AM	Lead (1st Draw)	4.52 ug/l	15 ug/L	Std Method 3113B
B Hall Second Floor Boys/Girls Left Fountain						
0522-1084-38	4/30/2022 1:06:00 PM	5/9/2022 9:18:00 AM	Lead (1st Draw)	6.52 ug/l	15 ug/L	Std Method 3113B
B Hall Second Floor Boys/Girls Center Fountain						
0522-1084-39	4/30/2022 1:07:00 PM	5/9/2022 9:18:00 AM	Lead (1st Draw)	6.01 ug/l	15 ug/L	Std Method 3113B
B Hall Second Floor Boys/Girls Right Fountain						
0522-1084-4	4/30/2022 11:38:00 AM	5/5/2022 8:42:00 AM	Lead (1st Draw)	3.29 ug/l	15 ug/L	Std Method 3113B
Kitchen Spray Near Walk In						
0522-1084-40	4/30/2022 1:12:00 PM	5/9/2022 9:18:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
F Wing Between Boys/Girls Bottle Filler						
0522-1084-41	4/30/2022 1:13:00 PM	5/9/2022 9:18:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
F Wing Between Boys/Girls Fountain						
0522-1084-42	4/30/2022 1:18:00 PM	5/9/2022 9:18:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
Weight Room Fountain/Bottle Filler						
0522-1084-43	4/30/2022 1:25:00 PM	5/9/2022 9:18:00 AM	Lead (1st Draw)	2.01 ug/l	15 ug/L	Std Method 3113B
Snack Bar Handwashing Sink						
0522-1084-44	4/30/2022 1:26:00 PM	5/9/2022 9:18:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
Snack Bar Compartment Sink						
0522-1084-5	4/30/2022 11:41:00 AM	5/5/2022 8:42:00 AM	Lead (1st Draw)	9.59 ug/l	15 ug/L	Std Method 3113B
Kitchen Backs up to Outlet With Spray (dishwasher)						
0522-1084-6	4/30/2022 11:44:00 AM	5/5/2022 8:42:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
A Hall Bottle Filler						
0522-1084-7	4/30/2022 11:47:00 AM	5/5/2022 8:42:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
PAC-A-177 Bottle Filler						
0522-1084-8	4/30/2022 11:53:00 AM	5/5/2022 8:42:00 AM	Lead (1st Draw)	2.08 ug/l	15 ug/L	Std Method 3113B
D Hall Center Boys/Girls Right Fountain						
0522-1084-9	4/30/2022 11:54:00 AM	5/5/2022 8:42:00 AM	Lead (1st Draw)	7.73 ug/l	15 ug/L	Std Method 3113B
D Hall Center Boys/Girls Center Fountain						

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Thursday, May 12, 2022

NJDEP Laboratory Certification # 14006

Page 3 of 4



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0522-1084	550 West Park Avenue - Ocean Twp	Ken, Waldele

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
------------	-----------	----------	-----------	--------	-------	--------

**Some or All of the parameters tested on this report
DID NOT PASS NJ Drinking Water Standards.**

This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.

Reviewed and Approved by:

Ashley Shann, Laboratory Manager Designee

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Thursday, May 12, 2022

NJDEP Laboratory Certification # 14006

Page 4 of 4



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0522-1083	555 Dow Avenue - Ocean Twp	Ken, Waldele

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0522-1083	4/30/2022 9:49:00 AM Basement Utility Spigot	5/3/2022 9:02:00 AM	Lead (1st Draw)	39.6 ug/l*	15 ug/L	Std Method 3113B
0522-1083-10	4/30/2022 10:12:00 AM Bottle Filler Across Room 207	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1083-11	4/30/2022 10:16:00 AM Outside Room 215 Left Fountain	5/3/2022 9:02:00 AM	Lead (1st Draw)	2.39 ug/l	15 ug/L	Std Method 3113B
0522-1083-12	4/30/2022 10:17:00 AM Outside Room 215 Right Fountain	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1083-13	4/30/2022 10:20:00 AM Outside Room 115 Right Fountain	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1083-14	4/30/2022 10:21:00 AM Outside Room 115 Left Fountain	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1083-15	4/30/2022 10:25:00 AM Fountain Near Custodial Office Left	5/3/2022 9:02:00 AM	Lead (1st Draw)	3.10 ug/l	15 ug/L	Std Method 3113B
0522-1083-16	4/30/2022 10:26:00 AM Fountain Near Custodial Office Center	5/3/2022 9:02:00 AM	Lead (1st Draw)	3.94 ug/l	15 ug/L	Std Method 3113B
0522-1083-17	4/30/2022 10:27:00 AM Fountain Near Custodial Office Right	5/5/2022 8:42:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1083-18	4/30/2022 10:29:00 AM Fountain Outside Room 100	5/5/2022 8:42:00 AM	Lead (1st Draw)	10.7 ug/l	15 ug/L	Std Method 3113B
0522-1083-19	4/30/2022 10:31:00 AM Fountain Inside Room 100	5/5/2022 8:42:00 AM	Lead (1st Draw)	8.12 ug/l	15 ug/L	Std Method 3113B
0522-1083-2	4/30/2022 9:51:00 AM Basement Utility Sink	5/3/2022 9:02:00 AM	Lead (1st Draw)	19.5 ug/l*	15 ug/L	Std Method 3113B
0522-1083-20	4/30/2022 10:35:00 AM Fountain Outside Room 99	5/5/2022 8:42:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1083-21	4/30/2022 10:37:00 AM Fountain Inside Room 99	5/5/2022 8:42:00 AM	Lead (1st Draw)	4.72 ug/l	15 ug/L	Std Method 3113B
0522-1083-22	4/30/2022 10:43:00 AM K1 Sink	5/5/2022 8:42:00 AM	Lead (1st Draw)	11.0 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, May 9, 2022

NJDEP Laboratory Certification # 14006

Page 1 of 3



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number **Sample Location** **Collected By**
0522-1083 555 Dow Avenue - Ocean Twp Ken, Waldele

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0522-1083-23	4/30/2022 10:45:00 AM K2 Sink	5/5/2022 8:42:00 AM	Lead (1st Draw)	8.97 ug/l	15 ug/L	Std Method 3113B
0522-1083-24	4/30/2022 10:47:00 AM Sink Across From K3	5/5/2022 8:42:00 AM	Lead (1st Draw)	2.97 ug/l	15 ug/L	Std Method 3113B
0522-1083-25	4/30/2022 10:52:00 AM Dishwasher	5/5/2022 8:42:00 AM	Lead (1st Draw)	2.70 ug/l	15 ug/L	Std Method 3113B
0522-1083-26	4/30/2022 10:55:00 AM Coffee Maker Kitchen	5/5/2022 8:42:00 AM	Lead (1st Draw)	76.9 ug/l*	15 ug/L	Std Method 3113B
0522-1083-27	4/30/2022 10:57:00 AM Compartment Sink by Coffee Maker	5/5/2022 8:42:00 AM	Lead (1st Draw)	13.2 ug/l	15 ug/L	Std Method 3113B
0522-1083-3	4/30/2022 9:55:00 AM Nurses Office Sink	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1083-4	4/30/2022 9:57:00 AM Outside Room 101 Left Fountain	5/3/2022 9:02:00 AM	Lead (1st Draw)	23.6 ug/l*	15 ug/L	Std Method 3113B
0522-1083-5	4/30/2022 9:58:00 AM Outside Room 101 Right Fountain	5/3/2022 9:02:00 AM	Lead (1st Draw)	5.28 ug/l	15 ug/L	Std Method 3113B
0522-1083-6	4/30/2022 10:01:00 AM Fountain Outside Girls Room First Floor	5/3/2022 9:02:00 AM	Lead (1st Draw)	8.52 ug/l	15 ug/L	Std Method 3113B
0522-1083-7	4/30/2022 10:06:00 AM Outside Boys Room First Floor Bottle Filler	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1083-8	4/30/2022 10:08:00 AM Left Fountain Room 201	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1083-9	4/30/2022 10:09:00 AM Right Fountain Room 201	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, May 9, 2022

NJDEP Laboratory Certification # 14006

Page 2 of 3



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0522-1083	555 Dow Avenue - Ocean Twp	Ken, Waldele

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
------------	-----------	----------	-----------	--------	-------	--------

**Some or All of the parameters tested on this report
DID NOT PASS NJ Drinking Water Standards.**

This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.

Reviewed and Approved by:

Ashley Shann, Laboratory Manager Designee

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, May 9, 2022

NJDEP Laboratory Certification # 14006

Page 3 of 3



RAdata, LLC
 27 Ironia Road, Unit 2
 Flanders, NJ 07836
 973-927-7303 Phone
 973-927-4980 Fax

Customer: John Bosmans Sr.
 Ocean Township School District
 163 Monmouth Road
 Oakhurst, NJ 077550000

Laboratory Results

Sample Number **Sample Location** **Collected By**
 0522-1082 901 Bendermere Avenue - Ocean Twp Ken, Waldele

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0522-1082	4/30/2022 8:15:00 AM Boiler Room Source Spigot	5/3/2022 9:02:00 AM	Lead (1st Draw)	45.8 ug/l*	15 ug/L	Std Method 3113B
0522-1082-10	4/30/2022 8:32:00 AM Room 111 Sink	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1082-11	4/30/2022 8:40:00 AM Room 102 Sink	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1082-12	4/30/2022 8:42:00 AM Room 110 Sink	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1082-13	4/30/2022 8:49:00 AM Drinking Fountain Between 14&15	5/3/2022 9:02:00 AM	Lead (1st Draw)	19.8 ug/l*	15 ug/L	Std Method 3113B
0522-1082-14	4/30/2022 8:45:00 AM Outside Room 23 Fountain	5/3/2022 9:02:00 AM	Lead (1st Draw)	4.54 ug/l	15 ug/L	Std Method 3113B
0522-1082-15	4/30/2022 8:52:00 AM Bottle Fill Across From 10	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1082-16	4/30/2022 8:54:00 AM Nurses Office Sink	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1082-17	4/30/2022 8:58:00 AM Teachers Work Room Sink	5/3/2022 9:02:00 AM	Lead (1st Draw)	4.73 ug/l	15 ug/L	Std Method 3113B
0522-1082-18	4/30/2022 9:00:00 AM Drinking Fountain Across From 6	5/3/2022 9:02:00 AM	Lead (1st Draw)	3.67 ug/l	15 ug/L	Std Method 3113B
0522-1082-19	4/30/2022 9:03:00 AM Fountain Between 3&4	5/3/2022 9:02:00 AM	Lead (1st Draw)	3.43 ug/l	15 ug/L	Std Method 3113B
0522-1082-2	4/30/2022 8:17:00 AM Room 114 Sink	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1082-20	4/30/2022 9:08:00 AM Art Room Sink Right	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1082-21	4/30/2022 9:07:00 AM Art Room Sink Left	5/3/2022 9:02:00 AM	Lead (1st Draw)	3.62 ug/l	15 ug/L	Std Method 3113B
0522-1082-22	4/30/2022 9:11:00 AM Music Room Sink	5/3/2022 9:02:00 AM	Lead (1st Draw)	4.81 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Friday, May 6, 2022

NJDEP Laboratory Certification # 14006

Page 1 of 3



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
 Ocean Township School District
 163 Monmouth Road
 Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By						
0522-1082	901 Bendermere Avenue - Ocean Twp	Ken, Waldele						
Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method		
0522-1082-23	4/30/2022 9:13:00 AM Outside Gym Bottle Fill	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B		
0522-1082-24	4/30/2022 9:14:00 AM Outside Gym Fountain	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B		
0522-1082-3	4/30/2022 8:19:00 AM Outside Room 114 Fountain Left	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B		
0522-1082-4	4/30/2022 8:21:00 AM Outside Room 114 Fountain Right	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B		
0522-1082-5	4/30/2022 8:22:00 AM Room 113 Sink	5/3/2022 9:02:00 AM	Lead (1st Draw)	2.30 ug/l	15 ug/L	Std Method 3113B		
0522-1082-6	4/30/2022 8:24:00 AM Room 105 Sink	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B		
0522-1082-7	4/30/2022 8:26:00 AM Room 112 Sink	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B		
0522-1082-8	4/30/2022 8:27:00 AM Room 104 Sink	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B		
0522-1082-9	4/30/2022 8:29:00 AM Room 103 Sink	5/3/2022 9:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B		

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Friday, May 6, 2022

NJDEP Laboratory Certification # 14006

Page 2 of 3



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0522-1082	901 Bendermere Avenue - Ocean Twp	Ken, Waldele

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
------------	-----------	----------	-----------	--------	-------	--------

**Some or All of the parameters tested on this report
DID NOT PASS NJ Drinking Water Standards.**

This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.

Reviewed and Approved by:

Ashley Shann, Laboratory Manager Designee

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Friday, May 6, 2022

NJDEP Laboratory Certification # 14006

Page 3 of 3



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
 Ocean Township School District
 163 Monmouth Road
 Oakhurst, NJ 077550000

Laboratory Results

Sample Number **Sample Location** **Collected By**
 0522-1086 733 Bowne Road - Ocean Twp Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0522-1086	4/30/2022 11:12:00 AM Room 721 Bubbler Source	5/17/2022 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-10	4/30/2022 11:38:00 AM Room 103 Bubbler	5/17/2022 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-11	4/30/2022 11:42:00 AM Room 102 Bubbler	5/17/2022 8:44:00 AM	Lead (1st Draw)	11.5 ug/l	15 ug/L	Std Method 3113B
0522-1086-12	4/30/2022 11:44:00 AM Room 101 Bubbler	5/17/2022 8:44:00 AM	Lead (1st Draw)	20.7 ug/l*	15 ug/L	Std Method 3113B
0522-1086-13	4/30/2022 11:47:00 AM Room 108 Bubbler	5/17/2022 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-14	4/30/2022 11:49:00 AM Room 107 Bubbler	5/17/2022 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-15	4/30/2022 11:51:00 AM Room 106 Bubbler	5/17/2022 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-16	4/30/2022 11:54:00 AM Room 100 Bubbler	5/17/2022 8:44:00 AM	Lead (1st Draw)	2.63 ug/l	15 ug/L	Std Method 3113B
0522-1086-17	4/30/2022 11:56:00 AM Room 105 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	7.79 ug/l	15 ug/L	Std Method 3113B
0522-1086-18	4/30/2022 12:01:00 PM Wing 2 Fountain by Custodian	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-19	4/30/2022 12:04:00 PM Room 204 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-2	4/30/2022 11:14:00 AM Fountain Between 721-722	5/17/2022 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-20	4/30/2022 12:06:00 PM Room 203 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	3.46 ug/l	15 ug/L	Std Method 3113B
0522-1086-21	4/30/2022 12:11:00 PM Room 200 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	5.38 ug/l	15 ug/L	Std Method 3113B
0522-1086-22	4/30/2022 12:13:00 PM Room 200 Faucet	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, May 23, 2022

NJDEP Laboratory Certification # 14006

Page 1 of 5



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By				
0522-1086	733 Bowne Road - Ocean Twp	Richard, Hand				
Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0522-1086-23	4/30/2022 12:17:00 PM Room 202 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	5.83 ug/l	15 ug/L	Std Method 3113B
0522-1086-24	4/30/2022 12:19:00 PM Room 201 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-25	4/30/2022 12:21:00 PM Room 208 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	4.71 ug/l	15 ug/L	Std Method 3113B
0522-1086-26	4/30/2022 12:25:00 PM Room 207 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-27	4/30/2022 12:28:00 PM Room 206 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-28	4/30/2022 12:31:00 PM Room 205 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	3.73 ug/l	15 ug/L	Std Method 3113B
0522-1086-29	4/30/2022 12:34:00 PM Room 606 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-3	4/30/2022 11:17:00 AM Room 722 bubbler	5/17/2022 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-30	4/30/2022 12:36:00 PM Room 608 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	2.71 ug/l	15 ug/L	Std Method 3113B
0522-1086-31	4/30/2022 12:39:00 PM Wing 3 Fountain by Custodian	5/19/2022 10:38:00 AM	Lead (1st Draw)	25.6 ug/l*	15 ug/L	Std Method 3113B
0522-1086-32	4/30/2022 12:41:00 PM Room 304 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-33	4/30/2022 12:43:00 PM Room 303 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-34	4/30/2022 12:46:00 PM Room 300 Bathroom Tap	5/19/2022 10:38:00 AM	Lead (1st Draw)	4.89 ug/l	15 ug/L	Std Method 3113B
0522-1086-35	4/30/2022 12:49:00 PM Room 302 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-36	4/30/2022 12:51:00 PM Room 301 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	3.97 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, May 23, 2022

NJDEP Laboratory Certification # 14006

Page 2 of 5



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0522-1086	733 Bowne Road - Ocean Twp	Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0522-1086-37	4/30/2022 12:54:00 PM Room 308 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-38	4/30/2022 12:56:00 PM Room 307 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	2.08 ug/l	15 ug/L	Std Method 3113B
0522-1086-39	4/30/2022 12:58:00 PM Room 306 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-4	4/30/2022 11:21:00 AM Nurses Main Sink	5/17/2022 8:44:00 AM	Lead (1st Draw)	2.99 ug/l	15 ug/L	Std Method 3113B
0522-1086-40	4/30/2022 1:00:00 PM Room 305 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-41	4/30/2022 1:05:00 PM Bottle Filler by Kitchen	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-42	4/30/2022 1:06:00 PM Fountain by Kitchen	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-43	4/30/2022 1:08:00 PM Room 401 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-44	4/30/2022 1:10:00 PM Fountain by 402 Left	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-45	4/30/2022 1:11:00 PM Fountain by 402 Right	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-46	4/30/2022 1:15:00 PM Room 402 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-47	4/30/2022 1:18:00 PM Room 403 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-48	4/30/2022 1:20:00 PM Room 412 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-49	4/30/2022 1:23:00 PM Room 404 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-5	4/30/2022 11:23:00 AM Fountain By Nurses Office	5/17/2022 8:44:00 AM	Lead (1st Draw)	2.05 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, May 23, 2022

NJDEP Laboratory Certification # 14006

Page 3 of 5



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0522-1086	733 Bowne Road - Ocean Twp	Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0522-1086-50	4/30/2022 1:25:00 PM Room 405 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-51	4/30/2022 1:27:00 PM Room 410 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	3.15 ug/l	15 ug/L	Std Method 3113B
0522-1086-52	4/30/2022 1:30:00 PM Room 411 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-53	4/30/2022 1:34:00 PM Room 406 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-54	4/30/2022 1:36:00 PM Room 407 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-55	4/30/2022 1:38:00 PM Room 408 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-56	4/30/2022 1:40:00 PM Room 409 Bubbler	5/19/2022 10:38:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-6	4/30/2022 11:27:00 AM Teachers Lounge Sink	5/17/2022 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-7	4/30/2022 11:29:00 AM Bottle Filler by Teachers Lounge	5/17/2022 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1086-8	4/30/2022 11:33:00 AM Fountain Across from Wing One Custodian	5/17/2022 8:44:00 AM	Lead (1st Draw)	4.09 ug/l	15 ug/L	Std Method 3113B
0522-1086-9	4/30/2022 11:35:00 AM Room 104 Bubbler	5/17/2022 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the Initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, May 23, 2022

NJDEP Laboratory Certification # 14006

Page 4 of 5



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0522-1086	733 Bowne Road - Ocean Twp	Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
------------	-----------	----------	-----------	--------	-------	--------

**Some or All of the parameters tested on this report
DID NOT PASS NJ Drinking Water Standards.**

This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.

Reviewed and Approved by:

Ashley Shann, Laboratory Manager Designee

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, May 23, 2022

NJDEP Laboratory Certification # 14006

Page 5 of 5



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number **Sample Location** **Collected By**
0522-1085 1200 West Park Avenue - Ocean Twp Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0522-1085	4/30/2022 8:15:00 AM Fountain by 5143 Source	5/11/2022 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1085-10	4/30/2022 8:50:00 AM Teachers Lounge 661 Kitchen Sink	5/13/2022 10:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1085-11	4/30/2022 8:53:00 AM Fountain Across 651	5/13/2022 10:02:00 AM	Lead (1st Draw)	2.43 ug/l	15 ug/L	Std Method 3113B
0522-1085-12	4/30/2022 8:56:00 AM Fountain Across 656	5/13/2022 10:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1085-13	4/30/2022 9:00:00 AM Teachers Lounge Sink 761	5/13/2022 10:02:00 AM	Lead (1st Draw)	2.82 ug/l	15 ug/L	Std Method 3113B
0522-1085-14	4/30/2022 9:05:00 AM Fountain by 751	5/13/2022 10:02:00 AM	Lead (1st Draw)	2.44 ug/l	15 ug/L	Std Method 3113B
0522-1085-15	4/30/2022 9:07:00 AM Fountain by 757	5/13/2022 10:02:00 AM	Lead (1st Draw)	4.57 ug/l	15 ug/L	Std Method 3113B
0522-1085-16	4/30/2022 9:10:00 AM Teachers Lounge 861 KT	5/13/2022 10:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1085-17	4/30/2022 9:13:00 AM Fountain by 851	5/13/2022 10:02:00 AM	Lead (1st Draw)	3.21 ug/l	15 ug/L	Std Method 3113B
0522-1085-18	4/30/2022 9:15:00 AM Fountain by 857	5/13/2022 10:02:00 AM	Lead (1st Draw)	5.18 ug/l	15 ug/L	Std Method 3113B
0522-1085-19	4/30/2022 9:21:00 AM Nurses Office Main Sink	5/13/2022 10:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1085-2	4/30/2022 8:19:00 AM Fountain by 5112	5/13/2022 10:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1085-20	4/30/2022 9:23:00 AM Fountain Sixth Grade Hall	5/13/2022 10:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1085-21	4/30/2022 9:27:00 AM Room 606 Sink	5/13/2022 10:02:00 AM	Lead (1st Draw)	11.1 ug/l	15 ug/L	Std Method 3113B
0522-1085-22	4/30/2022 9:34:00 AM Room 600 Sink Food Prep	5/13/2022 10:02:00 AM	Lead (1st Draw)	2.78 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, May 23, 2022

NJDEP Laboratory Certification # 14006

Page 1 of 4



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
 Ocean Township School District
 163 Monmouth Road
 Oakhurst, NJ 077550000

Laboratory Results

Sample Number **Sample Location** **Collected By**
 0522-1085 1200 West Park Avenue - Ocean Twp Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0522-1085-23	4/30/2022 9:37:00 AM	5/13/2022 10:02:00 AM	Lead (1st Draw) Fountain Seventh Grade Hall Left	2.27 ug/l	15 ug/L	Std Method 3113B
0522-1085-24	4/30/2022 9:38:00 AM	5/13/2022 10:02:00 AM	Lead (1st Draw) Fountain Seventh Grade Hall Right	5.03 ug/l	15 ug/L	Std Method 3113B
0522-1085-25	4/30/2022 9:42:00 AM	5/13/2022 10:02:00 AM	Lead (1st Draw) Room 706 Sink	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1085-26	4/30/2022 9:47:00 AM	5/13/2022 10:02:00 AM	Lead (1st Draw) Fountain Eighth Grade Hall	2.44 ug/l	15 ug/L	Std Method 3113B
0522-1085-27	4/30/2022 9:49:00 AM	5/13/2022 10:02:00 AM	Lead (1st Draw) Room 806 Sink	5.43 ug/l	15 ug/L	Std Method 3113B
0522-1085-28	4/30/2022 9:53:00 AM	5/13/2022 10:02:00 AM	Lead (1st Draw) Room 601 IMC Sink	7.41 ug/l	15 ug/L	Std Method 3113B
0522-1085-29	4/30/2022 9:59:00 AM	5/13/2022 10:02:00 AM	Lead (1st Draw) Left Fountain Across Band Room	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1085-3	4/30/2022 8:21:00 AM	5/13/2022 10:02:00 AM	Lead (1st Draw) Fountain by 5133	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1085-30	4/30/2022 10:00:00 AM	5/13/2022 10:02:00 AM	Lead (1st Draw) Right Fountain Across Band Room	36.7 ug/l*	15 ug/L	Std Method 3113B
0522-1085-31	4/30/2022 10:05:00 AM	5/13/2022 10:02:00 AM	Lead (1st Draw) Main Office Fountain	6.11 ug/l	15 ug/L	Std Method 3113B
0522-1085-32	4/30/2022 10:08:00 AM	5/13/2022 10:02:00 AM	Lead (1st Draw) Main Office Kitchen Sink	6.42 ug/l	15 ug/L	Std Method 3113B
0522-1085-33	4/30/2022 10:10:00 AM	5/13/2022 10:02:00 AM	Lead (1st Draw) Fountain Across Music Room	4.26 ug/l	15 ug/L	Std Method 3113B
0522-1085-34	4/30/2022 10:18:00 AM	5/17/2022 8:44:00 AM	Lead (1st Draw) Fountain Main Office Hall	4.47 ug/l	15 ug/L	Std Method 3113B
0522-1085-35	4/30/2022 10:21:00 AM	5/17/2022 8:44:00 AM	Lead (1st Draw) Lunch Room Sink Main Entrance	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1085-36	4/30/2022 10:24:00 AM	5/17/2022 8:44:00 AM	Lead (1st Draw) Fountain Across From 310	6.32 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, May 23, 2022

NJDEP Laboratory Certification # 14006

Page 2 of 4



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
 Ocean Township School District
 163 Monmouth Road
 Oakhurst, NJ 077550000

Laboratory Results

Sample Number **Sample Location** **Collected By**
 0522-1085 1200 West Park Avenue - Ocean Twp Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0522-1085-37	4/30/2022 10:28:00 AM Fountain Outside Boys Locker	5/17/2022 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1085-38	4/30/2022 10:31:00 AM Fountain Outside Girls Locker	5/17/2022 8:44:00 AM	Lead (1st Draw)	3.22 ug/l	15 ug/L	Std Method 3113B
0522-1085-39	4/30/2022 10:35:00 AM Fountain By 208	5/17/2022 8:44:00 AM	Lead (1st Draw)	2.15 ug/l	15 ug/L	Std Method 3113B
0522-1085-4	4/30/2022 8:24:00 AM Fountain by 5104	5/13/2022 10:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1085-40	4/30/2022 10:40:00 AM Kitchen Kettle	5/17/2022 8:44:00 AM	Lead (1st Draw)	7.35 ug/l	15 ug/L	Std Method 3113B
0522-1085-41	4/30/2022 10:44:00 AM Kitchen Ice Machine	5/17/2022 8:44:00 AM	Lead (1st Draw)	38.7 ug/l*	15 ug/L	Std Method 3113B
0522-1085-42	4/30/2022 10:47:00 AM Kitchen Island Sink	5/17/2022 8:44:00 AM	Lead (1st Draw)	5.98 ug/l	15 ug/L	Std Method 3113B
0522-1085-5	4/30/2022 8:27:00 AM Fountain Across From 5104	5/13/2022 10:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1085-6	4/30/2022 8:35:00 AM Office 5121 Kitchen Sink	5/13/2022 10:02:00 AM	Lead (1st Draw)	129 ug/l*	15 ug/L	Std Method 3113B
0522-1085-7	4/30/2022 8:39:00 AM Fountain Across From 5205	5/13/2022 10:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1085-8	4/30/2022 8:43:00 AM Fountain by 5227	5/13/2022 10:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1085-9	4/30/2022 8:46:00 AM Teachers Lounge 5214 Kitchen	5/13/2022 10:02:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, May 23, 2022

NJDEP Laboratory Certification # 14006

Page 3 of 4



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: John Bosmans Sr.
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0522-1085	1200 West Park Avenue - Ocean Twp	Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
------------	-----------	----------	-----------	--------	-------	--------

**Some or All of the parameters tested on this report
DID NOT PASS NJ Drinking Water Standards.**

This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.

Reviewed and Approved by:

Ashley Shann, Laboratory Manager Designee

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, May 23, 2022

NJDEP Laboratory Certification # 14006

Page 4 of 4