

Seaford Union Free School District

22-53407

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
<b>Seaford Manor Elementary School</b>							
SUFSD-0548	2038	Across Room 11B	Water Fountain-No Chiller	Potable	6/5/2025	12.4	Removed From Service, Pending Remediation
SUFSD-0601	2053	Room 7A	Water Fountain-No Chiller	Potable	6/5/2025	3800	Removed From Service, Pending Remediation