

ANALYTICAL LABORATORIES, INC. (ALI)
4208 Bethlehem Pike
Telford, PA 18969
(215) 723-6466
PA DEP ID# 09-00332

SAMPLE ANALYSIS REPORT

Customer: Central Bucks School District
320 West Swamp Road
Doylestown, PA 18901

Attn: [REDACTED]
FAX:
EMAIL:

Sample number: 11841-241
Date sampled : 08/14/24
Time sampled : 1115
Date received: 08/14/24
Sampled by : Customer
PWS ID # :

Sample source: Holicong Bottle Filler 140A
Bus Lobby - Elkay

ANALYTICAL RESULTS

ALI PA DEP ID# 09-00332 is not accredited for the following method. The sample was subcontracted and analyzed by Cert. PA ID# 68-05519.


<u>Parameter</u>	<u>Result</u> <u>ng/l</u>	<u>Flag</u>	<u>MCL</u> <u>ng/l</u>	<u>RL</u> <u>ng/l</u>	<u>Analysis</u> <u>Date</u>	<u>Time</u>
Method 537.1						
PFBS PerFluoroButaneSulfonic acid	< 2.0			2.0	08/28/24	0513
PFHxA PerFluoroHexanoic Acid	< 2.0			2.0	08/28/24	0513
HFPO-DA HexaFluoroPropylene Oxide Dimer Acid(Genx)	< 2.0			2.0	08/28/24	0513
PFHpA PerFluoroHeptanoic Acid	< 2.0			2.0	08/28/24	0513
PFHxS PerFluoroHexaneSulfonic acid	< 2.0			2.0	08/28/24	0513
ADONA 4,8-dioxa-3H-perfluoronanoic acid(Genx)	< 2.0			2.0	08/28/24	0513
PFOA PerFluoroOctanoic Acid	< 2.0		14	2.0	08/28/24	0513
PFOS PerFluoroOctaneSulfonic acid	< 2.0		18	2.0	08/28/24	0513
PFNA PerFluoroNonanoic Acid	< 2.0			2.0	08/28/24	0513
9Cl-PF3ONS 9-chlorohexadecafluoro-3- oxanone-1-sulfonic acid	< 2.0			2.0	08/28/24	0513
PFDA PerFluoroDecanoic Acid	< 2.0			2.0	08/28/24	0513
PFUnA PerFluoroUndecanoic Acid	< 2.0					

Symbol key:

< - less than, RL - minimum reporting level
ng/l - nanograms/liter(parts per trillion)
MCL - PA DEP Maximum Contaminant Level

Flag

J - The reported result is below Minimum
Reporting Level but greater than the
Method Detection Limit. The reported
result is an estimate.


Geoff W. Kinka/Manager

ANALYTICAL LABORATORIES, INC. (ALI)
4208 Bethlehem Pike
Telford, PA 18969
(215) 723-6466
PA DEP ID# 09-00332

SAMPLE ANALYSIS REPORT

Customer: Central Bucks School District
320 West Swamp Road
Doylestown, PA 18901

Attn: [REDACTED]
FAX:
EMAIL:

Sample number: 11841-242
Date sampled : 08/14/24
Time sampled : 1115
Date received: 08/14/24
Sampled by : Customer
PWS ID # :

Sample source: Holicong Bottle Filler 140A
Bus Lobby - Elkay

ANALYTICAL RESULTS

ALI PA DEP ID# 09-00332 is not accredited for the following method. The sample was subcontracted and analyzed by Cert. PA ID# 68-05519.

<u>Parameter</u>	<u>Result.</u> <u>ng/l</u>	Flag	MCL ng/l	RL, ng/l	Analysis Date	Time
Method 537.1						
11-Cl-PF3OUDS 11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	< 2.0			2.0	08/28/24	0513
NMeFOSAA N-Methyl perFluoroOctaneSulfonamidoAcetic Acid	< 2.0			2.0	08/28/24	0513
NEtFOSA N-Ethyl perFluoroOctaneSulfonamidoAcetic Acid	< 2.0			2.0	08/28/24	0513
PFDoA PerFluoroDodecanoic Acid	< 2.0			2.0	08/28/24	0513
PFTriDA PerFluoroTriDecanoic Acid	< 2.0			2.0	08/28/24	0513
PFTA PerFluoroTetradecanoic Acid	< 2.0			2.0	08/28/24	0513

Symbol key:
< - less than, RL - minimum reporting level
ng/l - nanograms/liter (parts per trillion)
MCL - PA DEP Maximum Contaminant Level

Flag
J - The reported result is below Minimum Reporting Level but greater than the Method Detection Limit. The reported result is an estimate.


Geoff W. Kinka/Manager

ANALYTICAL LABORATORIES, INC. (ALI)
4208 Bethlehem Pike
Telford, PA 18969
(215) 723-6466
PA DEP ID# 09-00332

SAMPLE ANALYSIS REPORT

Customer: Central Bucks School District
320 West Swamp Road
Doylestown, PA 18901

Attn: [REDACTED]
FAX: [REDACTED]
EMAIL:

Sample number: 11840-241
Date sampled : 08/14/24
Time sampled : 1109
Date received: 08/14/24
Sampled by : Customer
PWS ID # :

Sample source: Holicong Sports Ice/Jug Filler - Altair(Distribution)

ANALYTICAL RESULTS

ALI PA DEP ID# 09-00332 is not accredited for the following method. The sample was subcontracted and analyzed by Cert. PA ID# 68-05519.

<u>Parameter</u>	<u>Result.</u> <u>ng/l</u>	<u>Flag</u>	<u>MCL</u> <u>ng/l</u>	<u>RL,</u> <u>ng/l</u>	<u>Analysis</u> <u>Date</u>	<u>Time</u>
Method 537.1						
PFBS PerFluoroButaneSulfonic acid	< 2.0			2.0	08/28/24	0704
PFBxS PerFluoroHexanoic Acid	< 2.0			2.0	08/28/24	0704
HFPO-DA HexaFluoroPropylene Oxide Dimer Acid(Genx)	< 2.0			2.0	08/28/24	0704
PFBxPA PerFluoroHeptanoic Acid	< 2.0			2.0	08/28/24	0704
PFBxS PerFluoroHexaneSulfonic acid	< 2.0			2.0	08/28/24	0704
ADONA 4,8-dioxa-3H-perfluoronanoic acid(Genx)	< 2.0			2.0	08/28/24	0704
PFOA PerFluoroOctanoic Acid	< 2.0		14	2.0	08/28/24	0704
PFOS PerFluoroOctaneSulfonic acid	< 2.0		18	2.0	08/28/24	0704
PFNA PerFluoroNonanoic Acid	< 2.0			2.0	08/28/24	0704
9Cl-PF3ONS 9-chlorohexadecafluoro-3- oxanone-1-sulfonic acid	< 2.0			2.0	08/28/24	0704
PFDA PerFluoroDecanoic Acid	< 2.0			2.0	08/28/24	0704
PFUNA PerFluoroUndecanoic Acid	< 2.0			2.0	08/28/24	0704

Symbol key:

< - less than, RL - minimum reporting level
ng/l - nanograms/liter(parts per trillion)
MCL - PA DEP Maximum Contaminant Level

Flag

J - The reported result is below Minimum
Reporting Level but greater than the
Method Detection Limit. The reported
result is an estimate.


Geoff W. Kinka/Manager

ANALYTICAL LABORATORIES, INC. (ALI)
4208 Bethlehem Pike
Telford, PA 18969
(215) 723-6466
PA DEP ID# 09-00332

SAMPLE ANALYSIS REPORT

Customer: Central Bucks School District
320 West Swamp Road
Doylestown, PA 18901

Attn: [REDACTED]
FAX: [REDACTED]
EMAIL: [REDACTED]

Sample number: 11840-242
Date sampled : 08/14/24
Time sampled : 1109
Date received: 08/14/24
Sampled by : Customer
PWS ID # :

Sample source: Holicong Sports Ice/Jug Filler - Altair(Distribution)

ANALYTICAL RESULTS

ALI PA DEP ID# 09-00332 is not accredited for the following method. The sample was subcontracted and analyzed by Cert. PA ID# 68-05519.

<u>Parameter</u>	<u>Result</u> <u>ng/l</u>	Flag	MCL ng/l	RL, ng/l	Analysis Date	Time
Method 537.1						
11-Cl-PF30UdS 11-chloroeicosafuoro-3-oxaundecane-1-sulfonic acid	< 2.0			2.0	08/28/24	0704
NMeFOSAA N-Methyl perFluoroOctaneSulfonamidoAcetic Acid	< 2.0			2.0	08/28/24	0704
NEtFOSA N-Ethyl perFluoroOctaneSulfonamidoAcetic Acid	< 2.0			2.0	08/28/24	0704
PFDoA PerFluoroDodecanoic Acid	< 2.0			2.0	08/28/24	0704
PFTriDA PerFluoroTriDecanoic Acid	< 2.0			2.0	08/28/24	0704
PFTA PerFluoroTetradecanoic Acid	< 2.0			2.0	08/28/24	0704

Symbol key:

< - less than, RL - minimum reporting level
ng/l - nanograms/liter(parts per trillion)
MCL - PA DEP Maximum Contaminant Level

Flag

J - The reported result is below Minimum Reporting Level but greater than the Method Detection Limit. The reported result is an estimate.


Geoff W. Kinka/Manager