Sample #	Location	Outlet Type	Notes	Date	Time	Concentration (ug/L)
WHS-AUDH-1	Corridor by Auditorium	Bottle Filler		6/4/2025	0526	<5.00
WHS-AUDH-2	Corridor by Auditorium	Drinking Fountain		6/4/2025	0527	<5.00
WHS-113-1	Woodshop, Room 113	Bottle Filler		6/4/2025	0529	<5.00
WHS-113-2	Woodshop, Room 113	Drinking Fountain		6/4/2025	0529	<5.00
WHS-123-1	Band Office, Room 123	Tap	Marked	6/4/2025	0530	17.7
WHS-NO-1	Nurse's Office	Tap		6/4/2025	0531	<5.00
WHS-FAC-1	Faculty Room	Tap		6/4/2025	0533	<5.00
WHS-KIT-1M	Kitchen, Room 88	Tap	Middle, D-Wall	6/4/2025	0535	5.39
WHS-KIT-2	Kitchen, Room 88	Ice Machine		6/4/2025	0536	<5.00
WHS-KIT-3M	Kitchen, Room 88	Tap	Middle, B-Wall	6/4/2025	0537	<5.00
WHS-KIT-4L	Kitchen, Room 88	Tap	D-Wall, Left	6/4/2025	0538	9.40
WHS-KIT-5R	Kitchen, Room 88	Tap	D-Wall, Right	6/4/2025	0538	<5.00
WHS-CAF-1	Cafeteria, Room 87	Bottle Filler		6/4/2025	0540	<5.00
WHS-CAF-2L	Cafeteria, Room 87	Drinking Fountain	Left	6/4/2025	0540	<5.00
WHS-CAF-3R	Cafeteria, Room 87	Drinking Fountain	Right	6/4/2025	0541	<5.00
WHS-GYM-1	Gym, by Boy's Coach's Office	Drinking Fountain		6/4/2025	0542	<5.00
WHS-GYM-3	Gym, by Boy's Coach's Office	Bottle Filler		6/4/2025	0543	<5.00
WHS-GYM-4	Gym, by Girl's Coach's Office	Bottle Filler		6/4/2025	0543	<5.00
WHS-GYM-2	Gym, by Girl's Coach's Office	Drinking Fountain		6/4/2025	0545	<5.00
WHS-38H-1	Corridor by Room 38	Bottle Filler		6/4/2025	0546	<5.00
WHS-38H-2	Corridor by Room 38	Drinking Fountain		6/4/2025	0546	<5.00
WHS-155-1	Classroom 155	Tap	B-Wall	6/4/2025	0549	<5.00
WHS-155-2	Classroom 155	Tap	D-Wall	6/4/2025	0549	<5.00
WHS-LIBH-1	Corridor by Library	Bottle Filler		6/4/2025	0552	<5.00
WHS-LIBH-2	Corridor by Library	Drinking Fountain		6/4/2025	0552	<5.00
WHS-5H-1	Corridor by Room 5	Bottle Filler		6/4/2025	0555	<5.00
WHS-5H-2	Corridor by Room 5	Drinking Fountain		6/4/2025	0555	<5.00
WHS-CON-1	Concession Stand			6/4/2025	0600	<5.00
WHS-CON-2	Concession Stand			6/4/2025	0600	<5.00
WHS-CON-3	Concession Stand			6/4/2025	0600	<5.00

Sample #	Location	Outlet Type	Notes	Date	Time	Concentration (ug/L)
WMS-KIT-1M	Kitchen	Tap	Middle, A-Wall	6/4/2025	0540	7.05
WMS-KIT-3	Kitchen	Pot Filler		6/4/2025	0541	<5.00
WMS-KIT-2M	Kitchen	Tap	Middle, C-Wall	6/4/2025	0542	5.89
WMS-KIT-4	Kitchen	Ice Machine	In Caf Closet	6/4/2025	0546	<5.00
WMS-45-1	Washroom 45	Tap		6/4/2025	0551	<5.00
WMS-45-2	Washroom 45	Overhead Sprayer		6/4/2025	0552	<5.00
WMS-CAF-1	Cafeteria	Bottle Filler		6/4/2025	0552	<5.00
MWS-CAF-2	Cafeteria	Drinking Fountain		6/4/2025	0553	<5.00
WMS-HCH-1	Corridor by Home & Careers	Bottle Filler		6/4/2025	0554	<5.00
WMS-HCH-2	Corridor by Home & Careers	Drinking Fountain		6/4/2025	0555	<5.00
WMS-HC-1	Home & Careers	Tap	Kit 1, A-Wall	6/4/2025	0556	<5.00
WMS-HC-1S	Home & Careers	Sprayer	Kit 1, A-Wall	6/4/2025	0556	<5.00
WMS-HC-2	Home & Careers	Tap	Kit 1, C-Wall	6/4/2025	0600	<5.00
WMS-HC-2S	Home & Careers	Sprayer	Kit 1, C-Wall	6/4/2025	0600	<5.00
WMS-HC-3	Home & Careers	Tap	Kit 2, A-Wall	6/4/2025	0601	<5.00
WMS-HC-3S	Home & Careers	Sprayer	Kit 2, A-Wall	6/4/2025	0601	<5.00
WMS-HC-4	Home & Careers	Tap	Kit 2, C-Wall	6/4/2025	0603	<5.00
WMS-HC-4S	Home & Careers	Sprayer	Kit 2, C-Wall	6/4/2025	0604	<5.00
WMS-HC-5	Home & Careers	Tap	Kit 3, A-Wall	6/4/2025	0606	<5.00
WMS-HC-5S	Home & Careers	Sprayer	Kit 3, A-Wall	6/4/2025	0606	<5.00
WMS-HC-6	Home & Careers	Tap	Kit 3, C-Wall	6/4/2025	0607	<5.00
WMS-HC-6S	Home & Careers	Sprayer	Kit 3, C-Wall	6/4/2025	0607	<5.00
WMS-BLRH-1	Corridor by Boy's Locker Room	Bottle Filler		6/4/2025	0610	<5.00
WMS-BLRH-2	Corridor by Boy's Locker Room	Drinking Fountain		6/4/2025	0610	<5.00
WMS-NO-1	Nurse's Office	Tap		6/4/2025	0611	<5.00
WMS-GYMH-1	Corridor by Gym	Bottle Filler		6/4/2025	0612	<5.00
WMS-GYM-2	Corridor by Gym	Drinking Fountain		6/4/2025	0613	<5.00
WMS-BSH-1	Corridor by Back Stage	Bottle Filler		6/4/2025	0614	<5.00
WMS-BSH-2	Corridor by Back Stage	Drinking Fountain		6/4/2025	0615	<5.00
WMS-9H-1	Corridor by Room 9	Bottle Filler		6/4/2025	0619	<5.00
WMS-9H-2	Corridor by Room 9	Drinking Fountain		6/4/2025	0619	<5.00
WMS-109H-1	Corridor by Room 109	Bottle Filler		6/4/2025	0621	<5.00

Sample #	Location	Outlet Type	Notes	Date	Time	Concentration (ug/L)
WMS-109H-2	Corridor by Room 109	Drinking Fountain		6/4/2025	0621	<5.00
WMS-29H-1	Corridor by Room 29	Bottle Filler		6/4/2025	0623	<5.00
WMS-29H-2	Corridor by Room 29	Drinking Fountain		6/4/2025	0623	<5.00
WMS-27H-1	Corridor by Room 27	Bottle Filler		6/4/2025	0625	<5.00
WMS-27H-2	Corridor by Room 27	Drinking Fountain		6/4/2025	0625	<5.00
WMS-21H-1	Corridor by Room 21	Bottle Filler		6/4/2025	0626	<5.00
WMS-21H-2	Corridor by Room 21	Drinking Fountain		6/4/2025	0626	<5.00
WMS-SL-1	Staff Lounge	Tap	Mixed	6/4/2025	0627	10.4
WMS-SL-2	Staff Lounge	Sprayer	Mixed	6/4/2025	0627	13.6
WMS-40H-1	Corridor by Room 40	Bottle Filler		6/4/2025	0630	<5.00
WMS-40H-2	Corridor by Room 40	Drinking Fountain		6/4/2025	0630	<5.00
WMS-35H-1	Corridor by Room 35	Bottle Filler		6/4/2025	0633	<5.00
WMS-35H-2	Corridor by Room 35	Drinking Fountain		6/4/2025	0633	<5.00

Sample #	Location	Outlet Type	Notes	Date	Time	Concentration (ug/L)
WDO-MNT-1	Maintenance	Bottle Filler		6/4/2025	0530	<5.00
WDO-MNT-2	Maintenance	Drinking Fountain		6/4/2025	0530	<5.00
WDO-REC-1	Receiving Kitchen	Tap		6/4/2025	0532	<5.00

Sample #	Location	Outlet Type	Notes	Date	Time	Concentration (ug/L)
WBG-MB-1	Maintenance Bay	Tap		6/5/2025	0531	<5.00
WBG-KIT-1	Kitchenette	Bottle Filler		6/5/2025	0532	<5.00
WBG-KIT-2	Kitchenette	Drinking Fountain		6/5/2025	0533	<5.00
WBG-KIT-3	Kitchenette	Tap		6/5/2025	0535	<5.00

Sample #	Location	Outlet Type	Notes	Date	Time	Concentration (ug/L)
WES-20-1	Classroom 20	Tap		6/5/2025	0616	13.1
WES-20-2	Classroom 20	Drinking Fountain		6/5/2025	0616	<5.00
WES-21-1	Classroom 21	Tap		6/5/2025	0613	11.5
WES-22-1	Classroom 22	Tap		6/5/2025	0612	6.61
WES-22-2	Classroom 22	Drinking Fountain		6/5/2025	0612	<5.00
WES-23-1	Classroom 23	Tap		6/5/2025	0615	7.36
WES-PD-1	Professional Development	Drinking Fountain		6/5/2025	0611	<5.00
WES-BR-1	Band Room	Tap		6/5/2025	0608	<5.00
WES-BR-2	Band Room	Drinking Fountain		6/5/2025	0608	<5.00
WES-52-1	Classroom 52	Tap		6/5/2025	0605	<5.00
WES-52-2	Classroom 52	Drinking Fountain		6/5/2025	0605	<5.00
WES-53-1	Classroom 53	Tap		6/5/2025	0606	<5.00
WES-53-2	Classroom 53	Drinking Fountain		6/5/2025	0606	<5.00
WES-54-1	Classroom 54	Tap		6/5/2025	0609	<5.00
WES-54-2	Classroom 54	Drinking Fountain		6/5/2025	0609	<5.00
WES-CAF-1	Cafeteria	Bottle Filler		6/5/2025	0619	<5.00
WES-CAF-2	Cafeteria	Drinking Fountain		6/5/2025	0619	<5.00
WES-NO-1L	Nurse's Office	Tap	Left	6/5/2025	0622	<5.00
WES-NO-2R	Nurse's Office	Tap	Right	6/5/2025	0622	<5.00
WES-NOH-1	Corridor by Nurse's Office	Bottle Filler		6/5/2025	0621	<5.00
WES-NOH-2	Corridor by Nurse's Office	Drinking Fountain		6/5/2025	0621	<5.00
WES-2-1	Classroom 2	Tap		6/5/2025	0644	<5.00
WES-2-2	Classroom 2	Drinking Fountain		6/5/2025	0645	<5.00
WES-3-1	Classroom 3	Tap		6/5/2025	0635	<5.00
WES-3-2	Classroom 3	Drinking Fountain		6/5/2025	0636	<5.00
WES-4-1	Classroom 4	Tap		6/5/2025	0629	<5.00
WES-4-2	Classroom 4	Drinking Fountain		6/5/2025	0630	<5.00
WES-5-1	Classroom 5	Tap		6/5/2025	0626	<5.00
WES-5-2	Classroom 5	Drinking Fountain		6/5/2025	0627	<5.00
WES-6-1	Classroom 6	Tap		6/5/2025	0628	<5.00
WES-6-2	Classroom 6	Drinking Fountain		6/5/2025	0629	6.27
WES-7-1	Classroom 7	Tap		6/5/2025	0632	<5.00

Sample #	Location	Outlet Type	Notes	Date	Time	Concentration (ug/L)
WES-7-2	Classroom 7	Drinking Fountain		6/5/2025	0633	<5.00
WES-8-1	Classroom 8	Tap		6/5/2025	0640	<5.00
WES-8-2	Classroom 8	Drinking Fountain		6/5/2025	0641	<5.00
WES-9-1	Classroom 9	Tap		6/5/2025	0646	<5.00
WES-9-2	Classroom 9	Drinking Fountain		6/5/2025	0647	<5.00
WES-10-1	Classroom 10	Tap		6/5/2025	0637	<5.00
WES-10-2	Classroom 10	Drinking Fountain		6/5/2025	0637	<5.00
WES-11-1	Classroom 11	Tap		6/5/2025	0635	<5.00
WES-11-2	Classroom 11	Drinking Fountain		6/5/2025	0635	<5.00
WES-12-1	Classroom 12	Tap		6/5/2025	0633	<5.00
WES-12-2	Classroom 12	Drinking Fountain		6/5/2025	0633	<5.00
WES-13-1	Classroom 13	Tap		6/5/2025	0630	<5.00
WES-13-2	Classroom 13	Drinking Fountain		6/5/2025	0630	<5.00
WES-14-1	Classroom 14	Tap		6/5/2025	0625	<5.00
WES-14-2	Classroom 14	Drinking Fountain		6/5/2025	0625	<5.00
WES-15-1	Classroom 15	Tap		6/5/2025	0627	<5.00
WES-15-2	Classroom 15	Drinking Fountain		6/5/2025	0627	<5.00
WES-16-1	Classroom 16	Tap		6/5/2025	0629	<5.00
WES-16-2	Classroom 16	Drinking Fountain		6/5/2025	0629	<5.00
WES-17-1	Classroom 17	Tap		6/5/2025	0631	9.91
WES-17-2	Classroom 17	Drinking Fountain		6/5/2025	0631	<5.00
WES-18-1	Classroom 18	Tap		6/5/2025	0634	<5.00
WES-18-2	Classroom 18	Drinking Fountain		6/5/2025	0634	<5.00
WES-KITD-1	Kitchen, Dishwashing	Ice Machine		6/5/2025	0559	<5.00
WES-KITD-2A	Kitchen, Dishwashing	Tap	A-Wall, Left	6/5/2025	0600	<5.00
WES-KITD-3A	Kitchen, Dishwashing	Tap	A-Wall, Right	6/5/2025	0601	<5.00
WES-KITD-4A	Kitchen, Dishwashing	Overhead Sprayer	A-Wall	6/5/2025	0606	<5.00
WES-KITD-5B	Kitchen, Dishwashing	Overhead Sprayer		6/5/2025	0602	<5.00
WES-KITP-1	Kitchen, Prep	Tap	D-Wall	6/5/2025	0603	<5.00
WES-38-1	Classroom 38	Tap		6/5/2025	0551	8.85
WES-38-2	Classroom 38	Drinking Fountain		6/5/2025	0551	<5.00
WES-39-1	Classroom 39	Tap		6/5/2025	0547	5.61

Sample #	Location	Outlet Type	Notes	Date	Time	Concentration (ug/L)
WES-39-2	Classroom 39	Drinking Fountain		6/5/2025	0547	<5.00
WES-40-1	Classroom 40	Tap		6/5/2025	0544	<5.00
WES-40-2	Classroom 40	Drinking Fountain		6/5/2025	0544	<5.00
WES-41-1	Classroom 41	Tap		6/5/2025	0542	8.18
WES-41-2	Classroom 41	Drinking Fountain		6/5/2025	0542	<5.00
WES-42-1	Classroom 42	Tap		6/5/2025	0537	<5.00
WES-42-2	Classroom 42	Drinking Fountain		6/5/2025	0537	<5.00
WES-43-1	Classroom 43	Tap		6/5/2025	0539	<5.00
WES-43-2	Classroom 43	Drinking Fountain		6/5/2025	0539	<5.00
WES-44-1	Classroom 44	Tap		6/5/2025	0541	<5.00
WES-44-2	Classroom 44	Drinking Fountain		6/5/2025	0541	<5.00
WES-45-1	Classroom 45	Tap		6/5/2025	0546	<5.00
WES-45-2	Classroom 45	Drinking Fountain		6/5/2025	0546	<5.00
WES-46-1	Classroom 46	Tap		6/5/2025	0549	<5.00
WES-46-2	Classroom 46	Drinking Fountain		6/5/2025	0549	<5.00
WES-GYM-1	Gymnasium	Tap		6/5/2025	0620	<5.00
WES-GYM-2	Gymnasium	Drinking Fountain		6/5/2025	0621	<5.00
WES-25-1	Classroom 25	Tap		6/5/2025	0623	<5.00
WES-25-2	Classroom 25	Drinking Fountain		6/5/2025	0642	5.73
WES-26-1	Classroom 26	Tap		6/5/2025	0618	<5.00
WES-26-2	Classroom 26	Drinking Fountain		6/5/2025	0619	<5.00
WES-27-1	Classroom 27	Tap		6/5/2025	0616	<5.00
WES-27-2	Classroom 27	Drinking Fountain		6/5/2025	0617	<5.00
WES-28-1	Classroom 28	Tap		6/5/2025	0612	<5.00
WES-28-2	Classroom 28	Drinking Fountain		6/5/2025	0613	<5.00
WES-29-1	Classroom 29	Tap		6/5/2025	0609	<5.00
WES-29-2	Classroom 29	Drinking Fountain		6/5/2025	0910	<5.00
WES-30-1	Classroom 30	Tap		6/5/2025	0557	<5.00
WES-30-2	Classroom 30	Drinking Fountain		6/5/2025	0558	<5.00
WES-31-1	Classroom 31	Tap		6/5/2025	0549	<5.00
WES-31-2	Classroom 31	Drinking Fountain		6/5/2025	0550	<5.00
WES-32-1	Classroom 32	Tap		6/5/2025	0552	<5.00

Sample #	Location	Outlet Type	Notes	Date	Time	Concentration (ug/L)
WES-32-2	Classroom 32	Drinking Fountain		6/5/2025	0553	<5.00
WES-33-1	Classroom 33	Tap		6/5/2025	0555	<5.00
WES-33-2	Classroom 33	Drinking Fountain		6/5/2025	0555	<5.00
WES-34-1	Classroom 34	Tap		6/5/2025	0559	<5.00
WES-34-2	Classroom 34	Drinking Fountain		6/5/2025	0600	<5.00
WES-SL-1	Staff Lounge	Tap		6/5/2025	0546	<5.00
WES-SL-2	Staff Lounge	Sprayer		6/5/2025	0547	<5.00