

6132X-41

CITY OF PHILADELPHIA
DEPARTMENT OF LICENSES AND INSPECTIONS
COMMERCIAL AND INDUSTRIAL FIRE UNIT
CERTIFICATION OF
STANDBY/EMERGENCY ELECTRICAL SYSTEM

PROPERTY NAME: Philadelphia Charter School For Arts and Sciences at HR Edmunds

PROPERTY ADDRESS: 1197 Haworth Street
Philadelphia, PA. 19124

TYPE OF TEST: Emergency

DATE OF TEST: July 14, 2025

TYPE OF SYSTEM: Generator

FIRE PUMP: X YES NO


Maximum output of system was 151 amps. The generator ran for 136 minutes under full load operating conditions.

This system was tested in accordance with the operational inspection and testing procedures established in both the Philadelphia Fire Prevention Code F-501.4 (R) and Section 6-4 of NFPA 110.

X The result of the test(s) indicate(s) that no elements of the system were found to be defective on this date and the system is certified.

 The result of the test(s) indicate(s) that certain elements of the system were found to be defective on this date and the system could not be certified.

COMMENTS:


CONTRACTOR'S SIGNATURE

Bruce D. Shelly
CONTRACTOR'S NAME (PRINTED)

162312
CONTRACTOR'S LICENSES NUMBER

6132X-4

Welcome Fred Reid

City of Philadelphia | Mayor's Office | City Council | Courts | District Attorney | Sheriff



[Home](#) [Search](#) [Profile](#) [Pay](#) [My Payments](#) [Sign Out](#)

Building Certification BC-2025-018832 (Submitted)

CONFIRMATION

Your Building Certification has been successfully submitted. The Department of Licenses and Inspections will notify you if there are any issues found with your submission. Any Certifications submitted as Deficient or Unsafe will be investigated by an Inspector.

Building BC-2025-018832: Submitted
Certification: 1197 HAWORTH ST, Philadelphia, PA 19124-2505
Building 1328992 Philadelphia Charter School for the Arts and Sciences

[Back to Home](#)

Screen ID: 2929294