

6132X-3

**CITY OF PHILADELPHIA
DEPARTMENT OF LICENSES AND INSPECTIONS
COMMERCIAL AND INDUSTRIAL FIRE UNIT
CERTIFICATION OF
STANDBY/EMERGENCY ELECTRICAL SYSTEM**

PROPERTY NAME: Philadelphia Preforming Arts Charter School

PROPERTY ADDRESS: 2407 South Broad Street
Philadelphia, PA. 19107

TYPE OF TEST: Emergency

DATE OF TEST: July 2, 2025

TYPE OF SYSTEM: Generator

FIRE PUMP: X YES NO

Maximum output of system was 34.6 amps. The generator ran for
138 minutes under full load operating conditions.

This system was tested in accordance with the operational inspection and testing procedures established in both the Philadelphia Fire Prevention Code F-501.4 (R) and Section 6-4 of NFPA 110.

X The result of the test(s) indicate(s) that no elements of the system were found to be defective on this date and the system is certified.

 The result of the test(s) indicate(s) that certain elements of the system were found to be defective on this date and the system could not be certified.

COMMENTS:

Bruce D. Shelly
CONTRACTOR'S SIGNATURE

Bruce D. Shelly
CONTRACTOR'S NAME (PRINTED)

162312
CONTRACTOR'S LICENSES NUMBER

0132X-3

Welcome Fred Read

City of Philadelphia | Mayor's Office | City Council | Courts | District Attorney | Sheriff



[Home](#) [Search](#) [Profile](#) [Pay](#) [My Payments](#) [Sign Out](#)

Building Certification BC-2025-018833 (Submitted)

CONFIRMATION

Your Building Certification has been successfully submitted. The Department of Licenses and Inspections will notify you if there are any issues found with your submission. Any Certifications submitted as Deficient or Unsafe will be investigated by an Inspector.

Building Certification: BC-2025-018833: Submitted
2407 S BROAD ST, Philadelphia, PA 19148-3508
Building 1525249

[Back to Home](#)

Screen ID: 2929294