

6132X-2

CITY OF PHILADELPHIA
DEPARTMENT OF LICENSES AND INSPECTIONS
COMMERCIAL AND INDUSTRIAL FIRE UNIT
CERTIFICATION OF
STANDBY/EMERGENCY ELECTRICAL SYSTEM

PROPERTY NAME: _____Philadelphia Preforming Arts Charter School_____

PROPERTY ADDRESS: _____2600 South Broad Street_____
_____Philadelphia, PA. 19107_____

TYPE OF TEST: _____Emergency_____

DATE OF TEST: _____July 2, 2025_____

TYPE OF SYSTEM: _____Generator_____

FIRE PUMP: _____X_____YES _____NO

Maximum output of system was 42 amps. The generator ran for
134 minutes under full load operating conditions.

This system was tested in accordance with the operational inspection and testing procedures established in both the Philadelphia Fire Prevention Code F-501.4 (R) and Section 6-4 of NFPA 110.

X The result of the test(s) indicate(s) that no elements of the system were found to be defective on this date and the system is certified.

_____ The result of the test(s) indicate(s) that certain elements of the system were found to be defective on this date and the system could not be certified.

COMMENTS:

Bruce D. Shelly
CONTRACTOR'S SIGNATURE

_____Bruce D. Shelly_____

CONTRACTOR'S NAME (PRINTED)

_____162312_____

CONTRACTOR'S LICENSES NUMBER

6132X-2

Welcome Fred Read

City of Philadelphia | Mayor's Office | City Council | Courts | District Attorney | Sheriff



[Home](#) [Search](#) [Profile](#) [Pay](#) [My Payments](#) [Sign Out](#)



Building Certification BC-2025-018835 (Submitted)

CONFIRMATION

Your Building Certification has been successfully submitted. The Department of Licenses and Inspections will notify you if there are any issues found with your submission. Any Certifications submitted as Deficient or Unsafe will be investigated by an Inspector.

Building Certification: BC-2025-018835: Submitted
2600-30 S BROAD ST, Philadelphia, PA 19145-4616
Building 1440087 Philadelphia Performing Arts Charter School

[Back to Home](#)

Screen ID: 2929294