

Districtwide Lead in Drinking Water Sampling and Remediation Plan

2023-2025

Eastern Suffolk BOCES



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779

T: 631.580.3191 • **F:** 631.580.3195 • **W:** envirohealth.org

DISTRICTWIDE LEAD IN DRINKING WATER SAMPLING AND REMEDIATION PLAN

2023-2025

Prepared for: EASTERN SUFFOLK BOCES
100 Barton Avenue
Patchogue, NY 11772

Prepared by: ENVIROSCIENCE CONSULTANTS, LLC
2150 Smithtown Avenue
Ronkonkoma, New York 11779
(631) 580-3191

Project Manager: *Pamela Chadderton*

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>
1.0	Executive Summary
2.0	Sampling Methodology
3.0	Initial Results
Appendices	
Appendix A	Barton Armory
Appendix B	Bixhorn Technical Center
Appendix C	Bellport Academic Center
Appendix D	Brookhaven Learning Center-East
Appendix E	Brookhaven Learning Center-West
Appendix F	Edward Milliken Technical Center
Appendix G	HB Ward Technical Center
Appendix H	Islip Academic Center
Appendix I	Islip Career Center
Appendix J	James Hines Administration Center
Appendix K	Jefferson Academic Center
Appendix L	Sayville Elementary School
Appendix M	Westhampton Beach Learning Center
Appendix N	Sequoia High School
Appendix O	Tecumseh Elementary School

1.0 EXECUTIVE SUMMARY

The Eastern Suffolk BOCES has developed their 2023-2025 Lead in Drinking Water Sampling and Remediation Plan, as required by the New York State Department of Health (Public Health Law Sections 1370-a and 1110, Subpart 67-4 Lead Testing in School Drinking Water).

In accordance with the regulation, this Lead Remediation Plan is prepared to identify locations deemed as Applicable Drinking Water Sources and report first draw sample results, to mitigate locations where sample results exceed 5 parts per billion, to identify locations deemed as Non-Applicable Water Sources, communicate this designation to building occupants, and to develop strategies for monitoring locations deemed Non-Applicable Water Sources to insure building occupants do not consume water from these locations.

The following locations within the Eastern Suffolk BOCES buildings have been deemed Applicable Drinking Water Sources by the administration:

- 1) Water fountains and bottle filling stations;
- 2) Kitchen water faucets and pot fillers used in food preparation;
- 3) Ice machines
- 4) Home Economics classroom sinks
- 5) Nurse's Office and Faculty Room sinks

First draw samples were collected from each of these locations within the district and analyzed by a New York State Department of Health ELAP certified laboratory. The chains of custody are available upon request. For results at or below 5 ppb, no further action is required. For locations above 5 ppb, options include: second and third draw sample collection to determine source of lead, designation of the location as Non-applicable Water Source, or permanent removal of the fixture from the location. In either case, the result was communicated by Enviroscience Consultants, and the fixture was shut off by the district immediately upon receipt of results.

The following locations within the Eastern Suffolk BOCES buildings were deemed Non-Applicable Water Sources by the administration:

- 1) Science Laboratory sinks
- 2) Art Room sinks
- 3) Technical Classroom sinks
- 4) Other Classroom sinks
- 5) Bathroom sinks
- 6) Outside spigots
- 7) Custodial Closet sinks
- 8) Mixed Valve sinks (or hot only)

In these cases, the Eastern Suffolk BOCES staff have placed signs adjacent to the fixture to notify occupants that the water is not intended for consumption. To further support this protocol, the following management of the locations is required:

- 1) Science Laboratory sinks - communicate in writing with students that these locations are for science experiments and hand washing only, not for consumption. This is most easily accomplished by including this language in the laboratory safety paperwork distributed to students at the beginning of the school year. This program should be monitored by the respective science teachers, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 2) Art Room sinks - communicate in writing to students that these locations are for cleaning of art supplies and hand washing only, not for consumption. This is most easily accomplished by including this language in the course paperwork distributed to students at the beginning of the school year. This program should be monitored by the respective art teachers, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 3) Technical Classroom sinks - classrooms in this category often include wood shop or auto mechanics classrooms, where students are to hand wash after bathroom usage or activities as part of a regular hygiene program. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 4) Other classroom sinks - classrooms in this category often include elementary classrooms, where students are to hand wash after bathroom usage or activities as part of a regular hygiene program. This program should be monitored by teachers and staff

to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.


- 5) Bathroom sinks - in intermediate buildings, signage should be sufficient for communicating the concept of hand washing only. In elementary schools, personal hygiene should be integrated into curriculum to ensure students understand bathroom sinks are for hand washing only, and not consumption. Further, show what the signage looks like in bathrooms, so they learn to recognize its meaning. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 6) Outside spigots - all-weather signage will be installed at each location. Further, spigots will have a special key maintained by the custodial staff to ensure that non-authorized persons do not fill sports coolers or use hoses for consumption. This program should be monitored by custodial staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 7) Custodial Closet sinks - these locations should be accessed by custodial personnel only and locked when not in use. Access to others should be restricted. This program should be monitored by custodial staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 8) Mixed Valve sinks (or hot only) – per Public Health Law Sections 1370-a and 1110, Subpart 67-4 Lead Testing in School Drinking Water mixed valve or hot water only sources are not required to be sampled. Signage is required for these sources. Signage should be sufficient for communicating the concept of hand washing only. In elementary schools, personal hygiene should be integrated into curriculum to ensure students understand bathroom sinks are for hand washing only, and not consumption. Further, show what the signage looks like so they learn to recognize its meaning. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.

All locations deemed non-applicable, but do not have signs, should be taken offline until signs have been posted. Signs are suggested to have pictures that instruct for handwashing only, do not drink.

2.0 SAMPLING METHODOLOGY

In accordance with the regulation, Enviroscience Consultants, LLC performed initial water sampling at the Eastern Suffolk BOCES buildings from 2023-2025. Samples were collected in wide-mouth 250 milliliter containers and were collected in the morning hours before the facilities opened. The water sources were not used for at least 8 hours and not more than 18 hours prior to sampling. Unique source numbers and designations were assigned to each source location. Unique sample identification numbers were assigned to each sample taken. The key to fixture type codes, source designations, and the sampling location schematics are shown below.

Code Key for Lead in Water			
Fixture Type Codes			
BF	Bottle Filler	SK	Sink
HB	Hose Bib	SL	Supply Line
IM	Ice Machine	SP	Spigot
OS	Other Source	SPY	Spray
PF	Pot Filler	SS	Slop Sink
		V	Valve
		WC	Water Cooler
		WF	Water Fountain
Source Designations			
App	Applicable	N/A	Non-applicable










 **ENVIROSCIENCE**
CONSULTANTS, INC.
2150 SMITHTOWN AVENUE
RONKONKOMA, NY 11779
(631) 580-3191
FAX 580-3195
www.envirohealth.org

KEY PLAN
NO SCALE

WATER SAMPLING METHODOLOGY

NOT TO SCALE
Date: 9/26/2016
By: Robert Cardona
DRAWING 1 of 2

SCIENCE ROOM TYPE 1 DIAGRAM	SCIENCE ROOM TYPE 2 DIAGRAM	SCIENCE ROOM TYPE 3 DIAGRAM																																																																																								
																																																																																										
SAMPLE IDENTIFICATION (example) <table border="1"> <thead> <tr> <th>LOCATION</th> <th>SOURCE</th> </tr> </thead> <tbody> <tr><td>Room 200 - Teacher Station</td><td>SK</td></tr> <tr><td>Room 200 - Counter 1 @ (A)</td><td>SK</td></tr> <tr><td>Room 200 - Counter 1 @ (B)</td><td>SK</td></tr> <tr><td>Room 200 - Counter 2 @ (A)</td><td>SK</td></tr> <tr><td>Room 200 - Counter 2 @ (B)</td><td>SK</td></tr> <tr><td>Room 200 - Counter 3 @ (A)</td><td>SK</td></tr> <tr><td>Room 200 - Counter 3 @ (B)</td><td>SK</td></tr> </tbody> </table>	LOCATION	SOURCE	Room 200 - Teacher Station	SK	Room 200 - Counter 1 @ (A)	SK	Room 200 - Counter 1 @ (B)	SK	Room 200 - Counter 2 @ (A)	SK	Room 200 - Counter 2 @ (B)	SK	Room 200 - Counter 3 @ (A)	SK	Room 200 - Counter 3 @ (B)	SK	SAMPLE IDENTIFICATION (example) <table border="1"> <thead> <tr> <th>LOCATION</th> <th>SOURCE</th> </tr> </thead> <tbody> <tr><td>Room 200 - Teacher Station</td><td>SK</td></tr> <tr><td>Room 200 - Table 1 @ (A)</td><td>SK</td></tr> <tr><td>Room 200 - Table 1 @ (B)</td><td>SK</td></tr> <tr><td>Room 200 - Table 2 @ (A)</td><td>SK</td></tr> <tr><td>Room 200 - Table 2 @ (B)</td><td>SK</td></tr> <tr><td>Room 200 - Table 3 @ (A)</td><td>SK</td></tr> <tr><td>Room 200 - Table 3 @ (B)</td><td>SK</td></tr> <tr><td>Room 200 - Table 4 @ (A)</td><td>SK</td></tr> <tr><td>Room 200 - Table 4 @ (B)</td><td>SK</td></tr> <tr><td>Room 200 - Counter 1 @ (A)</td><td>SK</td></tr> <tr><td>Room 200 - Counter 1 @ (B)</td><td>SK</td></tr> <tr><td>Room 200 - Counter 2 @ (A)</td><td>SK</td></tr> <tr><td>Room 200 - Counter 2 @ (B)</td><td>SK</td></tr> <tr><td>Room 200 - Counter 3 @ (A)</td><td>SK</td></tr> <tr><td>Room 200 - Counter 3 @ (B)</td><td>SK</td></tr> </tbody> </table>	LOCATION	SOURCE	Room 200 - Teacher Station	SK	Room 200 - Table 1 @ (A)	SK	Room 200 - Table 1 @ (B)	SK	Room 200 - Table 2 @ (A)	SK	Room 200 - Table 2 @ (B)	SK	Room 200 - Table 3 @ (A)	SK	Room 200 - Table 3 @ (B)	SK	Room 200 - Table 4 @ (A)	SK	Room 200 - Table 4 @ (B)	SK	Room 200 - Counter 1 @ (A)	SK	Room 200 - Counter 1 @ (B)	SK	Room 200 - Counter 2 @ (A)	SK	Room 200 - Counter 2 @ (B)	SK	Room 200 - Counter 3 @ (A)	SK	Room 200 - Counter 3 @ (B)	SK	SAMPLE IDENTIFICATION (example) <table border="1"> <thead> <tr> <th>LOCATION</th> <th>SOURCE</th> </tr> </thead> <tbody> <tr><td>Room 200 - Teacher Station</td><td>SK</td></tr> <tr><td>Room 200 - POD 1 @ (A)</td><td>SK</td></tr> <tr><td>Room 200 - POD 1 @ (B)</td><td>SK</td></tr> <tr><td>Room 200 - POD 1 @ (C)</td><td>SK</td></tr> <tr><td>Room 200 - POD 1 @ (D)</td><td>SK</td></tr> <tr><td>Room 200 - POD 1 @ (E)</td><td>SK</td></tr> <tr><td>Room 200 - POD 1 @ (F)</td><td>SK</td></tr> <tr><td>Room 200 - POD 2 @ (A)</td><td>SK</td></tr> <tr><td>Room 200 - POD 2 @ (B)</td><td>SK</td></tr> <tr><td>Room 200 - POD 2 @ (C)</td><td>SK</td></tr> <tr><td>Room 200 - POD 2 @ (D)</td><td>SK</td></tr> <tr><td>Room 200 - POD 2 @ (E)</td><td>SK</td></tr> <tr><td>Room 200 - POD 2 @ (F)</td><td>SK</td></tr> <tr><td>Room 200 - POD 3 @ (A)</td><td>SK</td></tr> <tr><td>Room 200 - POD 3 @ (B)</td><td>SK</td></tr> <tr><td>Room 200 - POD 3 @ (C)</td><td>SK</td></tr> <tr><td>Room 200 - POD 3 @ (D)</td><td>SK</td></tr> <tr><td>Room 200 - POD 3 @ (E)</td><td>SK</td></tr> <tr><td>Room 200 - POD 3 @ (F)</td><td>SK</td></tr> </tbody> </table>	LOCATION	SOURCE	Room 200 - Teacher Station	SK	Room 200 - POD 1 @ (A)	SK	Room 200 - POD 1 @ (B)	SK	Room 200 - POD 1 @ (C)	SK	Room 200 - POD 1 @ (D)	SK	Room 200 - POD 1 @ (E)	SK	Room 200 - POD 1 @ (F)	SK	Room 200 - POD 2 @ (A)	SK	Room 200 - POD 2 @ (B)	SK	Room 200 - POD 2 @ (C)	SK	Room 200 - POD 2 @ (D)	SK	Room 200 - POD 2 @ (E)	SK	Room 200 - POD 2 @ (F)	SK	Room 200 - POD 3 @ (A)	SK	Room 200 - POD 3 @ (B)	SK	Room 200 - POD 3 @ (C)	SK	Room 200 - POD 3 @ (D)	SK	Room 200 - POD 3 @ (E)	SK	Room 200 - POD 3 @ (F)	SK
LOCATION	SOURCE																																																																																									
Room 200 - Teacher Station	SK																																																																																									
Room 200 - Counter 1 @ (A)	SK																																																																																									
Room 200 - Counter 1 @ (B)	SK																																																																																									
Room 200 - Counter 2 @ (A)	SK																																																																																									
Room 200 - Counter 2 @ (B)	SK																																																																																									
Room 200 - Counter 3 @ (A)	SK																																																																																									
Room 200 - Counter 3 @ (B)	SK																																																																																									
LOCATION	SOURCE																																																																																									
Room 200 - Teacher Station	SK																																																																																									
Room 200 - Table 1 @ (A)	SK																																																																																									
Room 200 - Table 1 @ (B)	SK																																																																																									
Room 200 - Table 2 @ (A)	SK																																																																																									
Room 200 - Table 2 @ (B)	SK																																																																																									
Room 200 - Table 3 @ (A)	SK																																																																																									
Room 200 - Table 3 @ (B)	SK																																																																																									
Room 200 - Table 4 @ (A)	SK																																																																																									
Room 200 - Table 4 @ (B)	SK																																																																																									
Room 200 - Counter 1 @ (A)	SK																																																																																									
Room 200 - Counter 1 @ (B)	SK																																																																																									
Room 200 - Counter 2 @ (A)	SK																																																																																									
Room 200 - Counter 2 @ (B)	SK																																																																																									
Room 200 - Counter 3 @ (A)	SK																																																																																									
Room 200 - Counter 3 @ (B)	SK																																																																																									
LOCATION	SOURCE																																																																																									
Room 200 - Teacher Station	SK																																																																																									
Room 200 - POD 1 @ (A)	SK																																																																																									
Room 200 - POD 1 @ (B)	SK																																																																																									
Room 200 - POD 1 @ (C)	SK																																																																																									
Room 200 - POD 1 @ (D)	SK																																																																																									
Room 200 - POD 1 @ (E)	SK																																																																																									
Room 200 - POD 1 @ (F)	SK																																																																																									
Room 200 - POD 2 @ (A)	SK																																																																																									
Room 200 - POD 2 @ (B)	SK																																																																																									
Room 200 - POD 2 @ (C)	SK																																																																																									
Room 200 - POD 2 @ (D)	SK																																																																																									
Room 200 - POD 2 @ (E)	SK																																																																																									
Room 200 - POD 2 @ (F)	SK																																																																																									
Room 200 - POD 3 @ (A)	SK																																																																																									
Room 200 - POD 3 @ (B)	SK																																																																																									
Room 200 - POD 3 @ (C)	SK																																																																																									
Room 200 - POD 3 @ (D)	SK																																																																																									
Room 200 - POD 3 @ (E)	SK																																																																																									
Room 200 - POD 3 @ (F)	SK																																																																																									
																																																																																										
NOT TO SCALE Date: 9/26/2016 By: Robert Cardona	WATER SAMPLING METHODOLOGY	KEY PLAN NO SCALE																																																																																								
 ENVIROSCIENCE CONSULTANTS, INC. 2150 SMITHTOWN AVENUE RONKONKOMA, NY 11779 (631) 560-3181 FAX 560-3185 www.envirohealth.org	ENVIRONMENTAL HEALTH	DRAWING 2 of 2																																																																																								

3.0 Initial Results

All water source locations in each of the school buildings were assessed. Water source locations identified as drinking water sources were considered Applicable, and first draw samples were collected. Water source locations identified as non-drinking water sources were considered non-applicable and these locations were documented.

The results of the initial sampling and the use of signs warning against water use at non-applicable sources is documented in the School Water Outlet Inventory for each building.

All elevated locations should be taken off line until the remediation is completed. Any other drinking water sources in these buildings that were not functional at the time of initial sampling and have not been tested should be tested before returning to service. All locations deemed non-applicable, but do not have signs, should be taken offline until signs have been posted. Signs are suggested to have pictures that instruct for handwashing only, do not drink.

The following is a summary of results in parts per billion (ppb) of locations in the Eastern Suffolk BOCES buildings where sample results were found above 5 ppb:

Barton Armory			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
No Elevated Fixtures			

Bixhorn Technical Center			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Room 202 Water Fountain	325	1/23/2025	Capped

Bellport Academic Center			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Kitchen Prep Sink	7.0	4/18/2024	Removed From Service; Pending Retest

Brookhaven Learning Center-East			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Room 6 Handwash Sink	11.0	4/19/2024	Sign Posted

Brookhaven Learning Center-West			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
No Elevated Fixtures			

Edward Milliken Technical Center			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Nurse's Office Spigot/Bottle Filler	88.0	2/4/2025	Removed From Service; Pending Remediation
Nurse's Office Bathroom Sink	9.0	2/4/2025	Removed From Service; Pending Remediation
Room 112 Sink	23.0	2/4/2025	Removed From Service; Pending Remediation
Room 122 Pot Filler	11.0	2/4/2025	Removed From Service; Pending Remediation
Room 128 Steamer	69.0	2/4/2025	Removed From Service; Pending Remediation

HB Ward Technical Center			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Building-2 Room 207 by Ovens Sink	11	2/13/2025	Removed From Service; Pending Remediation
Building-2 Room 202 sink	8	2/13/2025	Removed From Service; Pending Remediation

Islip Academic Center			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Nurse's Office Sink	13.0	2/5/2025	Removed From Service; Pending Remediation

Islip Career Center			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Nurse's Office - Left Sink	15.0	2/5/2025	Removed From Service; Pending Remediation
Kitchen Prep (Small) Sink	27.0	2/5/2025	Removed From Service; Pending Remediation

James Hines Administration Center			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
No Elevated Fixtures			

Jefferson Academic Center			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Room 112 Left Sink	9.0	2/7/2025	Removed From Service; Pending Remediation

Jefferson Academic Center

SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Room 112 Right Sink	9.0	2/7/2025	Removed From Service; Pending Remediation

Sayville Elementary School

SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Kitchen Dishwash 3 Bay Sink	6.0	1/24/2025	Sign
Room 103 Bathroom (Left) Sink	6.0	1/24/2025	Sign
Room 103 Bathroom (Right) Sink	7.0	1/24/2025	Sign
Room 101 Bathroom (Left) Sink	19.0	1/24/2025	Sign
Room 101 Bathroom (Right) Sink	10.0	1/24/2025	Sign

Westhampton Beach Learning Center

SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
No Elevated Fixtures			

Sequoia High School

SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Kitchen 2 Bay Sink	9.0	12/29/2023	Removed From Service; Pending Retest
Kitchen Pot Filler-Right	20.0	12/29/2023	Removed From Service; Pending Retest
Kitchen Pot Filler-Middle	14.0	12/29/2023	Removed From Service; Pending Retest

Sequoia High School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Kitchen Pot Filler-Left	62.0	12/29/2023	Removed From Service; Pending Retest
Conference Room 5/8 Coffee Room Sink	8.0	12/29/2023	Removed From Service; Pending Retest

Tecumseh Elementary School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Kitchen Steamer Supply Spigot	133.0	6/20/2024	Removed From Service; Pending Remediation
Kitchen Island Sink	9.0	6/20/2024	Sign
Nurse's Office Sink	23.0	6/20/2024	Sign and Bottled Water

Appendix A
Barton Armory

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1010	1001-1	Kitchen	SK	App	2.0	12/28/2023	-	-	-	-
	1001-2	Kitchen	SPY	App	2.0	12/28/2023	-	-	-	-
1008	1002-1	Men's Bathroom by Main Entrance (left)	SK	N/A		12/28/2023	-	-	-	Sign
	1002-2	Men's Bathroom by Main Entrance (right)	SK	N/A		12/28/2023	-	-	-	Sign
1002	1003-1	Receiving Warehouse	SK	App		12/28/2023	-	-	-	Sign
1001	1007-1	Maintenance Shop Coffee Line	SL	App	<1.0	12/28/2023	-	-	-	-
	1007-2	Maintenance Shop Fridge Water Line	OS	App		12/28/2023	-	-	-	Non-functional; Sampling Required if Repaired
	1007-3	Maintenance Shop Fridge Ice Machine	IM	App		12/28/2023	-	-	-	Non-functional; Sampling Required if Repaired
	1007-4	Maintenance Shop Ice Machine	IM	App	<1.0	12/28/2023	-	-	-	-
	1007-5	Maintenance Shop Unit (left)	SK	N/A		12/28/2023	-	-	-	Sign
	1007-6	Maintenance Shop Unit (right)	SK	N/A		12/28/2023	-	-	-	Sign
1019	1004-1	Hall by Main Entrance	WF	App	<1.0	12/28/2023	-	-	-	-
	1004-2	Hall by Main Entrance	BF	App	<1.0	12/28/2023	-	-	-	-
1007	1005-1	Custodial Closet-First floor	SS	N/A		12/28/2023	-	-	-	Sign
1006A	1006-1	Women's Bathroom-First Floor (left)	SK	N/A		12/28/2023	-	-	-	Sign
	1006-2	Women's Bathroom-First Floor (center)	SK	N/A		12/28/2023	-	-	-	Sign
	1006-2	Women's Bathroom-First Floor (right)	SK	N/A		12/28/2023	-	-	-	Sign
2002A	2001-1	Women's Bathroom-Second Floor (left)	SK	N/A		12/28/2023	-	-	-	Sign
	2001-2	Women's Bathroom-Second Floor (right)	SK	N/A		12/28/2023	-	-	-	Sign
2007	2002-1	Hall -Second Floor	WF	App	<1.0	12/28/2023	-	-	-	-

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2007	2002-2	Hall -Second Floor	BF	App	<1.0	12/28/2023	-	-	-	-
2004	2003-1	Men's Bathroom-Second Floor (right)	SK	N/A		12/28/2023	-	-	-	Sign
	2003-2	Men's Bathroom-Second Floor (left)	SK	N/A		12/28/2023	-	-	-	Sign
2005	2004-1	Custodial Closet-Second Floor	SS	N/A		12/28/2023	-	-	-	Sign

Laboratory Report

NYE Report #: 237342-28049

December 29, 2023

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Eastern Suffolk BOCES; Barton Armory

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on December 28, 2023. New York Environmental analyzed the samples on December 29, 2023 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	28 Dec 2023
Date Received:	28 Dec 2023
Date Analyzed:	29 Dec 2023

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
231228L024	1	Kitchen-SK, Initial	0.001	0.002	mg/L	
231228L025	2	Kitchen-SPY, Initial	0.001	0.002	mg/L	
231228L026	3	Hall by Main Entrance-WF, Initial	0.001	<0.001	mg/L	
231228L027	4	Hall by Main Entrance-BF, Initial	0.001	<0.001	mg/L	
231228L028	5	Hall-Second Floor-WF, Initial	0.001	<0.001	mg/L	
231228L029	6	Hall-Second Floor-BF, Initial	0.001	<0.001	mg/L	
231228L030	7	Maintenance Shop Coffee Line-SL, Initial	0.001	<0.001	mg/L	
231228L031	8	Maintenance Shop Ice Machine-IM, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix B
Bixhorn Technical Center

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Room 417 Women's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1001-2	Room 417 Men's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1001-3	Room 418 Reception Area	BF	App	<1.0	1/23/2025	-	-	-	-
1001-4	Room 418 Reception Area	WF	App	<1.0	1/23/2025	-	-	-	-
1002-1	Room 408 Girl's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1002-2	Room 408 Boy's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1002-3	Room 408	WF	App	2.0	1/23/2025	-	-	-	-
1002-4	Room 408-Trough Sink-Left	SK	N/A		1/23/2025	-	-	-	Sign
1002-5	Room 408-Trough Sink-Right	SK	N/A		1/23/2025	-	-	-	Sign
1003-1	Room 406 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1003-2	Room 406	WF	App	4.0	1/23/2025	-	-	-	-
1004-1	Room 413 Men's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1004-2	Room 413-Double Sink-Right	SK	N/A		1/23/2025	-	-	-	Sign
1004-3	Room 413-Double Sink-Left	SK	N/A		1/23/2025	-	-	-	Sign
1005-1	Women's Bathroom Room 409	SK	N/A		1/23/2025	-	-	-	Sign
1006-1	Men's Bathroom Room 407	SK	N/A		1/23/2025	-	-	-	Sign
1007-1	Room 405-Double Sink-Right	SK	N/A		1/23/2025	-	-	-	Sign
1007-2	Room 405-Double Sink-Left	SK	N/A		1/23/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1007-3	Room 405 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1007-4	Room 405-Slop Sink	SS	N/A		1/23/2025	-	-	-	Sign
1008-1	Room 404-Room A	SK	N/A		1/23/2025	-	-	-	Sign
1008-2	Room 404- Room B	SK	N/A		1/23/2025	-	-	-	Sign
1008-3	Room 404-Laundry Room	SK	N/A		1/23/2025	-	-	-	Sign
1008-4	Room 404-Hospital Bed Room	SK	N/A		1/23/2025	-	-	-	Sign
1008-5	Room 404-Hospital Bed Room	SK	N/A		1/23/2025	-	-	-	Sign
1008-6	Room 404-Common Space	BF	App	<1.0	1/23/2025	-	-	-	-
1008-7	Room 404-Common Space	WF	App	<1.0	1/23/2025	-	-	-	-
1008-8	Room 404 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1008-9	Room 404	SS	N/A		1/23/2025	-	-	-	Sign
1009-1	Hallway by Room 403	BF	App	<1.0	1/23/2025	-	-	-	-
1009-2	Hallway by Room 403	WF	App	<1.0	1/23/2025	-	-	-	-
1010-1	Room 403	SS	N/A		1/23/2025	-	-	-	Sign
1010-2	Room 403 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1011-1	Room 402 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1012-1	Room 316 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1012-2	Room 316	SS	N/A		1/23/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1010-3	Room 316	BF	App	<1.0	1/23/2025	-	-	-	-
1012-3	Room 316	WF	App	<1.0	1/23/2025	-	-	-	-
1013-1	Hallway by Room 311	BF	App	<1.0	1/23/2025	-	-	-	-
1013-2	Hallway by Room 311	WF	App	<1.0	1/23/2025	-	-	-	-
1014-1	Room 311 Common Area	BF	App	<1.0	1/23/2025	-	-	-	-
1014-2	Room 311 Common Area	WF	App	<1.0	1/23/2025	-	-	-	-
1015-1	Room 314 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1016-1	Bathroom by Room 308	SK	N/A		1/23/2025	-	-	-	Sign
1017-1	Room 308 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1017-2	Room 308	BF	App	<1.0	1/23/2025	-	-	-	-
1017-3	Room 308	WF	App	<1.0	1/23/2025	-	-	-	-
1017-4	Room 308-Laundry Room	SS	N/A		1/23/2025	-	-	-	Sign
1018-1	Room 309 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1018-2	Room 309	WF	App	<1.0	1/23/2025	-	-	-	-
1018-3	Room 309-Grooming Table-Left	SK	N/A		1/23/2025	-	-	-	Sign
1018-4	Room 309-Grooming Table-Middle	SK	N/A		1/23/2025	-	-	-	Sign
1018-5	Room 309-Grooming Table-Right	SK	N/A		1/23/2025	-	-	-	Sign
1018-6	Room 309-Animal Food Dish Sink	SK	N/A		1/23/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1018-7	Room 309-Animal Sink	SK	N/A		1/23/2025	-	-	-	Sign
1019-1	Room 305-Aquarium Room-3 Sink-Left	SS	N/A		1/23/2025	-	-	-	Sign
1019-2	Room 305-Aquarium Room-3 Sink-Right	SS	N/A		1/23/2025	-	-	-	Sign
1019-3	Room 305-Aquarium Room-Grooming Table	SK	N/A		1/23/2025	-	-	-	Sign
1019-4	Room 305-Lesson Room-Left	SK	N/A		1/23/2025	-	-	-	Sign
1019-5	Room 305-Lesson Room-Right	SK	N/A		1/23/2025	-	-	-	Sign
1019-6	Room 305 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1020-1	Room 306	WF	App	<1.0	1/23/2025	-	-	-	-
1020-2	Room 306-Trough-2 Sink-Right	SK	N/A		1/23/2025	-	-	-	Sign
1020-3	Room 306-Trough-2 Sink-Left	SK	N/A		1/23/2025	-	-	-	Sign
1020-4	Room 306 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1021-1	Room 303	SS	N/A		1/23/2025	-	-	-	Sign
1021-2	Room 303 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1022-1	Room 202 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1022-2	Room 202	WF	App	325.0	1/23/2025				Capped
1022-3	Room 202	SK	N/A		1/23/2025	-	-	-	Sign
1022-7	Room 202 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1023-2	Room 206 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1023-3	Room 206	SS	N/A		1/23/2025	-	-	-	Sign
1024-1	Room 208 Men's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1024-2	Room 208 Women's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1025-1	Room 212 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1025-2	Room 212-Development Room	SS	N/A		1/23/2025	-	-	-	Sign
1025-3	Room 212-Chemical Room-Left	SK	N/A		1/23/2025	-	-	-	Sign
1025-4	Room 212-Chemical Room-Right	SK	N/A		1/23/2025	-	-	-	Sign
1025-5	Room 212-Dark Room	SK	N/A		1/23/2025	-	-	-	Sign
1026-1	Hallway by Room 212	BF	App	<1.0	1/23/2025	-	-	-	-
1026-2	Hallway by Room 212	WF	App	<1.0	1/23/2025	-	-	-	-
1027-1	Room 214 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1027-2	Room 214	SK	N/A		1/23/2025	-	-	-	Sign
1028-1	Room 219 Boy's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1028-2	Room 219 Girl's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1029-2	Room 217 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1030-1	Room 215 Girl's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1030-2	Room 215 Boy's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1030-3	Room 215-Left	SK	N/A		1/23/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1030-4	Room 215-Right	SK	N/A		1/23/2025	-	-	-	Sign
1031-1	Room 213 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1032-1	Bathroom by Room 207	SK	N/A		1/23/2025	-	-	-	Sign
1034-2	Room 205 Boy's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1034-3	Room 205 Girl's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1035-1	Room 203 Girl's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1035-2	Room 203 Boy's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1035-3	Room 203	SK	N/A		1/23/2025	-	-	-	Sign
1036-1	Room 139 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1036-3	Room 139-Sink #2	SK	N/A		1/23/2025	-	-	-	Sign
1036-4	Room 139-Sink #3	SK	N/A		1/23/2025	-	-	-	Sign
1036-5	Room 139-Sink #1	SK	N/A		1/23/2025	-	-	-	Sign
1036-6	Room 139 Dental Chair 1-Bowl Rinse	OS	N/A		1/23/2025	-	-	-	Sign
1036-7	Room 139 Dental Chair 1-Cup Filler	OS	N/A		1/23/2025	-	-	-	Sign
1036-8	Room 139 Dental Chair 2-Bowl Rinse	OS	N/A		1/23/2025	-	-	-	Sign
1036-9	Room 139 Dental Chair 2-Cup Filler	OS	N/A		1/23/2025	-	-	-	Sign
1036-10	Room 139 Dental Chair 3-Bowl Rinse	OS	N/A		1/23/2025	-	-	-	Sign
1036-11	Room 139 Dental Chair 3-Cup Filler	OS	N/A		1/23/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1036-12	Room 139 Dental Chair 4-Bowl Rinse	OS	N/A		1/23/2025	-	-	-	Sign
1036-13	Room 139 Dental Chair 4-Cup Filer	OS	N/A		1/23/2025	-	-	-	Sign
1037-2	Room 128 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1037-3	Room 128	SK	N/A		1/23/2025	-	-	-	Sign
1038-1	Room 137 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1039-1	Room 135-Back Space-Left	SK	N/A		1/23/2025	-	-	-	Sign
1039-2	Room 135-Back Space-Right	SK	N/A		1/23/2025	-	-	-	Sign
1039-3	Room 135-Middle Space	SK	N/A		1/23/2025	-	-	-	Sign
1039-4	Room 135 Men's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1039-5	Room 135 Women's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1040-1	Room 126 Men's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1040-4	Room 126 Women's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1041-1	Room 133 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1041-3	Room 133-Back Space-Left	SK	N/A		1/23/2025	-	-	-	Sign
1041-4	Room 133-Back Space-Right	SK	N/A		1/23/2025	-	-	-	Sign
1042-1	Room 122-Culinary Arts-Pot Filler	PF	App		1/23/2025	-	-	-	Not in use yet
1042-2	Room 122-Culinary Arts-2 Bay -Dishwasher	SK	N/A		1/23/2025	-	-	-	Sign
1042-3	Room 122-Culinary Arts-Handwash	SK	N/A		1/23/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1042-4	Room 122-Culinary Arts-2 Bay -Dishwasher	SK	N/A		1/23/2025	-	-	-	Sign
1042-5	Room 122-Culinary Arts-Dishwasher	SPY	N/A		1/23/2025	-	-	-	Sign
1042-6	Room 122-Culinary Arts	BF	App	<1.0	1/23/2025	-	-	-	-
1042-7	Room 122-Culinary Arts	WF	App	<1.0	1/23/2025	-	-	-	-
1042-8	Room 122-Culinary Arts-Handwash	SK	N/A		1/23/2025	-	-	-	Sign
1042-9	Room 122-Culinary Arts-Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1043-1	Room 114 Bathroom-Left	SK	N/A		1/23/2025	-	-	-	Sign
1043-2	Room 114 Bathroom-Right	SK	N/A		1/23/2025	-	-	-	Sign
1043-3	Room 114	BF	App	<1.0	1/23/2025	-	-	-	-
1043-4	Room 114	WF	App	<1.0	1/23/2025	-	-	-	-
1044-1	Faculty Room Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1044-2	Faculty Room Kitchenette	SK	N/A		1/23/2025	-	-	-	Sign
1045-1	Room 129 Laundry	SK	N/A		1/23/2025	-	-	-	Sign
1045-2	Room 129 Hair Wash-Left	SK	N/A		1/23/2025	-	-	-	Sign
1045-3	Room 129 Hair Wash-Right	SK	N/A		1/23/2025	-	-	-	Sign
1045-4	Room 129 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1046-1	Room 127 Women's Bathroom-Left	SK	N/A		1/23/2025	-	-	-	Sign
1046-2	Room 127 Women's Bathroom-Right	SK	N/A		1/23/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1047-1	Room 125 Men's Bathroom-Left	SK	N/A		1/23/2025	-	-	-	Sign
1047-2	Room 125 Men's Bathroom-Right	SK	N/A		1/23/2025	-	-	-	Sign
1048-1	Hallway by Men's Bathroom	BF	App	<1.0	1/23/2025	-	-	-	-
1048-2	Hallway by Men's Bathroom	WF	App	<1.0	1/23/2025	-	-	-	-
1049-1	Room 123 Bathroom-Left	SK	N/A		1/23/2025	-	-	-	Sign
1049-2	Room 123 Bathroom-Right	SK	N/A		1/23/2025	-	-	-	Sign
1049-3	Room 123 Kitchenette	SK	N/A		1/23/2025	-	-	-	Sign
1050-1	Room 117 Staff Only-Women's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1051-1	Room 117 Staff Only-Men's Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1052-1	Room 101 Kitchenette	SK	N/A		1/23/2025	-	-	-	Sign
1052-2	Room 101 Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1053-1	Room 102-Custodial	SS	N/A		1/23/2025	-	-	-	Sign
1053-2	Room 102-Custodial Kitchenette	SK	N/A		1/23/2025	-	-	-	Sign
1053-3	Room 102-Custodial Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1053-4	Room 102-Custodial Bathroom	SK	N/A		1/23/2025	-	-	-	Sign
1054-1	Custodial Closet-D Wing	SS	N/A		1/23/2025	-	-	-	Sign
1055-1	Custodial Closet-C Wing	SS	N/A		1/23/2025	-	-	-	Sign
1056-1	Custodial Closet-B Wing	SS	N/A		1/23/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1057-1	Custodial Closet-A Wing	SS	N/A		1/23/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2500235-32173

January 27, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Eastern Suffolk BOCES; Bixhorn Technical Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on January 24, 2025. New York Environmental analyzed the samples on January 27, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	23 Jan 2025
Date Received:	24 Jan 2025
Date Analyzed:	27 Jan 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250124J007	1	Room 418 Reception Area-BF, Initial	0.001	<0.001	mg/L	
250124J008	2	Room 418 Reception Area-WF, Initial	0.001	<0.001	mg/L	
250124J009	3	Room 408-WF, Initial	0.001	0.002	mg/L	
250124J010	4	Room 406-WF, Initial	0.001	0.004	mg/L	
250124J011	5	Room 404-Common Space-BF, Initial	0.001	<0.001	mg/L	
250124J012	6	Room 404-Common Space-WF, Initial	0.001	<0.001	mg/L	
250124J013	7	Hallway by Room 403-BF, Initial	0.001	<0.001	mg/L	
250124J014	8	Hallway by Room 403-WF, Initial	0.001	<0.001	mg/L	
250124J015	9	Room 316-BF, Initial	0.001	<0.001	mg/L	
250124J016	10	Room 316-WF, Initial	0.001	<0.001	mg/L	
250124J017	11	Hallway by Room 311-BF, Initial	0.001	<0.001	mg/L	
250124J018	12	Hallway by Room 311-WF, Initial	0.001	<0.001	mg/L	
250124J019	13	Room 311 Common Area-BF, Initial	0.001	<0.001	mg/L	
250124J020	14	Room 311 Common Area-WF, Initial	0.001	<0.001	mg/L	
250124J021	15	Room 308-BF, Initial	0.001	<0.001	mg/L	
250124J022	16	Room 308-WF, Initial	0.001	<0.001	mg/L	
250124J023	17	Room 309-WF, Initial	0.001	<0.001	mg/L	
250124J024	18	Room 306-WF, Initial	0.001	<0.001	mg/L	
250124J025	19	Room 202-WF, Initial	0.001	0.325	mg/L	E,H
250124J026	20	Hallway by Room 212-BF, Initial	0.001	<0.001	mg/L	
250124J027	21	Hallway by Room 212-WF, Initial	0.001	<0.001	mg/L	
250124J028	22	Room 122-Culinary Arts-BF, Initial	0.001	<0.001	mg/L	
250124J029	23	Room 122-Culinary Arts-WF, Initial	0.001	<0.001	mg/L	
250124J030	24	Room 114-BF, Initial	0.001	<0.001	mg/L	
250124J031	25	Room 114-WF, Initial	0.001	<0.001	mg/L	
250124J032	26	Hallway by Men's Bathroom-BF, Initial	0.001	<0.001	mg/L	



Date Collected:	23 Jan 2025
Date Received:	24 Jan 2025
Date Analyzed:	27 Jan 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
250124J033	27	Hallway by Men's Bathroom-WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.



Appendix C
Bellport Academic Center

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Kitchen Handwash @ A	SK	N/A		4/18/2024	-	-	-	Sign
1001-2	Kitchen 3 Bay Dishwash - left	SK	N/A		4/18/2024	-	-	-	Sign
1001-3	Kitchen 3 Bay Dishwash - right	SK	N/A		4/18/2024	-	-	-	Sign
1001-4	Kitchen 3 Bay Dishwash	SPY	N/A		4/18/2024	-	-	-	Sign
1001-5	Kitchen Handwash @ B	SK	N/A		4/18/2024	-	-	-	Sign
1001-6	Kitchen 2-Bay	SK	App	3.0	4/18/2024	-	-	-	-
1001-7	Kitchen Prep	SK	App	3.0	5/1/2024	<1.0	<1.0	5/1/24	Remediation Complete
				7.0	4/18/2024				Removed from Service; Pending Retest
1001-8	Kitchen Custodial Closet	SS	N/A		4/18/2024	-	-	-	Sign
1002-1	Serving Line Handwash	SK	N/A		4/18/2024	-	-	-	Sign
1002-2	Serving Line	SK	N/A		4/18/2024	-	-	-	Sign
1003-1	Faculty Room by Kitchen	SK	App	1.0	4/18/2024	-	-	-	-
1003-2	Faculty Room Bathroom	SK	N/A		4/18/2024	-	-	-	Sign
1004-1	Bathroom by Faculty Room	SK	N/A		4/18/2024	-	-	-	Sign
1005-1	Nurse's Office	SK	App	6.0	4/18/2024				Remediation Complete; Sign
1005-2	Nurse's Office Bathroom	SK	N/A	2.0	4/18/2024	-	-	-	Sign
1006-1	Women's Faculty Bathroom by Lobby @ A	SK	N/A		4/18/2024	-	-	-	Sign
1006-2	Women's Faculty Bathroom by Lobby @ B	SK	N/A		4/18/2024	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1006-3	Women's Faculty Bathroom by Lobby @ C	SK	N/A		4/18/2024	-	-	-	Sign
1006-4	Women's Faculty Bathroom by Lobby @ D	SK	N/A		4/18/2024	-	-	-	Sign
1006-5	Women's Faculty Bathroom by Lobby @ E	SK	N/A		4/18/2024	-	-	-	Sign
1007-1	Lobby	WF	App	<1.0	4/18/2024	-	-	-	-
1007-2	Lobby	BF	App	<1.0	4/18/2024	-	-	-	-
1008-1	Men's Faculty Bathroom by Lobby @ A	SK	N/A		4/18/2024	-	-	-	Sign
1008-2	Men's Faculty Bathroom by Lobby @ B	SK	N/A		4/18/2024	-	-	-	Sign
1008-3	Men's Faculty Bathroom by Lobby @ C	SK	N/A		4/18/2024	-	-	-	Sign
1008-4	Men's Faculty Bathroom by Lobby @ D	SK	N/A		4/18/2024	-	-	-	Sign
1008-5	Men's Faculty Bathroom by Lobby @ E	SK	N/A		4/18/2024	-	-	-	Sign
1009-1	Room 614	SK	N/A		4/18/2024	-	-	-	Sign
1010-1	Room 611	SK	N/A		4/18/2024	-	-	-	Sign
1011-1	Room 604	SK	N/A		4/18/2024	-	-	-	Sign
1012-1	Room 602	SK	N/A		4/18/2024	-	-	-	Sign
1013-1	Hallway by Gym	WF	App	<1.0	4/18/2024	-	-	-	-
1013-2	Hallway by Gym	BF	App	<1.0	4/18/2024	-	-	-	-
1014-1	Custodial Closet by Room 512	SS	N/A		4/18/2024	-	-	-	Sign
1015-1	Women's Bathroom by Room 512 @ A	SK	N/A		4/18/2024	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1015-2	Women's Bathroom by Room 512 @ B	SK	N/A		4/18/2024	-	-	-	Sign
1015-3	Women's Bathroom by Room 512 @ C	SK	N/A		4/18/2024	-	-	-	Sign
1015-4	Women's Bathroom by Room 512 @ D	SK	N/A		4/18/2024	-	-	-	Sign
1015-5	Women's Bathroom by Room 512 @ E	SK	N/A		4/18/2024	-	-	-	Sign
1016-1	Girl's Bathroom by Room 512	SK	N/A		4/18/2024	-	-	-	Sign
1017-1	Boy's Bathroom by Room 512	SK	N/A		4/18/2024	-	-	-	Sign
1018-1	Men's Bathroom by Room 512 @ A	SK	N/A		4/18/2024	-	-	-	Sign
1018-2	Men's Bathroom by Room 512 @ B	SK	N/A		4/18/2024	-	-	-	Sign
1018-3	Men's Bathroom by Room 512 @ C	SK	N/A		4/18/2024	-	-	-	Sign
1018-4	Men's Bathroom by Room 512 @ D	SK	N/A		4/18/2024	-	-	-	Sign
1018-5	Men's Bathroom by Room 512 @ E	SK	N/A		4/18/2024	-	-	-	Sign
1019-1	Room 510	SK	N/A		4/18/2024	-	-	-	Sign
1020-1	Room 508	SK	N/A		4/18/2024	-	-	-	Sign
1021-1	Hallway across Room 502	WF	App	<1.0	4/18/2024	-	-	-	-
1021-2	Hallway across Room 502	BF	App	<1.0	4/18/2024	-	-	-	-

Laboratory Report

NYE Report #: 2402598-29410

April 23, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: ES BOCES; Bellport Academic Center

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on April 22, 2024. New York Environmental analyzed the samples on April 23, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	18 Apr 2024
Date Received:	22 Apr 2024
Date Analyzed:	23 Apr 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240422Q075	1	Kitchen 2-Bay-SK, Initial	0.001	0.003	mg/L	
240422Q076	2	Kitchen Prep-SK, Initial	0.001	0.007	mg/L	H
240422Q077	3	Faculty Room by Kitchen-SK, Initial	0.001	0.001	mg/L	
240422Q078	4	Nurse's Office-SK, Initial	0.001	0.006	mg/L	H
240422Q079	5	Nurse's Office Bathroom-SK, Initial	0.001	0.002	mg/L	
240422Q080	6	Lobby-WF, Initial	0.001	<0.001	mg/L	
240422Q081	7	Lobby-BF, Initial	0.001	<0.001	mg/L	
240422Q082	8	Hallway by Gym-WF, Initial	0.001	<0.001	mg/L	
240422Q083	9	Hallway by Gym-BF, Initial	0.001	<0.001	mg/L	
240422Q084	10	Hallway across Room 502-WF, Initial	0.001	<0.001	mg/L	
240422Q085	11	Hallway across Room 502-BF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

NYE Report #: 2402806-29515

May 3, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Eastern Suffolk BOCES; Bellport Academic Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 02, 2024. New York Environmental analyzed the samples on May 03, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	01 May 2024
Date Received:	02 May 2024
Date Analyzed:	03 May 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
240502N050	1A	Kitchen Prep-1A, Initial	0.001	0.003	mg/L	
240502N051	1B	Kitchen Prep-1B, 15 Sec Flush	0.001	<0.001	mg/L	
240502N052	1C	Kitchen Prep-1C, 60 Sec Flush	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix D
Brookhaven Learning Center-East

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Room 1	WF	N/A		4/19/2024	-	-	-	Removed from Service; Fixture Removed
1001-2	Room 1	SK	N/A		4/19/2024	-	-	-	Sign
1002-1	Room 2	SK	N/A		4/19/2024	-	-	-	Sign
1002-2	Room 2	WF	N/A		4/19/2024	-	-	-	Removed from Service
1003-1	Room 3	SK	N/A		4/19/2024	-	-	-	Sign
1004-1	Room 4 - Front	SK	N/A		4/19/2024	-	-	-	Removed from Service
1004-6	Room 4 - Rear	SK	App	2.0	4/19/2024	-	-	-	-
1005-1	Room 5	WF	N/A		4/19/2024	-	-	-	Removed from Service
1005-2	Room 5	SK	N/A		4/19/2024	-	-	-	Sign
1006-1	Room 6 Handwash	SK	App	11.0	4/19/2024				Sign
1006-2	Room 6 Counter 1	SK	N/A		4/19/2024	-	-	-	Sign
1006-3	Room 6 Counter 2	BF	N/A		4/19/2024	-	-	-	Removed from Service
1006-4	Room 6 Counter 2	SK	N/A		4/19/2024	-	-	-	Sign
1006-5	Room 6	WF	N/A		4/19/2024	-	-	-	Removed from Service
1007-1	Room 7	SK	N/A		4/19/2024	-	-	-	Sign
1007-2	Room 7	WF	N/A		4/19/2024	-	-	-	Removed from Service
1008-1	Room 9	WF	N/A		4/19/2024	-	-	-	Removed from Service
1008-2	Room 9	SK	N/A		4/19/2024	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1009-1	Nurse's Office	SK	App	<1.0	4/19/2024	-	-	-	-
1009-2	Nurse's Office	SPY	App	<1.0	4/19/2024	-	-	-	-
1009-3	Nurse's Office Eyewash	OS	N/A		4/19/2024	-	-	-	-
1010-1	Room 11	SK	N/A		4/19/2024	-	-	-	Sign
1011-1	Faculty Room	SK	App	2.0	4/19/2024	-	-	-	-
1012-1	Custodian Office	SS	N/A		4/19/2024	-	-	-	Sign
1013-1	Hallway by Women's Staff Bathroom	BF	App	<1.0	4/19/2024	-	-	-	-
1013-2	Hallway by Women's Staff Bathroom	WF	App	<1.0	4/19/2024	-	-	-	-
1014-1	Women's Bathroom by Room 12 @A	SK	N/A		4/19/2024	-	-	-	Sign
1014-2	Women's Bathroom by Room 12 @B	SK	N/A		4/19/2024	-	-	-	Sign
1015-1	All Gender Bathroom by Room 12	SK	N/A		4/19/2024	-	-	-	Sign
1016-1	Room 12 Handwash	SK	N/A		4/19/2024	-	-	-	Sign
1016-2	Room 12 Counter @A	SK	N/A		4/19/2024	-	-	-	Sign
1016-3	Room 12 Counter @B	SK	N/A		4/19/2024	-	-	-	Sign
1017-1	Room 13 Lobby Handwash	SK	N/A		4/19/2024	-	-	-	Sign
1017-2	Room 13 Workshop	SK	N/A		4/19/2024	-	-	-	Sign
1017-3	Room 13 Workshop	SPY	N/A		4/19/2024	-	-	-	Sign
1017-4	Room 13 Workshop Conference Room	SK	N/A		4/19/2024	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1018-1	Room 14 Counter @A	SK	App	<1.0	4/19/2024	-	-	-	-
1018-2	Room 14 Counter @B	SK	App	<1.0	4/19/2024	-	-	-	-
1018-3	Room 14 Counter @C	SK	App	<1.0	4/19/2024	-	-	-	-
1018-4	Room 14 Counter @D	SK	App	<1.0	4/19/2024	-	-	-	-
1019-1	Room 15 Lobby	SK	N/A		4/19/2024	-	-	-	Sign
1019-2	Room 15 Kitchen Handwash @A	SK	App	<1.0	4/19/2024	-	-	-	-
1019-3	Room 15 Sanitizer	SK	App	<1.0	4/19/2024	-	-	-	-
1019-4	Room 15 Sanitizer	SPY	App	<1.0	4/19/2024	-	-	-	-
1019-5	Room 15 Kitchen Prep	SK	App	<1.0	4/19/2024	-	-	-	-
1019-6	Room 15 Kitchen Handwash @B	SK	App	<1.0	4/19/2024	-	-	-	-
1020-1	Room 16	SK	App	<1.0	4/19/2024	-	-	-	-
1021-1	Boy's Bathroom by Room 17	SK	N/A		4/19/2024	-	-	-	Sign
1022-1	Room 17D Closet Unit @A	SS	N/A		4/19/2024	-	-	-	Sign
1022-2	Room 17D Closet Unit @B	SS	N/A		4/19/2024	-	-	-	Sign
1023-1	Room 19 Bathroom	SK	N/A		4/19/2024	-	-	-	Sign
1024-1	Hallway by Room 18	BF	App	<1.0	4/19/2024	-	-	-	-
1024-2	Hallway by Room 18	WF	App	<1.0	4/19/2024	-	-	-	-
1025-1	Room 18 Bathroom	SK	N/A		4/19/2024	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1026-1	Custodian Closet by Room 18	SS	N/A		4/19/2024	-	-	-	Sign
1027-1	Room 8 (right)	SK	App	2.0	4/19/2024	-	-	-	-
1027-2	Room 8 (left)	SK	App	<1.0	4/19/2024	-	-	-	-

Laboratory Report

NYE Report #: 2402534-29377

April 22, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Brookhaven Learning Center East

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on April 19, 2024. New York Environmental analyzed the samples on April 22, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	19 Apr 2024
Date Received:	19 Apr 2024
Date Analyzed:	22 Apr 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240419P009	1	Room 4 - Rear-SK, Initial	0.001	0.002	mg/L	
240419P010	2	Room 6 Handwash-SK, Initial	0.001	0.011	mg/L	H
240419P011	3	Room 8 (right)-SK, Initial	0.001	0.002	mg/L	
240419P012	4	Room 8 (left)-SK, Initial	0.001	<0.001	mg/L	
240419P013	5	Nurse's Office-SK, Initial	0.001	<0.001	mg/L	
240419P014	6	Nurse's Office-SPY, Initial	0.001	<0.001	mg/L	
240419P015	7	Faculty Room-SK, Initial	0.001	0.002	mg/L	
240419P016	8	Hallway by Women's Staff Bathroom-BF, Initial	0.001	<0.001	mg/L	
240419P017	9	Hallway by Women's Staff Bathroom-WF, Initial	0.001	<0.001	mg/L	
240419P018	10	Room 15 Kitchen Handwash @A-SK, Initial	0.001	0.004	mg/L	
240419P019	11	Room 15 Sanitizer-SK, Initial	0.001	<0.001	mg/L	
240419P020	12	Room 15 Kitchen Handwash @B-SK, Initial	0.001	<0.001	mg/L	
240419P021	13	Room 15 Sanitizer-SPY, Initial	0.001	<0.001	mg/L	
240419P022	14	Room 15 Kitchen Prep-SK, Initial	0.001	<0.001	mg/L	
240419P023	15	Room 16-SK, Initial	0.001	<0.001	mg/L	
240419P024	16	Room 14 Counter @A-SK, Initial	0.001	<0.001	mg/L	
240419P025	17	Room 14 Counter @B-SK, Initial	0.001	<0.001	mg/L	
240419P026	18	Room 14 Counter @C-SK, Initial	0.001	<0.001	mg/L	
240419P027	19	Room 14 Counter @D-SK, Initial	0.001	0.001	mg/L	
240419P028	20	Hallway by Room 18-BF, Initial	0.001	<0.001	mg/L	
240419P029	21	Hallway by Room 18-WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



Appendix E
Brookhaven Learning Center-West

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Room 21	SK	N/A		4/18/2024	-	-	-	Sign
1002-1	Room 22	SK	N/A		4/18/2024	-	-	-	Sign
1003-1	Room 24	SK	N/A		4/18/2024	-	-	-	Sign
1004-1	Room 23	SK	N/A		4/18/2024	-	-	-	Sign
1005-1	Room 25	SK	N/A		4/18/2024	-	-	-	Sign
1006-1	Room 26 by Stove	SK	App		4/18/2024	-	-	-	Removed from Service
1006-2	Room 26 by Stove	SPY	App		4/18/2024	-	-	-	Removed from Service
1006-3	Room 26	SK	N/A		4/18/2024	-	-	-	Sign
1007-1	Hallway by Utility Room	WF	App	<1.0	4/18/2024	-	-	-	-
1007-2	Hallway by Utility Room	BF	App	<1.0	4/18/2024	-	-	-	-
1008-1	Changing Room Girl's @A	SK	N/A		4/18/2024	-	-	-	Sign
1008-2	Changing Room Girl's @B	SK	N/A		4/18/2024	-	-	-	Sign
1009-1	Utility Room by Main Office	SS	N/A		4/18/2024	-	-	-	Sign
1010-1	Men's Bathroom by Main Office	SK	N/A		4/18/2024	-	-	-	Sign
1011-1	Women's Bathroom by Main Entrance @A	SK	N/A		4/18/2024	-	-	-	Sign
1011-2	Women's Bathroom by Main Entrance @B	SK	N/A		4/18/2024	-	-	-	Sign
1012-1	Kitchen 2 Piece Food Prep	SK	App	<1.0	4/18/2024	-	-	-	-
1012-2	Kitchen 3 Piece-Left	SK	N/A		4/18/2024	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1012-3	Kitchen 3 Piece-Right	SK	N/A		4/18/2024	-	-	-	Sign
1013-1	Serving Line Handwash	SK	App	4.0	4/18/2024	-	-	-	-
1014-1	Unisex Bathroom by Assistant Principle's Off	SK	N/A		4/18/2024	-	-	-	Sign
1015-1	Nurse's Office	SK	App	<1.0	4/18/2024	-	-	-	-
1015-2	Nurse's Office	SPY	App	4.0	4/18/2024	-	-	-	-
1015-3	Nurse's Office Bathroom	SK	N/A		4/18/2024	-	-	-	Sign
1016-1	Changing Room Boy's @A	SK	N/A		4/18/2024	-	-	-	Sign
1016-2	Changing Room Boy's @B	SK	N/A		4/18/2024	-	-	-	Sign
1017-1	Hallway by Electric Room	WF	App	<1.0	4/18/2024	-	-	-	-
1017-2	Hallway by Electric Room	BF	App	<1.0	4/18/2024	-	-	-	-
1018-1	Room 28	SK	N/A		4/18/2024	-	-	-	Sign
1019-1	Room 30	SK	N/A		4/18/2024	-	-	-	Sign
1020-1	Room 29	SK	N/A		4/18/2024	-	-	-	Sign
1021-1	Room 32	SK	N/A		4/18/2024	-	-	-	Sign
1022-1	Room 31	SK	N/A		4/18/2024	-	-	-	Sign
1023-1	Room 33	SK	N/A		4/18/2024	-	-	-	Sign
1024-1	Weight Room	SK	N/A		4/18/2024	-	-	-	Sign

Laboratory Report

NYE Report #: 2402599-29411

April 23, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: ES BOCES; Brookhaven Learning Center West

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on April 22, 2024. New York Environmental analyzed the samples on April 23, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	18 Apr 2024
Date Received:	22 Apr 2024
Date Analyzed:	23 Apr 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240422Q086	1	Hallway by Utility Room-WF, Initial	0.001	<0.001	mg/L	
240422Q087	2	Hallway by Utility Room-BF, Initial	0.001	<0.001	mg/L	
240422Q088	3	Kitchen 2 Piece Food Prep-SK, Initial	0.001	<0.001	mg/L	
240422Q089	4	Serving Line Handwash-SK, Initial	0.001	0.004	mg/L	
240422Q090	5	Nurse's Office-SK, Initial	0.001	<0.001	mg/L	
240422Q091	6	Nurse's Office-SPY, Initial	0.001	0.004	mg/L	
240422Q092	7	Hallway by Electric Room-WF, Initial	0.001	<0.001	mg/L	
240422Q093	8	Hallway by Electric Room-BF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix F
Edward Milliken Technical Center

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Custodial Office Kitchenette	SK	App	<1.0	2/4/2025	-	-	-	-
1001-2	Custodial Office Men's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1001-3	Custodial Office Women's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1001-4	Custodial Office	SS	N/A		2/4/2025	-	-	-	Sign
1002-1	Room 101 Kitchenette	SK	App	2.0	2/4/2025	-	-	-	-
1002-2	Room 101	SK	N/A		2/4/2025	-	-	-	Sign
1002-3	Room 101 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1003-1	ADA Bathroom by Main Office	SK	N/A		2/4/2025	-	-	-	Sign
1004-1	Women's Bathroom by Main Office	SK	N/A		2/4/2025	-	-	-	Sign
1005-1	Main Office Kitchenette	SK	App	<1.0	2/4/2025	-	-	-	-
1006-1	Guidance Men's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1006-2	Guidance Women's Bathroom @ A	SK	N/A		2/4/2025	-	-	-	Sign
1006-3	Guidance Women's Bathroom @ B	SK	N/A		2/4/2025	-	-	-	Sign
1007-1	Nurse's Office	SK	App	5.0	2/4/2025	-	-	-	-
1007-2	Nurse's Office	SPY	App	<1.0	2/4/2025	-	-	-	-
1007-3	Nurse's Office	BF	App	88.0	2/4/2025				Removed from Service; Pending Remediation
1007-4	Nurse's Office Bathroom	SK	App	9.0	2/4/2025				Removed from Service; Pending Remediation
1008-1	"A" Hallway	BF	App	<1.0	2/4/2025	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1008-2	"A" Hallway	WF	App	<1.0	2/4/2025	-	-	-	-
1009-1	Men's Bathroom by Nurse's Office @ A	SK	N/A		2/4/2025	-	-	-	Sign
1009-2	Men's Bathroom by Nurse's Office @ B	SK	N/A		2/4/2025	-	-	-	Sign
1010-1	Women's Bathroom by Nurse's Office @ A	SK	N/A		2/4/2025	-	-	-	Sign
1010-2	Women's Bathroom by Nurse's Office @ B	SK	N/A		2/4/2025	-	-	-	Sign
1011-1	Room 112	SK	App	23.0	2/4/2025				Removed from Service; Pending Remediation
1011-2	Room 112 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1012-1	Room 116 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1012-2	Room 116	SS	N/A		2/4/2025	-	-	-	Sign
1013-1	Room 129	SK	N/A		2/4/2025	-	-	-	Sign
1013-2	Room 129 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1013-3	Room 129 Station 1	SPY	N/A		2/4/2025	-	-	-	Sign
1013-4	Room 129 Station 2	SPY	N/A		2/4/2025	-	-	-	Sign
1013-5	Room 129 Station 3	SPY	N/A		2/4/2025	-	-	-	Sign
1013-6	Room 129 Station 4	SPY	N/A		2/4/2025	-	-	-	Sign
1013-7	Room 129 Station 5	SPY	N/A		2/4/2025	-	-	-	Sign
1013-8	Room 129 Station 6	SPY	N/A		2/4/2025	-	-	-	Sign
1014-1	Room 118 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1015-1	Room 122 Kitchen Prep by Storage	SK	App	4.0	2/4/2025	-	-	-	-
1015-2	Room 122 Kitchen Prep by Stove/Cleveland	SK	App	1.0	2/4/2025	-	-	-	-
1015-3	Room 122 Kitchen Prep #3	SK	N/A		2/4/2025	-	-	-	Removed from Service
1015-4	Room 122 Kitchen Potfiller	PF	App	11.0	2/4/2025				Removed from Service; Pending Remediation
1015-5	Room 122 Kitchen 2-Bay - Left	SK	App	3.0	2/4/2025	-	-	-	-
1015-6	Room 122 Kitchen 2-Bay - right	SK	App	<1.0	2/4/2025	-	-	-	-
1015-7	Room 122 Kitchen 3-Bay Dishwash left	SK	N/A		2/4/2025	-	-	-	Sign
1015-8	Room 122 Kitchen 3-Bay Dishwash right	SK	N/A		2/4/2025	-	-	-	Sign
1015-9	Room 122 Kitchen Dishwash	SPY	N/A		2/4/2025	-	-	-	Sign
1015-10	Room 122 Kitchen Coffee @ A	CF	N/A		2/4/2025	-	-	-	Filtered Water ; Stainless Steel Appliance
1015-11	Room 122 Kitchen Coffee @ B	CF	N/A		2/4/2025	-	-	-	Filtered Water ; Stainless Steel Appliance
1015-12	Room 122 Kitchen Handwash by window	SK	N/A		2/4/2025	-	-	-	Sign
1015-13	Room 122 Kitchen 3-Bay Dishwash left	SK	N/A		2/4/2025	-	-	-	Sign
1015-14	Room 122 Kitchen Grindmaster	CF	N/A		2/4/2025	-	-	-	Removed from Service
1015-15	Room 122 Kitchen Island	SK	N/A		2/4/2025	-	-	-	Removed from Service
1015-16	Room 122 Kitchen Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1015-17	Room 122 Kitchen	SS	N/A		2/4/2025	-	-	-	Sign
1015-18	Room 122 Kitchen	IM	App	<1.0	2/4/2025	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1016-1	Room 133	SK	N/A		2/4/2025	-	-	-	Sign
1016-2	Room 133 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1016-3	Room 133 Station 1	SPY	N/A		2/4/2025	-	-	-	Sign
1016-4	Room 133 Station 2	SPY	N/A		2/4/2025	-	-	-	Sign
1016-5	Room 133 Station 3	SPY	N/A		2/4/2025	-	-	-	Sign
1016-6	Room 133 Station 4	SPY	N/A		2/4/2025	-	-	-	Sign
1016-7	Room 133 Station 5	SPY	N/A		2/4/2025	-	-	-	Sign
1016-8	Room 133 Station 6	SPY	N/A		2/4/2025	-	-	-	Sign
1017-1	"A" Hallway	SS	N/A		2/4/2025	-	-	-	Sign
1018-1	Room 126	SK	N/A		2/4/2025	-	-	-	Sign
1018-2	Room 126 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1018-3	Room 126 Bathroom by Door	SK	N/A		2/4/2025	-	-	-	Sign
1018-4	Room 126	WF	App		2/4/2025	-	-	-	Removed from Service
1019-1	Room 135	SK	N/A		2/4/2025	-	-	-	Sign
1019-2	Room 135 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1019-3	Room 135 Station 1	SPY	N/A		2/4/2025	-	-	-	Sign
1019-4	Room 135 Station 2	SPY	N/A		2/4/2025	-	-	-	Sign
1019-5	Room 135 Station 3	SPY	N/A		2/4/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1019-6	Room 135 Station 4	SPY	N/A		2/4/2025	-	-	-	Sign
1019-7	Room 135 Station 5	SPY	N/A		2/4/2025	-	-	-	Sign
1020-1	Bathroom by Room 135	SK	N/A		2/4/2025	-	-	-	Sign
1021-1	Room 128 Kitchen	BF	App	<1.0	2/4/2025	-	-	-	-
1021-2	Room 128 Kitchen	WF	App	<1.0	2/4/2025	-	-	-	-
1021-3	Room 128 Kitchen Handsink	SK	N/A		2/4/2025	-	-	-	Sign
1021-4	Room 128 Kitchen Steamer	OS	App	69.0	2/4/2025				Removed from Service; Pending Remediation
1021-5	Room 128 Kitchen Dishwasher Station	SPY	N/A		2/4/2025	-	-	-	Sign
1021-6	Room 128 Kitchen Dishwasher Station	SK	N/A		2/4/2025	-	-	-	Sign
1021-7	Room 128 Kitchen Dishwash single- far left	SK	N/A		2/4/2025	-	-	-	Sign
1021-8	Room 128 Kitchen 2-Bay Dishwash right	SK	N/A		2/4/2025	-	-	-	Sign
1021-9	Room 128 Kitchen	IM	App	<1.0	2/4/2025	-	-	-	-
1021-10	Room 128 Kitchen Island Handwash @ A	SK	N/A		2/4/2025	-	-	-	Sign
1021-11	Room 128 Kitchen Island Prep @ A	SK	App	4.0	2/4/2025	-	-	-	-
1021-12	Room 128 Kitchen Island Prep @ B	SK	App	4.0	2/4/2025	-	-	-	-
1021-13	Room 128 Kitchen Island Handwash @ B	SK	N/A		2/4/2025	-	-	-	Sign
1021-14	Room 128 Kitchen Island Prep @ C	SK	App	3.0	2/4/2025	-	-	-	-
1021-15	Room 128 Kitchen Island Prep @ D	SK	App	3.0	2/4/2025	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1021-16	Room 128 Kitchen Island Prep @ E	SK	App	4.0	2/4/2025	-	-	-	-
1021-17	Room 128 Kitchen Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1021-18	Room 128 Kitchen	SS	N/A		2/4/2025	-	-	-	Sign
1022-1	Room 137 Stock Room	SK	N/A		2/4/2025	-	-	-	Sign
1022-2	Room 137 / Room 139	WF	App		2/4/2025	-	-	-	Removed from Service
1022-3	Room 137 / Room 139 Women's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1022-4	Room 137 / Room 139 Men's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1023-1	Room 203 Counter @ A	SK	N/A		2/4/2025	-	-	-	Sign
1023-2	Room 203 Counter @ A Eyewash	SPY	N/A		2/4/2025	-	-	-	Sign
1023-3	Room 203 Counter @ B	SK	N/A		2/4/2025	-	-	-	Sign
1023-4	Room 203 Counter @ C	SK	N/A		2/4/2025	-	-	-	Sign
1023-5	Room 203 Counter @ D	SK	N/A		2/4/2025	-	-	-	Sign
1023-6	Room 203 Women's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1023-7	Room 203 Men's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1024-1	Room 202	SK	N/A		2/4/2025	-	-	-	Sign
1024-2	Room 202 Women's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1024-3	Room 202 Men's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1025-1	Room 204 Eyewash	EW	N/A		2/4/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1025-2	Room 204	WF	App		2/4/2025	-	-	-	Removed from Service
1025-3	Room 204 Women's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1025-4	Room 204 Men's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1026-1	Room 205 Women's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1026-2	Room 205 Men's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1027-1	"B" Hallway	BF	App	<1.0	2/4/2025	-	-	-	-
1027-2	"B" Hallway	WF	App	<1.0	2/4/2025	-	-	-	-
1028-1	"B" Hallway Women's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1029-1	"B" Hallway Custodial Closet	SS	N/A		2/4/2025	-	-	-	Sign
1030-1	"B" Hallway ADA Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1031-1	Room 208	WF	App		2/4/2025	-	-	-	Removed from Service
1031-2	Room 208 Women's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1031-3	Room 208 Men's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1032-1	Room 207	SK	N/A		2/4/2025	-	-	-	Sign
1032-2	Room 207 Women's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1032-3	Room 207 Men's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1033-1	Room 217	SS	N/A		2/4/2025	-	-	-	Sign
1033-2	Room 217 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1033-3	Room 217	WF	App		2/4/2025	-	-	-	Removed from Service
1034-1	Room 210 Counter @ A	SK	N/A		2/4/2025	-	-	-	Sign
1034-2	Room 210 Counter @ B	SK	N/A		2/4/2025	-	-	-	Sign
1034-3	Room 210 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1034-4	Room 210	SS	N/A		2/4/2025	-	-	-	Sign
1035-1	Room 212 Counter @ A	SK	N/A		2/4/2025	-	-	-	Sign
1035-2	Room 212 Counter @ B	SK	N/A		2/4/2025	-	-	-	Sign
1035-3	Room 212 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1035-4	Room 212	SS	N/A		2/4/2025	-	-	-	Sign
1036-1	Room 219 Counter @ A	SK	N/A		2/4/2025	-	-	-	Sign
1036-2	Room 219 Counter @ B	SK	N/A		2/4/2025	-	-	-	Sign
1036-3	Room 219	WF	App		2/4/2025	-	-	-	Removed from Service
1036-4	Room 219	SS	N/A		2/4/2025	-	-	-	Sign
1036-5	Room 219 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1037-1	Room 303 Eyewash	EW	N/A		2/4/2025	-	-	-	Sign
1037-2	Room 303 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1037-3	Room 303	SS	N/A		2/4/2025	-	-	-	Sign
1038-1	Room 305 Unit @ A	SS	N/A		2/4/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1038-2	Room 305 Unit @ B	SS	N/A		2/4/2025	-	-	-	Sign
1038-3	Room 305 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1038-4	Room 305	SS	N/A		2/4/2025	-	-	-	Sign
1039-1	Room 306 Eyewash	EW	N/A		2/4/2025	-	-	-	-
1039-2	Room 306	WF	App		2/4/2025	-	-	-	Removed from Service
1039-3	Room 306 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1039-4	Room 306	SS	N/A		2/4/2025	-	-	-	Sign
1040-1	"C" Hallway	BF	App	<1.0	2/4/2025	-	-	-	-
1040-2	"C" Hallway	WF	App	<1.0	2/4/2025	-	-	-	-
1041-1	Room 309 Unit @ A	SS	N/A		2/4/2025	-	-	-	Sign
1041-2	Room 309 Unit @ B	SS	N/A		2/4/2025	-	-	-	Sign
1041-3	Room 309 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1042-1	Room 308 Eyewash	EW	N/A		2/4/2025	-	-	-	-
1042-2	Room 308	WF	App		2/4/2025	-	-	-	Removed from Service
1042-3	Room 308 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1042-4	Room 308	SS	N/A		2/4/2025	-	-	-	Sign
1043-1	"C" Hallway ADA Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1044-1	"C" Hallway Custodial Closet	SS	N/A		2/4/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1045-1	"C" Hallway Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1046-1	Room 311 Eyewash	EW	N/A		2/4/2025	-	-	-	-
1046-2	Room 311	WF	App		2/4/2025	-	-	-	Removed from Service
1046-3	Room 311 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1047-1	Room 316 Bradley	SK	N/A		2/4/2025	-	-	-	Sign
1047-2	Room 316	WF	App		2/4/2025	-	-	-	Removed from Service
1047-3	Room 316 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1048-1	Room 403	SK	N/A		2/4/2025	-	-	-	Sign
1048-2	Room 403 Eyewash	EW	N/A		2/4/2025	-	-	-	Sign
1048-3	Room 403	WF	App		2/4/2025	-	-	-	Removed from Service
1048-4	Room 403 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1048-5	Room 403	SS	N/A		2/4/2025	-	-	-	Sign
1049-1	Room 402	SS	N/A		2/4/2025	-	-	-	Sign
1049-2	Room 402	WF	App		2/4/2025	-	-	-	Removed from Service
1049-3	Room 402 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1049-4	Room 402	SS	N/A		2/4/2025	-	-	-	Sign
1050-1	Room 405A	SK	N/A		2/4/2025	-	-	-	Sign
1050-2	Room 405A Station 1	SPY	N/A		2/4/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1050-3	Room 405A Station 2	SPY	N/A		2/4/2025	-	-	-	Sign
1050-4	Room 405A Station 3	SPY	N/A		2/4/2025	-	-	-	Sign
1050-5	Room 405A Station 4	SPY	N/A		2/4/2025	-	-	-	Sign
1051-1	Room 405B Eyewash	EW	N/A		2/4/2025	-	-	-	Sign
1051-2	Room 405B	WF	App		2/4/2025	-	-	-	Removed from Service
1051-3	Room 405B Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1051-4	Room 405B	SS	N/A		2/4/2025	-	-	-	Sign
1052-1	"D" Hallway ADA Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1053-1	"D" Hallway Women's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1054-1	"D" Hallway Custodial Closet	SS	N/A		2/4/2025	-	-	-	Sign
1055-1	Room 404 Unit @ A	SS	N/A		2/4/2025	-	-	-	Sign
1055-2	Room 404 Unit @ B	SS	N/A		2/4/2025	-	-	-	Sign
1055-3	Room 404	BF	App	<1.0	2/4/2025	-	-	-	-
1055-4	Room 404	WF	App	<1.0	2/4/2025	-	-	-	-
1055-5	Room 404 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1056-1	"D" Hallway	WF	App	<1.0	2/4/2025	-	-	-	-
1056-2	"D" Hallway	BF	App	<1.0	2/4/2025	-	-	-	-
1057-1	Room 413 Eyewash	EW	N/A		2/4/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1057-2	Room 413 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1057-3	Room 413	SS	N/A		2/4/2025	-	-	-	Sign
1058-1	Room 406 Eyewash	EW	N/A		2/4/2025	-	-	-	Sign
1058-2	Room 406 Women's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1058-3	Room 406 Men's Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1059-1	Room 415 Bathroom	SK	N/A		2/4/2025	-	-	-	Sign
1059-2	Room 415 Fridge	SP	App	<1.0	2/4/2025	-	-	-	-

Laboratory Report

NYE Report #: 2500484-32294

February 7, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: ES BOCES; Edward Miliken Technical Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on February 05, 2025. New York Environmental analyzed the samples on February 06, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	04 Feb 2025
Date Received:	05 Feb 2025
Date Analyzed:	06 Feb 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250205R032	1	Custodial Office Kitchenette-SK, Initial	0.001	<0.001	mg/L	
250205R033	2	Room 101 Kitchenette-SK, Initial	0.001	0.002	mg/L	
250205R034	3	Main Office Kitchenette-SK, Initial	0.001	<0.001	mg/L	
250205R035	4	Nurse's Office-SK, Initial	0.001	0.005	mg/L	
250205R036	5	Nurse's Office-SPY, Initial	0.001	<0.001	mg/L	
250205R037	6	Nurse's Office-BF, Initial	0.001	0.088	mg/L	E,H
250205R038	7	Nurse's Office Bathroom-SK, Initial	0.001	0.009	mg/L	H
250205R039	8	"A" Hallway -BF, Initial	0.001	<0.001	mg/L	
250205R040	9	"A" Hallway -WF, Initial	0.001	<0.001	mg/L	
250205R041	10	Room 112-SK, Initial	0.001	0.023	mg/L	H
250205R042	11	Room 122 Kitchen Prep by Storage-SK, Initial	0.001	0.004	mg/L	
250205R043	12	Room 122 Kitchen Prep by Stove/Cleveland-SK, Initial	0.001	0.001	mg/L	
250205R044	13	Room 122 Kitchen 2-Bay - Left-SK, Initial	0.001	0.003	mg/L	
250205R045	14	Room 122 Kitchen 2-Bay - right-SK, Initial	0.001	<0.001	mg/L	
250205R046	15	Room 122 Kitchen Potfiller-PF, Initial	0.001	0.011	mg/L	H
250205R047	16	Room 122 Kitchen-IM, Initial	0.001	<0.001	mg/L	
250205R048	17	Room 128 Kitchen-BF, Initial	0.001	<0.001	mg/L	
250205R049	18	Room 128 Kitchen-WF, Initial	0.001	<0.001	mg/L	
250205R050	19	Room 128 Kitchen Steamer-OS, Initial	0.001	0.069	mg/L	E,H
250205R051	20	Room 128 Kitchen-IM, Initial	0.001	<0.001	mg/L	
250205R052	21	Room 128 Kitchen Island Prep @ A-SK, Initial	0.001	0.004	mg/L	
250205R053	22	Room 128 Kitchen Island Prep @ B-SK, Initial	0.001	0.004	mg/L	
250205R054	23	Room 128 Kitchen Island Prep @ C-SK, Initial	0.001	0.003	mg/L	
250205R055	24	Room 128 Kitchen Island Prep @ D-SK, Initial	0.001	0.003	mg/L	
250205R056	25	Room 128 Kitchen Island Prep @ E-SK, Initial	0.001	0.004	mg/L	
250205R057	26	"B" Hallway-BF, Initial	0.001	<0.001	mg/L	



Date Collected:	04 Feb 2025
Date Received:	05 Feb 2025
Date Analyzed:	06 Feb 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
250205R058	27	"B" Hallway-WF, Initial	0.001	<0.001	mg/L	
250205R059	28	"C" Hallway-BF, Initial	0.001	<0.001	mg/L	
250205R060	29	"C" Hallway-WF, Initial	0.001	<0.001	mg/L	
250205R061	30	Room 404-BF, Initial	0.001	<0.001	mg/L	
250205R062	31	Room 404-WF, Initial	0.001	<0.001	mg/L	
250205R063	32	"D" Hallway-WF, Initial	0.001	<0.001	mg/L	
250205R064	33	"D" Hallway-BF, Initial	0.001	<0.001	mg/L	
250205R065	34	Room 415 Fridge-SP, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Appendix G
HB Ward Technical Center

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Building 1 - Lobby	BF	App	<1.0	2/13/2025	-	-	-	-
1001-2	Building 1 - Lobby	WF	App	<1.0	2/13/2025	-	-	-	-
1002-1	Building 1 - Room 116	SK	N/A		2/13/2025	-	-	-	Sign
1002-2	Building 1 - Room 116 Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
1002-3	Building 1 - Room 116 Kitchen	SK	N/A		2/13/2025	-	-	-	Sign
1002-4	Building 1 - Room 116 Kitchen	SPY	N/A		2/13/2025	-	-	-	Sign
1003-1	Building 1 - Mens Bathroom 105 @ A	SK	N/A		2/13/2025	-	-	-	Sign
1003-2	Building 1 - Mens Bathroom 105 @ B	SK	N/A		2/13/2025	-	-	-	Sign
1003-3	Building 1 - Mens Bathroom 105 @ C	SK	N/A		2/13/2025	-	-	-	Sign
1004-1	Building 1 - Room 107	SK	N/A		2/13/2025	-	-	-	Sign
1004-2	Building 1 - Room 107 Mens Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
1004-3	Building 1 - Room 107 Womens Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
1005-1	Building 1 - Custodial Closet 109	SS	N/A		2/13/2025	-	-	-	Sign
1006-1	Building 1 - Womens Bathroom 111 @ A	SK	N/A		2/13/2025	-	-	-	Sign
1006-2	Building 1 - Womens Bathroom 111 @B	SK	N/A		2/13/2025	-	-	-	Sign
1006-3	Building 1 - Womens Bathroom 111 @C	SK	N/A		2/13/2025	-	-	-	Sign
1006-4	Building 1 - Womens Bathroom 111 @D	SK	N/A		2/13/2025	-	-	-	Sign
1007-1	Building 1 - Room 118 Station 1	0	N/A		2/13/2025	-	-	-	Sign
1007-2	Building 1 - Room 118 Station 2	SK	N/A		2/13/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1007-3	Building 1 - Room 118 Station 3	SK	N/A		2/13/2025	-	-	-	Sign
1007-4	Building 1 - Room 118 Station 4	SK	N/A		2/13/2025	-	-	-	Sign
1007-5	Building 1 - Room 118	SK	N/A		2/13/2025	-	-	-	Sign
1008-1	Building 1 - Room 113	SK	N/A		2/13/2025	-	-	-	Sign
1008-2	Building 1 - Room 113 Station 1	SK	N/A		2/13/2025	-	-	-	Sign
1008-3	Building 1 - Room 113 Station 2	SK	N/A		2/13/2025	-	-	-	Sign
1008-4	Building 1 - Room 113 Station 3	SK	N/A		2/13/2025	-	-	-	Sign
1008-5	Building 1 - Room 113 Station 4	SK	N/A		2/13/2025	-	-	-	Sign
1008-6	Building 1 - Room 113 Station 5	SK	N/A		2/13/2025	-	-	-	Sign
1009-1	Building 1 - Room 115	SK	N/A		2/13/2025	-	-	-	Sign
1009-2	Building 1 - Room 115 Station 1	SK	N/A		2/13/2025	-	-	-	Sign
1009-3	Building 1 - Room 115 Station 2	SK	N/A		2/13/2025	-	-	-	Sign
1009-4	Building 1 - Room 115 Station 3	SK	N/A		2/13/2025	-	-	-	Sign
1009-5	Building 1 - Room 115 Station 4	SK	N/A		2/13/2025	-	-	-	Sign
1009-6	Building 1 - Room 115 Station 5	SK	N/A		2/13/2025	-	-	-	Sign
1009-7	Building 1 - Room 115 Station 6	SK	N/A		2/13/2025	-	-	-	Sign
1010-1	Building 1 - Room 117	SK	N/A		2/13/2025	-	-	-	Removed from Service
1010-2	Building 1 - Room 117	SPY	N/A		2/13/2025	-	-	-	Removed from Service
1010-3	Building 1 - Room 117	SP	N/A		2/13/2025	-	-	-	Removed from Service

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1011-1	Building 1 - Nurse's Office Bathroom	SK	App	4.0	2/13/2025	-	-	-	-
1012-1	Building 1 - Custodial Closet 124	SS	N/A		2/13/2025	-	-	-	Sign
1013-1	Building 1 - Room 128	SS	N/A		2/13/2025	-	-	-	Sign
1014-1	Building 1 - Girls Bathroom 130 @ A	SK	N/A		2/13/2025	-	-	-	Sign
1014-2	Building 1 - Girls Bathroom 130 @ B	SK	N/A		2/13/2025	-	-	-	Sign
1015-1	Building 1 - Hall between 130 / 132	BF	App	<1.0	2/13/2025	-	-	-	-
1015-2	Building 1 - Hall between 130 / 132	WF	App	<1.0	2/13/2025	-	-	-	-
1016-1	Building 1 - Boys Bathroom 132	SK	N/A		2/13/2025	-	-	-	Sign
1017-1	Building 1 - Room 134 @ A	SK	N/A		2/13/2025	-	-	-	Sign
1017-2	Building 1 - Room 134 @ B	SK	N/A		2/13/2025	-	-	-	Sign
1018-1	Building 1 - Room 136 @ A	SK	N/A		2/13/2025	-	-	-	Sign
1018-2	Building 1 - Room 136 @ B	SK	N/A		2/13/2025	-	-	-	Sign
1019-1	Building 1 - Room 138 Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
2001-1	Building 2 - Room 211 Womens Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
2001-2	Building 2 - Room 211 Mens Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
2002-1	Building 2 - Bathroom 213 @ A	SK	N/A		2/13/2025	-	-	-	Sign
2002-2	Building 2 - Bathroom 213 @ B	SK	N/A		2/13/2025	-	-	-	Sign
2003-1	Building 2 - Hall by Bathroom 213	BF	App	<1.0	2/13/2025	-	-	-	-
2003-2	Building 2 - Hall by Bathroom 213	WF	App	<1.0	2/13/2025	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2004-1	Building 2 - Custodial Closet 215	SS	N/A		2/13/2025	-	-	-	Sign
2005-1	Building 2 - Mens Bathroom 217	SK	N/A		2/13/2025	-	-	-	Sign
2006-1	Building 2 - Womens Bathroom by Room 219	SK	N/A		2/13/2025	-	-	-	Sign
2007-1	Building 2 - Room 223 Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
2008-1	Building 2 - Culinary Lobby	BF	App	<1.0	2/13/2025	-	-	-	-
2008-2	Building 2 - Culinary Lobby	WF	App	<1.0	2/13/2025	-	-	-	-
2009-1	Building 2 - Womens Bathroom at Culinary Lobby	SK	N/A		2/13/2025	-	-	-	Sign
2010-1	Building 2 - Mens Bathroom at Cilinary Lobby	SK	N/A		2/13/2025	-	-	-	-
2011-1	Building 2 - Room 202	SK	App	8.0	2/13/2025	-	-	-	Removed from Service; Pending Remediation
2011-2	Building 2 - Room 202 Handwash	SK	App	<1.0	2/13/2025	-	-	-	-
2011-3	Building 2 - Room 202 Coffee Maker	CF	App	1.0	2/13/2025	-	-	-	-
2012-1	Building 2 - Room 207	IM	App	<1.0	2/13/2025	-	-	-	-
2012-2	Building 2 - Room 207 Dishwash	SPY	N/A		2/13/2025	-	-	-	Sign
2012-3	Building 2 - Room 207 Handwash @ A	SK	N/A		2/13/2025	-	-	-	Sign
2012-4	Building 2 - Room 207 3-Bay	SPY	N/A		2/13/2025	-	-	-	Sign
2012-5	Building 2 - Room 207 Custodial Closet	SS	N/A		2/13/2025	-	-	-	Sign
2012-6	Building 2 - Room 207 Handwash @ B	SK	N/A		2/13/2025	-	-	-	Sign
2012-7	Building 2 - Room 207 3-Bay @ A	SK	N/A		2/13/2025	-	-	-	Sign
2012-8	Building 2 - Room 207 3-Bay @ B	SPY	N/A		2/13/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2012-9	Building 2 - Room 207 2-Bay Knife Sink	SPY	N/A		2/13/2025	-	-	-	Sign
2012-10	Building 2 - Room 207 Handwash @ C	SPY	N/A		2/13/2025	-	-	-	Sign
2012-11	Building 2 - Room 207 Handwash @ D	SK	N/A		2/13/2025	-	-	-	Sign
2012-12	Building 2 - Room 207 Island	SK	App	<1.0	2/13/2025	-	-	-	-
2012-13	Building 2 - Room 207 by Baker's Pride	SK	App	3.0	2/13/2025	-	-	-	-
2012-14	Building 2 - Room 207 Potfiller	PF	N/A		2/13/2025	-	-	-	Sign
2012-15	Building 2 - Room 207 by Ovens	SK	App	11.0	2/13/2025	-	-	-	Removed from Service; Pending Remediation
2013-1	Building 2 - Mens Bathroom by Room 207	SK	N/A		2/13/2025	-	-	-	Sign
2014-1	Building 2 - Custodial Closet by Room 207	SS	N/A		2/13/2025	-	-	-	Sign
2015-1	Building 2 - Womens Bathroom by Room 207	SK	N/A		2/13/2025	-	-	-	Sign
3001-1	Building 3 - Boys Bathroom 301	SK	N/A		2/13/2025	-	-	-	Sign
3002-1	Building 3 - Room 303 Unit @ A	SK	N/A		2/13/2025	-	-	-	Sign
3002-2	Building 3 - Room 303 Unit @ B	SK	N/A		2/13/2025	-	-	-	Sign
3003-1	Building 3 - Custodial Closet 305	SS	N/A		2/13/2025	-	-	-	Sign
3004-1	Building 3 - Bathroom 307	SK	N/A		2/13/2025	-	-	-	Sign
3005-1	Building 3 - Hall by Room 306	BF	App	<1.0	2/13/2025	-	-	-	-
3005-2	Building 3 - Hall by Room 306	WF	App	<1.0	2/13/2025	-	-	-	-
3006-1	Building 3 - Room 306 Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
3006-2	Building 3 - Room 306 Laundry	SS	N/A		2/13/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
3006-3	Building 3 - Room 306 Pet Shower @ A	SK	N/A		2/13/2025	-	-	-	Sign
3006-4	Building 3 - Room 306 Pet Shower @ B	SK	N/A		2/13/2025	-	-	-	Sign
3006-5	Building 3 - Room 306	SS	N/A		2/13/2025	-	-	-	Sign
3007-1	Building 3 - Girls Bathroom 302	SK	N/A		2/13/2025	-	-	-	Sign
4001-1	Building 4 - Room 404	BF	App	<1.0	2/13/2025	-	-	-	-
4001-2	Building 4 - Room 404	WF	App	<1.0	2/13/2025	-	-	-	-
4001-3	Building 4 - Room 404 Unit @ A	SK	N/A		2/13/2025	-	-	-	Sign
4001-4	Building 4 - Room 404 Unit @ B	SK	N/A		2/13/2025	-	-	-	Sign
4001-5	Building 4 - Room 404 Unit @ C	SK	N/A		2/13/2025	-	-	-	Sign
4001-6	Building 4 - Room 404 Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
4002-1	Building 4 - Room 403	BF	App	<1.0	2/13/2025	-	-	-	-
4002-2	Building 4 - Room 403	WF	App	<1.0	2/13/2025	-	-	-	-
4002-3	Building 4 - Room 403 Unit @ A	SK	N/A		2/13/2025	-	-	-	Sign
4002-4	Building 4 - Room 403 Unit @ B	SK	N/A		2/13/2025	-	-	-	Sign
4002-5	Building 4 - Room 403 Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
4003-1	Building 4 - Custodial Closet 404	SK	N/A		2/13/2025	-	-	-	Sign
4004-1	Building 4 - Lobby Girls Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
4005-1	Building 4 - Lobby Boys Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
4006-1	Building 4 - Room 401	BF	App	<1.0	2/13/2025	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
4006-2	Building 4 - Room 401	WF	App	<1.0	2/13/2025	-	-	-	-
4006-3	Building 4 - Room 401 Unit @ A	SK	N/A		2/13/2025	-	-	-	Sign
4006-4	Building 4 - Room 401 Unit @ B	SK	N/A		2/13/2025	-	-	-	Sign
4006-5	Building 4 - Room 401 Unit @ C	SK	N/A		2/13/2025	-	-	-	Sign
4006-6	Building 4 - Room 401 Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
5001-1	Building 5 - Room 507	SK	N/A		2/13/2025	-	-	-	Sign
5001-2	Building 5 - Room 507 Coffee Maker	CF	N/A		2/13/2025	-	-	-	Sign
5002-1	Building 5 - Room 509 Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
5002-2	Building 5 - Room 509 Unit @ A	SK	N/A		2/13/2025	-	-	-	Sign
5002-3	Building 5 - Room 509 Unit @ B	SK	N/A		2/13/2025	-	-	-	Sign
5003-1	Building 5 - Custodial Closet 511	SK	N/A		2/13/2025	-	-	-	Sign
5004-1	Building 5 - Bathroom 513	SK	N/A		2/13/2025	-	-	-	Sign
5005-1	Building 5 - Mens Bathroom 515	SK	N/A		2/13/2025	-	-	-	Sign
5006-1	Building 5 - Room 517	SK	N/A		2/13/2025	-	-	-	Sign
5006-2	Building 5 - Room 517 Station 1	SK	N/A		2/13/2025	-	-	-	Sign
5006-3	Building 5 - Room 517 Station 2	SK	N/A		2/13/2025	-	-	-	Sign
5006-4	Building 5 - Room 517 Station 3	SK	N/A		2/13/2025	-	-	-	Sign
5007-1	Building 5 - Room 525 @ A	SK	N/A		2/13/2025	-	-	-	Sign
5007-2	Building 5 - Room 525 @ B	SK	N/A		2/13/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
5008-1	Building 5 - Room 528	SK	N/A		2/13/2025	-	-	-	Sign
5009-1	Building 5 - Hall by 517	BF	App	<1.0	2/13/2025	-	-	-	-
5009-2	Building 5 - Hall by 517	WF	App	<1.0	2/13/2025	-	-	-	-
5010-1	Building 5 - Womens Bathroom 506 @ A	SK	N/A		2/13/2025	-	-	-	Sign
5010-2	Building 5 - Womens Bathroom 506 @ B	SK	N/A		2/13/2025	-	-	-	Sign
6001-1	Building 6 - Womens Bathroom 607	SK	N/A		2/13/2025	-	-	-	Sign
6002-1	Building 6 - Mens Bathroom 609	SK	N/A		2/13/2025	-	-	-	Sign
6003-1	Building 6 - Custodial Closet 615	SS	N/A		2/13/2025	-	-	-	Sign
6004-1	Building 6 - Room 602	SK	N/A		2/13/2025	-	-	-	Sign
7001-1	Building 7 - Custodial Closet 703	SK	N/A		2/13/2025	-	-	-	Sign
7002-1	Building 7 - Room 707	BF	App	<1.0	2/13/2025				-
7002-2	Building 7 - Room 707	WF	App	<1.0	2/13/2025	-	-	-	-
7002-3	Building 7 - Room 707 Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
7003-1	Building 7 - Room 710	WF	N/A		2/13/2025	-	-	-	Removed from Service
7003-2	Building 7 - Room 710 Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
7004-1	Building 7 - Lobby	SK	N/A		2/13/2025	-	-	-	Sign
7005-1	Building 7 - Bathroom 708	SK	N/A		2/13/2025	-	-	-	Sign
7006-1	Building 7 - Bathroom 706	SK	N/A		2/13/2025	-	-	-	Sign
8001-1	Roanoke House - Kitchen	SK	App	<1.0	2/13/2025	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
8002-1	Roanoke House - 1st Floor Bathroom	SK	N/A		2/13/2025	-	-	-	Sign
8003-1	Roanoke House - 2nd Floor Bathroom	SK	N/A		2/13/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2500608-32394

February 18, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Eastern Suffolk BOCES; Harry B. Ward Technical Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on February 14, 2025. New York Environmental analyzed the samples on February 16, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,

A handwritten signature in black ink, appearing to read 'Li Tsang', is written above a horizontal line.

Li Tsang, Laboratory Director

Date Collected:	13 Feb 2025
Date Received:	14 Feb 2025
Date Analyzed:	16 Feb 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250214O007	1	Building 5- Hall by by 517-BF, Initial	0.001	<0.001	mg/L	
250214O008	2	Building 5- Hall by by 517-WF, Initial	0.001	<0.001	mg/L	
250214O009	3	Building 4- Room 404-BF, Initial	0.001	<0.001	mg/L	
250214O010	4	Building 4- Room 404-WF, Initial	0.001	<0.001	mg/L	
250214O011	5	Building 4- Room 403-BF, Initial	0.001	<0.001	mg/L	
250214O012	6	Building 4- Room 403-WF, Initial	0.001	<0.001	mg/L	
250214O013	7	Building 4- Room 401-BF, Initial	0.001	<0.001	mg/L	
250214O014	8	Building 4- Room 401-WF, Initial	0.001	<0.001	mg/L	
250214O015	9	Building 3- Hall by Room 306-BF, Initial	0.001	<0.001	mg/L	
250214O016	10	Building 3- Hall by Room 306-WF, Initial	0.001	<0.001	mg/L	
250214O017	11	Roanoke House- Kitchen-SK, Initial	0.001	<0.001	mg/L	
250214O018	12	Building 7 - Room 707-BF, Initial	0.001	<0.001	mg/L	
250214O019	13	Building 7 - Room 707-WF, Initial	0.001	<0.001	mg/L	
250214O020	14	Building 2- Hall By Bathroom 213-BF, Initial	0.001	<0.001	mg/L	
250214O021	15	Building 2- Hall By Bathroom 213-WF, Initial	0.001	<0.001	mg/L	
250214O022	16	Building 2- Culinary Lobby-BF, Initial	0.001	<0.001	mg/L	
250214O023	17	Building 2- Culinary Lobby-WF, Initial	0.001	<0.001	mg/L	
250214O024	18	Building 2- 202-SK, Initial	0.001	0.008	mg/L	H
250214O025	19	Building 2- 202 Handwash-SK, Initial	0.001	<0.001	mg/L	
250214O026	20	Building 2- 202 Coffee Maker-CF, Initial	0.001	0.001	mg/L	
250214O027	21	Building 2 - Room 207-IM, Initial	0.001	<0.001	mg/L	
250214O028	22	Building 2 - Room 207 Island-SK, Initial	0.001	<0.001	mg/L	
250214O029	23	Building 2 - Room 207 by Ovens-SK, Initial	0.001	0.011	mg/L	H
250214O030	24	Building 2 - Room 207 by Baker's Pride-SK, Initial	0.001	0.003	mg/L	
250214O031	25	Building 1- Hall Between 130/132-BF, Initial	0.001	<0.001	mg/L	
250214O032	26	Building 1- Hall Between 130/132-WF, Initial	0.001	<0.001	mg/L	



Date Collected:	13 Feb 2025
Date Received:	14 Feb 2025
Date Analyzed:	16 Feb 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
250214O033	27	Building 1- Nurse's Office Bathroom-SK, Initial	0.001	0.004	mg/L	
250214O034	28	Building 1- Lobby-BF, Initial	0.001	<0.001	mg/L	
250214O035	29	Building 1- Lobby-WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Appendix H
Islip Academic Center

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Room W-9 Handwash	SK	N/A		2/5/2025	-	-	-	Sign
1001-2	Room W-9 Dishwash	SK	App	<1.0	2/5/2025	-	-	-	-
1001-3	Room W-9 Ice Machine	IM	App	<1.0	2/5/2025	-	-	-	-
1002-1	Shop Room	SS	N/A		2/5/2025	-	-	-	Sign
1003-1	Room W-7 Hair Wash Station	SPY	N/A		2/5/2025	-	-	-	Sign
1003-2	Room W-7	SK	N/A		2/5/2025	-	-	-	Sign
1004-1	Room W-5	SK	N/A		2/5/2025	-	-	-	Sign
1005-1	Room W-6	SK	N/A		2/5/2025	-	-	-	Sign
1006-1	Room W-3	SK	N/A		2/5/2025	-	-	-	Sign
1007-1	Room W-4	SK	N/A		2/5/2025	-	-	-	Sign
1008-1	Room W-1	SK	N/A		2/5/2025	-	-	-	Sign
1009-1	Room W-2	SK	N/A		2/5/2025	-	-	-	Sign
1010-1	Hallway by Room W-2	BF	App	<1.0	2/5/2025	-	-	-	-
1010-2	Hallway by Room W-2	WF	App	<1.0	2/5/2025	-	-	-	-
1011-1	Custodial Closet by Room W-2	SS	N/A		2/5/2025	-	-	-	Sign
1012-1	Boy's Bathroom by Main Office @ A	SK	N/A		2/5/2025	-	-	-	Sign
1012-2	Boy's Bathroom by Main Office @ B	SK	N/A		2/5/2025	-	-	-	Sign
1013-1	Girl's Bathroom by Gym @ A	SK	N/A		2/5/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1013-2	Girl's Bathroom by Gym @ B	SK	N/A		2/5/2025	-	-	-	Sign
1014-1	Kitchen 3 Bay - left	SK	N/A		2/5/2025	-	-	-	Sign
1014-2	Kitchen 3 Bay - left	SPY	N/A		2/5/2025	-	-	-	Sign
1014-3	Kitchen 3 Bay - right	SK	App	<1.0	2/5/2025	-	-	-	-
1014-4	Kitchen Handwash	SK	N/A		2/5/2025	-	-	-	Sign
1015-1	Women's Staff Bathroom	SK	N/A		2/5/2025	-	-	-	Sign
1016-1	Men's Staff Bathroom	SK	N/A		2/5/2025	-	-	-	Sign
1017-1	Nurse's Office	SK	App	13.0	2/5/2025				Removed From Service; Pending Remediation
1017-2	Nurse's Office Bathroom	SK	N/A		2/5/2025	-	-	-	Sign
1018-1	Hallway by Faculty Room	BF	App		2/5/2025	-	-	-	Removed from Service
1018-2	Hallway by Faculty Room	WF	App		2/5/2025	-	-	-	Removed from Service
1019-1	Faculty Room	SK	N/A		2/5/2025	-	-	-	Sign
1020-1	Room E-1	SK	N/A		2/5/2025	-	-	-	Sign
1021-1	Room E-3	SK	N/A		2/5/2025	-	-	-	Sign
1022-1	Room E-2	SK	N/A		2/5/2025	-	-	-	Sign
1023-1	Room E-4	SK	N/A		2/5/2025	-	-	-	Sign
1024-1	Room E-5	SK	N/A		2/5/2025	-	-	-	Sign
1025-1	Room E-7	SK	N/A		2/5/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1026-1	Room E-6	SK	N/A		2/5/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2500482-32292

February 6, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: ES BOCES; Islip Academic Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on February 05, 2025. New York Environmental analyzed the samples on February 06, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,

A handwritten signature in black ink, appearing to read 'Li Tsang', is written above a horizontal line.

Li Tsang, Laboratory Director

Date Collected:	05 Feb 2025
Date Received:	05 Feb 2025
Date Analyzed:	06 Feb 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
250205R003	1	Room W-9 Dishwash - SK, Initial	0.001	<0.001	mg/L	
250205R004	2	Room W-9 Ice Machine - IM, Initial	0.001	<0.001	mg/L	
250205R005	3	Hallway By Room W-2 - BF, Initial	0.001	<0.001	mg/L	
250205R006	4	Hallway By Room W-2 - WF, Initial	0.001	<0.001	mg/L	
250205R007	5	Kitchen 3 Bay - Right - SK, Initial	0.001	<0.001	mg/L	
250205R008	6	Nurse's Office - SK, Initial	0.001	0.013	mg/L	H

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Appendix I
Islip Career Center

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Custodial Closet in IOC Wing	SS	N/A		2/5/2024	-	-	-	Sign
1002-1	IOC Room 7 Office Bathroom	SK	N/A		2/5/2024	-	-	-	Sign
1003-1	Hallway by IOC Faculty Room	BF	App	<1.0	2/5/2024	-	-	-	-
1003-2	Hallway by IOC Faculty Room	WF	App	<1.0	2/5/2024	-	-	-	-
1004-1	IOC Room 9 Bathroom	SK	N/A		2/5/2024	-	-	-	Sign
1005-1	Custodial Closet by Room 4	SS	N/A		2/5/2024	-	-	-	Sign
1006-1	Girl's Bathroom by Room 4 @ A	SK	N/A		2/5/2024	-	-	-	Sign
1006-2	Girl's Bathroom by Room 4 @ B	SK	N/A		2/5/2024	-	-	-	Sign
1006-3	Girl's Bathroom by Room 4 @ C	SK	N/A		2/5/2024	-	-	-	Sign
1007-1	Boy's Bathroom by Room 4	SK	N/A		2/5/2024	-	-	-	Sign
1008-1	Men's Bathroom by Room 4 @ A	SK	N/A		2/5/2024	-	-	-	Sign
1008-2	Men's Bathroom by Room 4 @ B	SK	N/A		2/5/2024	-	-	-	Sign
1009-1	Women's Bathroom by Room 4	SK	N/A		2/5/2024	-	-	-	Sign
1009-2	Women's Bathroom ADA by Room 4	SK	N/A		2/5/2024	-	-	-	Sign
1010-1	Room 1	SK	N/A		2/5/2024	-	-	-	Removed from Service
1011-1	Room 28	SK	N/A		2/5/2024	-	-	-	Sign
1011-2	Room 28 Bathroom	SK	N/A		2/5/2024	-	-	-	Sign
1012-1	New Culinary Kitchen Classroom	SK	N/A		2/5/2024	-	-	-	Sign
1013-1	New Culinary Kitchen @ A (closest to hallway)	SK	App	<1.0	2/5/2024	-	-	-	-
1013-2	New Culinary Kitchen @ B	SK	App	<1.0	2/5/2024	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1013-4	New Culinary Kitchen @ C	SK	App	<1.0	2/5/2024	-	-	-	-
1013-5	New Culinary Kitchen @ D (rear)	SK	App	<1.0	2/5/2024	-	-	-	-
1013-6	New Culinary Kitchen Handwash Island @ A	SK	N/A		2/5/2024	-	-	-	Sign
1013-7	New Culinary Kitchen Handwash Island @ B	SK	N/A		2/5/2024	-	-	-	Sign
1013-8	New Culinary Kitchen Ice Machine	IM	App	<1.0	2/5/2024	-	-	-	-
1013-9	New Culinary Kitchen Steamer	SP	N/A		2/5/2024	-	-	-	Sign
1013-10	New Culinary Kitchen Dishwasher Station	SPY	N/A		2/5/2024	-	-	-	Sign
1013-11	New Culinary Kitchen Handwash @ C	SK	N/A		2/5/2024	-	-	-	Sign
1013-12	New Culinary Kitchen 3-Bay	SK	N/A		2/5/2024	-	-	-	Sign
1013-13	New Culinary Kitchen 3-Bay	SPY	N/A		2/5/2024	-	-	-	Sign
1013-14	New Culinary Kitchen	SS	N/A		2/5/2024	-	-	-	Sign
1013-15	New Culinary Kitchen Island Potfiller 1 closest to entrance	SP	App	<1.0	2/5/2024	-	-	-	-
1013-16	New Culinary Kitchen Island Potfiller 2	SP	App	<1.0	2/5/2024	-	-	-	-
1014-1	Custodial Closet by New Culinary Kitchen	SS	N/A		2/5/2024	-	-	-	Sign
1015-1	Custodial Closet by Room 21	SS	N/A		2/5/2024	-	-	-	Sign
1015-2	Custodial Closet by Room 21 Bathroom	SS	N/A		2/5/2024	-	-	-	Sign
1016-1	Room 23 Horticulture Unit @ A	SK	N/A		2/5/2024	-	-	-	Sign
1016-2	Room 23 Horticulture Unit @ B	SK	N/A		2/5/2024	-	-	-	Sign
1017-1	Room 22 Auto Body Trough Sink @ A	SK	N/A		2/5/2024	-	-	-	Sign
1017-2	Room 22 Auto Body Trough Sink @ B	SK	N/A		2/5/2024	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1017-3	Room 22 Auto Body Trough Sink @ C	SK	N/A		2/5/2024	-	-	-	Sign
1018-1	Room 21 Auto Mechanics Trough sink @ A	SK	N/A		2/5/2024	-	-	-	Sign
1018-2	Room 21 Auto Mechanics Trough sink @ B	SK	N/A		2/5/2024	-	-	-	Sign
1018-3	Room 21 Auto Mechanics Trough sink @ C	SK	N/A		2/5/2024	-	-	-	Sign
1018-4	Room 21 Auto Mechanics Eye Wash	EW	N/A		2/5/2024	-	-	-	Sign
1019-1	Room 20 Auto Mechanics Trough Sink @ A	SK	N/A		2/5/2024	-	-	-	Sign
1019-2	Room 20 Auto Mechanics Trough Sink @ B	SK	N/A		2/5/2024	-	-	-	Sign
1019-3	Room 20 Auto Mechanics Trough Sink @ C	SK	N/A		2/5/2024	-	-	-	Sign
1019-4	Room 20 Auto Mechanics Eye Wash	EW	N/A		2/5/2024	-	-	-	Sign
1020-1	Room 19 Weight Room	SK	N/A		2/5/2024	-	-	-	-
1020-2	Room 19 Weight Room	BF	App	<1.0	2/5/2024	-	-	-	-
1020-3	Room 19 Weight Room	WF	App	<1.0	2/5/2024	-	-	-	-
1021-1	Room 15 Unit 1 @ A	SK	N/A		2/5/2024	-	-	-	Sign
1021-2	Room 15 Unit 1 @ B	SK	N/A		2/5/2024	-	-	-	Sign
1021-3	Room 15 Unit 1 @ C	SK	N/A		2/5/2024	-	-	-	Sign
1021-4	Room 15 Unit 2 @ A	SK	N/A		2/5/2024	-	-	-	Sign
1021-5	Room 15 Unit 2 @ B	SK	N/A		2/5/2024	-	-	-	Sign
1021-6	Room 15 Unit 2 @ C	SK	N/A		2/5/2024	-	-	-	Sign
1021-7	Room 15 Eye Wash	EW	N/A		2/5/2024	-	-	-	Sign
1022-1	Room 18 Eye Wash	EW	N/A		2/5/2024	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1022-2	Room 18 Unit @ A	SK	N/A		2/5/2024	-	-	-	Sign
1022-3	Room 18 Unit @ B	SK	N/A		2/5/2024	-	-	-	Sign
1022-4	Room 18 New Stand Alone Unit	SK	N/A		2/5/2024	-	-	-	Sign
1023-1	Room 16 Unit @ A	SK	N/A		2/5/2024	-	-	-	Sign
1023-2	Room 16 Unit @ B	SK	N/A		2/5/2024	-	-	-	Sign
1023-3	Room 16 Eye Wash	EW	N/A		2/5/2024	-	-	-	Sign
1024-1	Room 14 Canine Careers Unit @ A	SK	N/A		2/5/2024	-	-	-	Sign
1024-2	Room 14 Canine Careers Unit @ B	SK	N/A		2/5/2024	-	-	-	Sign
1024-3	Room 14 Canine Careers Unit @ C	SK	N/A		2/5/2024	-	-	-	Sign
1024-4	Room 14 Eye Wash	EW	N/A		2/5/2024	-	-	-	Sign
1025-1	Room 13 hand wash sink	SS	N/A		2/5/2024	-	-	-	Sign
1026-1	Hallway by Room 13	BF	App	<1.0	2/5/2024	-	-	-	-
1026-2	Hallway by Room 13	WF	App	<1.0	2/5/2024	-	-	-	-
1027-1	Women's Bathroom by Room 13 @ A	SK	N/A		2/5/2024	-	-	-	Sign
1027-2	Women's Bathroom by Room 13 @ B	SK	N/A		2/5/2024	-	-	-	Sign
1028-1	All Gender Bathroom by Nurse's Office	SK	N/A		2/5/2024	-	-	-	Sign
1029-1	Nurse's Office - left sink	SK	App	15.0	2/5/2024				Removed from Service; Pending Remediation
1029-2	Nurse's Office - Hand wash	SK	N/A		2/5/2024	-	-	-	Sign
1029-3	Nurse's Office - Eye Wash	EW	N/A		2/5/2024	-	-	-	Sign
1030-1	Faculty Room	BF	App	<1.0	2/5/2024	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1030-2	Faculty Room	WF	App	<1.0	2/5/2024	-	-	-	-
1030-3	Faculty Room	SK	N/A		2/5/2024	-	-	-	Sign
1030-4	Faculty Room	SPY	N/A		2/5/2024	-	-	-	Sign
1031-1	Room 11/12	SK	N/A		2/5/2024	-	-	-	Sign
1031-2	Room 11/12	WF	App		2/5/2024	-	-	-	Removed from Service
1032-1	Room 11/12 Hand wash	SK	N/A		2/5/2024	-	-	-	Sign
1032-2	Room 12 Retail Center-hot water dispenser	OS	N/A		2/5/2024	-	-	-	Sign
1033-1	Room 9 Counter	SK	N/A		2/5/2024	-	-	-	Sign
1033-2	Room 9 Vanity @ A	SK	N/A		2/5/2024	-	-	-	Sign
1034-1	Kitchen Prep small	SK	App	27.0	2/5/2024				Removed from Service; Pending Remediation
1034-2	Kitchen Opposite Stove	SK	App	4.0	2/5/2024	-	-	-	-
1034-3	Kitchen Dishwash 3-Bay @ A	SK	N/A		2/5/2024	-	-	-	Sign
1034-4	Kitchen Dishwash 3-Bay @ B	SK	N/A		2/5/2024	-	-	-	Sign
1034-5	Kitchen Dishwash Station	SPY	N/A		2/5/2024	-	-	-	Sign
1035-1	Room 10 Cosmetology Eye Wash	EW	N/A		2/5/2024	-	-	-	Sign
1035-2	Room 10 Cosmetology	SK	N/A		2/5/2024	-	-	-	Sign
1035-3	Room 10 Hair wash Station @ A	SPY	N/A		2/5/2024	-	-	-	Sign
1035-4	Room 10 Hair wash Station @ B	SPY	N/A		2/5/2024	-	-	-	Sign
1035-5	Room 10 Hair wash Station @ C	SPY	N/A		2/5/2024	-	-	-	Sign
1035-7	Room 10 by Hair wash Station	SPY	N/A		2/5/2024	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1036-1	Room 7	WF	App		2/5/2024	-	-	-	Removed from Service
1036-2	Room 7- Hand Wash	SK	N/A		2/5/2024	-	-	-	Sign
1036-3	Room 7- 3 Compartment sink	SK	N/A		2/5/2024	-	-	-	Sign
1036-4	Room 7 - Counter 1	SK	App	<1.0	2/5/2024	-	-	-	-
1036-5	Room 7 - Counter 2 by Dishwasher	SK	App	3.0	2/5/2024	-	-	-	-
1036-6	Room 7 - Ice Machine	IM	App	<1.0	2/5/2024	-	-	-	-
1037-1	Room 8	WF	App		2/5/2024	-	-	-	Removed from Service
1037-2	Room 8	SK	N/A		2/5/2024	-	-	-	Sign
1038-1	Room 5	WF	N/A		2/5/2024	-	-	-	Sign
1038-2	Room 5	SK	N/A		2/5/2024	-	-	-	Sign
1039-1	Room 6	WF	N/A		2/5/2024	-	-	-	Removed from Service
1039-2	Room 6 - Hand wash	SK	N/A		2/5/2024	-	-	-	Sign
1039-3	Room 6 Counter - left	SK	App	<1.0	2/5/2024	-	-	-	-
1039-4	Room 6 Counter - right	SK	App	<1.0	2/5/2024	-	-	-	-
1039-5	Room 6 Dishwash Station	SK	N/A		2/5/2024	-	-	-	Sign
1039-6	Room 6 Dishwash Station	SPY	N/A		2/5/2024	-	-	-	Sign
1039-7	Room 6 closet	SS	N/A		2/5/2024	-	-	-	Sign
1040-1	Custodial Closet by Room 6	SS	N/A		2/5/2024	-	-	-	Sign
1041-1	Room 3	WF	App		2/5/2024	-	-	-	Removed from Service
1041-2	Room 3	SK	N/A		2/5/2024	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1042-1	Room 4	SK	N/A		2/5/2024	-	-	-	Sign
1042-2	Room 4 Hand wash	SK	N/A		2/5/2024	-	-	-	Sign
1043-1	Room 2	SK	N/A		2/5/2024	-	-	-	Sign
1043-2	Room 2 Hair wash Station left	SPY	N/A		2/5/2024	-	-	-	Sign
1043-3	Room 2 Hair wash Station right	SPY	N/A		2/5/2024	-	-	-	Sign
1044-1	Room 1 Counter 1- left	SK	N/A		2/5/2024	-	-	-	Sign
1044-2	Room 1 Counter 2 - right	SK	N/A		2/5/2024	-	-	-	Sign
1044-2	Room 1 Counter 2 Eye Wash	EW	N/A		2/5/2024	-	-	-	Sign

Laboratory Report

NYE Report #: 2500483-32293

February 6, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: ES BOCES; Islip Career Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on February 05, 2025. New York Environmental analyzed the samples on February 06, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	05 Feb 2025
Date Received:	05 Feb 2025
Date Analyzed:	06 Feb 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250205R009	1	Hallway by IOC Faculty Room-BF, Initial	0.001	<0.001	mg/L	
250205R010	2	Hallway by IOC Faculty Room-WF, Initial	0.001	<0.001	mg/L	
250205R011	3	New Culinary Kitchen @ A (closest to hallway)-SK, Initial	0.001	<0.001	mg/L	
250205R012	4	New Culinary Kitchen @ B -SK, Initial	0.001	<0.001	mg/L	
250205R013	5	New Culinary Kitchen @ C -SK, Initial	0.001	<0.001	mg/L	
250205R014	6	New Culinary Kitchen @ D (rear)-SK, Initial	0.001	<0.001	mg/L	
250205R015	7	New Culinary Kitchen Ice Machine-IM, Initial	0.001	<0.001	mg/L	
250205R016	8	New Culinary Kitchen Island Potfiller 1 closest to entrance-SP, Initial	0.001	<0.001	mg/L	
250205R017	9	New Culinary Kitchen Island Potfiller 2-SP, Initial	0.001	<0.001	mg/L	
250205R018	10	Room 19 Weight Room-BF, Initial	0.001	<0.001	mg/L	
250205R019	11	Room 19 Weight Room-WF, Initial	0.001	<0.001	mg/L	
250205R020	12	Hallway by Room 13-BF, Initial	0.001	<0.001	mg/L	
250205R021	13	Hallway by Room 13-WF, Initial	0.001	<0.001	mg/L	
250205R022	14	Nurse's Office - left sink-SK, Initial	0.001	0.015	mg/L	H
250205R023	15	Faculty Room-BF, Initial	0.001	<0.001	mg/L	
250205R024	16	Faculty Room-WF, Initial	0.001	<0.001	mg/L	
250205R025	17	Kitchen Opposite Stove-SK, Initial	0.001	0.004	mg/L	
250205R026	18	Kitchen Prep small-SK, Initial	0.001	0.027	mg/L	H
250205R027	19	Room 7 - Ice Machine-IM, Initial	0.001	<0.001	mg/L	
250205R028	20	Room 7 - Counter 1-SK, Initial	0.001	<0.001	mg/L	
250205R029	21	Room 7 - Counter 2 by dishwasher-SK, Initial	0.001	0.003	mg/L	
250205R030	22	Room 6 Counter - left-SK, Initial	0.001	<0.001	mg/L	
250205R031	23	Room 6 Counter - right-SK, Initial	0.001	0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



Appendix J
James Hines Administration Center

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-1	Faculty Lounge B-01	SK	App	3.0	12/28/2023	-	-	-	-
0001-2	Faculty Lounge B-01	SPY	N/A		12/28/2023	-	-	-	Removed from Service
0001-3	Faculty Lounge B-01	IM	App	<1.0	12/28/2023	-	-	-	-
0001-4	Faculty Lounge B-01 Coffee Maker	CF	N/A		12/28/2023	-	-	-	Removed from Service
0002-1	File Room B-35	SS	N/A		12/28/2023	-	-	-	Sign
0003-1	Mens Bathroom by B-02	SK	N/A		12/28/2023	-	-	-	Sign
0004-1	Womens Bathroom B-03 @ A	SK	N/A		12/28/2023	-	-	-	Sign
0004-2	Womens Bathroom B-03 @ B	SK	N/A		12/28/2023	-	-	-	Sign
0004-3	Womens Bathroom B-03 @ C	SK	N/A		12/28/2023	-	-	-	Sign
0005-1	Boiler Room B-31	SS	N/A		12/28/2023	-	-	-	Sign
0006-1	Hall by Elevator	BF	App	<1.0	12/28/2023	-	-	-	-
0006-2	Hall by Elevator	WF	App	<1.0	12/28/2023	-	-	-	-
1001-1	CEO Kitchenette	SK	App	<1.0	12/28/2023	-	-	-	-
1001-2	CEO Kitchenette	SPY	N/A		12/28/2023	-	-	-	Removed from Service
1002-1	Bathroom 108	SK	N/A		12/28/2023	-	-	-	Sign
1003-1	Women's Bathroom 79 @ A	SK	N/A		12/28/2023	-	-	-	Sign
1003-2	Women's Bathroom 79 @ B	SK	N/A		12/28/2023	-	-	-	Sign
1003-3	Women's Bathroom 79 @ C	SK	N/A		12/28/2023	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1004-1	Hall by Room 56	BF	App	<1.0	12/28/2023	-	-	-	-
1004-2	Hall by Room 56	WF	App	<1.0	12/28/2023	-	-	-	-
1005-1	Mens Bathroom 78 @ A	SK	N/A		12/28/2023	-	-	-	Sign
1005-1	Mens Bathroom 78 @ B	SK	N/A		12/28/2023	-	-	-	Sign
1006-1	Boiler Room 61	SS	N/A		12/28/2023	-	-	-	Sign
1007-1	Room 73	SK	App	2.0	12/28/2023	-	-	-	-
1007-2	Room 73	SPY	App	1.0	12/28/2023	-	-	-	-
1007-3	Room 73 Coffee Maker	CF	N/A		12/28/2023	-	-	-	Hot Water Only; Sampling Not Required
1007-4	Room 73	IM	App	<1.0	12/28/2023	-	-	-	-
1008-1	Unisex Bathroom 65	SK	N/A		12/28/2023	-	-	-	Sign
1009-1	Hall by Room 66	WF	App		12/28/2023	-	-	-	Non-functional; Sampling Required
1010-1	Unisex Bathroom 64	SK	N/A		12/28/2023	-	-	-	Sign
1011-1	Bathroom 127	SK	N/A		12/28/2023	-	-	-	Sign
1012-1	Womens Bathroom 31 in Room 32 @ A	SK	N/A		12/28/2023	-	-	-	Sign
1012-1	Womens Bathroom 31 in Room 32 @ B	SK	N/A		12/28/2023	-	-	-	Sign
1013-1	Mens Bathroom 30 in Room 32 @ A	SK	N/A		12/28/2023	-	-	-	Sign
1013-1	Mens Bathroom 30 in Room 32 @ B	SK	N/A		12/28/2023	-	-	-	Sign
1014-1	Receiving Room	SS	N/A		12/28/2023	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1014-1	Receiving Room Coffee Maker	CF	N/A		12/28/2023	-	-	-	Hot Water Only; Sampling Not Required
1015-1	Hall by Receiving Room	BF	App	<1.0	12/28/2023	-	-	-	-
1015-2	Hall by Receiving Room	WF	App	<1.0	12/28/2023	-	-	-	-

Laboratory Report

NYE Report #: 237343-28050

December 29, 2023

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Eastern Suffolk BOCES; James Hine Administration Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on December 28, 2023. New York Environmental analyzed the samples on December 29, 2023 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	28 Dec 2023
Date Received:	28 Dec 2023
Date Analyzed:	29 Dec 2023

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
231228L032	1	Faculty Lounge B-01-SK, Initial	0.001	0.003	mg/L	
231228L033	2	Faculty Lounge B-01-IM, Initial	0.001	<0.001	mg/L	
231228L034	3	Hall by Elevator-BF, Initial	0.001	<0.001	mg/L	
231228L035	4	Hall by Elevator-WF, Initial	0.001	<0.001	mg/L	
231228L036	5	CEO Kitchenette-SK, Initial	0.001	<0.001	mg/L	
231228L037	6	Hall by Room 56-BF, Initial	0.001	<0.001	mg/L	
231228L038	7	Hall by Room 56-WF, Initial	0.001	<0.001	mg/L	
231228L039	8	Room 73-SK, Initial	0.001	0.002	mg/L	
231228L040	9	Room 73-SPY, Initial	0.001	0.001	mg/L	
231228L041	10	Room 73-IM, Initial	0.001	<0.001	mg/L	
231228L042	11	Hall by Receiving Room-BF, Initial	0.001	<0.001	mg/L	
231228L043	12	Hall by Receiving Room-WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix K
Jefferson Academic Center

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-1	100 Wing Men's Bathroom @ A	SK	N/A		2/7/2025	-	-	-	Sign
0001-2	100 Wing Men's Bathroom @ B	SK	N/A		2/7/2025	-	-	-	Sign
0001-3	100 Wing Men's Bathroom @ C	SK	N/A		2/7/2025	-	-	-	Sign
0001-4	100 Wing Men's Bathroom @ D	SK	N/A		2/7/2025	-	-	-	Sign
0002-1	Custodial Office	SS	N/A		2/7/2025	-	-	-	Sign
0003-1	Room 106	SS	N/A		2/7/2025	-	-	-	Sign
0004-1	Hallway by Room 108	BF	App	<1.0	2/7/2025	-	-	-	-
0004-2	Hallway by Room 108	WF	App	<1.0	2/7/2025	-	-	-	-
0005-2	100 Wing Women's Bathroom @ B	SK	N/A		2/7/2025	-	-	-	Sign
0005-3	100 Wing Women's Bathroom @ C	SK	N/A		2/7/2025	-	-	-	Sign
0005-4	100 Wing Women's Bathroom @ D	SK	N/A		2/7/2025	-	-	-	Sign
0006-1	Girl's Locker Room Bathroom @ A	SK	N/A		2/7/2025	-	-	-	Sign
0006-2	Girl's Locker Room Bathroom @ B	SK	N/A		2/7/2025	-	-	-	Sign
0006-3	Girl's Locker Room Bathroom @ C	SK	N/A		2/7/2025	-	-	-	Sign
0006-4	Girl's Locker Room Bathroom @ D	SK	N/A		2/7/2025	-	-	-	Sign
0007-1	100 Wing Custodial Closet	SS	N/A		2/7/2025	-	-	-	Sign
0008-1	Hallway by 100 Wing Custodial Closet	WF	App	<1.0	2/7/2025	-	-	-	-
0008-2	Hallway by 100 Wing Custodial Closet	BF	App	<1.0	2/7/2025	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0009-1	Gym Custodial Closet	SS	N/A		2/7/2025	-	-	-	Sign
0010-1	Boy's Locker Room Bathroom @ A	SK	N/A		2/7/2025	-	-	-	Sign
0010-2	Boy's Locker Room Bathroom @ B	SK	N/A		2/7/2025	-	-	-	Sign
0010-3	Boy's Locker Room Bathroom @ C	SK	N/A		2/7/2025	-	-	-	Sign
1001-1	Room 112 @ A	SK	App	9.0	2/7/2025				Removed From Service; Pending Remediation
1001-2	Room 112 @ A	SPY	App	2.0	2/7/2025	-	-	-	-
1001-3	Room 112 @ B	SK	App	9.0	2/7/2025				Removed From Service; Pending Remediation
1001-4	Room 112 @ B	SPY	App	4.0	2/7/2025	-	-	-	-
1002-1	Faculty Room	SK	N/A		2/7/2025	-	-	-	Sign
1003-1	200 Wing Women's Faculty Bathroom	SK	N/A		2/7/2025	-	-	-	Sign
1004-1	200 Wing Men's Faculty Bathroom	SK	N/A		2/7/2025	-	-	-	Sign
1005-1	Hallway by Room 227	WF	App	<1.0	2/7/2025	-	-	-	-
1005-2	Hallway by Room 227	BF	App	<1.0	2/7/2025	-	-	-	-
1006-1	Room 226	SK	N/A		2/7/2025	-	-	-	Sign
1007-1	Fan Room	SS	N/A		2/7/2025	-	-	-	Sign
1008-1	Hallway by Room 233	WF	App	<1.0	2/7/2025	-	-	-	-
1008-2	Hallway by Room 233	BF	App	<1.0	2/7/2025	-	-	-	-
1009-1	Room 233 Bathroom-Principal	SK	N/A		2/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1010-1	Room 232 Nurse's Office	SK	App	2.0	2/7/2025	-	-	-	-
2001-1	Custodial Closet by Room 341	SK	N/A		2/7/2025	-	-	-	Sign
2002-1	300 Wing Men's Bathroom @ A	SK	N/A		2/7/2025	-	-	-	Sign
2002-2	300 Wing Men's Bathroom @ B	SK	N/A		2/7/2025	-	-	-	Sign
2003-1	Room 343	SK	N/A		2/7/2025	-	-	-	Sign
2004-1	Room 345	SK	N/A		2/7/2025	-	-	-	Sign
2005-1	Hallway by Room 350	WF	App	<1.0	2/7/2025	-	-	-	-
2005-2	Hallway by Room 350	BF	App	<1.0	2/7/2025	-	-	-	-
2006-1	300 Wing Women's Bathroom @ A	SK	N/A		2/7/2025	-	-	-	Sign
2006-2	300 Wing Women's Bathroom @ B	SK	N/A		2/7/2025	-	-	-	Sign
2006-3	300 Wing Women's Bathroom @ C	SK	N/A		2/7/2025	-	-	-	Sign
0011-1	Kitchen Handwash @ A	SK	N/A		2/7/2025	-	-	-	Sign
0011-2	Kitchen 3 Bay Sink	SK	N/A		2/7/2025	-	-	-	Sign
0011-3	Kitchen 3 Bay Sink	SPY	N/A		2/7/2025	-	-	-	Sign
0011-4	Kitchen Handwash @ B	SK	N/A		2/7/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2500513-32319

February 10, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: ES Boces; Jefferson Academic Center

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on February 07, 2025. New York Environmental analyzed the samples on February 10, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,

A handwritten signature in black ink, appearing to read 'Li Tsang', is written above a horizontal line.

Li Tsang, Laboratory Director

Date Collected:	07 Feb 2025
Date Received:	07 Feb 2025
Date Analyzed:	10 Feb 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250207P070	1	Hallway by Room 108-BF, Initial	0.001	<0.001	mg/L	
250207P071	2	Hallway by Room 108-WF, Initial	0.001	<0.001	mg/L	
250207P072	3	Kitchen 3 Bay Sink-SK, Initial	0.001	0.002	mg/L	
250207P073	4	Kitchen 3 Bay Sink-SPY, Initial	0.001	<0.001	mg/L	
250207P074	5	Hallway by 100 Wing Custodial Closet-WF, Initial	0.001	<0.001	mg/L	
250207P075	6	Hallway by 100 Wing Custodial Closet-BF, Initial	0.001	<0.001	mg/L	
250207P076	7	Room 112 @ A-SK, Initial	0.001	0.009	mg/L	H
250207P077	8	Room 112 @ A-SPY, Initial	0.001	0.002	mg/L	
250207P078	9	Room 112 @ B-SK, Initial	0.001	0.009	mg/L	H
250207P079	10	Room 112 @ B-SPY, Initial	0.001	0.004	mg/L	
250207P080	11	Hallway by Room 227-WF, Initial	0.001	<0.001	mg/L	
250207P081	12	Hallway by Room 227-BF, Initial	0.001	<0.001	mg/L	
250207P082	13	Hallway by Room 233-BF, Initial	0.001	<0.001	mg/L	
250207P083	14	Hallway by Room 233-WF, Initial	0.001	<0.001	mg/L	
250207P084	15	Room 232 Nurse's Office-SK, Initial	0.001	0.002	mg/L	
250207P085	16	Hallway By Room 350-BF, Initial	0.001	<0.001	mg/L	
250207P086	17	Hallway By Room 350-WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



Appendix L
Sayville Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-1	Boiler Room Bathroom	SK	N/A		1/24/2025	-	-	-	Sign
0002-1	Hallway by Boiler Room	WF	App		1/24/2025	-	-	-	Removed from Service
0003-1	Mens Bathroom by Room 614 @ A	SK	N/A		1/24/2025	-	-	-	Sign
0003-2	Mens Bathroom by Room 614 @ B	SK	N/A		1/24/2025	-	-	-	Sign
0003-3	Mens Bathroom by Room 614	SS	N/A		1/24/2025	-	-	-	Sign
0004-1	Cafeteria	BF	App	<1.0	1/24/2025	-	-	-	-
0004-2	Cafeteria	WF	App	<1.0	1/24/2025	-	-	-	-
0005-1	Girls Bathroom by Cafeteria	SK	N/A		1/24/2025	-	-	-	Sign
0006-1	Womens Faculty Bathroom by Cafeteria @ A	SK	N/A		1/24/2025	-	-	-	Sign
0006-2	Womens Faculty Bathroom by Cafeteria @ B	SK	N/A		1/24/2025	-	-	-	Sign
0006-3	Womens Faculty Bathroom by Cafeteria @ C	SK	N/A		1/24/2025	-	-	-	Sign
0006-4	Womens Faculty Bathroom by Cafeteria	SP	N/A		1/24/2025	-	-	-	Sign
0007-1	Kitchen Island	SK	App	1.0	1/24/2025	-	-	-	-
0007-2	Kitchen Dishwash 3 Bay	SPY	App	2.0	1/24/2025	-	-	-	-
0007-3	Kitchen Dishwash 3 Bay	SK	App	6.0	1/24/2025				Sign Posted
0009-1	Room 622 Life Skills	SK	App	2.0	1/24/2025	-	-	-	-
1001-1	Room 117 Bathroom	SK	N/A		1/24/2025	-	-	-	Sign
1002-1	Girls Bathroom by Room 112 @ A	SK	N/A		1/24/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1002-2	Girls Bathroom by Room 112 @ B	SK	N/A		1/24/2025	-	-	-	Sign
1002-3	Girls Bathroom by Room 112 @ C	SK	N/A		1/24/2025	-	-	-	Sign
1002-4	Girls Bathroom by Room 112 @ D	SK	N/A		1/24/2025	-	-	-	Sign
1003-1	Hallway by Room 112	BF	App	<1.0	1/24/2025	-	-	-	-
1003-2	Hallway by Room 112	WF	App	<1.0	1/24/2025	-	-	-	-
1004-1	Nurses's Office	SK	App	5.0	1/24/2025	-	-	-	-
1004-2	Nurses's Office Bathroom	SK	N/A		1/24/2025	-	-	-	Sign
1005-1	Custodial Closet by Nurses Office	SS	N/A		1/24/2025	-	-	-	Sign
1006-1	Boys Bathroom by Nurses Office @ A	SK	N/A		1/24/2025	-	-	-	Sign
1006-2	Boys Bathroom by Nurses Office @ B	SK	N/A		1/24/2025	-	-	-	Sign
1006-3	Boys Bathroom by Nurses Office @ C	SK	N/A		1/24/2025	-	-	-	Sign
1006-4	Boys Bathroom by Nurses Office @ D	SK	N/A		1/24/2025	-	-	-	Sign
1006-5	Boys Bathroom by Nurses Office	SP	N/A		1/24/2025	-	-	-	Sign
1007-1	Hallway by Room 103	WF	App		1/24/2025	-	-	-	Removed from Service
1008-1	Room 103 Bathroom (left)	SK	N/A	6.0	1/24/2025				Sign Posted
1008-2	Room 103 Bathroom (right)	SK	N/A	7.0	1/24/2025				Sign Posted
1009-1	Room 101 Bathroom (left)	SK	N/A	5.0	1/24/2025	-	-	-	Sign
1009-2	Room 101 Bathroom (right)	SK	N/A	19.0	1/24/2025				Sign Posted

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1010-1	Room 100	WF	App		1/24/2025	-	-	-	Removed from Service
1010-2	Room 100 Bathroom (left)	SK	N/A	10.0	1/24/2025				Sign Posted
1010-3	Room 100 Bathroom (right)	SK	N/A	5.0	1/24/2025	-	-	-	-
2001-1	Room 200 Art Closet	SK	N/A		1/24/2025	-	-	-	Sign
2002-1	Hallway by Room 207	WF	App		1/24/2025	-	-	-	Removed from Service
2003-1	Custodial Closet by Room 207	SS	N/A		1/24/2025	-	-	-	Sign
2004-1	Boys Bathroom by Room 207 @ A	SK	N/A		1/24/2025	-	-	-	Sign
2004-2	Boys Bathroom by Room 207 @ B	SK	N/A		1/24/2025	-	-	-	Sign
2004-3	Boys Bathroom by Room 207 @ C	SK	N/A		1/24/2025	-	-	-	Sign
2004-4	Boys Bathroom by Room 207 @ D	SK	N/A		1/24/2025	-	-	-	Sign
2004-5	Boys Bathroom by Room 207	SP	N/A		1/24/2025	-	-	-	Sign
2005-1	All Gender Bathroom	SK	N/A		1/24/2025	-	-	-	Sign
2006-1	Hallway by Room 208	WF	App	<1.0	1/24/2025	-	-	-	-
2006-2	Hallway by Room 208	BF	App	<1.0	1/24/2025	-	-	-	-
2007-1	Girls Bathroom by Room 210 @ A	SK	N/A		1/24/2025	-	-	-	Sign
2007-2	Girls Bathroom by Room 210 @ B	SK	N/A		1/24/2025	-	-	-	Sign
2007-3	Girls Bathroom by Room 210 @ C	SK	N/A		1/24/2025	-	-	-	Sign
2007-4	Girls Bathroom by Room 210 @ D	SK	N/A		1/24/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2007-5	Girls Bathroom by Room 210	SP	N/A		1/24/2025	-	-	-	Sign
2008-1	Gym Upstairs All Gender Bathroom	SK	N/A		1/24/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2500236-32174

January 27, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: ES BOCES; Sayville Elementary School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on January 24, 2025. New York Environmental analyzed the samples on January 27, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,

A handwritten signature in black ink, appearing to read 'Li Tsang', is written over a horizontal line.

Li Tsang, Laboratory Director

Date Collected:	24 Jan 2025
Date Received:	24 Jan 2025
Date Analyzed:	27 Jan 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250124J034	1	Cafeteria-BF, Initial	0.001	<0.001	mg/L	
250124J035	2	Cafeteria-WF, Initial	0.001	<0.001	mg/L	
250124J036	3	Kitchen Island-SK, Initial	0.001	0.001	mg/L	
250124J037	4	Kitchen Dishwash 3 Bay-SPY, Initial	0.001	0.002	mg/L	
250124J038	5	Kitchen Dishwash 3 Bay-SK, Initial	0.001	0.006	mg/L	H
250124J039	6	Room 622 Life Skills-SK, Initial	0.001	0.002	mg/L	
250124J040	7	Hallway by Room 112-BF, Initial	0.001	<0.001	mg/L	
250124J041	8	Hallway by Room 112-WF, Initial	0.001	<0.001	mg/L	
250124J042	9	Nurses's Office-SK, Initial	0.001	0.005	mg/L	
250124J043	10	Room 103 Bathroom (left)-SK, Initial	0.001	0.006	mg/L	H
250124J044	11	Room 103 Bathroom (right)-SK, Initial	0.001	0.007	mg/L	H
250124J045	12	Room 101 Bathroom (left)-SK, Initial	0.001	0.005	mg/L	
250124J046	13	Room 101 Bathroom (right)-SK, Initial	0.001	0.019	mg/L	H
250124J047	14	Room 100 Bathroom (left)-SK, Initial	0.001	0.010	mg/L	H
250124J048	15	Room 100 Bathroom (right)-SK, Initial	0.001	0.005	mg/L	
250124J049	16	Hallway by Room 208-WF, Initial	0.001	<0.001	mg/L	
250124J050	17	Hallway by Room 208-BF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



Appendix M
Westhampton Beach Learning Center

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Building 2 Men's Bathroom 58	SK	N/A		2/14/2025	-	-	-	Sign
1002-1	Building 2 Hallway by Men's Bathroom 58	BF	App	<1.0	2/14/2025	-	-	-	-
1002-2	Building 2 Hallway by Men's Bathroom 58	WF	App	<1.0	2/14/2025	-	-	-	-
1003-1	Building 2 Women's Bathroom 57	SK	N/A		2/14/2025	-	-	-	Sign
1004-1	Building 2 Copy Room 11	SK	N/A		2/14/2025	-	-	-	Sign
1005-1	Building 2 Bathroom 15	SK	N/A		2/14/2025	-	-	-	Sign
1006-1	Building 2 Textbook Office Bathroom	SK	N/A		2/14/2025	-	-	-	Sign
1007-1	Building 2 Custodial Closet 21	SS	N/A		2/14/2025	-	-	-	Sign
1008-1	Building 2 Hallway by Custodial Closet 21	BF	App	<1.0	2/14/2025	-	-	-	-
1008-2	Building 2 Hallway by Custodial Closet 21	WF	App	<1.0	2/14/2025	-	-	-	-
1009-1	Building 2 Women's Bathroom 23 @ A	SK	N/A		2/14/2025	-	-	-	Sign
1009-2	Building 2 Women's Bathroom 23 @ B	SK	N/A		2/14/2025	-	-	-	Sign
1010-1	Building 2 Conference Room 27	SK	N/A		2/14/2025	-	-	-	Sign
1011-1	Building 2 Faculty Kitchen	SK	N/A		2/14/2025	-	-	-	Sign
1012-1	Building 2 Room 24 Bathroom	SK	N/A		2/14/2025	-	-	-	Sign
1013-1	Building 3 Boy's Bathroom by Gym	SK	N/A		2/14/2025	-	-	-	Sign
1014-1	Building 3 Hallway by Gym/Front Office	WF	App	<1.0	2/14/2025	-	-	-	-
1014-2	Building 3 Hallway by Gym/Front Office	BF	App	<1.0	2/14/2025	-	-	-	-
1015-1	Building 3 Women's Bathroom by Front Office	SK	N/A		2/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1016-1	Building 3 Men's Bathroom by Front Office	SK	N/A		2/14/2025	-	-	-	Sign
1017-1	Building 3 Small Kitchen @ A	SK	N/A		2/14/2025	-	-	-	Sign
1017-2	Building 3 Small Kitchen @ B	SK	N/A		2/14/2025	-	-	-	Sign
1017-3	Building 3 Small Kitchen @ C	SK	N/A		2/14/2025	-	-	-	Sign
1018-1	Building 3 Women's Bathroom by Room 307 @ A	SK	N/A		2/14/2025	-	-	-	Sign
1018-2	Building 3 Women's Bathroom by Room 307 @ B	SK	N/A		2/14/2025	-	-	-	Sign
1019-1	Building 3 Custodial Closet by Room 307	SS	N/A		2/14/2025	-	-	-	Sign
1020-1	Building 3 Men's Bathroom by Room 307 @ A	SK	N/A		2/14/2025	-	-	-	Sign
1020-2	Building 3 Men's Bathroom by Room 307 @ B	SK	N/A		2/14/2025	-	-	-	Sign
1021-1	Building 3 Women's Staff Bathroom by Room 305	SK	N/A		2/14/2025	-	-	-	Sign
1022-1	Building 3 Common Area	SK	N/A		2/14/2025	-	-	-	Sign
1023-1	Building 3 Room 306D	SK	N/A		2/14/2025	-	-	-	Sign
1024-1	Building 3 Room 305	SK	N/A		2/14/2025	-	-	-	Sign
1025-1	Building 3 Room 304	SK	N/A		2/14/2025	-	-	-	Sign
1026-1	Building 3 Room 303	SK	N/A		2/14/2025	-	-	-	Sign
1027-1	Building 3 Common Area Kitchen @ A	SK	N/A		2/14/2025	-	-	-	Sign
1027-2	Building 3 Common Area Kitchen @ B	SK	N/A		2/14/2025	-	-	-	Sign
1027-3	Building 3 Common Area Kitchen @ C	SK	N/A		2/14/2025	-	-	-	Sign
1027-4	Building 3 Common Area Kitchen @ D	SK	N/A		2/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1028-1	Building 3 Room 302	SK	N/A		2/14/2025	-	-	-	Sign
1029-1	Building 3 Room 301	SK	N/A		2/14/2025	-	-	-	Sign
1030-1	Building 3 Custodial Closet by Nurse's Office	SS	N/A		2/14/2025	-	-	-	Sign
1031-1	Building 3 Women's Bathroom by Room 218	SK	N/A		2/14/2025	-	-	-	Sign
1032-1	Building 3 Men's Bathroom by Room 218	SK	N/A		2/14/2025	-	-	-	Sign
1033-1	Building 3 Main Kitchen Handwash	SK	N/A		2/14/2025	-	-	-	Sign Required
1033-2	Building 3 Main Kitchen Dishwash	SPY	App	1.0	2/14/2025	-	-	-	-
1033-3	Building 3 Main Kitchen Dishwash	SK	App	3.0	2/14/2025	-	-	-	-
1034-1	Building 3 Custodial Closet by Main Kitchen	SS	N/A		2/14/2025	-	-	-	Sign
1035-1	Building 3 Room 217	SK	N/A		2/14/2025	-	-	-	Sign
1036-1	Building 3 Room 209	SK	N/A		2/14/2025	-	-	-	Sign
1036-2	Building 3 Room 209 Changing Area	SK	N/A		2/14/2025	-	-	-	Sign
1037-1	Building 3 Room 208	SK	N/A		2/14/2025	-	-	-	Sign
1038-1	Building 3 Room 207	SK	N/A		2/14/2025	-	-	-	Sign
1039-1	Building 3 Room 206	SK	N/A		2/14/2025	-	-	-	Sign
1040-1	Building 3 Room 205	SK	N/A		2/14/2025	-	-	-	Sign
1041-1	Building 3 Room 204	SK	N/A		2/14/2025	-	-	-	Sign
1042-1	Building 3 Room 202	SK	N/A		2/14/2025	-	-	-	Sign
1043-1	Building 3 Room 201	SK	N/A		2/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1044-1	Building 3 200 Wing Kitchen	SK	N/A		2/14/2025	-	-	-	Sign
1045-1	Building 3 200 Wing Girl's Bathroom	SK	N/A		2/14/2025	-	-	-	Sign
1046-1	Building 3 200 Wing Boy's Bathroom	SK	N/A		2/14/2025	-	-	-	Sign
1047-1	Building 3 Hallway by 200 Wing Boy's Bathroom	BF	App	<1.0	2/14/2025	-	-	-	-
1047-2	Building 3 Hallway by 200 Wing Boy's Bathroom	WF	App	<1.0	2/14/2025	-	-	-	-
1048-1	Building 3 B Faculty Room	SK	N/A		2/14/2025	-	-	-	Sign
1049-1	Building 3 Nurse's Office	SK	App	<1.0	2/14/2025	-	-	-	-
1050-1	Building 4 Cafeteria	SK	N/A		2/14/2025	-	-	-	Sign
1051-1	Building 4 Women's Faculty Bathroom by Room 21	SK	N/A		2/14/2025	-	-	-	Sign
1052-1	Building 4 Men's Faculty Bathroom by Room 21	SK	N/A		2/14/2025	-	-	-	Sign
1053-1	Building 4 Faculty Lounge	SK	N/A		2/14/2025	-	-	-	Sign
1054-1	Building 4 Custodial Closet by Room 8	SS	N/A		2/14/2025	-	-	-	Sign
1055-1	Building 4 Women's Bathroom by Room 8 @ A	SK	N/A		2/14/2025	-	-	-	Sign
1055-2	Building 4 Women's Bathroom by Room 8 @ B	SK	N/A		2/14/2025	-	-	-	Sign
1055-3	Building 4 Women's Bathroom by Room 8 @ C	SK	N/A		2/14/2025	-	-	-	Sign
1056-1	Building 4 Hallway by Room 8	BF	App	<1.0	2/14/2025	-	-	-	-
1056-2	Building 4 Hallway by Room 8	WF	App	<1.0	2/14/2025	-	-	-	-
1057-1	Building 4 Men's Bathroom by Room 8 @ A	SK	N/A		2/14/2025	-	-	-	Sign
1057-2	Building 4 Men's Bathroom by Room 8 @ B	SK	N/A		2/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1057-3	Building 4 Men's Bathroom by Room 8 @ C	SK	N/A		2/14/2025	-	-	-	Sign
1058-1	Building 1 Hallway by Room 19	BF	App	<1.0	2/14/2025	-	-	-	-
1058-2	Building 1 Hallway by Room 19	WF	App	<1.0	2/14/2025	-	-	-	-
1059-1	Building 1 Girl's Bathroom 18	SK	N/A		2/14/2025	-	-	-	Sign
1060-1	Building 1 Staff Bathroom	SK	N/A		2/14/2025	-	-	-	Sign
1061-1	Building 1 Boy's Bathroom 17	SK	N/A		2/14/2025	-	-	-	Sign
1062-1	Building 1 Room 10	SK	N/A		2/14/2025	-	-	-	Sign
1063-1	Building 1 Custodial Closet by Room 10	SK	N/A		2/14/2025	-	-	-	Sign
1064-1	Building 1 Kitchen	SK	N/A		2/14/2025	-	-	-	Sign
1064-2	Building 1 Kitchen	SPY	N/A		2/14/2025	-	-	-	Sign
1065-1	Building 1 Room 11	SK	N/A		2/14/2025	-	-	-	Sign
1066-1	Building 1 Room 12	SK	N/A		2/14/2025	-	-	-	Sign
1067-1	Building 1 Room 1 Bathroom	SK	N/A		2/14/2025	-	-	-	Sign
1068-1	Building 1 Room 2 Bathroom	SK	N/A		2/14/2025	-	-	-	Sign
1069-1	Building 1 Faculty Room	SK	N/A		2/14/2025	-	-	-	Sign
1069-2	Building 1 Faculty Room Bathroom	SK	N/A		2/14/2025	-	-	-	Sign
1070-1	Building 1 Nurse's Office	SK	App	2.0	2/14/2025	-	-	-	-
1070-2	Building 1 Nurse's Office Bathroom	SK	N/A		2/14/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2500609-32395

February 18, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Eastern Suffolk BOCES; Westhampton Beach Learning Center

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on February 14, 2025. New York Environmental analyzed the samples on February 16, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	14 Feb 2025
Date Received:	14 Feb 2025
Date Analyzed:	16 Feb 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250214O036	1	Building 1 Nurse's Office-SK, Initial	0.001	0.002	mg/L	
250214O037	2	Building 1 Hallway By Room 19-BF, Initial	0.001	<0.001	mg/L	
250214O038	3	Building 1 Hallway By Room 19-WF, Initial	0.001	<0.001	mg/L	
250214O039	4	Building 2 Hallway By Men's Bathroom 58-BF, Initial	0.001	<0.001	mg/L	
250214O040	5	Building 2 Hallway By Men's Bathroom 58-WF, Initial	0.001	<0.001	mg/L	
250214O041	6	Building 2 Hallway By Custodial Closet 21-BF, Initial	0.001	<0.001	mg/L	
250214O042	7	Building 2 Hallway By Custodial Closet 21-WF, Initial	0.001	<0.001	mg/L	
250214O043	8	Building 3 Main Kitchen Dishwash-SPY, Initial	0.001	0.001	mg/L	
250214O044	9	Building 3 Main Kitchen Dishwash-SK, Initial	0.001	0.003	mg/L	
250214O045	10	Building 3 Hallway by 200 Wing Boy's Bathroom-BF, Initial	0.001	<0.001	mg/L	
250214O046	11	Building 3 Hallway by 200 Wing Boy's Bathroom-WF, Initial	0.001	<0.001	mg/L	
250214O047	12	Building 3 Nurse's Office-SK, Initial	0.001	<0.001	mg/L	
250214O048	13	Building 3 Hallway By Gym/ Front Office-WF, Initial	0.001	<0.001	mg/L	
250214O049	14	Building 3 Hallway By Gym/ Front Office-BF, Initial	0.001	<0.001	mg/L	
250214O050	15	Building 4 Hallway By Room 8-BF, Initial	0.001	<0.001	mg/L	
250214O051	16	Building 4 Hallway By Room 8-WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation



Appendix N
Sequoia High School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	First Floor Faculty Room	SK	App	<1.0	12/29/2023	-	-	-	-
1001-2	First Floor Faculty Room Coffee Supply Line	SL	App	<1.0	12/29/2023	-	-	-	-
1001-3	First Floor Faculty Room Scotsman	OS	App	<1.0	12/29/2023	-	-	-	-
1001-4	First Floor Faculty Room Scotsman	IM	App	<1.0	12/29/2023	-	-	-	-
1002-1	Coffee Room 2-Bay	SK	N/A		12/29/2023	-	-	-	Sign
1002-2	Coffee Room Handwash	SK	N/A		12/29/2023	-	-	-	Sign
1002-3	Coffee Room Coffee Supply Line	SL	App	<1.0	12/29/2023	-	-	-	-
1002-4	Coffee Room by Lockers	SS	N/A		12/29/2023	-	-	-	Sign
1002-5	Coffee Room by Lockers Handwash	SK	N/A		12/29/2023	-	-	-	Sign
1003-1	Kitchen Prep	SK	App	<1.0	12/29/2023	-	-	-	-
1003-2	Kitchen Handwash @A	SK	N/A		12/29/2023	-	-	-	Sign
1003-3	Kitchen 2 Bay	SK	App	5.0	1/9/2024	<1.0	<1.0	1/9/24	Remediation Complete
				9.0	12/29/2023	-	-	-	Removed from Service; Pending Retest
1003-4	Kitchen Pot Filler-Right	PF	App	6.0	1/9/2024	2.0	2.0	1/9/24	Removed from Service; Sign Posted
				20.0	12/29/2023	-	-	-	Removed from Service; Pending Retest
1003-5	Kitchen Pot Filler-Middle	PF	App	11.0	1/9/2024	1.0	6.0	1/9/24	Removed from Service; Sign Posted
				14.0	12/29/2023	-	-	-	Removed from Service; Pending Retest

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1003-6	Kitchen Pot Filler-Left	PF	App	17.0	1/9/2024	1.0	4.0	1/9/24	Removed from Service; Sign Posted
				62.0	12/29/2023	-	-	-	Removed from Service; Pending Retest
1003-7	Kitchen Handwash @B	SK	N/A		12/29/2023	-	-	-	Sign
1003-8	Kitchen Handwash @C	SK	N/A		12/29/2023	-	-	-	Sign
1003-9	Kitchen Ice Machine	IM	App	<1.0	12/29/2023	-	-	-	-
1004-1	Kitchen Dishwash Room Counter 1 Left	SPY	N/A		12/29/2023	-	-	-	Sign
1004-2	Kitchen Dishwash Room Counter 1 Middle	SK	N/A		12/29/2023	-	-	-	Sign
1004-3	Kitchen Dishwash Room Counter 1 Right	SPY	N/A		12/29/2023	-	-	-	Sign
1004-4	Kitchen Dishwash Room Handwash	SK	N/A		12/29/2023	-	-	-	Sign
1004-5	Kitchen Dishwash Room Counter 2	SPY	N/A		12/29/2023	-	-	-	Sign
1004-6	Kitchen Dishwash Room	SS	N/A		12/29/2023	-	-	-	Sign
1005-1	Men's Bathroom by Kitchen	SK	N/A		12/29/2023	-	-	-	Sign
1006-1	Women's Bathroom by Kitchen	SK	N/A		12/29/2023	-	-	-	Sign
1027-1	Custodial Closet 108	SS	N/A		12/29/2023	-	-	-	Sign
1007-1	Conference Room 5/8 Coffee Room	SK	App	2.0	1/9/2024	-	-	-	Remdiation Complete
				8.0	12/29/2023	-	-	-	Removed from Service; Pending Retest
1008-1	Hall by Conference Room 8	WF	App	<1.0	12/29/2023	-	-	-	-
1008-2	Hall by Conference Room 8	BF	App	<1.0	12/29/2023	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1009-1	Men's Bathroom by Auditorium @ A	SK	N/A		12/29/2023	-	-	-	Sign
1009-2	Men's Bathroom by Auditorium @ B	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
1009-3	Men's Bathroom by Auditorium @ C	SK	N/A		12/29/2023	-	-	-	Sign
1010-1	Women's Bathroom by Auditorium @ A	SK	N/A		12/29/2023	-	-	-	Sign
1010-2	Women's Bathroom by Auditorium @ B	SK	N/A		12/29/2023	-	-	-	Sign
1010-3	Women's Bathroom by Auditorium @ C	SK	N/A		12/29/2023	-	-	-	Sign
1011-1	Women's Bathroom-East by Auditorium @ A	SK	N/A		12/29/2023	-	-	-	Sign
1011-2	Women's Bathroom-East by Auditorium @ B	SK	N/A		12/29/2023	-	-	-	Sign
1011-3	Women's Bathroom-East by Auditorium @ C	SK	N/A		12/29/2023	-	-	-	Sign
1011-4	Women's Bathroom-East by Auditorium @ D	SK	N/A		12/29/2023	-	-	-	Sign
1011-5	Women's Bathroom-East by Auditorium @ E	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
1012-1	Hall by Auditorium	WF	App	<1.0	12/29/2023	-	-	-	-
1012-2	Hall by Auditorium	BF	App	<1.0	12/29/2023	-	-	-	-
1013-1	Hall by Bathroom 148	WF	App	<1.0	12/29/2023	-	-	-	-
1013-2	Hall by Bathroom 148	BF	App	<1.0	12/29/2023	-	-	-	-
1014-1	Men's Bathroom 148 @A	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
1014-2	Men's Bathroom 148 @B	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
1014-3	Men's Bathroom 148 @C	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1014-4	Men's Bathroom 148 @D	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
1015-1	Women's Bathroom 149 @A	SK	N/A		12/29/2023	-	-	-	Sign
1015-2	Women's Bathroom 149 @B	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
1015-3	Women's Bathroom 149 @C	SK	N/A		12/29/2023	-	-	-	Sign
1015-4	Women's Bathroom 149 @D	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
1016-1	Hall by Bathroom 158	WF	App	<1.0	12/29/2023	-	-	-	-
1016-2	Hall by Bathroom 158	BF	App	<1.0	12/29/2023	-	-	-	-
1017-1	Men's Bathroom 160 @A	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
1017-2	Men's Bathroom 160 @B	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
1017-3	Men's Bathroom 160 @C	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
1017-4	Men's Bathroom 160 @D	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
1018-1	Women's Bathroom 159 @ A	SK	N/A		12/29/2023	-	-	-	Sign
1018-2	Women's Bathroom 159 @ B	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
1018-3	Women's Bathroom 159 @ C	SK	N/A		12/29/2023	-	-	-	,
1018-4	Women's Bathroom 159 @ D	SK	N/A		12/29/2023	-	-	-	Sign
1019-1	Hall by Cafeteria	WF	App	<1.0	12/29/2023	-	-	-	-
1019-2	Hall by Cafeteria	BF	App	<1.0	12/29/2023	-	-	-	-
1020-1	Women's Bathroom by Cafeteria	SK	N/A		12/29/2023	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1021-1	Principal's Bathroom by Cafeteria	SK	N/A		12/29/2023	-	-	-	Sign
1022-1	Cafeteria Serving Area Handwash Left	SK	N/A		12/29/2023	-	-	-	Sign
1022-2	Cafeteria Serving Area Handwash Right	SK	N/A		12/29/2023	-	-	-	Sign
1027-1	Custodial Closet 124	SS	N/A		12/29/2023	-	-	-	Sign
1023-1	Nurse's Office	SK	App	<1.0	12/29/2023	-	-	-	-
1023-2	Nurse's Office Bathroom	SK	N/A		12/29/2023	-	-	-	Sign
1023-3	Nurse's Office Room 122	SK	App	1.0	12/29/2023	-	-	-	-
1024-1	Hall by Nurse's Office	WF	App	<1.0	12/29/2023	-	-	-	-
1024-2	Hall by Nurse's Office	BF	App	<1.0	12/29/2023	-	-	-	-
1028-1	Men's Bathroom by Nurse's Office @ A	SK	N/A		12/29/2023	-	-	-	Sign
1028-2	Men's Bathroom by Nurse's Office @ B	SK	N/A		12/29/2023	-	-	-	Sign
1028-3	Men's Bathroom by Nurse's Office @ C	SK	N/A		12/29/2023	-	-	-	Sign
1028-4	Men's Bathroom by Nurse's Office @ D	SK	N/A		12/29/2023	-	-	-	Sign
1028-5	Men's Bathroom by Nurse's Office @ E	SK	N/A		12/29/2023	-	-	-	Sign
1025-1	Room 121	SK	App	<1.0	12/29/2023	-	-	-	-
1026-1	Room 145	SK	App	2.0	12/29/2023	-	-	-	-
2001-1	Hall by Bathroom 215	WF	App		12/29/2023	-	-	-	Non-functional; Sampling Required
2001-2	Hall by Bathroom 215	BF	App	<1.0	12/29/2023	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2002-1	Men's Bathroom 215 @A	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
2002-2	Men's Bathroom 215 @B	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
2002-3	Men's Bathroom 215 @C	SK	N/A		12/29/2023	-	-	-	Sign
2003-1	Women's Bathroom 214 @A	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
2003-1	Women's Bathroom 214 @B	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
2003-1	Women's Bathroom 214 @C	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
2004-1	Second Floor Faculty Room	SK	App	<1.0	12/29/2023	-	-	-	-
2005-1	Hall by Bathroom 232	WF	App	<1.0	12/29/2023	-	-	-	-
2005-2	Hall by Bathroom 232	BF	App	<1.0	12/29/2023	-	-	-	-
2006-1	Women's Bathroom 232 @A	SK	N/A		12/29/2023	-	-	-	Sign
2006-2	Women's Bathroom 232 @B	SK	N/A		12/29/2023	-	-	-	Sign
2006-3	Women's Bathroom 232 @C	SK	N/A		12/29/2023	-	-	-	Sign
2006-4	Women's Bathroom 232 @D	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
2007-1	Men's Bathroom 230 @A	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
2007-2	Men's Bathroom 230 @B	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
2007-3	Men's Bathroom 230 @C	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
2007-4	Men's Bathroom 230 @D	SK	N/A		12/29/2023	-	-	-	Sign
2008-1	Women's Bathroom 244 @A	SK	N/A		12/29/2023	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2008-2	Women's Bathroom 244 @B	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
2008-3	Women's Bathroom 244 @C	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
2008-4	Women's Bathroom 244 @D	SK	N/A		12/29/2023	-	-	-	Sign
2009-1	Men's Bathroom 245 @A	SK	N/A		12/29/2023	-	-	-	Sign
2009-2	Men's Bathroom 245 @B	SK	N/A		12/29/2023	-	-	-	Sign
2009-3	Men's Bathroom 245 @C	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
2009-4	Men's Bathroom 245 @D	SK	N/A		12/29/2023	-	-	-	Mixed Valve; Sign
2010-1	Hall by Bathroom 245	WF	App	<1.0	12/29/2023	-	-	-	-
2010-2	Hall by Bathroom 245	BF	App	<1.0	12/29/2023	-	-	-	-

Laboratory Report

NYE Report #: 237365-28063

January 2, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Eastern Suffolk BOCES; Sequoya High School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on December 29, 2023. New York Environmental analyzed the samples on January 02, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	29 Dec 2023
Date Received:	29 Dec 2023
Date Analyzed:	02 Jan 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
231229N001	1	Kitchen Prep-SK, Initial	0.001	<0.001	mg/L	
231229N002	2	Kitchen 2 Bay-SK, Initial	0.001	0.009	mg/L	H
231229N003	3	Kitchen Pot Filler-Right-PF, Initial	0.001	0.020	mg/L	H
231229N004	4	Kitchen Pot Filler-Middle-PF, Initial	0.001	0.014	mg/L	H
231229N005	5	Kitchen Pot Filler-Left-PF, Initial	0.001	0.062	mg/L	E,H
231229N006	6	Kitchen Ice Machine-IM, Initial	0.001	<0.001	mg/L	
231229N007	7	Coffee Room Coffee Supply Line-SL, Initial	0.001	<0.001	mg/L	
231229N008	8	First Floor Faculty Room-SK, Initial	0.001	<0.001	mg/L	
231229N009	9	First Floor Faculty Room Coffee Supply Line-SL, Initial	0.001	<0.001	mg/L	
231229N010	10	First Floor Faculty Room Scotsman-IM, Initial	0.001	<0.001	mg/L	
231229N011	11	First Floor Faculty Room Scotsman-OS, Initial	0.001	<0.001	mg/L	
231229N012	12	Conference Room 5/8 Coffee Room-SK, Initial	0.001	0.008	mg/L	H
231229N013	13	Hall by Conference Room 8-WF, Initial	0.001	<0.001	mg/L	
231229N014	14	Hall by Conference Room 8-BF, Initial	0.001	<0.001	mg/L	
231229N015	15	Hall by Auditorium-WF, Initial	0.001	<0.001	mg/L	
231229N016	16	Hall by Auditorium-BF, Initial	0.001	<0.001	mg/L	
231229N017	17	Room 121-SK, Initial	0.001	<0.001	mg/L	
231229N018	18	Hall by Nurse's Office-WF, Initial	0.001	<0.001	mg/L	
231229N019	19	Hall by Nurse's Office-BF, Initial	0.001	<0.001	mg/L	
231229N020	20	Nurse's Office-SK, Initial	0.001	<0.001	mg/L	
231229N021	21	Nurse's Office Room 122-SK, Initial	0.001	0.001	mg/L	
231229N022	22	Hall by Cafeteria-WF, Initial	0.001	<0.001	mg/L	
231229N023	23	Hall by Cafeteria-BF, Initial	0.001	<0.001	mg/L	
231229N024	24	Hall by Bathroom 158-WF, Initial	0.001	<0.001	mg/L	
231229N025	25	Hall by Bathroom 158-BF, Initial	0.001	<0.001	mg/L	
231229N026	26	Room 145-SK, Initial	0.001	0.002	mg/L	



Date Collected:	29 Dec 2023
Date Received:	29 Dec 2023
Date Analyzed:	02 Jan 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
231229N027	27	Hall by Bathroom 148-WF, Initial	0.001	<0.001	mg/L	
231229N028	28	Hall by Bathroom 148-BF, Initial	0.001	<0.001	mg/L	
231229N029	29	Hall by Bathroom 232-WF, Initial	0.001	<0.001	mg/L	
231229N030	30	Hall by Bathroom 232-BF, Initial	0.001	<0.001	mg/L	
231229N031	31	Hall by Bathroom 245-WF, Initial	0.001	<0.001	mg/L	
231229N032	32	Hall by Bathroom 245-BF, Initial	0.001	<0.001	mg/L	
231229N033	33	Hall by Bathroom 215-BF, Initial	0.001	<0.001	mg/L	
231229N034	34	Second Floor Faculty Room-SK, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

NYE Report #: 2400173-28135

January 12, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Eastern Suffolk BOCES; Sequoya High School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on January 10, 2024. New York Environmental analyzed the samples on January 12, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	09 Jan 2024
Date Received:	10 Jan 2024
Date Analyzed:	12 Jan 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240110Q001	1a	Kitchen 2 Bay-SK, 1st	0.001	0.005	mg/L	
240110Q002	1b	Kitchen 2 Bay-SK, 15 sec	0.001	<0.001	mg/L	
240110Q003	1c	Kitchen 2 Bay-SK, 60 sec	0.001	<0.001	mg/L	
240110Q004	2a	Kitchen Pot Filler-Right-PF, 1st	0.001	0.006	mg/L	H
240110Q005	2b	Kitchen Pot Filler-Right-PF, 15 sec	0.001	0.002	mg/L	
240110Q006	2c	Kitchen Pot Filler-Right-PF, 60 sec	0.001	0.002	mg/L	
240110Q007	3a	Kitchen Pot Filler-Middle-PF, 1st	0.001	0.011	mg/L	H
240110Q008	3b	Kitchen Pot Filler-Middle-PF, 15 sec	0.001	0.001	mg/L	
240110Q009	3c	Kitchen Pot Filler-Middle-PF, 60 sec	0.001	0.006	mg/L	H
240110Q010	4a	Kitchen Pot Filler-Left-PF, 1st	0.001	0.017	mg/L	H
240110Q011	4b	Kitchen Pot Filler-Left-PF, 15 sec	0.001	0.001	mg/L	
240110Q012	4c	Kitchen Pot Filler-Left-PF, 60 sec	0.001	0.004	mg/L	
240110Q013	5a	Conference Room 5/8 Coffee Room-SK, 1st	0.001	0.002	mg/L	
240110Q014	5b	Conference Room 5/8 Coffee Room-SK, 15 sec	0.001	NA	mg/L	
240110Q015	5c	Conference Room 5/8 Coffee Room-SK, 60 sec	0.001	NA	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

NA: Sample not analyzed per customer request.

H: Sample result exceeds applicable regulatory limit.



Appendix O
Tecumseh Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1000-1	Kitchen 1 Bay Handwash by Bathroom	SK	N/A		6/20/2024	-	-	-	Sign
1000-2	Kitchen 2 Bay (Left)	SK	N/A		6/20/2024	-	-	-	Sign
1000-3	Kitchen 2 Bay (Right)	SK	N/A		6/20/2024	-	-	-	Sign
1000-4	Kitchen 1 Bay Handwash by Dishwashing Sta	SK	N/A		6/20/2024	-	-	-	Sign
1000-5	Kitchen Dishwashing Station	SPY	N/A		6/20/2024	-	-	-	Sign
1000-6	Kitchen Pot Filler	PF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1000-7	Kitchen Island	SK	App	9.0	6/20/2024	-	-	-	Sign
1000-8	Kitchen Bathroom	SK	N/A		6/20/2024	-	-	-	Sign
1000-9	Kitchen Can Wash Room 50C	SP	N/A		6/20/2024	-	-	-	Sign
1000-10	Kitchen Steamer Supply Spigot-Before Filter	SP	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1000-10	Kitchen Steamer Supply Spigot-After Filter	SP	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1000-11	Kitchen Steamer Supply Spigot	SP	App	<1.0	8/28/2024	<1.0	<1.0	8/28/2024	Remediation Complete
				36.0	7/30/2024	-	-	-	Removed from Service; Pending Remediaton
				133.0	6/20/2024	-	-	-	Removed from Service; Pending Remediaton
1001-1	Hall by Boiler Room 48	WF	N/A		6/20/2024	-	-	-	Non-functional; Waterline Turned Off; Sign
1002-1	Custodian Office 47	SK	N/A		6/20/2024	-	-	-	Sign
1002-2	Custodian Office 47	SS	N/A		6/20/2024	-	-	-	Sign Required
1003-1	Cafeterium	WF	App	<1.0	8/11/2023	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1003-2	Cafeterium	BF	App	<1.0	8/11/2023	-	-	-	-
1004-1	Girls Locker Room Bathroom	SK	N/A		6/20/2024	-	-	-	Sign
1005-1	Main Office	SK	N/A		6/20/2024	-	-	-	Sign
1006-1	Nurses Office	SK	App	23.0	6/20/2024	-	-	-	Removed from Service; Pending Remedaiton
1006-2	Nurses Office Bathroom	SK	N/A		6/20/2024	-	-	-	Sign
1007-1	Mens Bathroom by Gym @ A	SK	N/A		6/20/2024	-	-	-	-
1007-2	Mens Bathroom by Gym @ B	SK	N/A		6/20/2024	-	-	-	-
1008-1	Hall by Gym	WF	App	<1.0	6/20/2024	-	-	-	-
1008-2	Hall by Gym Bottle Filler	BF	App	<1.0	6/20/2024	-	-	-	-
1009-1	Custodial Closet by Room 23	SS	N/A		6/20/2024	-	-	-	Sign/Locked Door
1010-1	Womens Bathroom by Room 23 @ A	SK	N/A		6/20/2024	-	-	-	Sign
1010-2	Womens Bathroom by Room 23 @ B	SK	N/A		6/20/2024	-	-	-	Sign
1011-1	Room 23	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1011-2	Room 23	SK	N/A		6/20/2024	-	-	-	Sign
1012-1	Room 22	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1012-2	Room 22	SK	N/A		6/20/2024	-	-	-	Sign
1013-1	Faculty Room 9	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1013-2	Faculty Room 9	SK	N/A		6/20/2024	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1014-1	Room 21	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1014-2	Room 21	SK	N/A		6/20/2024	-	-	-	Sign
1015-1	Room 10	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1015-2	Room 10	SK	N/A		6/20/2024	-	-	-	Sign
1016-1	Hall by Room 10	WF	N/A		6/20/2024	-	-	-	-
1016-1	Hall by Room 10	WF	App	<1.0	9/7/2023	-	-	-	-
1016-2	Hall by Room 10	BF	App	<1.0	9/7/2023	-	-	-	-
1017-1	Room 20	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1017-2	Room 20	SK	N/A		6/20/2024	-	-	-	Sign
1018-1	Room 11	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1018-2	Room 11	SK	N/A		6/20/2024	-	-	-	Sign
1019-1	Room 19	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1019-2	Room 19	SK	N/A		6/20/2024	-	-	-	Sign
1020-1	Room 12 Multi Purpose Room	WF	App	<1.0	6/20/2024	-	-	-	-
1020-2	Room 12 Multi Purpose Room	SK	N/A		6/20/2024	-	-	-	Sign
1021-1	Room 18	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1021-2	Room 18	SK	N/A		6/20/2024	-	-	-	Sign
1022-1	Art Room 17	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1022-2	Art Room 17	SK	N/A		6/20/2024	-	-	-	Sign
1023-1	Room 16	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1023-2	Room 16	SK	N/A		6/20/2024	-	-	-	Sign
1023-3	Room 16 Bathroom	SK	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1024-1	Room 15	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1024-2	Room 15	SK	N/A		6/20/2024	-	-	-	Sign
1024-3	Room 15 Bathroom	SK	N/A		6/20/2024	-	-	-	Sign
1025-1	Room 14	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1025-2	Room 14 @ A (Right)	SK	N/A		6/20/2024	-	-	-	Sign
1025-3	Room 14 @ B (Left)	SK	N/A		6/20/2024	-	-	-	Sign
1026-1	Room 13	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1026-2	Room 13 @ A (Left)	SK	N/A		6/20/2024	-	-	-	Sign
1026-3	Room 13 @ B (Right)	SK	N/A		6/20/2024	-	-	-	Sign
1027-1	Boys Locker Room Bathroom	SK	N/A		6/20/2024	-	-	-	Sign
1028-1	Room 25	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1028-2	Room 25	SK	N/A		6/20/2024	-	-	-	Sign
1029-1	Room 26	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1029-2	Room 26	SK	N/A		6/20/2024	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1030-1	Room 27	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1030-2	Room 27	SK	N/A		6/20/2024	-	-	-	Sign
1031-1	Room 28	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1031-2	Room 28	SK	N/A		6/20/2024	-	-	-	Sign
1032-1	Room 29	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1032-2	Room 29	SK	N/A		6/20/2024	-	-	-	Sign
1033-1	Room 30	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1033-2	Room 30	SK	N/A		6/20/2024	-	-	-	Sign
1034-1	Room 31	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1034-2	Room 31	SK	N/A		6/20/2024	-	-	-	Sign
1035-1	Room 32	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1035-2	Room 32	SK	N/A		6/20/2024	-	-	-	Sign
1036-1	Room 33 OT/PT	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1036-2	Room 33 OT/PT	SK	N/A		6/20/2024	-	-	-	Sign
1037-1	Room 34	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1037-2	Room 34	SK	N/A		6/20/2024	-	-	-	Sign
1038-1	Room 35	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1038-2	Room 35	SK	N/A		6/20/2024	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1039-1	Boys Bathroom by Room 35 @ A	SK	N/A		6/20/2024	-	-	-	Sign
1039-2	Boys Bathroom by Room 35 @ B	SK	N/A		6/20/2024	-	-	-	Sign
1039-3	Boys Bathroom by Room 35 @ C	SK	N/A		6/20/2024	-	-	-	Sign
1039-4	Boys Bathroom by Room 35 @ D	SK	N/A		6/20/2024	-	-	-	Sign
1040-1	Custodial Closet by Room 35	SS	N/A		6/20/2024	-	-	-	Sign/Locked Door
1041-1	Hall by Room 35	WF	App	<1.0	6/20/2024	-	-	-	-
1041-2	Hall by Room 35 Bottle Filler	BF	App	<1.0	6/20/2024	-	-	-	-
1042-1	Girls Bathroom by Room 35 @ A	SK	N/A		6/20/2024	-	-	-	Sign
1042-2	Girls Bathroom by Room 35 @ B	SK	N/A		6/20/2024	-	-	-	Sign
1042-3	Girls Bathroom by Room 35 @ C	SK	N/A		6/20/2024	-	-	-	Sign
1042-4	Girls Bathroom by Room 35 @ D	SK	N/A		6/20/2024	-	-	-	Sign
1043-1	Room 38	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1043-2	Room 38	SK	N/A		6/20/2024	-	-	-	Sign
1044-1	Room 39	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1044-2	Room 39	SK	N/A		6/20/2024	-	-	-	Sign
1045-1	Boys Bathroom by Room 60 @ A	SK	N/A		6/20/2024	-	-	-	Sign
1045-2	Boys Bathroom by Room 60 @ B	SK	N/A		6/20/2024	-	-	-	Sign
1046-1	Custodial Closet by Room 60	SS	N/A		6/20/2024	-	-	-	Sign/Locked Door

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1047-1	Girls Bathroom by Room 60 @ A	SK	N/A		6/20/2024	-	-	-	Sign
1047-2	Girls Bathroom by Room 60 @ B	SK	N/A		6/20/2024	-	-	-	Sign
1048-1	Hall by Room 60 (Right)	WF	App	<1.0	6/20/2024	-	-	-	-
1048-2	Hall by Room 60 Bottle Filler (Right)	BF	App	<1.0	6/20/2024	-	-	-	-
1048-3	Hall by Room 60 (Left)	WF	N/A		6/20/2024	-	-	-	Non-functional; Waterline Turned Off; Sign
1049-1	Room 60	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1049-2	Room 60	SK	N/A		6/20/2024	-	-	-	Sign
1050-1	Room 59	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1050-2	Room 59	SK	N/A		6/20/2024	-	-	-	Sign
1051-1	Room 58	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1051-2	Room 58	SK	N/A		6/20/2024	-	-	-	Sign
1052-1	Room 57	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1052-2	Room 57	SK	N/A		6/20/2024	-	-	-	Sign
1053-1	Room 56	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1053-2	Room 56	SK	N/A		6/20/2024	-	-	-	Sign
1054-1	Room 55	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1054-2	Room 55	SK	N/A		6/20/2024	-	-	-	Sign
1055-1	Room 54	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1055-2	Room 54	SK	N/A		6/20/2024	-	-	-	Sign
1056-1	Room 53	WF	N/A		6/20/2024	-	-	-	Removed from Service; Fixture Removed
1056-2	Room 53	SK	N/A		6/20/2024	-	-	-	Sign

Laboratory Report

NYE Report #: 234254-26071

August 16, 2023

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Eastern Suffolk BOCES; Tecumseh Elementary School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on August 14, 2023. New York Environmental analyzed the samples on August 15, 2023 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,

A handwritten signature in black ink, appearing to read 'Li Tsang', is written over a horizontal line.

Li Tsang, Laboratory Director

Date Collected:	11 Aug 2023
Date Received:	14 Aug 2023
Date Analyzed:	15 Aug 2023

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
230814L011	1	Cafeterium - WF	0.001	<0.001	mg/L	
230814L012	2	Cafeterium - BF	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation



Laboratory Report

NYE Report #: 234839-26424

September 11, 2023

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Tecumseh Elementary School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on September 08, 2023. New York Environmental analyzed the samples on September 10, 2023 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,

A handwritten signature in black ink, appearing to be 'Li Tsang', written over a horizontal line.

Li Tsang, Laboratory Director

Date Collected:	07 Sep 2023
Date Received:	08 Sep 2023
Date Analyzed:	10 Sep 2023

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
230908K001	1	Hall by Room 10-BF, Initial	0.001	<0.001	mg/L	
230908K002	2	Hall by Room 10-WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation



Laboratory Report

NYE Report #: 2404250-30348

June 25, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Eastern Suffolk Boces; Tecumseh Elementary School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 21, 2024. New York Environmental analyzed the samples on June 24, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,

A handwritten signature in black ink, appearing to be 'Li Tsang', written over a horizontal line.

Li Tsang, Laboratory Director

Date Collected:	20 Jun 2024
Date Received:	21 Jun 2024
Date Analyzed:	24 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240621M032	1	Kitchen Island-SK, Initial	0.001	0.009	mg/L	H
240621M033	2	Kitchen Steamer Supply Spigot-SP, Initial	0.001	0.133	mg/L	E,H
240621M034	3	Nurses Office-SK, Initial	0.001	0.023	mg/L	H
240621M035	4	Hall by Gym-WF, Initial	0.001	<0.001	mg/L	
240621M036	5	Hall by Gym Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
240621M037	6	Room 12 Multi Purpose room-WF, Initial	0.001	<0.001	mg/L	
240621M038	7	Hall by Room 35-WF, Initial	0.001	<0.001	mg/L	
240621M039	8	Hall by Room 35 Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
240621M040	9	Hall by Room 60 (Right)-WF, Initial	0.001	<0.001	mg/L	
240621M041	10	Hall by Room 60 Bottle Filler (Right)-BF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.



Laboratory Report

NYE Report #: 2405000-30765

August 1, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Eastern Suffolk BOCES; Tecumseh Elementary School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on July 31, 2024. New York Environmental analyzed the samples on August 01, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,

A handwritten signature in black ink, appearing to read 'Li Tsang', is written over a horizontal line.

Li Tsang, Laboratory Director

Date Collected:	30 Jul 2024
Date Received:	31 Jul 2024
Date Analyzed:	01 Aug 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
240731L006	1	Kitchen-Steamer Supply-SP, Initial	0.001	0.036	mg/L	H

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

NYE Report #: 2405510-31012

September 4, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Eastern Suffolk BOCES; Tecumseh Elementary School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on August 29, 2024. New York Environmental analyzed the samples on August 30, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,

A handwritten signature in black ink, appearing to read 'Li Tsang', is written over a horizontal line.

Li Tsang, Laboratory Director

Date Collected:	28 Aug 2024
Date Received:	29 Aug 2024
Date Analyzed:	30 Aug 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
240829K001	1	Kitchen Steamer Supply Line-SP, Initial	0.001	<0.001	mg/L	
240829K002	2	Kitchen Steamer Supply Line-SP, 15 Sec Follow-up	0.001	<0.001	mg/L	
240829K003	3	Kitchen Steamer Supply Line-SP, 60 Sec Follow-up	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation