

Questions and Answers for

RFQ 26-002JO

DESIGN BUILD SERVICES FOR BDA-IN-BUILDING DISTRIBUTED ANTENNA SYSTEM & FIRE PANEL/ALARM UPGRADES

- Can you please provide addresses and floor plans of each building? If not, how many floors and overall sq ft of each?
- Plans provided. They can Google the addresses
- Does the vendor have to bid on both the Distributed Antenna System & Fire Panel Alarm scopes? Can vendors bid on only the DAS scope?
- Yes
- What are the working hours for this project?
- During school is fine as long as not disturbing school, but most work will need to be done nights, weekends, break.
- Can you provide a fire rating on each building or structure?
- Most corridors are 1 hours and classrooms are 2 hours.
- Can you provide the sprinkler status of each building?
- Brookhollow ES No Sprinkler
- Caldwell ES Building has sprinkler system
- Cele MS Building has sprinkler system
- Copperfield ES AFD, Building has sprinkler system
- Delco ES AFD, Partial sprinkler system
- Dessau ES No Sprinkler
- Dessau MS AFD, Building has sprinkler system
- Henderson HS Building has sprinkler system
- Kelly Lane MS Building has sprinkler system Murchison ES
- NW Academy No Sprinkler
- Park Crest MS Stage only/New addition wing
- Parmer Lane ES No Sprinkler
- Pflugerville ES No Sprinkler

- Pflugerville HS No Sprinkler
 - Pflugerville MS No Sprinkler
 - Provan Opp Ctr Building has sprinkler system
 - Riojas ES Building has sprinkler system
 - River Oaks No Sprinkler
 - Rowe Lane ES Building has sprinkler system
 - Ruth Barron ES Building has sprinkler system
 - Spring Hill ES No Sprinkler
 - Weiland ES Building has sprinkler system
 - Westview MS No Sprinkler
 - Windermere ES ½ of the school has a sprinkler system.
-
- Who is the FCC license for the jurisdiction(s)?
 - Williamson County & Travis County
 - Does the school district have a preferred low voltage contractor the winning vendor should utilize for the cable installation?
 - No, but STS360 has been doing some of the other campuses.
 - Should vendors include annual compliance audit/monitoring & management of the ERCES systems?
 - No
 - For the BDA Campuses are floor plans being provided?
 - Google link was sent upon request.
-
- On Fire Alarm upgrades is the district providing fire watch services while the fire system is being upgraded?
 - No. Contractor
-
- Are we able to walk any schools we are unfamiliar with?
 - Yes. Please contact for meeting time.