

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action	Units
1-93 SINK	7/10/2025 09:40	7/17/2025 22:40	70367053001	Lead	2.4	5	ug/L
2- BOYS LOCKER ROOM	7/10/2025 09:42	7/17/2025 22:41	70367053002	Lead	2.0	5	ug/L
3- BOYS LOCKER ROOM	7/10/2025 09:45	7/17/2025 22:43	70367053003	Lead	3.0	5	ug/L
4- GIRLS LOCKER ROOM	7/10/2025 09:46	7/17/2025 22:47	70367053004	Lead	7.2	5	ug/L
5-GIRLS LOCKER ROOM	7/10/2025 09:48	7/17/2025 22:49	70367053005	Lead	1.5	5	ug/L
6-86	7/10/2025 09:49	7/17/2025 22:50	70367053006	Lead	<1.0	5	ug/L
7- 86	7/10/2025 09:50	7/17/2025 22:52	70367053007	Lead	<1.0	5	ug/L
8- 84	7/10/2025 09:51	7/17/2025 22:54	70367053008	Lead	1.2	5	ug/L
9-87	7/10/2025 09:52	7/17/2025 22:55	70367053009	Lead	<1.0	5	ug/L
10- 2	7/10/2025 09:54	7/17/2025 22:57	70367053010	Lead	24.2	5	ug/L
11 - 2	7/10/2025 09:55	7/17/2025 22:58	70367053011	Lead	22.4	5	ug/L
12- 2	7/10/2025 09:57	7/21/2025 16:48	70367053012	Lead	22.4	5	ug/L
13- 2	7/10/2025 09:58	7/21/2025 16:49	70367053013	Lead	26.6	5	ug/L
14- 44	7/10/2025 09:59	7/21/2025 16:51	70367053014	Lead	1.4	5	ug/L
15 - 44	7/10/2025 10:00	7/21/2025 16:53	70367053015	Lead	<1.0	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb