ACIA
Airborne Contamination Identification Associates Ltd.
3430 Woodbridge Circle York, PA 17406 - PH: 717-767-1850 FAX: 717-767-1860

Customer Name: Derry Township
Address: 30C East Granada Ave
City, State, Zip: Hershey PA 17033
Attn:
email:
Date: July 30, 2025
RE: Early Childhood Center Water Sampling Results

Sample Date: 07/15/25
Lab ID AC24663:

Lab Sample Number	Client Sample ID/ Sample Location	Copper	EPA Action Level Copper	Lead	EPA Action Level Lead
1	Left Ftn @ 8	260 ppb	1,300 ppb	ND	15 ppb
2	Ftn @ 4	200 ppb	1,300 ppb	ND	15 ppb
3	Left Ftn @ 40	180 ppb	1,300 ppb	ND	15 ppb
4	Right Ftn @ Gym	190 ppb	1,300 ppb	ND	15 ppb
5	Right Ftn @ 20	390 ppb	1,300 ppb	ND	15 ppb
6	Right Ftn @32	180 ppb	1,300 ppb	ND	15 ppb

* ND- None Detected
** ppb- Parts per Billion

Comments / Recommendations:

ACIA has found all locations sampled on July 15, 2025 to be within EPA limits. There are no further recommendations at this time.

Regards,

AIRBORNE CONTAMINATION IDENTIFICATION ASSOCIATES, LTD.

Randall R. Leaman

Our Certifications:
WBENC: Certified Women Owned Business (WBE)
Pennsylvania Home Improvement Contractor Registration Number: PA 059333
NADCA Certified Ventilation Systems Mold Remediators (CVSMR)
NADCA Certified Air Systems Cleaning Specialists (ASCS)
AEE – Certified Indoor Air Quality Professional (CIAQP)
ACAC: Certified Mold Remediation Supervisor (Required by Maryland Law) (CMRS)
Anabec: Certified Microbial Remediator Supervisor and Product Distributor (CMRS
Co-Stars Number: 008-002

ACIA
Airborne Contamination Identification Associates Ltd.
3430 Woodbridge Circle York, PA 17406 - PH: 717-767-1850 FAX: 717-767-1860

Customer Name: Derry Township
Address: 30C East Granada Ave
City, State, Zip: Hershey PA 17033
Attn:
email:
Date: July 30, 2025
RE: Hershey Elem. Water Sampling Results

Sample Date: 07/15/25
Lab ID AC24836:

Lab Sample Number	Client Sample ID/ Sample Location	Copper	EPA Action Level Copper	Lead	EPA Action Level Lead
1	Left Ftn @ 7	260 ppb	1,300 ppb	ND	15 ppb
2	Left Ftn @ 26	160 ppb	1,300 ppb	ND	15 ppb
3	Right Ftn @ 35	160 ppb	1,300 ppb	ND	15 ppb
4	Left Ftn @ Café 2	110 ppb	1,300 ppb	ND	15 ppb
5	Right Ftn @ 62	170 ppb	1,300 ppb	ND	15 ppb
6	Gym Ftn	130 ppb	1,300 ppb	1.04 ppb	15 ppb

* ND- None Detected
** ppb- Parts per Billion

Comments / Recommendations:

ACIA has found all locations sampled on July 15, 2025 to be within EPA limits. There are no further recommendations at this time.

Regards,

AIRBORNE CONTAMINATION IDENTIFICATION ASSOCIATES, LTD.

Randall R. Leaman

Our Certifications:
WBENC: Certified Women Owned Business (WBE)
Pennsylvania Home Improvement Contractor Registration Number: PA 059333
NADCA Certified Ventilation Systems Mold Remediators (CVSMR)
NADCA Certified Air Systems Cleaning Specialists (ASCS)
AEE – Certified Indoor Air Quality Professional (CIAQP)
ACAC: Certified Mold Remediation Supervisor (Required by Maryland Law) (CMRS)
Anabec: Certified Microbial Remediator Supervisor and Product Distributor (CMRS
Co-Stars Number: 008-002

ACIA
Airborne Contamination Identification Associates Ltd.
3430 Woodbridge Circle York, PA 17406 - PH: 717-767-1850 FAX: 717-767-1860

Customer Name: Derry Township
Address: 30C East Granada Ave
City, State, Zip: Hershey PA 17033
Attn:
email:
Date: July 30, 2025
RE: Hershey Middle School Water Sampling Results

Sample Date: 07/15/25
Lab ID AC24720:

Lab Sample Number	Client Sample ID/ Sample Location	Copper	EPA Action Level Copper	Lead	EPA Action Level Lead
1	Ftn @ A133	940 ppb	1,300 ppb	ND	15 ppb
2	Ftn @ A144	250 ppb	1,300 ppb	ND	15 ppb
3	Ftn @ LGI	650 ppb	1,300 ppb	ND	15 ppb
4	Ftn @ B116	290 ppb	1,300 ppb	ND	15 ppb
5	Ftn @ 659	140 ppb	1,300 ppb	ND	15 ppb
6	Ftn @ 616	1,000 ppb	1,300 ppb	ND	15 ppb

* ND- None Detected
** ppb- Parts per Billion

Comments / Recommendations:

ACIA has found all locations sampled on July 15, 2025 to be within EPA limits. There are no further recommendations at this time.

Regards,

AIRBORNE CONTAMINATION IDENTIFICATION ASSOCIATES, LTD.

Randall R. Leaman

Our Certifications:
WBENC: Certified Women Owned Business (WBE)
Pennsylvania Home Improvement Contractor Registration Number: PA 059333
NADCA Certified Ventilation Systems Mold Remediators (CVSMR)
NADCA Certified Air Systems Cleaning Specialists (ASCS)
AEE – Certified Indoor Air Quality Professional (CIAQP)
ACAC: Certified Mold Remediation Supervisor (Required by Maryland Law) (CMRS)
Anabec: Certified Microbial Remediator Supervisor and Product Distributor (CMRS
Co-Stars Number: 008-002

ACIA
Airborne Contamination Identification Associates Ltd.
3430 Woodbridge Circle York, PA 17406 - PH: 717-767-1850 FAX: 717-767-1860

Customer Name: Derry Township
Address: 30C East Granada Ave
City, State, Zip: Hershey PA 17033
Attn:
email:
Date: July 30, 2025
RE: Hershey High School Water Sampling Results

Sample Date: 07/15/25
Lab ID AC24832:

Lab Sample Number	Client Sample ID/ Sample Location	Copper	EPA Action Level Copper	Lead	EPA Action Level Lead
1	B001 Ftn	190 ppb	1,300 ppb	ND	15 ppb
2	Left Ftn @ Gym	150 ppb	1,300 ppb	ND	15 ppb
3	Right Ftn @ Chorus	230 ppb	1,300 ppb	ND	15 ppb
4	Right Ftn @ G152	680 ppb	1,300 ppb	ND	15 ppb
5	Left Ftn @ D209	500 ppb	1,300 ppb	ND	15 ppb
6	Right Ftn @ F227	280 ppb	1,300 ppb	ND	15 ppb

* ND- None Detected
** ppb- Parts per Billion

Comments / Recommendations:

ACIA has found all locations sampled on July 15, 2025 to be within EPA limits. There are no further recommendations at this time.

Regards,

AIRBORNE CONTAMINATION IDENTIFICATION ASSOCIATES, LTD.

Randall R. Leaman

Our Certifications:
WBENC: Certified Women Owned Business (WBE)
Pennsylvania Home Improvement Contractor Registration Number: PA 059333
NADCA Certified Ventilation Systems Mold Remediators (CVSMR)
NADCA Certified Air Systems Cleaning Specialists (ASCS)
AEE – Certified Indoor Air Quality Professional (CIAQP)
ACAC: Certified Mold Remediation Supervisor (Required by Maryland Law) (CMRS)
Anabec: Certified Microbial Remediator Supervisor and Product Distributor (CMRS
Co-Stars Number: 008-002