

Building	Device Name	Location	Fixture Type	2025 Test level (>5 ppb)	Immediate Action Taken	Remedial Action Plan
Dansville HS:	HS-135-S	Choral Music	Sink	6.4	Out of Service - 7/23/25	Replace lines and/or faucet
	HS-301-S4	301 West Wall	Sink	5	Out of Service - 7/23/25	Replace lines and/or faucet
	HS-307-S7	307 West Wall	Sink	8.7	Out of Service - 7/23/25	Replace lines and/or faucet
	HS-307-S9	307 East Sink	Sink	31.8	Out of Service - 7/23/25	Replace lines and/or faucet
	HS-312-S4	312 South Wall	Sink	9.4	Out of Service - 7/23/25	Replace lines and/or faucet
Dansville MS Bldg on Clara Barton:	MS-005-S2	Kitchen	Sink	10.3	Out of Service - 7/23/25	Replace lines and/or faucet
	MS-005-S4	Kitchen	Sink	27.9	Out of Service - 7/23/25	Replace lines and/or faucet
	MS-11B-S	Boys Locker Room Restroom	Sink	16.7	Out of Service - 7/23/25	Install Signage
	MS-308-S	308	Sink	18.8	Out of Service - 7/23/25	Install Signage
	MS-C100-DF	Corridor C100	Drinking Fountain	6.5	Out of Service - 7/23/25	Replace lines and/or faucet
	MS-T100-S2	T100	Sink	8.4	Out of Service - 7/23/25	Replace lines and/or faucet
	MS-T100-S4	T100	Sink	26.3	Out of Service - 7/23/25	Replace lines and/or faucet
	MS-T202-S1	T202	Sink	20.3	Out of Service - 7/23/25	Replace lines and/or faucet
	MS-T202-S3	T202	Sink	15.5	Out of Service - 7/23/25	Replace lines and/or faucet
	MS-T205-S2	T205	Sink	5.4	Out of Service - 7/23/25	Replace lines and/or faucet
	MS-T301-S1	T301	Sink	29.2	Out of Service - 7/23/25	Replace lines and/or faucet
	MS-T301-S4	T301	Sink	27.6	Out of Service - 7/23/25	Replace lines and/or faucet
	MS-T302-S1	T302	Sink	60.9	Out of Service - 7/23/25	Replace lines and/or faucet
	MS-T302-S3	T302	Sink	25.5	Out of Service - 7/23/25	Replace lines and/or faucet
	MS-T302-S4	T302	Sink	71.8	Out of Service - 7/23/25	Replace lines and/or faucet
Dansville ES:	ES-200-S10	200 Prep Area	Sink	5.3	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-129-S6	Kitchen- Handwashing Sink Exterior W	Sink	6.1	Out of Service - 7/23/25	Install Signage
	ES-99T-S	Coaches office 99E restroom	Sink	6.4	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-130-S	127 Bathroom	Sink	7	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-200-S9B	200 R	Drinking Fountain	18.7	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-200-S2	200	Sink	20.7	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-200-S1	200	Sink	32.5	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-129-S8	Kitchen- Faucet Storage Wall	Sink	38.5	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-129-SP7	Kitchen-Sprayer Storage Wall	Sprayer	41.7	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-200-S5B	200 R	Sink	51.2	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-200-S6B	200 R	Sink	52	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-200-S6A	200 L	Sink	62.9	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-200-S7A	200 L	Sink	64.1	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-200-S9A	200 L	Sink	70.9	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-200-S7B	200 R	Sink	75.3	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-200-S3	200	Sink	88.4	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-200-S8B	200 R	Drinking Fountain	93.3	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-200-S5A	200 L	Sink	93.6	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-200-S4A	200 L	Sink	94.6	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-200-S8A	200 L	Sink	103	Out of Service - 7/23/25	Replace lines and/or faucet
	ES-200-S4B	200 R	Sink	109	Out of Service - 7/23/25	Replace lines and/or faucet
Dansville Primary:	PS-102-DF	102	Drinking Fountain	9	Out of Service - 7/23/25	Replace lines and/or faucet
	PS-104-DF	104	Drinking Fountain	54.8	Out of Service - 7/23/25	Replace lines and/or faucet
Ralph Clements Field:	RCF-TR-S	Trainer's Room	Sink	24.4	Out of Service - 7/23/25	Install Signage
Dansville District Office	DO-MR-S	Men's Restroom	Sink	6.5	Out of Service - 7/23/25	Signage installed