

July 22, 2025

Mr. Derek Brown
Dansville CSD
337 Main Street
Dansville, New York 14437

Re: Lead Testing in School Drinking Water

Dear Mr. Brown:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Dansville CSD, including:

- Dansville Elementary School – 280 Main Street, Dansville, NY

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on May 27, 2025. As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 21 sources of potable water at Dansville Elementary School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (*Response Actions Required Under NYS Regulations*).

Thank you for the opportunity to be of service to Dansville CSD.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Dansville CSD

Prepared by:



**3860 California Road
Orchard Park, New York 14127**

Conditions as of May 27, 2025

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Dansville CSD to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- Dansville Elementary School – 280 Main Street, Dansville, NY

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Dansville Elementary School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***3Ts for Reducing Lead in Drinking Water in Schools***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at Dansville Elementary School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Dansville Elementary School	May 27, 2025	110	89	21

*NYS Action Level is 5 parts per billion

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
ES-200-S10	200 Prep Area	Sink	5.3
ES-129-S6	Kitchen- Handwashing Sink Exterior Wall	Sink	6.1
ES-99T-S	Coaches office 99E restroom	Sink	6.4
ES-130-S	127 Bathroom	Sink	7.0
ES-200-S9B	200 R	Drinking Fountain	18.7
ES-200-S2	200	Sink	20.7
ES-200-S1	200	Sink	32.5
ES-129-S8	Kitchen- Faucet Storage Wall	Sink	38.5
ES-129-SP7	Kitchen-Sprayer Storage Wall	Sprayer	41.7
ES-200-S5B	200 R	Sink	51.2
ES-200-S6B	200 R	Sink	52.0
ES-200-S6A	200 L	Sink	62.9
ES-200-S7A	200 L	Sink	64.1
ES-200-S9A	200 L	Sink	70.9
ES-200-S7B	200 R	Sink	75.3
ES-200-S3	200	Sink	88.4
ES-200-S8B	200 R	Drinking Fountain	93.3
ES-200-S5A	200 L	Sink	93.6
ES-200-S4A	200 L	Sink	94.6
ES-200-S8A	200 L	Sink	103
ES-200-S4B	200 R	Sink	109

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports and Chain of Custody Documents



June 24, 2025

Service Request No:R2506756

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Dansville CSD Elementary School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory June 06, 2025
For your reference, these analyses have been assigned our service request number **R2506756**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Client: Stohl Environmental
Project: Dansville CSD Elementary School
Sample Matrix: Drinking Water

Service Request: R2506756
Date Received: 06/06/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 06/06/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by

A handwritten signature in black ink, appearing to read 'Meghan Pedicini', is written over a horizontal line.

Date

06/24/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: ES-97B-S				Lab ID: R2506756-003		
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.2			1.0	ug/L	200.8
CLIENT ID: ES-101-S2A				Lab ID: R2506756-008		
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.4			1.0	ug/L	200.8
CLIENT ID: ES-101-S2B				Lab ID: R2506756-009		
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8
CLIENT ID: ES-101-S2C				Lab ID: R2506756-010		
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8
CLIENT ID: ES-C100-DF				Lab ID: R2506756-011		
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.4			1.0	ug/L	200.8
CLIENT ID: ES-107-S				Lab ID: R2506756-016		
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8
CLIENT ID: ES-107-DF				Lab ID: R2506756-017		
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.8			1.0	ug/L	200.8
CLIENT ID: ES-106-S				Lab ID: R2506756-020		
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8
CLIENT ID: ES-99B-S				Lab ID: R2506756-022		
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.1			1.0	ug/L	200.8
CLIENT ID: ES-99C-S1				Lab ID: R2506756-023		
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8
CLIENT ID: ES-99C-S2				Lab ID: R2506756-024		
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8
CLIENT ID: ES-99D-S1				Lab ID: R2506756-025		
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: ES-99D-S2			Lab ID: R2506756-026			
-----------------------------	--	--	-----------------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8

CLIENT ID: ES-99T-S			Lab ID: R2506756-027			
----------------------------	--	--	-----------------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.4			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3

Service Request:R2506756

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2506756-001	ES-94-S	5/27/2025	
R2506756-002	ES-97-S	5/27/2025	
R2506756-003	ES-97B-S	5/27/2025	
R2506756-004	ES-97T-S	5/27/2025	
R2506756-005	ES-100D-S	5/27/2025	
R2506756-006	ES-100A-S	5/27/2025	
R2506756-007	ES-101-S1	5/27/2025	
R2506756-008	ES-101-S2A	5/27/2025	
R2506756-009	ES-101-S2B	5/27/2025	
R2506756-010	ES-101-S2C	5/27/2025	
R2506756-011	ES-C100-DF	5/27/2025	
R2506756-012	ES-103-S	5/27/2025	
R2506756-013	ES-103-DF	5/27/2025	
R2506756-014	ES-105-S	5/27/2025	
R2506756-015	ES-105-DF	5/27/2025	
R2506756-016	ES-107-S	5/27/2025	
R2506756-017	ES-107-DF	5/27/2025	
R2506756-018	ES-109-S	5/27/2025	
R2506756-019	ES-109-DF	5/27/2025	
R2506756-020	ES-106-S	5/27/2025	
R2506756-021	ES-C100-BF	5/27/2025	
R2506756-022	ES-99B-S	5/27/2025	
R2506756-023	ES-99C-S1	5/27/2025	
R2506756-024	ES-99C-S2	5/27/2025	
R2506756-025	ES-99D-S1	5/27/2025	
R2506756-026	ES-99D-S2	5/27/2025	
R2506756-027	ES-99T-S	5/27/2025	
R2506756-028	ES-135-EDF1	5/27/2025	
R2506756-029	ES-135-EBF	5/27/2025	
R2506756-030	ES-135-WDF2	5/27/2025	
R2506756-031	ES-135-WDF3	5/27/2025	
R2506756-032	ES-146-S	5/27/2025	
R2506756-033	ES-146-DF	5/27/2025	
R2506756-034	ES-145-S	5/27/2025	
R2506756-035	ES-145-DF	5/27/2025	
R2506756-036	ES-144-S	5/27/2025	



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-201.3

Client: Dansville CSD Contact: Derek Brown

Building: Elementary School Location: 280 Main St, Dansville, NY 14437

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
ES-94-S	94 Faculty Lounge	Sink	0:39
ES-97-S	Nurse Office	Sink	0:40
ES-97B-S	Nurse Exam Room	Sink	0:41
ES-97T-S	Nurse Restroom	Sink	0:42
ES-100D-S	100 Restroom	Sink	0:43
ES-100A-S	100 Principals Office	Sink	0:44
ES-101-S1	101 Art North West Corner	Sink	0:45
ES-101-S2A	101 Art East Wall Left	Sink	0:46
ES-101-S2B	102 Art East Wall Center	Sink	0:47
ES-101-S2C	103 Art East Wall Right	Sink	0:48
ES-C100-DF	Corridor C100 Between 102D & 102E	Drinking Fountain	0:38
ES-103-S	103	Sink	0:37
ES-103-DF	103	Drinking Fountain	0:36
ES-105-S	105	Sink	0:35
ES-105-DF	105	Drinking Fountain	0:34
ES-107-S	107	Sink	0:33
ES-107-DF	107	Drinking Fountain	0:32
ES-109-S	109	Sink	0:31

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

☒ If checked, also e-mail results to:

Rfranoine@stohlenvironmental.com

Sampled By: R. Franoine & M. Scinta Print Name Stohl Env: R. Franoine & M. Scinta Date: 5/27/2025

Relinquished By: Rebecca Franoine Print Name Stohl Env: Rebecca Franoine Date: 6/5/2025

Received (Name / Lab): Mark Long Date: 6/6/25 Time: 15:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

R2506756

5

Stohl Environmental
Dansville CSD Elementary School





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-201.3

Client: Dansville CSD Contact: Derek Brown

Building: Elementary School Location: 280 Main St, Dansville, NY 14437

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
ES-109-DF	109	Drinking Fountain	0:30
ES-106-S	106	Sink	0:29
ES-C100-BF	Corridor C100 South Hallway	Bottle Filler	0:28
ES-99B-S	Coaches office 99A restroom	Sink	0:27
ES-99C-S1	Changing room South Left	Sink	0:26
ES-99C-S2	Changing room South Right	Sink	0:25
ES-99D-S1	Changing room North Left	Sink	0:24
ES-99D-S2	Changing room North Right	Sink	0:23
ES-99T-S	Coaches office 99E restroom	Sink	0:22
ES-135-EDF1	East Entrance	Drinking Fountain	0:21
ES-135-EBF	East Entrance	Bottle Filler	0:20
ES-135-WDF2	West Entrance Left Fountain	Drinking Fountain	0:19
ES-135-WDF3	West Entrance Right Fountain	Drinking Fountain	0:18
ES-146-S	146	Sink	0:17
ES-146-DF	146	Drinking Fountain	0:16
ES-145-S	145	Sink	0:15
ES-145-DF	145	Drinking Fountain	0:14
ES-144-S	144	Sink	0:13

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Rfrancoine@stohlenvironmental.com

Sampled By: R. Francoine & M. Scinta Print Name Stohl Env: R. Francoine & M. Scint Date: 5/27/2025

Relinquished By: Rebecca Francoine Print Name Stohl Env: Rebecca Francoine Date: 6/5/2025

Received (Name / Lab): Matt Long Date: 6/6/25 Time: 15:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Cooler Receipt and Preservation

R2506756

5

Stahl Environmental
Danville CSD Elementary School



Project/Client Stahl Env.

Folder Number _____

Cooler received on 6/6/20

by: RDA

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>N</u>
2	Custody papers properly completed (ink, signed)?	<u>Y</u> N
3	Did all bottles arrive in good condition (unbroken)?	<u>Y</u> N
4	Circle: <u>Wet Ice</u> Dry Ice Gel packs present?	<u>Y</u> N

5a	Did VOA vials have sig* bubbles?	Y N <u>NA</u>
5b	Sig* bubbles: Alk? Y N <u>NA</u> Sulfide? Y N <u>NA</u>	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035se	<u>NA</u>

8. Temperature Readings

Date: 6/6/20 Time: 14:20

ID: IR#12 IR#1

From: Temp Blank Sample Bottle

Temp (°C)	<u>19.2</u>						
Within 0-6°C?	<u>Y</u> <u>N</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule

& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by RDA on 6/6/20 at 14:21
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 6/11/25 Time: 12:35 by: KL

- Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- Did all bottle labels and tags agree with custody papers? YES NO
- Were correct containers used for the tests indicated? YES NO
- Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- Were dissolved metals filtered in the field? YES NO N/A
- Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?	Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
≥12		NaOH	Yes No						
≤2	<u>204524</u>	HNO ₃	<u>X</u>	<u>NOYE</u>		<u>All</u>	<u>4ml each</u>	<u>242045</u>	<u>All 52</u>
≤2		H ₂ SO ₄							
<4		NaHSO ₄							
5-9		For 608pest		No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522		If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃							
		ZnAcetate	- -						
		HCl	** **						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 101424-2ADD, 111824-2ADD, 102824-2ADD,

Explain all Discrepancies/ Other Comments:

* metals do not need to be on ice

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: KL

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.	+	Correlation coefficient for MSA is <0.995.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).	N	Inorganics- Matrix spike recovery was outside laboratory limits.
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.	N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.	S	Concentration has been determined using Method of Standard Additions (MSA).
E	Organics- Concentration has exceeded the calibration range for that specific analysis.	W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.	P	Concentration >40% difference between the two GC columns.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.	C	Confirmed by GC/MS
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.	Q	DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
#	Spike was diluted out.	X	See Case Narrative for discussion.
		MRL	Method Reporting Limit. Also known as:
		LOQ	Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
		MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
		LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
		ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506756**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-94-S**Date Collected:** 05/27/25**Lab Code:** R2506756-001**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-97-S**Date Collected:** 05/27/25**Lab Code:** R2506756-002**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-97B-S**Date Collected:** 05/27/25**Lab Code:** R2506756-003**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-97T-S**Date Collected:** 05/27/25**Lab Code:** R2506756-004**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-100D-S**Date Collected:** 05/27/25**Lab Code:** R2506756-005**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506756**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-100A-S**Date Collected:** 05/27/25**Lab Code:** R2506756-006**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-101-S1**Date Collected:** 05/27/25**Lab Code:** R2506756-007**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-101-S2A**Date Collected:** 05/27/25**Lab Code:** R2506756-008**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-101-S2B**Date Collected:** 05/27/25**Lab Code:** R2506756-009**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-101-S2C**Date Collected:** 05/27/25**Lab Code:** R2506756-010**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506756**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-C100-DF**Date Collected:** 05/27/25**Lab Code:** R2506756-011**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-103-S**Date Collected:** 05/27/25**Lab Code:** R2506756-012**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-103-DF**Date Collected:** 05/27/25**Lab Code:** R2506756-013**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-105-S**Date Collected:** 05/27/25**Lab Code:** R2506756-014**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-105-DF**Date Collected:** 05/27/25**Lab Code:** R2506756-015**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506756**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-107-S**Date Collected:** 05/27/25**Lab Code:** R2506756-016**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-107-DF**Date Collected:** 05/27/25**Lab Code:** R2506756-017**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-109-S**Date Collected:** 05/27/25**Lab Code:** R2506756-018**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-109-DF**Date Collected:** 05/27/25**Lab Code:** R2506756-019**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-106-S**Date Collected:** 05/27/25**Lab Code:** R2506756-020**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506756**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-C100-BF**Date Collected:** 05/27/25**Lab Code:** R2506756-021**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-99B-S**Date Collected:** 05/27/25**Lab Code:** R2506756-022**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-99C-S1**Date Collected:** 05/27/25**Lab Code:** R2506756-023**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-99C-S2**Date Collected:** 05/27/25**Lab Code:** R2506756-024**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

NMANSEN

Sample Name: ES-99D-S1**Date Collected:** 05/27/25**Lab Code:** R2506756-025**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506756**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-99D-S2**Date Collected:** 05/27/25**Lab Code:** R2506756-026**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-99T-S**Date Collected:** 05/27/25**Lab Code:** R2506756-027**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-135-EDF1**Date Collected:** 05/27/25**Lab Code:** R2506756-028**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-135-EBF**Date Collected:** 05/27/25**Lab Code:** R2506756-029**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-135-WDF2**Date Collected:** 05/27/25**Lab Code:** R2506756-030**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506756**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-135-WDF3**Date Collected:** 05/27/25**Lab Code:** R2506756-031**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-146-S**Date Collected:** 05/27/25**Lab Code:** R2506756-032**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-146-DF**Date Collected:** 05/27/25**Lab Code:** R2506756-033**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-145-S**Date Collected:** 05/27/25**Lab Code:** R2506756-034**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-145-DF**Date Collected:** 05/27/25**Lab Code:** R2506756-035**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental

Service Request: R2506756

Project: Dansville CSD Elementary School/2023L-201.3

Sample Name: ES-144-S

Date Collected: 05/27/25

Lab Code: R2506756-036

Date Received: 06/6/25

Sample Matrix: Drinking Water

Analysis Method

Extracted/Digested By

Analyzed By

200.8

MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7	200.2
200.8	200.2
6010C or 6010D	3005A/3010A
6020A or 6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010C or 6010D	3050B
6020A or 6020B	3050B
6010C or 6010D TCLP (1311) extract	3005A/3010A
6010C or 6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-94-S
Lab Code: R2506756-001

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 16:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-97-S
Lab Code: R2506756-002

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 16:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-97B-S
Lab Code: R2506756-003

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	06/18/25 16:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-97T-S
Lab Code: R2506756-004

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 17:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-100D-S
Lab Code: R2506756-005

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 17:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-100A-S
Lab Code: R2506756-006

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 17:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-101-S1
Lab Code: R2506756-007

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 17:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-101-S2A
Lab Code: R2506756-008

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.4	ug/L	1.0	1	06/18/25 17:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-101-S2B
Lab Code: R2506756-009

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	06/18/25 17:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-101-S2C
Lab Code: R2506756-010

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	06/18/25 17:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-C100-DF
Lab Code: R2506756-011

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	06/18/25 17:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-103-S
Lab Code: R2506756-012

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 17:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-103-DF
Lab Code: R2506756-013

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 17:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-105-S
Lab Code: R2506756-014

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 17:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-105-DF
Lab Code: R2506756-015

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 17:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-107-S
Lab Code: R2506756-016

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	06/18/25 17:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-107-DF
Lab Code: R2506756-017

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.8	ug/L	1.0	1	06/18/25 17:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-109-S
Lab Code: R2506756-018

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 17:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-109-DF
Lab Code: R2506756-019

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 17:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-106-S
Lab Code: R2506756-020

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	06/23/25 10:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-C100-BF
Lab Code: R2506756-021

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 17:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-99B-S
Lab Code: R2506756-022

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.1	ug/L	1.0	1	06/18/25 17:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-99C-S1
Lab Code: R2506756-023

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	06/18/25 17:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-99C-S2
Lab Code: R2506756-024

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	06/14/25 11:58	06/13/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-99D-S1
Lab Code: R2506756-025

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	06/18/25 17:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-99D-S2
Lab Code: R2506756-026

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	06/18/25 17:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-99T-S
Lab Code: R2506756-027

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.4	ug/L	1.0	1	06/18/25 17:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-135-EDF1
Lab Code: R2506756-028

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 17:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-135-EBF
Lab Code: R2506756-029

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-135-WDF2
Lab Code: R2506756-030

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-135-WDF3
Lab Code: R2506756-031

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-146-S
Lab Code: R2506756-032

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-146-DF
Lab Code: R2506756-033

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-145-S
Lab Code: R2506756-034

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-145-DF
Lab Code: R2506756-035

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-144-S
Lab Code: R2506756-036

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:10	



QC Summary Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2506756-MB1

Service Request: R2506756
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/14/25 11:37	06/13/25	
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 17:38	NA	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2506756-MB2

Service Request: R2506756
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 16:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2506756-MB3

Service Request: R2506756
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/23/25 10:47	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25
Date Analyzed: 06/18/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: ES-109-DF
Lab Code: R2506756-019
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	20.4	20.0	102	19.7	20.0	98	70-130	4	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506756
Date Collected: 05/27/25
Date Received: 06/06/25
Date Analyzed: 06/23/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: ES-106-S
Lab Code: R2506756-020
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2506756-020MS		Result	Duplicate Matrix Spike R2506756-020DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.3	22.3	20.0	105	21.5	20.0	101	70-130	4	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506756
Date Analyzed: 06/14/25 - 06/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L**Basis:**NA**Lab Control Sample**

R2506756-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.5	20.0	97	85-115
Lead, Total	200.8	20.6	20.0	103	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506756
Date Analyzed: 06/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2506756-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.7	20.0	104	85-115

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506756

Date Analyzed: 06/23/25

Lab Control Sample Summary

Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2506756-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.3	20.0	107	85-115



June 23, 2025

Service Request No:R2506757

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Dansville CSD Elementary School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory June 06, 2025
For your reference, these analyses have been assigned our service request number **R2506757**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE

+1 585 288 5380

FAX

+1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Client: Stohl Environmental
Project: Dansville CSD Elementary School
Sample Matrix: Drinking Water

Service Request: R2506757
Date Received: 06/06/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 06/06/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by

A handwritten signature in black ink, appearing to read 'Meghan Pedicini', is written over a horizontal line.

Date

06/20/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: ES-144-DF		Lab ID: R2506757-001				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.9			1.0	ug/L	200.8
CLIENT ID: ES-117-S		Lab ID: R2506757-014				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8
CLIENT ID: ES-122-S2		Lab ID: R2506757-019				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.8			1.0	ug/L	200.8
CLIENT ID: ES-126-S		Lab ID: R2506757-021				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.0			1.0	ug/L	200.8
CLIENT ID: ES-127-S		Lab ID: R2506757-023				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8
CLIENT ID: ES-130-S		Lab ID: R2506757-025				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	7.0			1.0	ug/L	200.8
CLIENT ID: ES-129-SP2		Lab ID: R2506757-027				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8
CLIENT ID: ES-129-S3		Lab ID: R2506757-028				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.4			1.0	ug/L	200.8
CLIENT ID: ES-129-S6		Lab ID: R2506757-031				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.1			1.0	ug/L	200.8
CLIENT ID: ES-129-SP7		Lab ID: R2506757-032				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	41.7			1.0	ug/L	200.8
CLIENT ID: ES-129-S8		Lab ID: R2506757-033				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	38.5			1.0	ug/L	200.8
CLIENT ID: ES-200-S1		Lab ID: R2506757-034				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	32.5			1.0	ug/L	200.8



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: ES-200-S2			Lab ID: R2506757-035			
-----------------------------	--	--	-----------------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	20.7			1.0	ug/L	200.8

CLIENT ID: ES-200-S3			Lab ID: R2506757-036			
-----------------------------	--	--	-----------------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	88.4			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3

Service Request:R2506757

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2506757-001	ES-144-DF	5/27/2025	
R2506757-002	ES-141-S	5/27/2025	
R2506757-003	ES-139-S	5/27/2025	
R2506757-004	ES-C102-DF	5/27/2025	
R2506757-005	ES-C102-BF	5/27/2025	
R2506757-006	ES-113-S	5/27/2025	
R2506757-007	ES-113-DF	5/27/2025	
R2506757-008	ES-114-S	5/27/2025	
R2506757-009	ES-114-DF	5/27/2025	
R2506757-010	ES-115-S	5/27/2025	
R2506757-011	ES-115-DF	5/27/2025	
R2506757-012	ES-116-S	5/27/2025	
R2506757-013	ES-116-DF	5/27/2025	
R2506757-014	ES-117-S	5/27/2025	
R2506757-015	ES-117-DF	5/27/2025	
R2506757-016	ES-118-S	5/27/2025	
R2506757-017	ES-118-DF	5/27/2025	
R2506757-018	ES-122-S1	5/27/2025	
R2506757-019	ES-122-S2	5/27/2025	
R2506757-020	ES-123-S	5/27/2025	
R2506757-021	ES-126-S	5/27/2025	
R2506757-022	ES-128-S	5/27/2025	
R2506757-023	ES-127-S	5/27/2025	
R2506757-024	ES-127-S	5/27/2025	
R2506757-025	ES-130-S	5/27/2025	
R2506757-026	ES-129-S1	5/27/2025	
R2506757-027	ES-129-SP2	5/27/2025	
R2506757-028	ES-129-S3	5/27/2025	
R2506757-029	ES-129-SP4	5/27/2025	
R2506757-030	ES-129-S5	5/27/2025	
R2506757-031	ES-129-S6	5/27/2025	
R2506757-032	ES-129-SP7	5/27/2025	
R2506757-033	ES-129-S8	5/27/2025	
R2506757-034	ES-200-S1	5/27/2025	
R2506757-035	ES-200-S2	5/27/2025	
R2506757-036	ES-200-S3	5/27/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-201.3

Client: Dansville CSD

Contact: Derek Brown

Building: Elementary School

Location: 280 Main St, Dansville, NY 14437

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
ES-144-DF	144	Drinking Fountain	0:12
ES-141-S	141 Restroom	Sink	0:11
ES-139-S	139	Sink	0:10
ES-C102-DF	Corridor C102 Adjacent 112	Drinking Fountain	0:09
ES-C102-BF	Corridor C102 Adjacent 112	Bottle Filler	0:08
ES-113-S	113	Sink	0:07
ES-113-DF	113	Drinking Fountain	0:06
ES-114-S	114	Sink	0:05
ES-114-DF	114	Drinking Fountain	0:04
ES-115-S	115	Sink	0:03
ES-115-DF	115	Drinking Fountain	0:02
ES-116-S	116	Sink	0:01
ES-116-DF	116	Drinking Fountain	0:00
ES-117-S	117	Sink	23:59
ES-117-DF	117	Drinking Fountain	23:58
ES-118-S	118	Sink	23:57
ES-118-DF	118	Drinking Fountain	23:56
ES-122-S1	122 Music Classroom Right	Sink	23:55

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Rfranoine@stohlenvironmental.com

Sampled By: R. Franoine & M. Scinta Print Name Stohl Env: R. Franoine & M. Scinta Date: 5/27/2025

Relinquished By: Rebecca Franoine Print Name Stohl Env: Rebecca Franoine Date: 6/5/2025

Received (Name / Lab): Matt Franoine Date: 6/6/25 Time: 15:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-201.3

Client: Dansville CSD

Contact: Derek Brown

Building: Elementary School

Location: 280 Main St, Dansville, NY 14437

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
ES-122-S2	122 Music Classroom Left	Sink	23:54
ES-123-S	123	Sink	23:53
ES-126-S	126 Restroom	Sink	23:52
ES-128-S	128 Restroom	Sink	23:51
ES-127-S	127	Sink	23:50
ES-127-S2	127	Sink	23:48
ES-130-S	127 Bathroom	Sink	23:49
ES-129-S1	Kitchen - serving side center wall, North Side	Sink	23:40
ES-129-SP2	Kitchen - Exterior wall South Side	Sprayer	23:41
ES-129-S3	Kitchen -Center Wall South Side Right	Sink	23:42
ES-129-SP4	Kitchen - Center Wall Sprayer	Sprayer	23:43
ES-129-S5	Kitchen- Center Wall South Side Left	Sink	23:44
ES-129-S6	Kitchen- Handwashing Sink Exterior Wall	Sink	23:45
ES-129-SP7	Kitchen-Sprayer Storage Wall	Sprayer	23:46
ES-129-S8	Kitchen- Faucet Storage Wall	Sink	23:47
ES-200-S1	200	Sink	0:20
ES-200-S2	200	Sink	0:19
ES-200-S3	200	Sink	0:18

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Rfranjoiene@stohlenvironmental.com

Sampled By: R. Franjoiene & M. Scinta Print Name Stohl Env: R. Franjoiene & M. Scinta Date: 5/27/2025

Relinquished By: Rebecca Franjoiene Print Name Stohl Env: Rebecca Franjoiene Date: 6/5/2025

Received (Name / Lab): Matt Long Date: 6/6/25 Time: 15:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2506757

5

Stohl Environmental
Danville CSD Elementary School

Cooler Receipt and Preservation C

Project/Client Stohl Env. Folder Number _____Cooler received on 6/6/25 by: RDACOURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>N</u>
2	Custody papers properly completed (ink, signed)?	<u>Y</u> N
3	Did all bottles arrive in good condition (unbroken)?	<u>Y</u> N
4	Circle: <u>Wet Ice</u> Dry Ice Gel packs present?	<u>Y</u> N

5a	Did VOA vials have sig* bubbles?	Y N <u>NA</u>
5b	Sig* bubbles: Alk? Y N <u>NA</u> Sulfide? Y N <u>NA</u>	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035se	<u>NA</u>

8. Temperature Readings Date: 6/6/25 Time: 1420 ID: IR#12 IR#1 From: Temp Blank Sample Bottle

Temp (°C)	<u>14.2</u>						
Within 0-6°C?	<u>Y</u> <u>N</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule

& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by RDA on 6/6/25 at 1421
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y NCooler Breakdown/Preservation Check**: Date: 6/11/25 Time: 13:00 by: KE

9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
10. Did all bottle labels and tags agree with custody papers? YES NO
11. Were correct containers used for the tests indicated? YES NO
12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
13. Were dissolved metals filtered in the field? YES NO N/A
14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?	Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
≥12		NaOH	Yes No						
≤2	<u>204524</u>	HNO ₃	<u>X</u>	<u>None</u>		<u>All</u>	<u>4ml each</u>	<u>242045</u>	<u>All 2</u>
≤2		H ₂ SO ₄							
<4		NaHSO ₄							
5-9		For 608pest		No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522		If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃							
		ZnAcetate	- -						
		HCl	** **						

**VOAs and 1664 Not to be tested before analysis.
Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).Bottle lot numbers: 033125-2ADD, 102824-2ADD
Explain all Discrepancies/ Other Comments: _____X metals do not need to be on iceLabels secondary reviewed by: KE

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541



Miscellaneous Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.	+	Correlation coefficient for MSA is <0.995.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).	N	Inorganics- Matrix spike recovery was outside laboratory limits.
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.	N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.	S	Concentration has been determined using Method of Standard Additions (MSA).
E	Organics- Concentration has exceeded the calibration range for that specific analysis.	W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.	P	Concentration >40% difference between the two GC columns.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.	C	Confirmed by GC/MS
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.	Q	DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
#	Spike was diluted out.	X	See Case Narrative for discussion.
		MRL	Method Reporting Limit. Also known as:
		LOQ	Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
		MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
		LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
		ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506757**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-144-DF**Date Collected:** 05/27/25**Lab Code:** R2506757-001**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-141-S**Date Collected:** 05/27/25**Lab Code:** R2506757-002**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-139-S**Date Collected:** 05/27/25**Lab Code:** R2506757-003**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-C102-DF**Date Collected:** 05/27/25**Lab Code:** R2506757-004**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-C102-BF**Date Collected:** 05/27/25**Lab Code:** R2506757-005**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506757**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-113-S**Date Collected:** 05/27/25**Lab Code:** R2506757-006**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-113-DF**Date Collected:** 05/27/25**Lab Code:** R2506757-007**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-114-S**Date Collected:** 05/27/25**Lab Code:** R2506757-008**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-114-DF**Date Collected:** 05/27/25**Lab Code:** R2506757-009**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-115-S**Date Collected:** 05/27/25**Lab Code:** R2506757-010**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506757**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-115-DF**Date Collected:** 05/27/25**Lab Code:** R2506757-011**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-116-S**Date Collected:** 05/27/25**Lab Code:** R2506757-012**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-116-DF**Date Collected:** 05/27/25**Lab Code:** R2506757-013**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-117-S**Date Collected:** 05/27/25**Lab Code:** R2506757-014**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-117-DF**Date Collected:** 05/27/25**Lab Code:** R2506757-015**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506757**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-118-S**Date Collected:** 05/27/25**Lab Code:** R2506757-016**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-118-DF**Date Collected:** 05/27/25**Lab Code:** R2506757-017**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-122-S1**Date Collected:** 05/27/25**Lab Code:** R2506757-018**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-122-S2**Date Collected:** 05/27/25**Lab Code:** R2506757-019**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-123-S**Date Collected:** 05/27/25**Lab Code:** R2506757-020**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506757**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-126-S**Date Collected:** 05/27/25**Lab Code:** R2506757-021**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-128-S**Date Collected:** 05/27/25**Lab Code:** R2506757-022**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-127-S**Date Collected:** 05/27/25**Lab Code:** R2506757-023**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-127-S**Date Collected:** 05/27/25**Lab Code:** R2506757-024**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-130-S**Date Collected:** 05/27/25**Lab Code:** R2506757-025**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506757**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-129-S1**Date Collected:** 05/27/25**Lab Code:** R2506757-026**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-129-SP2**Date Collected:** 05/27/25**Lab Code:** R2506757-027**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-129-S3**Date Collected:** 05/27/25**Lab Code:** R2506757-028**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-129-SP4**Date Collected:** 05/27/25**Lab Code:** R2506757-029**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-129-S5**Date Collected:** 05/27/25**Lab Code:** R2506757-030**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506757**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-129-S6**Date Collected:** 05/27/25**Lab Code:** R2506757-031**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-129-SP7**Date Collected:** 05/27/25**Lab Code:** R2506757-032**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

NMANSEN

Sample Name: ES-129-S8**Date Collected:** 05/27/25**Lab Code:** R2506757-033**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-200-S1**Date Collected:** 05/27/25**Lab Code:** R2506757-034**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-200-S2**Date Collected:** 05/27/25**Lab Code:** R2506757-035**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental

Service Request: R2506757

Project: Dansville CSD Elementary School/2023L-201.3

Sample Name: ES-200-S3

Date Collected: 05/27/25

Lab Code: R2506757-036

Date Received: 06/6/25

Sample Matrix: Drinking Water

Analysis Method

Extracted/Digested By

Analyzed By

200.8

MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7	200.2
200.8	200.2
6010C or 6010D	3005A/3010A
6020A or 6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010C or 6010D	3050B
6020A or 6020B	3050B
6010C or 6010D TCLP (1311) extract	3005A/3010A
6010C or 6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-144-DF
Lab Code: R2506757-001

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.9	ug/L	1.0	1	06/18/25 18:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-141-S
Lab Code: R2506757-002

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-139-S
Lab Code: R2506757-003

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-C102-DF
Lab Code: R2506757-004

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-C102-BF
Lab Code: R2506757-005

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-113-S
Lab Code: R2506757-006

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-113-DF
Lab Code: R2506757-007

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-114-S
Lab Code: R2506757-008

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-114-DF
Lab Code: R2506757-009

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-115-S
Lab Code: R2506757-010

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-115-DF
Lab Code: R2506757-011

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-116-S
Lab Code: R2506757-012

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-116-DF
Lab Code: R2506757-013

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-117-S
Lab Code: R2506757-014

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	06/18/25 18:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-117-DF
Lab Code: R2506757-015

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-118-S
Lab Code: R2506757-016

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-118-DF
Lab Code: R2506757-017

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-122-S1
Lab Code: R2506757-018

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-122-S2
Lab Code: R2506757-019

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	06/18/25 18:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-123-S
Lab Code: R2506757-020

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 19:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-126-S
Lab Code: R2506757-021

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	06/18/25 19:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-128-S
Lab Code: R2506757-022

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 19:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-127-S
Lab Code: R2506757-023

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	06/18/25 19:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-127-S
Lab Code: R2506757-024

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 19:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-130-S
Lab Code: R2506757-025

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.0	ug/L	1.0	1	06/18/25 19:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-129-S1
Lab Code: R2506757-026

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 19:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-129-SP2
Lab Code: R2506757-027

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	06/18/25 19:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-129-S3
Lab Code: R2506757-028

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.4	ug/L	1.0	1	06/18/25 19:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-129-SP4
Lab Code: R2506757-029

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 19:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-129-S5
Lab Code: R2506757-030

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 19:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-129-S6
Lab Code: R2506757-031

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.1	ug/L	1.0	1	06/18/25 19:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-129-SP7
Lab Code: R2506757-032

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	41.7	ug/L	1.0	1	06/14/25 11:59	06/13/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-129-S8
Lab Code: R2506757-033

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	38.5	ug/L	1.0	1	06/18/25 19:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-200-S1
Lab Code: R2506757-034

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	32.5	ug/L	1.0	1	06/18/25 19:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-200-S2
Lab Code: R2506757-035

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	20.7	ug/L	1.0	1	06/18/25 19:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-200-S3
Lab Code: R2506757-036

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	88.4	ug/L	1.0	1	06/18/25 19:41	



QC Summary Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2506757-MB1

Service Request: R2506757
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/14/25 11:37	06/13/25	
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 19:17	NA	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2506757-MB2

Service Request: R2506757
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 18:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2506757-MB3

Service Request: R2506757
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 17:38	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25
Date Analyzed: 06/18/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: ES-C102-DF
Lab Code: R2506757-004
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2506757-004MS		Result	Duplicate Matrix Spike R2506757-004DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	19.3	20.0	96	19.5	20.0	98	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25
Date Analyzed: 06/18/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: ES-C102-BF
Lab Code: R2506757-005
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2506757-005MS		Result	Duplicate Matrix Spike R2506757-005DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	19.5	20.0	98	19.7	20.0	98	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25
Date Analyzed: 06/18/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: ES-127-S
Lab Code: R2506757-024
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2506757-024MS		Result	Duplicate Matrix Spike R2506757-024DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	20.4	20.0	102	20.5	20.0	103	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506757
Date Collected: 05/27/25
Date Received: 06/06/25
Date Analyzed: 06/18/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: ES-130-S
Lab Code: R2506757-025
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2506757-025MS		Result	Duplicate Matrix Spike R2506757-025DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	7.0	27.0	20.0	100	27.2	20.0	101	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506757
Date Analyzed: 06/14/25 - 06/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2506757-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.5	20.0	97	85-115
Lead, Total	200.8	21.1	20.0	105	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506757
Date Analyzed: 06/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2506757-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.5	20.0	102	85-115

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506757

Date Analyzed: 06/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2506757-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.6	20.0	103	85-115



June 23, 2025

Service Request No:R2506758

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Dansville CSD Elementary School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory June 06, 2025
For your reference, these analyses have been assigned our service request number **R2506758**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Client: Stohl Environmental
Project: Dansville CSD Elementary School
Sample Matrix: Drinking Water

Service Request: R2506758
Date Received: 06/06/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty eight drinking water samples were received for analysis at ALS Environmental on 06/06/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by

A handwritten signature in black ink, appearing to read 'Meghan Pedicini', is written over a horizontal line.

Date

06/20/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: ES-200-S4A		Lab ID: R2506758-001				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	94.6			1.0	ug/L	200.8
CLIENT ID: ES-200-S4B		Lab ID: R2506758-002				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	109			1.0	ug/L	200.8
CLIENT ID: ES-200-S5A		Lab ID: R2506758-003				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	93.6			1.0	ug/L	200.8
CLIENT ID: ES-200-S5B		Lab ID: R2506758-004				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	51.2			1.0	ug/L	200.8
CLIENT ID: ES-200-S6A		Lab ID: R2506758-005				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	62.9			1.0	ug/L	200.8
CLIENT ID: ES-200-S6B		Lab ID: R2506758-006				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	52.0			1.0	ug/L	200.8
CLIENT ID: ES-200-S7A		Lab ID: R2506758-007				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	64.1			1.0	ug/L	200.8
CLIENT ID: ES-200-S7B		Lab ID: R2506758-008				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	75.3			1.0	ug/L	200.8
CLIENT ID: ES-200-S8A		Lab ID: R2506758-009				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	103			1.0	ug/L	200.8
CLIENT ID: ES-200-S8B		Lab ID: R2506758-010				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	93.3			1.0	ug/L	200.8
CLIENT ID: ES-200-S9A		Lab ID: R2506758-011				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	70.9			1.0	ug/L	200.8
CLIENT ID: ES-200-S9B		Lab ID: R2506758-012				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	18.7			1.0	ug/L	200.8



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: ES-200-S10			Lab ID: R2506758-013			
------------------------------	--	--	-----------------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.3			1.0	ug/L	200.8

CLIENT ID: ES-C200-DF			Lab ID: R2506758-016			
------------------------------	--	--	-----------------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.0			1.0	ug/L	200.8

CLIENT ID: ES-210-S			Lab ID: R2506758-035			
----------------------------	--	--	-----------------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.7			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3

Service Request:R2506758

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2506758-001	ES-200-S4A	5/27/2025	
R2506758-002	ES-200-S4B	5/27/2025	
R2506758-003	ES-200-S5A	5/27/2025	
R2506758-004	ES-200-S5B	5/27/2025	
R2506758-005	ES-200-S6A	5/27/2025	
R2506758-006	ES-200-S6B	5/27/2025	
R2506758-007	ES-200-S7A	5/27/2025	
R2506758-008	ES-200-S7B	5/27/2025	
R2506758-009	ES-200-S8A	5/27/2025	
R2506758-010	ES-200-S8B	5/27/2025	
R2506758-011	ES-200-S9A	5/27/2025	
R2506758-012	ES-200-S9B	5/27/2025	
R2506758-013	ES-200-S10	5/27/2025	
R2506758-014	ES-201-S	5/27/2025	
R2506758-015	ES-201-DF	5/27/2025	
R2506758-016	ES-C200-DF	5/27/2025	
R2506758-017	ES-202-S	5/27/2025	
R2506758-018	ES-202-DF	5/27/2025	
R2506758-019	ES-203-S	5/27/2025	
R2506758-020	ES-203-DF	5/27/2025	
R2506758-021	ES-T200-S	5/27/2025	
R2506758-022	ES-T201-S	5/27/2025	
R2506758-023	ES-204-S	5/27/2025	
R2506758-024	ES-204-DF	5/27/2025	
R2506758-025	ES-207-S	5/27/2025	
R2506758-026	ES-207-DF	5/27/2025	
R2506758-027	ES-206-S	5/27/2025	
R2506758-028	ES-206-DF	5/27/2025	
R2506758-029	ES-209-S	5/27/2025	
R2506758-030	ES-209-DF	5/27/2025	
R2506758-031	ES-C154-S	5/27/2025	
R2506758-032	ES-C154-DF	5/27/2025	
R2506758-033	ES-211-S	5/27/2025	
R2506758-034	ES-211-DF	5/27/2025	
R2506758-035	ES-210-S	5/27/2025	
R2506758-036	ES-210-DF	5/27/2025	
R2506758-037	ES-213-S	5/27/2025	
R2506758-038	ES-213-DF	5/27/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-201.3

Client: Dansville CSD Contact: Derek Brown

Building: Elementary School Location: 280 Main St, Dansville, NY 14437

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
ES-200-S4A	200 L	Sink	0:17
ES-200-S4B	200 R	Sink	0:16
ES-200-S5A	200 L	Sink	0:15
ES-200-S5B	200 R	Sink	0:14
ES-200-S6A	200 L	Sink	0:13
ES-200-S6B	200 R	Sink	0:12
ES-200-S7A	200 L	Sink	0:11
ES-200-S7B	200 R	Sink	0:10
ES-200-S8A	200 L	Drinking Fountain	0:09
ES-200-S8B	200 R	Drinking Fountain	0:08
ES-200-S9A	200 L	Sink	0:07
ES-200-S9B	200 R	Drinking Fountain	0:06
ES-200-S10	200 Prep Area	Sink	0:05
ES-201-S	201	Sink	0:04
ES-201-DF	201	Drinking Fountain	0:03
ES-C200-DF	Corridor C200 Adjacent 202D & 202E	Drinking Fountain	0:02
ES-202-S	202	Sink	0:01
ES-202-DF	202	Drinking Fountain	0:00

Notes:

Please e-mail lab results to labs@stohlenv.com

Rfranoine@stohlenvironmental.com

Sampled By: R. Franoine & M. Scinta Print Name Stohl Env: R. Franoine & M. Scinta Date: 5/27/2025

Relinquished By: Rebecca Franoine Print Name Stohl Env: Rebecca Franoine Date: 6/5/2025

Received (Name / Lab): Matthew Date: 6/6/25 Time: 15:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

R2506758

5

Stohl Environmental
Dansville CSD Elementary School





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-201.3

Client: Dansville CSD

Contact: Derek Brown

Building: Elementary School

Location: 280 Main St, Dansville, NY 14437

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
ES-203-S	203	Sink	23:59
ES-203-DF	203	Drinking Fountain	23:58
ES-T200-S	Faculty Restroom	Sink	23:57
ES-T201-S	Faculty Restroom	Sink	23:56
ES-204-S	204	Sink	23:55
ES-204-DF	204	Drinking Fountain	23:54
ES-207-S	207	Sink	23:53
ES-207-DF	207	Drinking Fountain	23:52
ES-206-S	206	Sink	23:51
ES-206-DF	206	Drinking Fountain	23:50
ES-209-S	209	Sink	23:49
ES-209-DF	209	Drinking Fountain	23:48
ES-C154-S	C154(Formerly 208)	Sink	23:47
ES-C154-DF	C154(Formerly 208)	Drinking Fountain	23:46
ES-211-S	211	Sink	23:45
ES-211-DF	211	Drinking Fountain	23:44
ES-210-S	210	Sink	23:43
ES-210-DF	210	Drinking Fountain	23:42

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Rfranjoiene@stohlenvironmental.com

Sampled By: R. Franjoine & M. Scinta Print Name Stohl Env: R. Franjoine & M. Scint Date: 5/27/2025

Relinquished By: Rebecca Franjoine Print Name Stohl Env: Rebecca Franjoine Date: 6/5/2025

Received (Name / Lab): Matthew Long Date: 6/6/25 15:25 Time: 15:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



STOHL Job # 2023L-201.3

Building: Elementary School Location: 280 Main St, Dansville, NY 14437

<u>LEAD</u>		<i>Turnaround</i>
Water by 200.8	X	10 Days

[illegible]

Rfranjoine@stohlenvironmental.com

Archived / Released: QA/QC InterLAB Use: Date: Time:



Cooler Receipt and Preservation

R2506758

5

Stohl Environmental
Dansville CSD Elementary SchoolProject/Client Stohl Env Folder Number _____Cooler received on 6/6/20 by: RDACOURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y ☒ N ☐
2	Custody papers properly completed (ink, signed)?	Y ☒ N ☐
3	Did all bottles arrive in good condition (unbroken)?	Y ☒ N ☐
4	Circle: <u>Wet Ice</u> Dry Ice Gel packs present?	Y ☒ N ☐

5a	Did VOA vials have sig* bubbles?	Y ☐ N ☒
5b	Sig* bubbles: Alk? Y ☐ N ☒ Sulfide? Y ☐ N ☒	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035se	<u>NA</u>

8. Temperature Readings Date: 6/6/20 Time: 14:20 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)							
Within 0-6°C?	Y ☒ N ☐	Y ☐ N ☐	Y ☐ N ☐	Y ☐ N ☐	Y ☐ N ☐	Y ☐ N ☐	Y ☐ N ☐
If <0°C, were samples frozen?	Y ☐ N ☐	Y ☐ N ☐	Y ☐ N ☐	Y ☐ N ☐	Y ☐ N ☐	Y ☐ N ☐	Y ☐ N ☐

If out of Temperature, note packing/ice condition: _____ Ice melted _____ Poorly Packed (described below) _____ Same Day Rule

& Client Approval to Run Samples: _____ Standing Approval _____ Client aware at drop-off _____ Client notified by: _____

All samples held in storage location: SMD by RDA on 6/6/20 at 14:21
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y ☐ N ☐Cooler Breakdown/Preservation Check**: Date: 6/11/25 Time: 13:20 by: RZ

9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES ☒ NO ☐
10. Did all bottle labels and tags agree with custody papers? YES ☒ NO ☐
11. Were correct containers used for the tests indicated? YES ☒ NO ☐
12. Were 5035 vials acceptable (no extra labels, not leaking)? YES ☐ NO ☒ N/A ☐
13. Were dissolved metals filtered in the field? YES ☐ NO ☒ N/A ☐
14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized _____ Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>204524</u>	HNO ₃		X	<u>None</u>		<u>All</u>	<u>4ml each</u>	<u>242045</u>	<u>All 42</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis.
Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).Bottle lot numbers: 102824-2ADD, 101424-2ADD
Explain all Discrepancies/ Other Comments:

* metals do not need to be on ice

Labels secondary reviewed by: RZ

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.	+	Correlation coefficient for MSA is <0.995.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).	N	Inorganics- Matrix spike recovery was outside laboratory limits.
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.	N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.	S	Concentration has been determined using Method of Standard Additions (MSA).
E	Organics- Concentration has exceeded the calibration range for that specific analysis.	W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.	P	Concentration >40% difference between the two GC columns.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.	C	Confirmed by GC/MS
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.	Q	DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
#	Spike was diluted out.	X	See Case Narrative for discussion.
		MRL	Method Reporting Limit. Also known as:
		LOQ	Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
		MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
		LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
		ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506758**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-200-S4A**Date Collected:** 05/27/25**Lab Code:** R2506758-001**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

NMANSEN

Sample Name: ES-200-S4B**Date Collected:** 05/27/25**Lab Code:** R2506758-002**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

NMANSEN

Sample Name: ES-200-S5A**Date Collected:** 05/27/25**Lab Code:** R2506758-003**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

NMANSEN

Sample Name: ES-200-S5B**Date Collected:** 05/27/25**Lab Code:** R2506758-004**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-200-S6A**Date Collected:** 05/27/25**Lab Code:** R2506758-005**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506758**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-200-S6B**Date Collected:** 05/27/25**Lab Code:** R2506758-006**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-200-S7A**Date Collected:** 05/27/25**Lab Code:** R2506758-007**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-200-S7B**Date Collected:** 05/27/25**Lab Code:** R2506758-008**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

NMANSEN

Sample Name: ES-200-S8A**Date Collected:** 05/27/25**Lab Code:** R2506758-009**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

NMANSEN

Sample Name: ES-200-S8B**Date Collected:** 05/27/25**Lab Code:** R2506758-010**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

NMANSEN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506758**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-200-S9A**Date Collected:** 05/27/25**Lab Code:** R2506758-011**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-200-S9B**Date Collected:** 05/27/25**Lab Code:** R2506758-012**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-200-S10**Date Collected:** 05/27/25**Lab Code:** R2506758-013**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-201-S**Date Collected:** 05/27/25**Lab Code:** R2506758-014**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-201-DF**Date Collected:** 05/27/25**Lab Code:** R2506758-015**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506758**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-C200-DF**Date Collected:** 05/27/25**Lab Code:** R2506758-016**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-202-S**Date Collected:** 05/27/25**Lab Code:** R2506758-017**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-202-DF**Date Collected:** 05/27/25**Lab Code:** R2506758-018**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-203-S**Date Collected:** 05/27/25**Lab Code:** R2506758-019**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-203-DF**Date Collected:** 05/27/25**Lab Code:** R2506758-020**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506758**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-T200-S**Date Collected:** 05/27/25**Lab Code:** R2506758-021**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-T201-S**Date Collected:** 05/27/25**Lab Code:** R2506758-022**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-204-S**Date Collected:** 05/27/25**Lab Code:** R2506758-023**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-204-DF**Date Collected:** 05/27/25**Lab Code:** R2506758-024**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-207-S**Date Collected:** 05/27/25**Lab Code:** R2506758-025**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506758**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-207-DF**Date Collected:** 05/27/25**Lab Code:** R2506758-026**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-206-S**Date Collected:** 05/27/25**Lab Code:** R2506758-027**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-206-DF**Date Collected:** 05/27/25**Lab Code:** R2506758-028**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-209-S**Date Collected:** 05/27/25**Lab Code:** R2506758-029**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-209-DF**Date Collected:** 05/27/25**Lab Code:** R2506758-030**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506758**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-C154-S**Date Collected:** 05/27/25**Lab Code:** R2506758-031**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-C154-DF**Date Collected:** 05/27/25**Lab Code:** R2506758-032**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-211-S**Date Collected:** 05/27/25**Lab Code:** R2506758-033**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-211-DF**Date Collected:** 05/27/25**Lab Code:** R2506758-034**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-210-S**Date Collected:** 05/27/25**Lab Code:** R2506758-035**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2506758**Project:** Dansville CSD Elementary School/2023L-201.3**Sample Name:** ES-210-DF**Date Collected:** 05/27/25**Lab Code:** R2506758-036**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-213-S**Date Collected:** 05/27/25**Lab Code:** R2506758-037**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: ES-213-DF**Date Collected:** 05/27/25**Lab Code:** R2506758-038**Date Received:** 06/6/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7	200.2
200.8	200.2
6010C or 6010D	3005A/3010A
6020A or 6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010C or 6010D	3050B
6020A or 6020B	3050B
6010C or 6010D TCLP (1311) extract	3005A/3010A
6010C or 6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-200-S4A
Lab Code: R2506758-001

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	94.6	ug/L	1.0	1	06/14/25 12:01	06/13/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-200-S4B
Lab Code: R2506758-002

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	109	ug/L	1.0	1	06/14/25 12:02	06/13/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-200-S5A
Lab Code: R2506758-003

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	93.6	ug/L	1.0	1	06/14/25 12:03	06/13/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-200-S5B
Lab Code: R2506758-004

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	51.2	ug/L	1.0	1	06/18/25 19:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-200-S6A
Lab Code: R2506758-005

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	62.9	ug/L	1.0	1	06/18/25 19:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-200-S6B
Lab Code: R2506758-006

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	52.0	ug/L	1.0	1	06/18/25 19:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-200-S7A
Lab Code: R2506758-007

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	64.1	ug/L	1.0	1	06/18/25 19:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-200-S7B
Lab Code: R2506758-008

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	75.3	ug/L	1.0	1	06/14/25 12:04	06/13/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-200-S8A
Lab Code: R2506758-009

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	103	ug/L	1.0	1	06/14/25 12:08	06/13/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-200-S8B
Lab Code: R2506758-010

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	93.3	ug/L	1.0	1	06/14/25 12:10	06/13/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-200-S9A
Lab Code: R2506758-011

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	70.9	ug/L	1.0	1	06/18/25 19:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-200-S9B
Lab Code: R2506758-012

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	18.7	ug/L	1.0	1	06/18/25 19:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-200-S10
Lab Code: R2506758-013

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.3	ug/L	1.0	1	06/18/25 19:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-201-S
Lab Code: R2506758-014

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 19:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-201-DF
Lab Code: R2506758-015

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 19:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-C200-DF
Lab Code: R2506758-016

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	06/18/25 20:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-202-S
Lab Code: R2506758-017

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-202-DF
Lab Code: R2506758-018

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-203-S
Lab Code: R2506758-019

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-203-DF
Lab Code: R2506758-020

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-T200-S
Lab Code: R2506758-021

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-T201-S
Lab Code: R2506758-022

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-204-S
Lab Code: R2506758-023

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-204-DF
Lab Code: R2506758-024

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-207-S
Lab Code: R2506758-025

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-207-DF
Lab Code: R2506758-026

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-206-S
Lab Code: R2506758-027

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-206-DF
Lab Code: R2506758-028

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-209-S
Lab Code: R2506758-029

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-209-DF
Lab Code: R2506758-030

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-C154-S
Lab Code: R2506758-031

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-C154-DF
Lab Code: R2506758-032

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-211-S
Lab Code: R2506758-033

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-211-DF
Lab Code: R2506758-034

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-210-S
Lab Code: R2506758-035

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	06/18/25 20:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-210-DF
Lab Code: R2506758-036

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-213-S
Lab Code: R2506758-037

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 21:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: ES-213-DF
Lab Code: R2506758-038

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25 16:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 21:04	



QC Summary Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2506758-MB1

Service Request: R2506758
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/14/25 11:37	06/13/25	
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:55	NA	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2506758-MB2

Service Request: R2506758
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 20:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2506758-MB3

Service Request: R2506758
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	06/18/25 19:17	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25
Date Analyzed: 06/18/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: ES-201-DF
Lab Code: R2506758-015
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2506758-015MS		Result	Duplicate Matrix Spike R2506758-015DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	20.4	20.0	102	20.6	20.0	103	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25
Date Analyzed: 06/18/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: ES-C200-DF
Lab Code: R2506758-016
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2506758-016MS		Result	Duplicate Matrix Spike R2506758-016DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.0	21.0	20.0	100	21.1	20.0	100	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25
Date Analyzed: 06/18/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: ES-210-S
Lab Code: R2506758-035
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2506758-035MS		Result	Duplicate Matrix Spike R2506758-035DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.7	21.8	20.0	100	22.0	20.0	102	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506758
Date Collected: 05/27/25
Date Received: 06/06/25
Date Analyzed: 06/18/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: ES-210-DF
Lab Code: R2506758-036
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	20.2	20.0	101	20.4	20.0	102	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506758
Date Analyzed: 06/14/25 - 06/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2506758-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.5	20.0	97	85-115
Lead, Total	200.8	20.7	20.0	103	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506758
Date Analyzed: 06/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2506758-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.8	20.0	104	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Dansville CSD Elementary School/2023L-201.3
Sample Matrix: Drinking Water

Service Request: R2506758
Date Analyzed: 06/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2506758-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.1	20.0	105	85-115

1.5 Laboratory Certifications

**NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER**



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology

Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Colilert)
---	-------------------------------------

Dissolved Gases

Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175

Fuel Additives

Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2

Metals I

Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.

Page 1 of 5

