

July 22, 2025

Mr. Derek Brown  
Dansville CSD  
337 Main Street  
Dansville, New York 14437

**Re: Lead Testing in School Drinking Water**

Dear Mr. Brown:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Dansville CSD, including:

- Dansville CSD Transportation – 9350 Main Street, Dansville, NY

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on May 28, 2025. As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 0 sources of potable water at the Dansville CSD Transportation Building have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion.

Thank you for the opportunity to be of service to Dansville CSD.

Sincerely,

Stohl Environmental, LLC.



Michael Scinta  
EPA Lead Risk Assessor

**Lead Testing in School Drinking Water**

**Prepared for:**

**Dansville CSD**

**Prepared by:**



**3860 California Road  
Orchard Park, New York 14127**

**Conditions as of May 28, 2025**

## Summary Tabulation

### Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

## 1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Dansville CSD to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- Dansville CSD Transportation – 9350 Main Street, Dansville, NY

### Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Dansville CSD Transportation Building. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

### Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***3Ts for Reducing Lead in Drinking Water in Schools***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

## 1.2 Executive Summary of Sampling and Analysis:

### Summary of Samples Collected at Dansville CSD Transportation Building:

| Building Name                | Date of Sampling | Total Samples | At or Below Action Level* | Above Action Level* |
|------------------------------|------------------|---------------|---------------------------|---------------------|
| Dansville CSD Transportation | May 28, 2025     | 6             | 6                         | 0                   |

*\*NYS Action Level is 5 parts per billion*

**1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:**

All the locations sampled were analyzed at less than the NYS Action Level of 5 ppb, therefore no further response action is required.

#### 1.4 Laboratory Analytical Reports and Chain of Custody Documents



June 17, 2025

Service Request No:R2506744

Michael Scinta  
Stohl Environmental  
3860 California Road  
Orchard Park, NY 14219

## Laboratory Results for: Dansville CSD Transportation

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory June 06, 2025  
For your reference, these analyses have been assigned our service request number **R2506744**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at [Meghan.Pedro@alsglobal.com](mailto:Meghan.Pedro@alsglobal.com).

Respectfully submitted,

**ALS Group USA, Corp. dba ALS Environmental**

Meghan Pedro  
Project Manager

CC: Rebecca  
Franjoine

**ADDRESS**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

**PHONE** +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.  
dba ALS Environmental



## Narrative Documents

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Stohl Environmental  
**Project:** Dansville CSD Transportation  
**Sample Matrix:** Drinking Water

**Service Request:** R2506744  
**Date Received:** 06/06/2025

#### CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

#### Sample Receipt:

Six drinking water samples were received for analysis at ALS Environmental on 06/06/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

#### Metals:

No significant anomalies were noted with this analysis.

Approved by

A handwritten signature in black ink, appearing to read "Meghan Pedicini".

Date

06/17/2025



## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)

**Client:** Stohl Environmental  
**Project:** Dansville CSD Transportation/2023L-201.8

**Service Request:**R2506744

**SAMPLE CROSS-REFERENCE**

| <u>SAMPLE #</u> | <u>CLIENT SAMPLE ID</u> | <u>DATE</u> | <u>TIME</u> |
|-----------------|-------------------------|-------------|-------------|
| R2506744-001    | TR-Break-S              | 5/28/2025   |             |
| R2506744-002    | TR-WR-S                 | 5/28/2025   |             |
| R2506744-003    | TR-MR-S                 | 5/28/2025   |             |
| R2506744-004    | TR-DF1                  | 5/28/2025   |             |
| R2506744-005    | TR-DF2                  | 5/28/2025   |             |
| R2506744-006    | TR-BF                   | 5/28/2025   |             |





# Cooler Receipt and Preservation

R2506744

5

Stohl Environmental  
Danville CSD Transportation

Project/Client Stohl Env.

Folder Number \_\_\_\_\_

Cooler received on 6/6/20

by: RDA

COURIER: ALS UPS FEDEX VELOCITY CLIENT

|   |                                                      |              |
|---|------------------------------------------------------|--------------|
| 1 | Were Custody seals on outside of cooler?             | Y <u>(N)</u> |
| 2 | Custody papers properly completed (ink, signed)?     | Y <u>(N)</u> |
| 3 | Did all bottles arrive in good condition (unbroken)? | Y <u>(N)</u> |
| 4 | Circle: <u>Wet Ice</u> Dry Ice Gel packs present?    | Y <u>(N)</u> |

|    |                                                         |                       |
|----|---------------------------------------------------------|-----------------------|
| 5a | Did VOA vials have sig* bubbles?                        | Y N <u>NA</u>         |
| 5b | Sig* bubbles: Alk? Y N <u>NA</u> Sulfide? Y N <u>NA</u> |                       |
| 6  | Where did the bottles originate?                        | <u>ALS/ROC</u> CLIENT |
| 7  | Soil VOA received as: Bulk Encore 5035se                | <u>(NA)</u>           |

8. Temperature Readings Date: 6/6/20 Time: 14:20 ID: IR#12 IR#1 From: Temp Blank Sample Bottle

| Temp (°C)                     |              |     |     |     |     |     |     |
|-------------------------------|--------------|-----|-----|-----|-----|-----|-----|
| Within 0-6°C?                 | Y <u>(N)</u> | Y N | Y N | Y N | Y N | Y N | Y N |
| If <0°C, were samples frozen? | Y N          | Y N | Y N | Y N | Y N | Y N | Y N |

If out of Temperature, note packing/ice condition: \_\_\_\_\_ Ice melted Poorly Packed (described below) Same Day Rule

& Client Approval to Run Samples: \_\_\_\_\_ Standing Approval Client aware at drop-off Client notified by: \_\_\_\_\_

All samples held in storage location: SHO by RDA on 6/6/20 at 14:21  
5035 samples placed in storage location: \_\_\_\_\_ by \_\_\_\_\_ on \_\_\_\_\_ at \_\_\_\_\_ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check\*\*: Date: 6/11/20 Time: 13:55 by: ME

- Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES (NO)
- Did all bottle labels and tags agree with custody papers? YES (NO)
- Were correct containers used for the tests indicated? YES (NO)
- Were 5035 vials acceptable (no extra labels, not leaking)? YES (NO) (N/A)
- Were dissolved metals filtered in the field? YES (NO) (N/A)
- Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated (N/A)

| pH                    | Lot of test paper | Reagent                                       | Preserved? | Lot Received                                                                                             | Exp | Sample ID Adjusted | Vol. Added      | Lot Added     | Final pH      |
|-----------------------|-------------------|-----------------------------------------------|------------|----------------------------------------------------------------------------------------------------------|-----|--------------------|-----------------|---------------|---------------|
| ≥12                   |                   | NaOH                                          | Yes No     |                                                                                                          |     |                    |                 |               |               |
| ≤2                    | <u>209524</u>     | HNO <sub>3</sub>                              |            | <u>None</u>                                                                                              |     | <u>All</u>         | <u>4ml each</u> | <u>241523</u> |               |
| ≤2                    |                   | H <sub>2</sub> SO <sub>4</sub>                |            |                                                                                                          |     |                    |                 | <u>241523</u> | <u>All 52</u> |
| <4                    |                   | NaHSO <sub>4</sub>                            |            |                                                                                                          |     |                    |                 | <u>6/6/20</u> |               |
| 5-9                   |                   | For 608pest                                   |            | No=Notify for 3day                                                                                       |     |                    |                 |               |               |
| Residual Chlorine (-) |                   | For CN, Phenol, 625, 608pest, 522             |            | If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol). |     |                    |                 |               |               |
|                       |                   | Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> |            |                                                                                                          |     |                    |                 |               |               |
|                       |                   | ZnAcetate                                     | - -        |                                                                                                          |     |                    |                 |               |               |
|                       |                   | HCl                                           | ** **      |                                                                                                          |     |                    |                 |               |               |

\*\*VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 111824-2AAD

Explain all Discrepancies/ Other Comments:

\* metals do not need to be on ice

ME

Labels secondary reviewed by: \_\_\_\_\_

\*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter

|       |        |
|-------|--------|
| HPROD | BULK   |
| HTR   | FLDT   |
| SUB   | HGFB   |
| ALS   | LL3541 |



## Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

|   |                                                                                                                                                                                                                                                                                                        |     |                                                                                                                                                                                                                      |
|---|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| U | Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.                                                                                                                       | +   | Correlation coefficient for MSA is <0.995.                                                                                                                                                                           |
| J | Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors). | N   | Inorganics- Matrix spike recovery was outside laboratory limits.                                                                                                                                                     |
| B | Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.                                                                                                                                                                            | N   | Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.                                                                                                                     |
| E | Inorganics- Concentration is estimated due to the serial dilution was outside control limits.                                                                                                                                                                                                          | S   | Concentration has been determined using Method of Standard Additions (MSA).                                                                                                                                          |
| E | Organics- Concentration has exceeded the calibration range for that specific analysis.                                                                                                                                                                                                                 | W   | Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.                                                                                                   |
| D | Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.                                                                                            | P   | Concentration >40% difference between the two GC columns.                                                                                                                                                            |
| * | Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.                                                                                                                  | C   | Confirmed by GC/MS                                                                                                                                                                                                   |
| H | Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.                                                                                                                                                                                                         | Q   | DoD reports: indicates a pesticide/Aroclor is not confirmed ( $\geq 100\%$ Difference between two GC columns).                                                                                                       |
| # | Spike was diluted out.                                                                                                                                                                                                                                                                                 | X   | See Case Narrative for discussion.                                                                                                                                                                                   |
|   |                                                                                                                                                                                                                                                                                                        | MRL | Method Reporting Limit. Also known as:                                                                                                                                                                               |
|   |                                                                                                                                                                                                                                                                                                        | LOQ | Limit of Quantitation (LOQ)<br>The lowest concentration at which the method analyte may be reliably quantified under the method conditions.                                                                          |
|   |                                                                                                                                                                                                                                                                                                        | MDL | Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier). |
|   |                                                                                                                                                                                                                                                                                                        | LOD | Limit of Detection. A value at or above the MDL which has been verified to be detectable.                                                                                                                            |
|   |                                                                                                                                                                                                                                                                                                        | ND  | Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.                                                                                                                               |

### Rochester Lab ID # for State Accreditations<sup>1</sup>



| NELAP States            |
|-------------------------|
| Florida ID # E87674     |
| New Hampshire ID # 2941 |
| New York ID # 10145     |
| Pennsylvania ID# 68-786 |
| Texas ID#T104704581     |
| Virginia #460167        |

| Non-NELAP States       |
|------------------------|
| Connecticut ID #PH0556 |
| Delaware Approved      |
| Maine ID #NY01587      |
| North Carolina #36701  |
| North Carolina #676    |
| Rhode Island LAO00333  |

<sup>1</sup> Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

## ALS Laboratory Group

---

### Acronyms

|            |                                                                                                                                          |
|------------|------------------------------------------------------------------------------------------------------------------------------------------|
| ASTM       | American Society for Testing and Materials                                                                                               |
| A2LA       | American Association for Laboratory Accreditation                                                                                        |
| CARB       | California Air Resources Board                                                                                                           |
| CAS Number | Chemical Abstract Service registry Number                                                                                                |
| CFC        | Chlorofluorocarbon                                                                                                                       |
| CFU        | Colony-Forming Unit                                                                                                                      |
| DEC        | Department of Environmental Conservation                                                                                                 |
| DEQ        | Department of Environmental Quality                                                                                                      |
| DHS        | Department of Health Services                                                                                                            |
| DOE        | Department of Ecology                                                                                                                    |
| DOH        | Department of Health                                                                                                                     |
| EPA        | U. S. Environmental Protection Agency                                                                                                    |
| ELAP       | Environmental Laboratory Accreditation Program                                                                                           |
| GC         | Gas Chromatography                                                                                                                       |
| GC/MS      | Gas Chromatography/Mass Spectrometry                                                                                                     |
| LUFT       | Leaking Underground Fuel Tank                                                                                                            |
| M          | Modified                                                                                                                                 |
| MCL        | Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA. |
| MDL        | Method Detection Limit                                                                                                                   |
| MPN        | Most Probable Number                                                                                                                     |
| MRL        | Method Reporting Limit                                                                                                                   |
| NA         | Not Applicable                                                                                                                           |
| NC         | Not Calculated                                                                                                                           |
| NCASI      | National Council of the Paper Industry for Air and Stream Improvement                                                                    |
| ND         | Not Detected                                                                                                                             |
| NIOSH      | National Institute for Occupational Safety and Health                                                                                    |
| PQL        | Practical Quantitation Limit                                                                                                             |
| RCRA       | Resource Conservation and Recovery Act                                                                                                   |
| SIM        | Selected Ion Monitoring                                                                                                                  |
| TPH        | Total Petroleum Hydrocarbons                                                                                                             |
| tr         | Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.                           |

**ALS Group USA, Corp.**

dba ALS Environmental

## Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Dansville CSD Transportation/2023L-201.8

**Service Request:** R2506744

**Sample Name:** TR-Break-S  
**Lab Code:** R2506744-001  
**Sample Matrix:** Drinking Water

**Date Collected:** 05/28/25**Date Received:** 06/6/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** TR-WR-S  
**Lab Code:** R2506744-002  
**Sample Matrix:** Drinking Water

**Date Collected:** 05/28/25**Date Received:** 06/6/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** TR-MR-S  
**Lab Code:** R2506744-003  
**Sample Matrix:** Drinking Water

**Date Collected:** 05/28/25**Date Received:** 06/6/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** TR-DF1  
**Lab Code:** R2506744-004  
**Sample Matrix:** Drinking Water

**Date Collected:** 05/28/25**Date Received:** 06/6/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** TR-DF2  
**Lab Code:** R2506744-005  
**Sample Matrix:** Drinking Water

**Date Collected:** 05/28/25**Date Received:** 06/6/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**ALS Group USA, Corp.**  
**dba ALS Environmental**

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Dansville CSD Transportation/2023L-201.8

**Service Request:** R2506744

**Sample Name:** TR-BF  
**Lab Code:** R2506744-006  
**Sample Matrix:** Drinking Water

**Date Collected:** 05/28/25  
**Date Received:** 06/6/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

| Analytical Method                                     | Preparation Method                      |
|-------------------------------------------------------|-----------------------------------------|
| 200.7                                                 | 200.2                                   |
| 200.8                                                 | 200.2                                   |
| 6010C or 6010D                                        | 3005A/3010A                             |
| 6020A or 6020B                                        | ILM05.3                                 |
| 9034 Sulfide Acid Soluble                             | 9030B                                   |
| SM 4500-CN-N-2016<br>Amenable and Residual<br>Cyanide | SM 4500-CN-G and<br>SM 4500-CN-B,C-2016 |
| SM 4500-CN-E WAD<br>Cyanide                           | SM 4500-CN-I                            |

#### Solid/Soil/Non-Aqueous Matrix

| Analytical Method                                                                                         | Preparation Method |
|-----------------------------------------------------------------------------------------------------------|--------------------|
| 6010C or 6010D                                                                                            | 3050B              |
| 6020A or 6020B                                                                                            | 3050B              |
| 6010C or 6010D TCLP<br>(1311) extract                                                                     | 3005A/3010A        |
| 6010C or 6010D SPLP<br>(1312) extract                                                                     | 3005A/3010A        |
| 7199                                                                                                      | 3060A              |
| 300.0 Anions/ 350.1/ 353.2/<br>SM 2320B/ SM 5210B/<br>9056A Anions                                        | DI extraction      |
| For analytical methods not listed, the preparation method is the same as the analytical method reference. |                    |

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



## Sample Results

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)



## Metals

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Dansville CSD Transportation/2023L-201.8  
**Sample Matrix:** Drinking Water  
**Sample Name:** TR-Break-S  
**Lab Code:** R2506744-001

**Service Request:** R2506744  
**Date Collected:** 05/28/25  
**Date Received:** 06/06/25 15:25  
**Basis:** NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed  | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total  | 200.8           | ND U   | ug/L  | 1.0 | 1    | 06/13/25 16:30 |   |

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Dansville CSD Transportation/2023L-201.8  
**Sample Matrix:** Drinking Water  
**Sample Name:** TR-WR-S  
**Lab Code:** R2506744-002

**Service Request:** R2506744  
**Date Collected:** 05/28/25  
**Date Received:** 06/06/25 15:25  
**Basis:** NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed  | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total  | 200.8           | ND U   | ug/L  | 1.0 | 1    | 06/13/25 16:31 |   |

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Dansville CSD Transportation/2023L-201.8  
**Sample Matrix:** Drinking Water  
**Sample Name:** TR-MR-S  
**Lab Code:** R2506744-003

**Service Request:** R2506744  
**Date Collected:** 05/28/25  
**Date Received:** 06/06/25 15:25  
**Basis:** NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed  | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total  | 200.8           | ND U   | ug/L  | 1.0 | 1    | 06/13/25 16:36 |   |

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Dansville CSD Transportation/2023L-201.8  
**Sample Matrix:** Drinking Water  
**Sample Name:** TR-DF1  
**Lab Code:** R2506744-004

**Service Request:** R2506744  
**Date Collected:** 05/28/25  
**Date Received:** 06/06/25 15:25  
**Basis:** NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed  | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total  | 200.8           | ND U   | ug/L  | 1.0 | 1    | 06/13/25 16:37 |   |

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Dansville CSD Transportation/2023L-201.8  
**Sample Matrix:** Drinking Water  
**Sample Name:** TR-DF2  
**Lab Code:** R2506744-005

**Service Request:** R2506744  
**Date Collected:** 05/28/25  
**Date Received:** 06/06/25 15:25  
**Basis:** NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed  | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total  | 200.8           | ND U   | ug/L  | 1.0 | 1    | 06/13/25 16:39 |   |

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Dansville CSD Transportation/2023L-201.8  
**Sample Matrix:** Drinking Water  
**Sample Name:** TR-BF  
**Lab Code:** R2506744-006

**Service Request:** R2506744  
**Date Collected:** 05/28/25  
**Date Received:** 06/06/25 15:25  
**Basis:** NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed  | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total  | 200.8           | ND U   | ug/L  | 1.0 | 1    | 06/13/25 16:41 |   |



## QC Summary Forms

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)



## Metals

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Dansville CSD Transportation/2023L-201.8  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2506744-MB

**Service Request:** R2506744  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

| Analyte Name | Analysis Method | Result | Units | MRL | Dil. | Date Analyzed  | Q |
|--------------|-----------------|--------|-------|-----|------|----------------|---|
| Lead, Total  | 200.8           | ND U   | ug/L  | 1.0 | 1    | 06/13/25 16:17 |   |

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Dansville CSD Transportation/2023L-201.8  
**Sample Matrix:** Drinking Water

**Service Request:** R2506744

**Date Analyzed:** 06/13/25

**Lab Control Sample Summary**

**Inorganic Parameters**

**Units:**ug/L

**Basis:**NA

**Lab Control Sample**

R2506744-LCS

| Analyte Name | Analytical Method | Result | Spike Amount | % Rec | % Rec Limits |
|--------------|-------------------|--------|--------------|-------|--------------|
| Lead, Total  | 200.8             | 20.9   | 20.0         | 104   | 85-115       |

## 1.5 Laboratory Certifications

**NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER**



Expires 12:01 AM April 01, 2026  
Issued April 01, 2025

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**  
*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

**MS. CHRISTINE KUTZER**  
**ALS ENVIRONMENTAL - ROCHESTER**  
**1565 JEFFERSON ROAD BUILDING 300, SUITE 360**  
**ROCHESTER, NY 14623**

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2016) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

**Bacteriology**

|                                         |                                     |
|-----------------------------------------|-------------------------------------|
| Coliform, Total / E. coli (Qualitative) | SM 20, 21-23 9223B (-04) (Colilert) |
|-----------------------------------------|-------------------------------------|

**Dissolved Gases**

|                   |         |
|-------------------|---------|
| Acetylene         | RSK-175 |
| Ethane            | RSK-175 |
| Ethene (Ethylene) | RSK-175 |
| Methane           | RSK-175 |
| Propane           | RSK-175 |

**Fuel Additives**

|                         |           |
|-------------------------|-----------|
| Methyl tert-butyl ether | EPA 524.2 |
| Naphthalene             | EPA 524.2 |

**Metals I**

|                  |                    |
|------------------|--------------------|
| Arsenic, Total   | EPA 200.8 Rev. 5.4 |
| Barium, Total    | EPA 200.8 Rev. 5.4 |
| Cadmium, Total   | EPA 200.8 Rev. 5.4 |
| Chromium, Total  | EPA 200.7 Rev. 4.4 |
|                  | EPA 200.8 Rev. 5.4 |
| Copper, Total    | EPA 200.8 Rev. 5.4 |
| Iron, Total      | EPA 200.7 Rev. 4.4 |
| Lead, Total      | EPA 200.8 Rev. 5.4 |
| Manganese, Total | EPA 200.7 Rev. 4.4 |
|                  | EPA 200.8 Rev. 5.4 |
| Mercury, Total   | EPA 245.1 Rev. 3.0 |
| Selenium, Total  | EPA 200.8 Rev. 5.4 |
| Silver, Total    | EPA 200.7 Rev. 4.4 |
|                  | EPA 200.8 Rev. 5.4 |
| Zinc, Total      | EPA 200.7 Rev. 4.4 |

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to [elap@health.ny.gov](mailto:elap@health.ny.gov).

Page 1 of 5

