

PO Box 733  
Marlboro, NY 12542  
Phone 845-236-7823  
Fax 845-236-3911  
NYSDOH #10824

## **ENVIRONMENTAL LABWORKS, INC.**

---

July 22, 2025

Saugerties CSD  
310 Washington Ave Ext  
Saugerties, NY 12477

Dear James,


The following are results of the analyses performed on water samples from **Mt Marion Elementary School** received at the laboratory on 06/26/25.

Date/Time Collected: 06/26/25 6:00-6:05am First Draw  
Collected By: SCSD  
Project ID: 06262530  
Secondary ID: MM252443-44

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
BOCES Bottle Filler 06262530-1	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	07/15/25
Rm 2 Bottle Filler 06262530-2	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	07/15/25

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #12150. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi  
Technical Director